

**ONS SLRA: Breakout Questions**

SLRA Section B2.1.31, 10 CFR Part 50, Appendix J

TRP: 044

Question Number	SLRA Section	SLRA Page	Background / Issue (As applicable/needed)	Discussion Question / Request
1	B2.1.31	N/A	<p>“Scope of Program” program element of GALL-SLR XI.S4 states, in part, “[t]he aging effects associated with containment pressure-retaining boundary components within the scope of subsequent license renewal and excluded from Type B or C Appendix J testing must still be managed. Other programs may be credited for managing the aging effects associated with these components; however, the component and the proposed AMP should be clearly identified”.</p> <p>“Scope of Program” program element in the ONS AMP basis document of 10 CFR Part 50, Appendix J (SLR-ONS-AMPR-XI.S4, Rev.1) provides a table (Table 4.1-1) that identifies the penetrations excluded from Type C containment isolation value testing and provides the AMPs that are credited with managing the applicable aging effects. However, it appears that the in-scope components excluded from Type B (containment penetration leak rate) testing and proposed AMPs are not mentioned.</p>	Please identify the in-scope components that are excluded from Type B testing, and associated AMPs credited for managing the aging effects in keeping with “Scope of Program” element of GALL-SLR XI.S4.