



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 12, 2022

Mr. John A. Krakuszeski
Site Vice President
Brunswick Steam Electric Plant
Duke Energy Progress, LLC
8470 River Rd., SE (M/C BNP001)
Southport, NC 28461

SUBJECT: BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2 – ISSUANCE
OF AMENDMENT NOS. 309 AND 337 REGARDING THE ADOPTION OF
TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER TSTF-580,
REVISION 1 (EPID L-2021-LLA-0216)

Dear Mr. Krakuszeski:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment Nos. 309 and 337 to Renewed Facility Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plant, Units 1 and 2, respectively. These license amendments are in response to your request dated December 2, 2021.

The amendments revise Technical Specification (TS) 3.4.7, "Residual Heat Removal (RHR) Shutdown Cooling System – Hot Shutdown," based on Technical Specification Task Force (TSTF) Traveler TSTF-580, Revision 1, "Provide Exception from Entering Mode 4 With No Operable RHR Shutdown Cooling."

A copy of our related Safety Evaluation is also enclosed. Notice of issuance will be included in the Commission's monthly *Federal Register* notice.

If you have any questions regarding this matter, please contact me at (301) 415-0272 or by e-mail at Lucas.Haeg@nrc.gov.

Sincerely,

/RA/

Luke Haeg, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos.: 50-325 and 50-324

Enclosures:

1. Amendment No. 309 to DPR-71
2. Amendment No. 337 to DPR-62
3. Safety Evaluation
4. Notices and Environmental Findings

cc: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY PROGRESS, LLC

DOCKET NO. 50-325

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 309
Renewed License No. DPR-71

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by Duke Energy Progress, LLC (the licensee), dated December 2, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Renewed Facility Operating License No. DPR-71 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 309, are hereby incorporated in the license. Duke Energy Progress, LLC shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 120 days.

FOR THE NUCLEAR REGULATORY COMMISSION

David J. Wrona, Chief
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachments:
Changes to the Renewed Operating
License, Technical Specifications

Date of Issuance: May 12, 2022

ATTACHMENT TO LICENSE AMENDMENT NO. 309

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 1

RENEWED FACILITY OPERATING LICENSE NO. DPR-71

DOCKET NO. 50-325

Replace page 6 of Renewed Facility Operating License No. DPR-71 with the attached page 6.

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

3.4-14

3.4-15

Insert Pages

3.4-14

3.4-15

(c) Transition License Conditions

1. Before achieving full compliance with 10 CFR 50.48(c), as specified by 2. below, risk-informed changes to the licensee's fire protection program may not be made without prior NRC review and approval unless the change has been demonstrated to have no more than a minimal risk impact, as described in 2. above.
2. The licensee shall implement the modifications to its facility, as described in Table S-1, "Plant Modifications Committed," of Duke letter BSEP 14-0122, dated November 20, 2014, to complete the transition to full compliance with 10 CFR 50.48(c) by the startup of the second refueling outage for each unit after issuance of the safety evaluation. The licensee shall maintain appropriate compensatory measures in place until completion of these modifications.
3. The licensee shall complete all implementation items, except item 9, listed in LAR Attachment S, Table S-2, "Implementation Items," of Duke letter BSEP 14-0122, dated November 20, 2014, within 180 days after NRC approval unless the 180th day falls within an outage window; then, in that case, completion of the implementation items, except item 9, shall occur no later than 60 days after startup from that particular outage. The licensee shall complete implementation of LAR Attachment S, Table S-2, Item 9, within 180 days after the startup of the second refueling outage for each unit after issuance of the safety evaluation.

C. This renewed license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2923 megawatts thermal.

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 309, are hereby incorporated in the license. Duke Energy Progress, LLC shall operate the facility in accordance with the Technical Specifications.

For Surveillance Requirements (SRs) that are new in Amendment 203 to Renewed Facility Operating License DPR-71, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 203. For SRs that existed prior to Amendment 203, including SRs with modified acceptance criteria and SRs whose frequency of

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 Residual Heat Removal (RHR) Shutdown Cooling System—Hot Shutdown

LCO 3.4.7 Two RHR shutdown cooling subsystems shall be OPERABLE, and, with no recirculation pump in operation, at least one RHR shutdown cooling subsystem shall be in operation.

-----NOTES-----

1. Both required RHR shutdown cooling subsystems and recirculation pumps may be removed from operation for up to 2 hours per 8 hour period.
 2. One required RHR shutdown cooling subsystem may be inoperable for up to 2 hours for the performance of Surveillances.
-

APPLICABILITY: MODE 3, with reactor steam dome pressure less than the RHR shutdown cooling isolation pressure.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each RHR shutdown cooling subsystem.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RHR shutdown cooling subsystem inoperable.	A.1 Verify an alternate method of decay heat removal is available.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate Action to restore RHR shutdown cooling subsystem to OPERABLE status.	Immediately

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Two required RHR shutdown cooling subsystems inoperable.</p>	<p>C.1 Verify an alternate method of decay heat removal is available for each inoperable RHR shutdown cooling subsystem.</p>	<p>1 hour <u>AND</u> Once per 24 hours thereafter</p>
<p>D. Required Action and associated Completion Time of Condition C not met.</p>	<p>-----NOTE----- LCO 3.0.3 and all other LCO Required Actions requiring a MODE change to MODE 4 may be suspended until one RHR shutdown cooling subsystem is restored to OPERABLE status. -----</p> <p>D.1 Initiate action to restore one RHR shutdown cooling subsystem to OPERABLE status.</p>	<p>Immediately</p>
<p>E. No RHR shutdown cooling subsystem in operation. <u>AND</u> No recirculation pump in operation.</p>	<p>E.1 Initiate action to restore one RHR shutdown cooling subsystem or one recirculation pump to operation. <u>AND</u> E.2 Verify reactor coolant circulation by an alternate method. <u>AND</u> E.3 Monitor reactor coolant temperature and pressure.</p>	<p>Immediately</p> <p>1 hour from discovery of no reactor coolant circulation <u>AND</u> Once per 12 hours thereafter</p> <p>Once per hour</p>



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY PROGRESS, LLC

DOCKET NO. 50-324

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 337
Renewed License No. DPR-62

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by Duke Energy Progress, LLC (the licensee), dated December 2, 2021, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Renewed Facility Operating License No. DPR-62 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 337, are hereby incorporated in the license. Duke Energy Progress, LLC shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 120 days.

FOR THE NUCLEAR REGULATORY COMMISSION

David J. Wrona, Chief
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachments:
Changes to the Renewed Operating
License, Technical Specifications

Date of Issuance: May 12, 2022

ATTACHMENT TO LICENSE AMENDMENT NO. 337

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

FACILITY OPERATING LICENSE NO. DPR-62

DOCKET NO. 50-324

Replace page 6 of Renewed Facility Operating License No. DPR-62 with the attached page 6.

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

3.4-14

3.4-15

Insert Pages

3.4-14

3.4-15

(c) Transition License Conditions

1. Before achieving full compliance with 10 CFR 50.48(c), as specified by 2. below, risk-informed changes to the licensee's fire protection program may not be made without prior NRC review and approval unless the change has been demonstrated to have no more than a minimal risk impact, as described in 2. above.
2. The licensee shall implement the modifications to its facility, as described in Table S-1, "Plant Modifications Committed," of Duke letter BSEP 14-0122, dated November 20, 2014, to complete the transition to full compliance with 10 CFR 50.48(c) by the startup of the second refueling outage for each unit after issuance of the safety evaluation. The licensee shall maintain appropriate compensatory measures in place until completion of these modifications.
3. The licensee shall complete all implementation items, except Item 9, listed in LAR Attachment S, Table S-2, "Implementation Items," of Duke letter BSEP 14-0122, dated November 20, 2014, within 180 days after NRC approval unless the 180th day falls within an outage window; then, in that case, completion of the implementation items, except item 9, shall occur no later than 60 days after startup from that particular outage. The licensee shall complete implementation of LAR Attachment S, Table S-2, Item 9, within 180 days after the startup of the second refueling outage for each unit after issuance of the safety evaluation.

C. This renewed license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2923 megawatts (thermal).

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 337, are hereby incorporated in the license. Duke Energy Progress, LLC shall operate the facility in accordance with the Technical Specifications.

For Surveillance Requirements (SRs) that are new in Amendment 233 to Renewed Facility Operating License DPR-62, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 233. For SRs that existed prior to Amendment 233,

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 Residual Heat Removal (RHR) Shutdown Cooling System—Hot Shutdown

LCO 3.4.7 Two RHR shutdown cooling subsystems shall be OPERABLE, and, with no recirculation pump in operation, at least one RHR shutdown cooling subsystem shall be in operation.

-----NOTES-----

1. Both required RHR shutdown cooling subsystems and recirculation pumps may be removed from operation for up to 2 hours per 8 hour period.
2. One required RHR shutdown cooling subsystem may be inoperable for up to 2 hours for the performance of Surveillances.

APPLICABILITY: MODE 3, with reactor steam dome pressure less than the RHR shutdown cooling isolation pressure.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each RHR shutdown cooling subsystem.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RHR shutdown cooling subsystem inoperable.	A.1 Verify an alternate method of decay heat removal is available.	1 hour <u>AND</u> Once per 24 hours thereafter
B. Required Action and associated Completion Time of Condition A not met.	B.1 Initiate Action to restore RHR shutdown cooling subsystem to OPERABLE status.	Immediately

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Two required RHR shutdown cooling subsystems inoperable.</p>	<p>C.1 Verify an alternate method of decay heat removal is available for each inoperable RHR shutdown cooling subsystem.</p>	<p>1 hour <u>AND</u> Once per 24 hours thereafter</p>
<p>D. Required Action and associated Completion Time of Condition C not met.</p>	<p>-----NOTE----- LCO 3.0.3 and all other LCO Required Actions requiring a MODE change to MODE 4 may be suspended until one RHR shutdown cooling subsystem is restored to OPERABLE status. -----</p> <p>D.1 Initiate action to restore one RHR shutdown cooling subsystem to OPERABLE status.</p>	<p>Immediately</p>
<p>E. No RHR shutdown cooling subsystem in operation. <u>AND</u> No recirculation pump in operation.</p>	<p>E.1 Initiate action to restore one RHR shutdown cooling subsystem or one recirculation pump to operation. <u>AND</u> E.2 Verify reactor coolant circulation by an alternate method. <u>AND</u> E.3 Monitor reactor coolant temperature and pressure.</p>	<p>Immediately</p> <p>1 hour from discovery of no reactor coolant circulation <u>AND</u> Once per 12 hours thereafter</p> <p>Once per hour</p>



UNITED STATES
NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
 RELATED TO
 AMENDMENT NO. 309 TO FACILITY OPERATING LICENSE NO. DPR-71
 AND AMENDMENT NO. 337 TO FACILITY OPERATING LICENSE NO. DPR-62
 DUKE ENERGY PROGRESS, LLC
 BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
 DOCKET NOS. 50-325 AND 50-324

<u>Application (i.e., initial and supplements)</u> <ul style="list-style-type: none"> • December 2, 2021, ML21336A716 	<u>Safety Evaluation Date</u> May 12, 2022
	<u>Principal Contributors to Safety Evaluation</u> <ul style="list-style-type: none"> • L. Haeg, NRR/DORL/LPL2-2 • C. Tilton, NRR/DSS/STSB

1.0 PROPOSED CHANGES

Duke Energy Progress, LLC (Duke Energy, the licensee), requested changes to the technical specifications (TSs) for Brunswick Steam Electric Plant, Units 1 and 2 (Brunswick) by license amendment request (LAR, application). In its application, the licensee requested that the U.S. Nuclear Regulatory Commission (NRC, the Commission) process the proposed amendments under the Consolidated Line Item Improvement Process (CLIIP). The proposed changes would revise the “RHR [Residual Heat Removal] Shutdown Cooling System – Hot Shutdown,” TS based on Technical Specification Task Force (TSTF) Traveler TSTF-580, Revision 1, “Provide Exception from Entering Mode 4 With No Operable RHR Shutdown Cooling” (ADAMS Accession No. ML21025A232), and the associated NRC staff safety evaluation (SE) of TSTF-580 (ADAMS Accession No. ML21188A227).

Irradiated fuel in the shutdown reactor core generates heat during the decay of fission products and increases the temperature of the reactor coolant. This decay heat must be removed to reduce the temperature of the reactor coolant to less than or equal to 212 degrees Fahrenheit (°F). This decay heat is removed by the RHR shutdown cooling system in preparation for performing refueling or maintenance operations, or for keeping the reactor in the hot shutdown condition or cold shutdown condition.

The Brunswick, Units 1 and 2, design consists of two redundant, manually controlled shutdown cooling subsystems of the RHR system to provide decay heat removal. Each loop consists of motor-driven pumps, a heat exchanger, and associated piping and valves. The RHR heat exchangers transfer heat to the RHR service water system. Some piping and heat exchangers that are passive components may be common to both subsystems.

TS 3.4.7, "Residual Heat Removal (RHR) Shutdown Cooling System – Hot Shutdown," is applicable in Mode 3, with the reactor steam dome pressure less than the RHR shutdown cooling isolation pressure. The limiting condition for operation (LCO) requires two operable RHR shutdown cooling subsystems and, if no recirculation pump is in operation, then at least one RHR shutdown cooling subsystem needs to be in operation.

1.1 Proposed TS Changes to Adopt TSTF-580

In accordance with NRC staff-approved TSTF-580, the licensee proposed changes that would revise the TS 3.4.7, "Residual Heat Removal (RHR) Shutdown Cooling System – Hot Shutdown," for Brunswick. Specifically, the licensee proposed the following changes to adopt TSTF-580:

- Condition A is changed to be limited to a single inoperable subsystem by revising it to state: "One required RHR shutdown cooling subsystem inoperable" with a Required Action to "Verify an alternate method of decay heat removal is available."
- Condition B addresses situations when Required Action A.1 and associated completion time (CT) are not met. The plural "(s)" is deleted in Required Action B.1 as a conforming change to Condition A which now addresses a single inoperable RHR shutdown cooling subsystem.
- A new Condition C is added which addresses two RHR shutdown cooling subsystems inoperable with a Required Action C.1 to verify an alternate method of decay heat removal is available for each inoperable RHR shutdown cooling subsystem. The new Condition C Required Action has a CT of 1 hour and once per 24 hours thereafter.
- A new Condition D is added to address situations when new Required Action C.1 and associated CT are not met. New Required Action D.1 requires action be initiated to restore one RHR shutdown cooling subsystem to operable status immediately. Required Action D.1 is modified by a note that states that LCO 3.0.3 and all other LCO Required Actions requiring a mode change to Mode 4 may be suspended until one RHR shutdown cooling subsystem is restored to operable status.
- Existing Condition C and associated Required Actions are renumbered as Condition E due to the new Conditions C and D.

1.2 Additional Proposed TS Changes

1.2.1 Editorial Variations

The licensee noted that Brunswick's TSs have different numbering than the standard technical specifications (STSs)¹. Specifically, STS 3.4.8, "Residual Heat Removal (RHR) Shutdown Cooling System - Hot Shutdown," correlates to Brunswick's TS 3.4.7, "Residual Heat Removal (RHR) Shutdown Cooling System – Hot Shutdown."

¹ U.S. Nuclear Regulatory Commission, "Standard Technical Specifications, General Electric BWR/4 Plants," NUREG-1433, Volume 1, "Specifications," and Volume 2, "Bases," Revision 5.0, September 2021 (ADAMS Accession Nos. ML21272A357 and ML21272A358, respectively).

2.0 REGULATORY EVALUATION

The regulation at paragraph 50.36(c)(2) of Title 10 of the *Code of Federal Regulations* (10 CFR) requires that TSs include LCOs. Per 10 CFR 50.36(c)(2)(i), LCOs “are the lowest functional capability or performance levels of equipment required for safe operation of the facility.” The regulation also requires that when an LCO of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the TSs until the condition can be met.

The NRC staff’s guidance for the review of TSs is in Chapter 16.0, “Technical Specifications,” of NUREG-0800, Revision 3, “Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water Reactor] Edition” (SRP), March 2010 (ADAMS Accession No. ML100351425). As described therein, as part of the regulatory standardization effort, the NRC staff has prepared STSs for each of the LWR nuclear designs. Accordingly, the NRC staff’s review includes consideration of whether the proposed changes are consistent with the STSs, as modified by NRC-approved travelers.

Traveler TSTF-580 revised the STSs related to RHR shutdown cooling system. The NRC approved TSTF-580 under the CLIIP on July 11, 2021 (ADAMS Package Accession No. ML21188A283).

3.0 TECHNICAL EVALUATION

3.1 Proposed TS Changes to Adopt TSTF-580

The NRC staff compared the licensee’s proposed TS changes in Section 1.1 of this SE against the changes approved in TSTF-580. In accordance with the SRP, Chapter 16.0, the NRC staff determined that the STS changes approved in TSTF-580 are applicable because Brunswick, Units 1 and 2, are boiling-water reactor (BWR) design plants and the NRC staff approved the TSTF-580 changes for BWR designs. The NRC staff finds that the licensee’s proposed changes to the Brunswick’s TSs in Section 1.1 of this SE are consistent with those found acceptable in TSTF-580.

In the SE of TSTF-580, the NRC staff concluded that TSTF-580 changes to STS 3.4.8, “Residual Heat Removal (RHR) Shutdown Cooling System – Hot Shutdown,” were acceptable because the changes did not alter the way the TSs are implemented for a single inoperable RHR shutdown cooling subsystem for Conditions A and B, and did not alter the way the TSs are implemented for two inoperable RHR shutdown cooling subsystems for new Condition C. Therefore, the NRC staff finds that the proposed changes to Brunswick’s TS LCO 3.4.7, Conditions A and B, and new Condition C, are acceptable because they continue to meet the requirements of 10 CFR 50.36(c)(2)(i) by providing remedial actions for when the LCO is not met.

In the SE of TSTF-580, the NRC staff also concluded that the TSTF-580 proposed addition of new Condition D in STS 3.4.8 is acceptable, because, without an operable RHR shutdown cooling subsystem and in a period of high decay heat load, it may not be possible to reduce the reactor coolant system temperature to the Mode 4 entry condition within the CT. Under this condition, remaining in Mode 3 allows fission product decay heat and other residual heat from the reactor core to be transferred at a rate such that specified acceptable fuel design limits and the design conditions of the reactor coolant pressure boundary will not be exceeded. The CT

reflects the importance of restoring a normal path for heat removal. Therefore, the NRC staff finds that proposed new Condition D and associated Required Action D.1 and the CT, are acceptable because it continues to meet the requirements of 10 CFR 50.36(c)(2)(i) by providing appropriate remedial actions when the LCO is not met.

3.1.1 Conclusion

The NRC staff finds that the proposed changes to Brunswick's TS LCO 3.4.7 are acceptable because appropriate remedial actions continue to be required when the LCO is not met and provide adequate protection of the health and safety of the public. Thus, the proposed changes continue to meet the requirements of 10 CFR 50.36(c)(2)(i) as discussed in Section 3.0 of the NRC staff's SE of TSTF-580.

3.2 Additional Proposed TS Changes

3.2.1 Editorial Changes

The licensee noted that Brunswick's TSs have different numbering than the STS. The NRC staff finds that the different TS numbering changes are acceptable because they do not substantively alter TS requirements.

3.3 TS Change Consistency

The NRC staff reviewed the proposed TS changes for technical clarity and consistency with the existing requirements for customary terminology and formatting. The NRC staff finds that the proposed changes are consistent with Chapter 16.0 of the SRP and are therefore acceptable.

4.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) there is reasonable assurance that such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

NOTICES AND ENVIRONMENTAL FINDINGS
 RELATED TO
 AMENDMENT NO. 309 TO FACILITY OPERATING LICENSE NO. DPR-71
 AND AMENDMENT NO. 337 TO FACILITY OPERATING LICENSE NO. DPR-62
 DUKE ENERGY PROGRESS, LLC
 BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
 DOCKET NOS. 50-325 AND 50-324

<u>Application (i.e., initial and supplements)</u>	<u>Safety Evaluation Date</u>
<ul style="list-style-type: none"> December 2, 2021 (ML21336A716) 	May 12, 2022

1.0 INTRODUCTION

Duke Energy Progress, LLC (the licensee) requested changes to the technical specifications (TSs) for Brunswick Steam Electric Plant, Units 1 and 2 (Brunswick), by license amendment request (LAR, application). In its application, the licensee requested that the U.S. Nuclear Regulatory Commission (NRC, the Commission) process the proposed amendment under the Consolidated Line Item Improvement Process (CLIIP). The proposed changes would revise the “RHR [Residual Heat Removal] Shutdown Cooling System – Hot Shutdown,” TS based on Technical Specifications Task Force (TSTF) Traveler TSTF-580, Revision 1, “Provide Exception from Entering Mode 4 With No Operable RHR Shutdown Cooling” TSTF-580 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21025A232), and the associated NRC staff’s safety evaluation of TSTF-580 (ADAMS Accession No. ML21188A227).

2.0 STATE CONSULTATION

In accordance with the Commission's regulations, the North Carolina State official was notified of the proposed issuance of the amendment on January 27, 2022. The State official had no comments.

3.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, which was published in the *Federal Register* on January 25, 2022 (87 FR 3844), and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need to be prepared in connection with the issuance of the amendment.

SUBJECT: BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2 – ISSUANCE OF AMENDMENT NOS. 309 AND 337 REGARDING THE ADOPTION OF TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER TSTF-580, REVISION 1 (EPID L-2021-LLA-0216) MAY 12, 2022

DISTRIBUTION:

PUBLIC
 PM Reading File
 RidsACRS_MailCTR Resource
 RidsNrrDorlLpl2-2 Resource
 RidsNrrDss Resource
 RidsNrrLARButler Resource
 RidsNrrPMBrunswick Resource
 RidsRgn2MailCenter Resource
 CTilton, NRR

ADAMS Accession No.: ML22028A174

OFFICE	NRR/DORL/LPL2-2/PM	NRR/DORL/LPL2-2/LA	NRR/DSS/STSB
NAME	LHaeg	RButler	VCusumano
DATE	1/28/2022	2/3/2022	2/22/2022
OFFICE	OGC – NLO	NRR/DORL/LPL2-2/BC	NRR/DORL/LPL2-2/PM
NAME	STurk	DWrona	LHaeg
DATE	5/4/2022	5/12/2022	5/12/2022

OFFICIAL RECORD COPY