Question: 1

(1 point)

Given the following on Unit 1:

- Unit is operating at 100% RTP
- Slave relay testing is being performed and a procedural error results in the inadvertent closure of 1RN-277B (RB NON ESS RET CONT OUTSIDE ISOL)

NC Pump trip criteria will be met when stator winding temperature rises to a r of °F	ninimum
Which ONE of the following completes the statement above?	

- A. 235
- B. 280
- C. 300
- D. 311

Question: 2

(1 point)

Given	the following on Unit 1:
	Unit is at 100% RTP 1A S/G has received a P-14 signal
Based	on the conditions above:
	1) The valves will CLOSE.
	To regain control of Feedwater Isolation components, the reactor trip breakers required to be CLOSED.
Which	ONE of the following completes the statement above?
A.	Main Steam Isolation are NOT
B.	CF to CA Nozzle Isolation are NOT
C.	Main Steam Isolation are
D.	CF to CA Nozzle Isolation are

ILT22-1 NRC MNS RO NRC Examination

Question: 3

(1 point)

Given the following:

- Both units are operating at 100% RTP
- An instrument air system leak develops in the Unit 1 Turbine Building
- The Diesel VI Compressors (G & H) "AUTO/OFF-RESET" selector switches are in 'AUTO"

The following indications are observed in the Control Room:



Based on the indications above:

- 1) 1VI-1812 (VI Air Dryer Bypass Filter Isol) is _____.
- 2) The Diesel VI Compressors (G & H) _____ received a start signal.

- A. 1. OPEN
 - 2. have
- B. 1. CLOSED
 - 2. have
- C. 1. OPEN
 - 2. have NOT
- D. 1. CLOSED
 - 2. have NOT

Question: 4

(1 point)

Given	the	following	on	Unit 2:
-------	-----	-----------	----	---------

- Unit is operating at 100% RTP
- An auto make-up to the VCT is in progress
- VCT level is 60% and rising

Subsequently:

Annunciator 2AD-7/D-3, VCT ABNORMAL LEVEL alarms

Based on continued level rise, the Annunciator Response for 2AD-7/D-3 will ensure that 2NV-137A (U2 NC Filter OTLT to VCT) is aligned to the ____(1)___.

2NV-137A will be in FULL DIVERT at ____(2)___%.

- A. 1. RHT
 - 2.66
- B. 1. NCDT
 - 2.66
- C. 1. RHT
 - 2.96
- D. 1. NCDT
 - 2.96

Question: 5

(1 point)

Given the following conditions on Unit 2:

- The unit is in solid operations while cooling down
- Both trains of ND are in service
- 2A NV pump is in service
- ND LETDOWN is in-service.

Based on the conditions above, a loss of VI to valve _____ would cause NC system pressure to increase.

Which ONE of the following completes the statement above?

(Consider each separately)

- A. 2RN-89A (RN to A KC Hx Control)
- B. 2KC-57A (2A ND Heat Exchanger Cooling Water Control)
- C. 2ND-29A (2A ND Hx Outlet Isol)
- D. 2ND-34 (A & B ND Hx Bypass)

ILT22-1 NRC MNS RO NRC Examination

Question: 6

(1 point)

Given the following on Unit 1:

- Unit was operating at 100% RTP
- A Reactor Trip/Safety Injection occurs
- The following trend is observed in the Control Room:

<u>Time after Trip/SI</u>	NC Pressure
1 minute	1800 psig
4 minutes	1600 psig
8 minutes	1400 psig
10 minutes	1100 psig

Based on the conditions above, Safety Injection Pump (NI) motor amps will START to ____(1) ___ between ____(2) ___ minutes.

- A. 1. lower
 - 2.4-8
- B. 1. rise
 - 2. 4-8
- C. 1. lower
 - 2. 8-10
- D. 1. rise
 - 2.8-10

ILT22-1 NRC MNS RO NRC Examination

Question: 7

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The following annunciators are received:

1AD-6 D-9 (PRT HI PRESS) 1AD-6 E-9 (PRT ABNORMAL LEVEL)

• The following OAC Alarms are received:

U1 PZR RELIEF TANK LEVEL HI-HI U1 PZR RELIEF TANK PRESS HI

- PRT pressure is 9 PSIG and RISING SLOWLY
- PRT level is 95% and RISING SLOWLY

The PRT rupture disc is designed to discharge to Containment when PRT pressure rises to a MAXIMUM of _____(1)___.

To prevent PRT rupture disc operation due to the conditions above, the operating crew must FIRST _____(2)___.

- A. 1. 100 PSIG
 - 2. drain the PRT to the NCDT
- B. 1. 85 PSIG
 - 2. drain the PRT to the NCDT
- C. 1. 85 PSIG
 - 2. vent the PRT to the Waste Gas system
- D. 1. 100 PSIG
 - 2. vent the PRT to the Waste Gas system

ILT22-1 NRC MNS RO NRC Examination

Question: 8

(1 point)

	Given	the	following	on	Unit	1:
--	-------	-----	-----------	----	------	----

- Unit is in Mode 5
- NC system is in a water solid condition
- 1A ND is in service
- 1B NV pump is in service
- 1NV-121 (UNIT 1 ND LETDOWN CONTROL) is THROTTLED to 50% to maintain letdown flow from ND
- 1NV-238 (UNIT 1 CHARGING HDR CONTROL) is in MANUAL

• ,	All plant parameters are stable
If VI we	ere lost to 1NV-121, NC system pressure would(1)
If VI we	ere lost to 1NV-238, NC system pressure would(2)
Which	ONE of the following completes the statements above?
	(Consider each failure separately)
A.	 rise lower
B.	1. lower2. lower
C.	1. rise2. rise
D.	 lower rise

Question: 9

(1 point)

Regard	ling the operation of 1KC-122 (KC Surge Tank Vent Valve):
	1EMF-46A(B) in(1) will cause the valve to close.
,	When the alarm clears, the valve will be(2) re-opened.
Which	ONE of the following completes the statements above?
A.	Trip 1 automatically
B.	1. Trip 1 2. locally
C.	1. Trip 2 2. locally
D.	1. Trip 22. automatically

ILT22-1 NRC MNS RO NRC Examination

Question: 10

(1 point)

Given the following on Unit 1:

Initial Conditions:



Subsequently a loss of power occurs:



Based on the indications above:

- 1) A power loss has occurred on _____.
- 2) 1NC-27C _____ lost position indication.

- A. 1. KXA
 - 2. has
- B. 1. KXA
 - 2. has NOT
- C. 1. KXB
 - 2. has
- D. 1. KXB
 - 2. has NOT

ILT22-1 NRC MNS RO NRC Examination

Question: 11
(1 point)

Regarding the Reactor Protection System:

A loss of _____ will prevent operation of the Shunt Trip associated with Reactor Trip Bypass Breaker 1BYB.

Which ONE of the following completes the statements above?

- A. 1EVDA
- B. 1EVDB
- C. 1EVDC
- D. 1EVDD

Question: 12

(1 point)

Given the following on Unit 1:

- Unit is operating at 70% RTP
- The OATC determines that AUTO rod withdrawal is not functioning
- Further investigation reveals that manual rod withdrawal is functioning normally
- Control Bank 'D' rods are currently at 190 steps

Which ONE of the following failures could cause this condition?

- A. PR Channel N-41 fails high.
- B. Loop 2 ΔT Channel fails high.
- C. Turbine Inlet Pressure Channel 1 fails low.
- D. Turbine Inlet Pressure Channel 2 fails low.

Question: 13

(1 point)

Given the following on Unit 1	:
-------------------------------	---

- A LOCA has occurred
- Containment pressure is 5 PSIG and lowering
- Phase A and Phase B have NOT been reset

Based on the conditions above:

- 1) Phase A _____ reset if the Phase A reset pushbuttons are depressed.
- 2) Phase B reset if the Phase B reset pushbuttons are depressed.

- A. 1. will
 - 2. will
- B. 1. will
 - 2. will NOT
- C. 1. will NOT
 - 2. will NOT
- D. 1. will NOT
 - 2. will

ILT22-1 NRC MNS RO NRC Examination

Question: 14

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- 1D VL AHU is not available

Subsequently:

- A LOCA occurs on Unit 1
- Containment pressure rapidly rose to 2.8 PSIG and is now slowly lowering
- Significant damage was caused to the discharge ductwork of 1A and 1B VL AHUs such that normal air flow was interrupted
- 1C VL AHU tripped OFF

		4.1	1141	
Based	on	the	conditions	above.

- 1) The _____ will lose cooling.
- 2) RV cooling water supply _____ be maintained for the VL AHUs.

- 1. Control Rod Drive (VR) Enclosure A.
 - 2. will NOT
- В. 1. Control Rod Drive (VR) Enclosure
 - 2. will
- C. 1. Incore Instrumentation (VT) Room
 - 2. will
- D. 1. Incore Instrumenation (VT) Room
 - 2. will NOT

Question: 15

D. 1. sooner 2. 15

(1 point)

Given the following on Unit 1:
 Unit is at 100% RTP It has been determined that eight Ice Condenser Intermediate Deck doors will not open due to excessive ice buildup
Based on the conditions above, peak containment pressure following a Design Basis Accident will be reached(1) than normal.
Containment design pressure is(2)PSIG.
Which ONE of the following completes the statements above?
A. 1. later 2. 3
B. 1. sooner 2. 3
C. 1. later 2. 15

ILT22-1 NRC MNS RO NRC Examination

Question: 16

(1 point)

Given the following on Unit 1:

- Unit is at 10% RTP
- 1AD-9/ A5 (ICE COND LOWER INLET DOORS OPEN) alarm is LIT
- The lower inlet door position display panel indicates that a door is OPEN
- An AO has confirmed a lower inlet door is cracked OPEN and the door will not move further OPEN and cannot be CLOSED
- The BOP has reported ice bed temperature is 25°F and slowly rising

Based on the conditions above:

- 1) The Action Statement of Tech Spec 3.6.12 (Ice Bed) _____ required to be entered.
- 2) The Action Statement of Tech Spec 3.6.13 (Ice Condenser Doors) _____ required to be entered.

- A. 1. is NOT
 - 2. is NOT
- B. 1. is
 - 2. is
- C. 1. is
 - 2. is NOT
- D. 1. is NOT
 - 2. is

Question: 17

(1 point)

Given the following on Unit 2:

- A Large Break LOCA has occurred
- "B" train of NS has been aligned per ES-1.3 (TRANSFER TO COLD LEG RECIRC)
- 2NI-185A (2A ND PUMP SUCTION FROM CONT SUMP ISOL) failed to OPEN from the control room

•	The crew is aligning ND aux spray as containment pressure continues to rise.
	on the conditions above, 2NS-43A (2A ND HX OUTLET TO NS CONT DE ISOL)(1) OPEN from the control room.
	-43A is able to be aligned, it(2) receive an AUTOMATIC signal to E as containment pressure lowers.
Which	ONE of the following completes the statements above?
A.	 will NOT does NOT
B.	 will NOT does
C.	 will does NOT
D.	1. will2. does

ILT22-1 NRC MNS RO NRC Examination

Question: 18

(1 point)

Given the following on Unit 1	Giver	n the fo	llowing	on L	Jnit 1	:
-------------------------------	-------	----------	---------	------	--------	---

- A large break LOCA has occurred
- Containment pressure is 3.2 PSIG and slowly lowering
- The crew has transitioned to ES-1.3 (TRANSFER TO COLD LEG RECIRCULATION)

	NIMUM containment sump level that will support alignment of the Containment (NS) pumps is feet.
Which	ONE of the following completes the statement above?
A.	1.0
B.	2.5
C.	3.0
D.	5.25

ILT22-1 NRC MNS RO NRC Examination

Question: 19

(1 point)

Given the	following	on Unit 1	1:
-----------	-----------	-----------	----

- Unit was at 100% RTP
- A Reactor Trip occurs
- The "B" Reactor trip breaker did not open
- ES-0.1 (REACTOR TRIP RESPONSE) is in progress

Based on the conditions above:

- 1) The Steam Dump _____ controller is in service.
- 2) The operator is required to reduce T_{AVG} to 557°F by selecting mode.

- A. 1. Load Rejection
 - 2. T_{AVG}
- B. 1. Load Rejection
 - 2. Steam Pressure
- C. 1. Plant Trip
 - 2. Tavg
- D. 1. Plant Trip
 - 2. Steam Pressure

II T22_1	NRC	MNC	$R\Omega$	NRC	Examination
IL 1 44-1	IVAC		ΚU	IVAC	EXamination

Question: 20
(1 point)

Given the following on Unit 1:

• Unit is at 100% RTP

Subsequently:

• 1A NCP trips

Based on the conditions above,

1) The 1A and 1B CF Pumps ______ trip.

2) The MDCA pumps will auto start if 2/4 detectors reach low-low level on a

Which ONE of the following completes the statements above?

MINIMUM of _____ S/Gs.

- A. 1. will NOT
 - 2. 2/4
- B. 1. will 2. 1/4
- C. 1. will NOT
 - 2. 1/4
- D. 1. will 2. 2/4

Question: 21

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- 1B NI pump is racked out and INOPERABLE for bearing replacement
- The 1A D/G has just been declared INOPERABLE due to an oil leak on the Woodward governor

Which ONE of the following describes an action which must be performed <u>WITHIN ONE HOUR</u> of declaring 1A D/G INOPERABLE to ensure compliance with TS 3.8.1 (AC SOURCES – OPERATING)?

- A. Perform PT/1/A/4350/025 (ESSENTIAL AUXILIARY POWER SYSTEM POWER SOURCE VERIFICATION)
- B. Determine the OPERABLE 1B D/G is not INOPERABLE due to a common cause failure
- C. Perform PT/1/A/4350/002 B (DIESEL GENERATOR 1B OPERABILITY TEST)
- D. Declare 1A NI pump INOPERABLE, because it is a required redundant feature supported by the INOPERABLE 1A D/G

Question: 22 1 point)
Given the following:
Both Units were operating at 100% RTP
Subsequently:
 A Loss of Offsite Power occurs on Unit 1 1A D/G starts and loads as designed, 1B D/G fails to start 45 minutes have passed since the Loss of Offsite Power occurred
Based on the conditions above:
1) 125 VDC Distribution Center (EVDB) is
2) AC Panelboard 1EKVB automatically transfer to 1KRP if power is lost.
Which ONE of the following completes the statements above?

- De-energized
 will A.
- Energized
 will B.
- De-energized
 will NOT C.
- Energized
 will NOT D.


ILT22-1 NRC MNS RO NRC Examination

Question: 23

(1 point)

Given the following on Unit 1:

- The Unit is at 100% RTP.
- Preparations for 1A D/G startup are in progress using PT/1/A/4350/002A, DIESEL GENERATOR 1A OPERABILITY TEST.
- Control Power indications on the 1A Diesel Generator Control Panel are as follows:



Based on the conditions above, the _____ breaker is the malfunction.

- A. 1ELXC Supply to 1EMXC
- B. 1ELXD Supply to 1EMXD
- C. 1ELXA Supply to 1EMXE
- D. 1ELXB Supply to 1EMXF

Question: 24

(1 point)

Given the following on Unit 2:

- The 2A1 DG Starting Air Tank has been removed from service and depressurized to repair an air leak
- The 2A2 DG Starting Air Tank is at 230 PSIG

Based on the conditions above, the 2A DG is capable of a MINIMUM of ____(1) ___ total starts.

During a DG start, the starting air solenoids receive a signal to close when DG speed is greater than or equal to a MINIMUM of ___(2)__.

- A. 1. 2
 - 2. 40%
- B. 1. 2
 - 2. 95%
- C. 1. 5
 - 2. 40%
- D. 1. 5
 - 2. 95%

ILT22-1 NRC MNS RO NRC Examination

Question: 25

(1 point)

- Unit is in Mode 5 with the NC system vented
- Containment Purge System (VP) is operating

Based on the conditions above	Based	on the	conditions	above
-------------------------------	-------	--------	------------	-------

- 1) a Trip 2 on _____ will secure VP.
- 2) to restart the VP system after a Trip 2 alarm, ____ is/are required to be reset.

Which ONE of the following completes the statements above?

EMF LEGEND:

2EMF-36(L) (UNIT VENT GAS) 2EMF-38(L) (CONTAINMENT PARTICULATE)

- A. 1. 2EMF-36
 - 2. Containment Ventilation (S_H) AND the EMF
- B. 1. 2EMF-38
 - 2. Containment Ventilation (SH) AND the EMF
- C. 1. 2EMF-36
 - 2. Containment Ventilation (S_H) ONLY
- D. 1. 2EMF-38
 - 2. Containment Ventilation (SH) ONLY

ILT22-1 NRC MNS RO NRC Examination

Question: 26

(1 point)

Given the following:

- 1A RN Pump is in service
- 2A RN Pump is in service
- A and B train RN is aligned to the Low Level Intake (LLI)

Subsequently:

• 1ETB normal incoming breaker inadvertently OPENS

Based on the conditions above:

- 1) 2A RN suction is aligned to the _____.
- 2) 2B RN suction is aligned to the _____.

- A. 1. LLI
 - 2. SNSWP
- B. 1. SNSWP
 - 2. LLI
- C. 1. SNSWP
 - 2. SNSWP
- D. 1. LLI
 - 2. LLI

Question: 27

(1 point)

\sim		•		1141
(-iv/0 h	tha	tall/	\sim	CONditioner
CHINELL	11115	10 1110	JVVIIICI	conditions:

- Unit 2 is at 100% RTP
- 'B' Train Components were in service.
- A Loss of Offsite Power occurs on both Units 1 and 2.

Based	on t	ha	conc	litions	· ah	01/0
Daseu	OHI	$\Pi \in$	(x)	11116)1 15	5 20	$\circ \lor \leftarrow$

The _____ provide(s) the assured source of cooling water to the Unit 2 Containment AHUs.

- A. RV pump selected in AUTO
- B. 2A RN pump ONLY
- C. 2B RN pump ONLY
- D. 2A AND 2B RN pumps

ILT22-1 NRC MNS RO NRC Examination

Question: 28

(1 point)

<u>Initial</u> Unit 1 HVAC Panel conditions:







Which ONE of the following lists the configuration of the Lower Containment (VL) Air Handling Units <u>AFTER</u> containment pressure rises to the conditions above?

- A. 1A OFF
 - 1C OFF
 - 1B Low Speed
 - 1D Low Speed
- B. 1A OFF
 - 1C OFF
 - 1B High Speed
 - 1D High Speed
- C. 1A Low Speed
 - 1C Low Speed
 - 1B Low Speed
 - 1D Low Speed
- D. 1A High Speed
 - 1C High Speed
 - 1B High Speed
 - 1D High Speed

uestion: point)	29			
Given the	following:			
• Un	it 2 is at 100% RTP			
Subseque	ently:			
	eak occurs on the steam equalization header actor power is 102% and rising slowly			
	the conditions above, annunciator 2AD-2 C8, P/R OVER POWER ROD(1) LIT.			
If the reactor power excursion continues, a reactor trip will occur if Power Range NI's exceed a MINIMUM setpoint of(2)				
Which ON	NE of the following completes the statements above?			
A.	1. is NOT 2. 109%			
B.	1. is NOT 2. 103%			
C.	1. is 2. 109%			
D.	1. is 2. 103%			

ILT22-1 NRC MNS RO NRC Examination

Question: 30

(1 point)

Given the following on Unit 2:

- Unit was at 100% RTP
- An inadvertent Reactor trip has occurred
- E-0 (REACTOR TRIP OR SAFETY INJECTION) has been implemented
- The following indications are observed:
 - One rod bottom light is NOT lit on DRPI
 - o Reactor Trip and Bypass breakers are OPEN
 - o IR Power is going DOWN

Per E-0), the OATC(1) required to manually trip the reactor.
	-0.1 (REACTOR TRIP RESPONSE), emergency boration(2) be d to mitigate this event.
Which	ONE of the following completes the statements above?
A.	1. is NOT 2. will
B.	 is NOT will NOT
C.	1. is 2. will
D.	1. is 2. will NOT

Question: 31

(1 point)

Given the	following	on	Unit	1:
-----------	-----------	----	------	----

- A LOCA has occurred
- Containment hydrogen concentration is slowly rising

 The TSC has recommended placing the H2 Purge Blower in service
The H2 Purge Blower is placed in service to maintain hydrogen concentration less that a MAXIMUM of(1)%.
While in operation, the H2 Purge blower return line vents air from containment to the (2)
Which ONE of the following completes the statements above?
A. 1. 4 2. Annulus

- B. 1. 6
 - 2. Annulus
- C. 1. 4
 - 2. Auxiliary Building
- D. 1. 6
 - 2. Auxiliary Building

Question: 3	32
-------------	----

(1 point)

- Unit is at 100% RTP
- "A" Train KC is in service
- 1A KF Pump is in service

Subsequently:

• The BOP reports that Unit 1 Spent Fuel Pool temperature is rising

The KF system is designed to maintain Spent Fuel pool temperature less than a MAXIMUM of ____(1) ___ for the maximum heat load condition.

1KC-149 (A KF HX OUTLET FLOW) ____ (2) ___ AUTOMATICALLY reposition in order to attempt to lower Spent Fuel Pool temperature.

Which ONE of the following completes the statements above?

- A. 1. 90°F
 - 2. will NOT
- B. 1. 140°F
 - 2. will NOT
- C. 1. 90°F
 - 2. will
- D. 1. 140°F
 - 2. will

Question: 33

(1 point)

Given the following on Unit 1:

 A fuel shuffle of irradiated fuel assemblies is in progress in Unit 1 Spent Fuel Pool

Subsequently,

- Control Room receives a 1RAD-3 F/5 "Cabinet Trouble" Alarm due to a loss of power to 1EMF-17 (SPENT FUEL BLDG REFUEL BRDG)
- Fuel movement operations have been suspended

Based on the conditions above, and

- 1) Per SLC 16.7.6 (RADIATION MONITORING FOR PLANT OPERATIONS), fuel movement operations _____ be recommenced with either a portable continuous monitor or RP continuous dose rate monitoring.
- 2) Per TS 3.7.12 (FUEL HANDLING VENTILATION EXHAUST SYSTEM), VF _____ required to be in FILTRATION Mode for the fuel shuffle.

- A. 1. can NOT
 - 2. is
- B. 1. can NOT
 - 2. is NOT
- C. 1. can
 - 2. is
- D. 1. can
 - 2. is NOT

Question: 34

(1 point)

Given the following on Unit 2:

- Unit is shutdown to MODE 3 in preparation for a refueling outage
- The operating crew has implemented OP/1/A/6100/SD-2 (COOLDOWN TO 400°F)
- The STM PRESS CONTROLLER is in "AUTO"
- NC Tavg is 553°F and STABLE

To continue the NC System cooldown, the BOP will be required to ____(1)____.

Maximum cooldown rate will be achieved when open status lights are lit for steam dump valves SB-3, ____(2)___, and SB-21.

- A. 1. place the "STM DUMP INTLK BYP" switches to the "BYP INTLK" position
 - 2. SB-9
- B. 1. place the STM PRESS CONTROLLER in "M" and adjust the output
 - 2. SB-9
- C. 1. place the "STM DUMP INTLK BYP" switches to the "BYP INTLK" position
 - 2. SB-12
- D. 1. place the STM PRESS CONTROLLER in "M" and adjust the output
 - 2. SB-12

Question: 35

(1 point)

Given	the 1	fol	lowing	on	U	Init	1	:

- The Unit is at 100% RTP
- OAC Alarm U1 Hydrogen Purity LO-LO has been received
- Hydrogen purity is currently 90% and lowering

Subsequently:

• The condition continues to degrade and the turbine is taken off-line

	-				
In order to prevent an explosive mixture of hydrogen and air, the generator will be rapidly purged of hydrogen using(1)					
The primary source of hydrogen impurity is via the(2) system.					
The primary source of flydrogen imparity is via the system.					
Which	ONE of the following completes the statement above?				
Α.	1. carbon dioxide				
Α.	2. LG (Generator Seal Oil)				
	2. 20 (Generator Godi Gil)				
В.	1. carbon dioxide				
.	KG (Generator Stator Cooling Water)				
	3 /				
C.	1. nitrogen				
	2. LG (Generator Seal Oil)				
D.	1. nitrogen				
	KG (Generator Stator Cooling Water)				

ILT22-1 NRC MNS RO NRC Examination

Question: 36

(1 point)

Question: 37

(1 point)

(-iv/0 n	tha	tal		
(JIVEII	1111	10 11	lowing:	
O: * O: :				•

- A release from Waste Gas Decay Tank 'C' is in progress
- EMF-50 (L) (WASTE GAS DISCHARGE) is declared INOPERABLE

The release is being monitored by _____(1)___.

If activity levels result in a Trip 2 on the monitoring EMF, the release ____(2) automatically terminate.

- A. 1. **2**EMF-36 (UNIT VENT GAS)
 - 2. will NOT
- B. 1. **2**EMF-36 (UNIT VENT GAS)
 - 2. will
- C. 1. **1**EMF-36 (UNIT VENT GAS)
 - 2. will NOT
- D. 1. **1**EMF-36 (UNIT VENT GAS)
 - 2. will

Question: 38 (1 point)

Given	the	fol	lowing:	
-------	-----	-----	---------	--

 Maintenance requires shifting the Train A RN Suction to the RC Supply Crossover.

Based on the conditions above:

- 1) Alignment of RC Supply valves affects RN pump operation for _____.
- 2) Realignment of the RN pump discharge be required.

- A. 1. Unit 1 ONLY
 - 2. will
- B. 1. Unit 1 ONLY
 - 2. will NOT
- C. 1. Unit 1 and Unit 2
 - 2. will NOT
- D. 1. Unit 1 and Unit 2
 - 2. will


ILT22-1 NRC MNS RO NRC Examination

Question: 39

(1 point)

Given the following on Unit 1:

- Unit is at 40% RTP
- The crew observes NC system pressure lowering rapidly
- The reactor trip breakers are CLOSED
- The OATC observes the following annunciator status on 1FO-1:



The OATC successfully initiates a MANUAL reactor trip

Based on the conditions above:

- 1) The color of annunciator window 1FO-1/E-6 will be _____.
- 2) An ATWS _____ occurred.

- A. 1. RED
 - 2. has NOT
- B. 1. WHITE
 - 2. has NOT
- C. 1. RED
 - 2. has
- D. 1. WHITE
 - 2. has

Question: 40

Given the	following	on	Unit	1:
-----------	-----------	----	------	----

- Unit is at 100% RTP
- Pressurizer pressure is 2150 PSIG and slowly lowering

• PI	RT pressure is 20 PSIG and slowly rising			
For the conditions above, a leaking PORV is indicated by an RTD temperature of				
Which O	NE of the following completes the statements above?			
A. 6	647°F			
B. 6	646°F			
C. 2	259°F			
D. 2	228°F			

ILT22-1 NRC MNS RO NRC Examination

Question: 41

(1 point)

Given the	following	on	Unit 2:
-----------	-----------	----	---------

- A Reactor trip and Safety Injection has occurred
- The CRS has implemented E-0 (REACTOR TRIP OR SAFETY INJECTION)

Par	· F.	ın٠
геі		·U.

Safety Injection termination criteria for Heat Sink will be met if N/R level in at least one S/G is greater than a MINIMUM of ____ (1) OR Total feed flow to the S/Gs is greater than a MINIMUM of ____(2) GPM.

- Α. 1. 11%
 - 2. 450
- B. 1. 11%
 - 2. 700
- C. 1. 17%
 - 2. 450
- D. 1. 17%
 - 2. 700

Question: 42

Giver	n the following on Unit 1:
•	A Large Break LOCA has occurred Containment pressure peaked at 3.5 PSIG and is currently 2.5 PSIG The CRS has implemented E-0 (REACTOR TRIP OR SAFETY INJECTION)
	0, the crew(1) required to perform Enclosure 2 (PHASE B HVAC PMENT)
	ontainment Air Return (VX) Isolation Damper Delta-P permissive(2) ethat the dampers will NOT open during the initial blowdown phase of the event.
Which	ONE of the following correctly completes the statements above?
A.	1. is 2. does
B.	1. is 2. does NOT
C.	1. is NOT2. does
D.	1. is NOT2. does NOT

ILT22-1 NRC MNS RO NRC Examination

Question: 43 (1 point)

Given the following on Unit 2:

• Unit is in MODE 1

Subsequently:

- The safety breaker to 2C NCP inadvertently OPENS
- The reactor did NOT trip
- The following Permissive Bistable Status light conditions are observed:
 - P-7 Lo Power Rx Trips Blocked DARK
 - o P-8 Hi Pwr Lo Flo Rx Trip Blocked LIT
 - o P-10 Nuclear At Power LIT
 - P-13 Turbine Not At Power LIT

Initial reactor power was _____(1) ____ and plant response _____(2) ____ as expected. Which ONE of the following completes the statement above? A. 1. less than 10% 2. was B. 1. less than 10% 2. was NOT C. 1. greater than 10% 2. was D. 1. greater than 10% 2. was NOT

ILT22-1 NRC MNS RO NRC Examination

Question: 44


(1 point)

Given the following on Unit 1:

• Unit was operating at 100% RTP.

Subsequently:

• The crew enters AP/1/A/5500/12, LOSS OF LETDOWN, CHARGING OR SEAL INJECTION based on the following indications:



Based on the conditions above, an inadvertent closure of _____ has occurred.

- A. 1NV-1A (U1 NC L/D Isol To Regenerative Hx)
- B. 1NV-7B (U1 Letdown Cont Outside Isol)
- C. 1NV-124 (U1 Letdown Press Control)
- D. 1NV-459 (U1 Variable L/D Orifice Outlet Flow Cntrl)

ILT22-1 NRC MNS RO NRC Examination

Question: 45

(1 point)

- A leak has developed on the KC system
- 1AD-10 / C1 (KC SURGE TANK ABNORMAL LEVEL) is in alarm
- The CRS has implemented AP-21 (LOSS OF KC OR KC SYSTEM LEAKAGE)

Per	ΔΓ	コ_つ	1	
1 01	\neg		- 1	

- 1) The FIRST action directed to restore KC surge tank level is to initiate makeup to the Surge tank from the ___(1)__ system.
- 2) If initial makeup is not adequate to restore or stabilize surge tank level, aligning makeup from the ___(2)__ system is required.

- A. 1. YM
 - 2. RN
- B. 1. YM
 - 2. NB
- C. 1. NB
 - 2. RN
- D. 1. NB
 - 2. YM

Question: 46

(1 point)

Given the following on Unit 2:

- A load increase is in progress
- The Pressurizer Pressure Master Controller **OUTPUT** fails LOW
- All Pressurizer Pressure control components are in AUTO
- NC system pressure is currently 2310 PSIG and rising slowly
- NO operator actions have been taken

Based on the conditions	apove.
-------------------------	--------

- 1) PZR Surge Line Temperature is _____.
- 2) 2NC-34A (PZR PORV) open as pressure increases above setpoint.

- A. 1. lowering
 - 2. will
- B. 1. lowering
 - 2. will NOT
- C. 1. rising
 - 2. will
- D. 1. rising
 - 2. will NOT

ILT22-1 NRC MNS RO NRC Examination

Question: 47

(1 point)

Which ONE of the following is a COMPLETE list of breakers that is required to be OPENED by FR-S.1 (RESPONSE TO NUCLEAR POWER GENERATION/ATWS) to trip the reactor LOCALLY?

- A. Reactor Trip Breakers
 Reactor Trip Bypass Breakers
 M/G Set Generator breakers
 M/G Set Motor breakers
- B. Reactor Trip Breakers Reactor Trip Bypass Breakers M/G Set Generator breakers
- C. Reactor Trip Breakers
 Reactor Trip Bypass Breakers
 M/G Set Motor breakers
- D. Reactor Trip Breakers Reactor Trip Bypass Breakers

ILT22-1 NRC MNS RO NRC Examination

Question: 48

Given	the following on Unit 1:
•	Unit is at 100% RTP A steam leak has occurred The CRS has implemented AP-01 (STEAM LEAK)
Per AF	P-01:
	ATC is required to reduce turbine load to maintain(1)less than or to 100% and NC Loop Delta-T's less than(2)D/T.
Which	ONE of the following completes the statement above?
A.	 TPBE (Thermal Power Best Estimate) 58°F
В.	 TPBE (Thermal Power Best Estimate) 60°F
C.	 Excore NI's 58°F
D.	 Excore Nl's 60°F


ILT22-1 NRC MNS RO NRC Examination

Question: 49

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- 1A, 1B and 1C S/G Levels are at program level for the current power
- The following timeline is observed for 1D S/G CF flow and SM flow:



Based on the indications above, AP-06 is required to be entered due to a failure of ____(1)___.

S/G (2) level indication will indicate actual level trends first.

- A. 1. 1CF-17AB (1D S/G CF CONTROL)
 - 2. W/R
- B. 1. 1CF-17AB (1D S/G CF CONTROL)
 - 2. N/R
- C. 1. 1CF-107AB (1D S/G CF CONTROL BYPASS)
 - 2. W/R
- D. 1. 1CF-107AB (1D S/G CF CONTROL BYPASS)
 - 2. N/R

Question: 50

Given	the	followi	ng	on	Unit	1:

- A Loss of Offsite Power has occurred

•	 The crew is verifying natural circulation flow per G-1 (GENERIC ENCLOSURES) Enclosure 33 (NATURAL CIRCULATION PARAMETERS)
NC Sys flow.	stem subcooling > 0 °F(1) required to support natural circulation
•	stem hot leg temperature at saturation temperature for S/G pressure) support or indicate natural circulation.
Which	ONE of the following completes the statements above?
A.	 is does NOT
B.	1. is 2. does
C.	 is NOT does NOT
D.	1. is NOT2. does

Question: 51

(1 point)

Given the following on Unit 1	1	:
-------------------------------	---	---

- Unit is at 100% RTP
- A loss of 1EKVA has occurred
- The CRS has implemented AP-15 (LOSS OF VITAL OR AUX CONTROL POWER)

Per AP-15, when checking 1EKVA ENERGIZED, the crew will check the _____.

This check is required to be performed early in the procedure due to _____.

Which ONE of the following completes the statements above?

- A. 1. switch indication on any pump powered from 1ETA LIT
 - 2. a loss of letdown and VCT makeup capability
- B. 1. switch indication on any pump powered from 1ETA LIT
 - 2. an inadvertent start of the TDCA pump
- C. 1. top row of status lights NORMAL
 - 2. a loss of letdown and VCT makeup capability
- D. 1. top row of status lights NORMAL
 - 2. an inadvertent start of the TDCA pump

Question: 52

(1 point)

Given the following on Unit 2:

• A BLACKOUT has occurred on 2ETB

•	D/G 2B failed to start due to an 86N relay actuation 2AD-11 / F4 (BATT EVCD UNDERVOLTAGE) is in alarm EVDD bus voltage is 113 VDC and lowering slowly
BATTE	P-07 (LOSS OF ELECTRICAL POWER), Enclosure 22 (SWAPPING ERY CHARGER POWER SUPPLIES), the action required to restore bus EVDD (1)
	ction is required because vital control power batteries are analyzed to last a MUM of(2)
Which	ONE of the following completes the statements above?
A.	 align Battery Charger EVCS to Bus EVDD one hour
B.	 align Battery Charger EVCS to Bus EVDD 30 minutes
C.	 swap Battery Charger EVCD power supply to 1EMXB one hour
D.	 swap Battery Charger EVCD power supply to 1EMXB 30 minutes

Question: 53

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- B Train components in service

Subsequently,

- 1B RN pump trips on overcurrent
- The CRS implements AP-20 (LOSS OF RN)
- 1A RN pump is placed in service
- The BOP operator positions the manual loader for 1RN-190B (RN TO B KC HX CONTROL) to 10% open
- The OATC, monitoring the OAC graphic for RN, notes 1RN-190B is indicating full open

1RN-19	90B is indicating full OPEN because
Which	ONE of the following completes the statement above?
A.	minimum flow requirements for the 1B RN Pump are not met
В.	minimum flow requirements for the 1A RN Pump are not met
C.	the manual loader is bypassed when the 1B RN pump breaker is open
D.	1RN-190B is interlocked to open when the 1B RN pump breaker opens


ILT22-1 NRC MNS RO NRC Examination

Question: 54

(1 point)

Given the following on Unit 1:

- An instrument air leak is occurring
- VI pressure is 89 PSIG and lowering slowly
- An operator observes the following on 1AD-12:



Based on the conditions above, VI ____(1) ___ separated from VS.

Per AP-22 (Loss of VI), operators are required to be dispatched to restore VI using ____(2) ___ VI compressors.

- A. 1. is NOT
 - 2. A, B, C
- B. 1. is NOT
 - 2. D, E, F
- C. 1. is 2. D, E, F
- D. 1. is 2. A, B, C

Question: 55

(1 point)

Given the	following o	on Unit 1:
-----------	-------------	------------

- Unit is at 45% RTP
- The Unit has entered AP-05 (GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES)
- Generator MVARS are NOT within the limits of the capability curve
- Generator MVARS are lagging

Based on the conditions ab-	ove and per AP-05:
-----------------------------	--------------------

The operator will depress _____(1) ___ on the "VOLTAGE ADJUST" pushbutton to adjust MVARS to within the capability curve.

IF unable to restore MVARS to within limits with the voltage regulator in AUTO or MAN, the crew will be required to _____(2)___.

- A. 1. LOWER
 - 2. trip the reactor
- B. 1. LOWER
 - 2. trip the turbine
- C. 1. RAISE
 - 2. trip the reactor
- D. 1. RAISE
 - 2. trip the turbine

Question: 56

Given the following on Unit 1	Given	the	following	on	Unit	1:
-------------------------------	-------	-----	-----------	----	------	----

- A Large Break LOCA has occurred
- A and B ND pumps are NOT available
- The CRS has implemented ECA-1.1 (LOSS OF EMERGENCY COOLANT RECIRC) but NO actions have been taken
- Containment pressure is 8 PSIG and slowly rising
- FWST level is 145 inches and lowering

ND PUMP SUCT	Level LO setpoint of _ ION FROM CONT SU CONT SUMP ISOL) _	IMP ISOL)	<u>AND</u> 1NI-185A (1A N	D PUMP `
Which ONE of the	e following completes	the stateme	ent above?	

- A. 1. 95
 - 2. will NOT
- B. 1. 95
 - 2. will
- C. 1. 135
 - 2. will NOT
- D. 1. 135
 - 2. will

Question: 57

(1 point)

Given the following on Unit 1:

- A runback from 100% RTP has occurred
- During the runback, control rod M-12 became stuck

AP-14 (ROD CONTI	ROL MALFU	NCTION)	requir	res a shutdown margin calculation to	C
be performed within	a MINIMUM	of <u>(1</u>	1)	anytime rods are misaligned greate	эr
than a MINIMUM of	(2)	steps, pe	er T.S	3.1.4 (ROD GROUP ALIGNMENT	
LIMITS).				•	
,					

- A. 1. 30 minutes
 - 2 12
- B. 1. 30 minutes
 - 2 24
- C. 1. one hour
 - 2 12
- D. 1. one hour
 - 2 24

Question: 58

11	point)
١.	politi,

Given	the	follo	wina	on	Unit	2:
0.00.			*****	\sim \cdot	O	_

- Unit is in MODE 5
- Source Range Nuclear Instrument count rates are rising
- The CRS implements AP-38 (EMERGENCY BORATION AND RESPONSE TO INADVERTENT DILUTION)
- All attempts to OPEN 2NV-265B (U2 NV PUMP BORIC ACID SUP ISOL) have been unsuccessful

Per AP-38:

1)	The crew will NEXT attempt to establish emergency boration	(1)	

2) A MINIMUM of _____ (2) ____ directed to be started.

Which ONE of the following completes the statements above?

COMPONENT LEGEND:

2NV-269 (UNIT 2 EMERGENCY BORATION VALVE)) 2NV-267A (BORIC ACID TO BLENDER CONTROL)

- A. 1. locally using 2NV-269 and 2NV-267A
 - 2. two Boric Acid pumps are
- B. 1. locally using 2NV-269 and 2NV-267A
 - 2. one Boric Acid pump is
- C. 1. by swapping NV suction to the FWST
 - 2. two Boric Acid pumps are
- D. 1. by swapping NV suction to the FWST
 - 2. one Boric Acid pump is

Question: 59

(1 point)

Given the following on Unit 2.		

Given ti	he fol	lowing	on U	Jnit 2:
----------	--------	--------	------	---------

- Power Range NIs indicate 47%
- Tavg is 571°F
- Pressurizer level on all channels indicates 43.5%

Based on the conditions above:

- 1) 2AD-6 / C7 (PZR HI LEVEL DEV CONTROL) _____ lit.
- 2) A malfunction has occurred affecting Selected _____ output.

- A. 1. is NOT
 - 2. Pzr Level 2
- B. 1. is NOT
 - 2. Pzr Level 1
- C. 1. is
 - 2. Pzr Level 2
- D. 1. is
 - 2. Pzr Level 1

ILT22-1 NRC MNS RO NRC Examination

Question: 60

	Given	the	following	on	Unit 2:
--	-------	-----	-----------	----	---------

- A tube leak has been identified on 2B S/G
- The CRS has implemented AP-10 (NC SYSTEM LEAKAGE WITHIN THE CAPACITY OF BOTH NV PUMPS), Case I (STEAM GENERATOR TUBE LEAKAGE)

	LEAKAGE)
Per AF	P-10:
	Charging flow is required to be maintained less than a MAXIMUM of GPM at all times.
	2) A S/G Tube Rupture will be indicated by the inability to maintain Pressurizer level above a MINIMUM of
Which	ONE of the following completes the statements above?
A.	1. 200 2. 4%
B.	1. 200 2. 11%
C.	1. 232 2. 4%
D.	1. 232 2. 11%

Question: 61

(1 point)

Given the	following of	on Unit 1:
-----------	--------------	------------

- Unit is at 85% RTP
- Main condenser vacuum is 24.5" Hg and degrading
- The CRS has implemented AP-23 (LOSS OF CONDENSER VACUUM)

Control Interlock (C-9) will block the ability to dump steam to the condenser when condenser vacuum degrades to less than a MAXIMUM of _____(1) ____ inches Hg. Per AP-23 basis, the reason for tripping the Main Turbine on loss of Condenser vacuum is to (2) . Which ONE of the following completes the statement above?

- A. 1. 23
 - 2. minimize low pressure turbine blading damage
- 1. 23 B.
 - 2. prevent turbine exhaust hood overheating
- C. 1. 20
 - 2. minimize low pressure turbine blading damage
- 1. 20 D.
 - 2. prevent turbine exhaust hood overheating

Question: 62

(1 point)

Given	the	fol	lowing:	•

- Both Units are at 100% RTP
- Unit 1 operators are performing a 500 gallon dilution for temperature control

Subsequently:

- AP-17 (LOSS OF CONTROL ROOM) is implemented due to toxic gas entering the control room
- The control room is IMMEDIATELY evacuated (NO Operator actions are performed)

Per AP-17:

- 1) An operator is required to secure the Reactor Makeup Water pump from the _____ panel.
- 2) S/G levels will be maintained within the specified range by _____.

- A. 1. local Reactor Makeup Water pump
 - 2. manually throttling the motor operated isolation valves in the doghouses
- B. 1. Aux Shutdown
 - 2. manually throttling the motor operated isolation valves in the doghouses
- C. 1. local Reactor Makeup Water pump
 - 2. adjusting the manual loaders at the local CA pump panels
- D. 1. Aux Shutdown
 - 2. adjusting the manual loaders at the local CA pump panels

Question: 63

(1 point)

Given the following on Unit 1:

- FR-C.2 (RESPONSE TO DEGRADED CORE COOLING) has been implemented
- NC pumps 1B and 1C are in service
- Reactor vessel dynamic D/P is 3% less than required and lowering
- The crew has just completed depressurizing the S/Gs to 190 PSIG

	on the conditions above and per FR-C.2,(1) NC pump(s) will be d(2)
Which	ONE of the following completes the statement above?
A.	 all due to anticipated loss of #1 seal requirements
B.	 all to reduce the loss of inventory
C.	 ONLY 1B due to anticipated loss of #1 seal requirements
D.	 ONLY 1B to reduce the loss of inventory

Question: 64

(1 point)

Given the following on Unit 1:

- A LOCA has occurred
- The CRS has implemented ES-1.2 (POST LOCA COOLDOWN AND DEPRESSURIZATION)
- NC system pressure is 1600 PSIG
- Pzr level is 15%
- Containment pressure peaked at 2.8 PSIG

Per ES-1.2:

- 1) When directed to initiate depressurization, the crew will use _____.
- 2) NC depressurization can be secured when Pzr level exceeds a MINIMUM value of _____.

- A. 1. normal PZR spray valves
 - 2. 50%
- B. 1. normal PZR spray valves
 - 2. 25%
- C. 1. a single PZR PORV
 - 2. 50%
- D. 1. a single PZR PORV
 - 2. 25%

Question: 65

Given	following on Unit 1:	
	A Reactor trip occurred from 100% RTP due to a large steam break The steam break has been isolated and the unit stabilized with the following conditions:	
	on the conditions above, FR-P.1 (RESPONSE TO IMMINENT PRESSURIZED IAL SHOCK CONDITION)(1) required to be entered.	
Per AD-OP-MNS 1001 (MNS CONDUCT OF ABNORMAL OPERATION), CSF status trees should be monitored(2)		
Which	ONE of the following completes the statements above?	
A.	 is NOT every 10-15 minutes 	
B.	 is NOT continuously 	
C.	1. is 2 every 10-15 minutes	
D.	1. is2. continuously	

ILT22-1 NRC MNS RO NRC Examination

Question: 66

Per Al	D-OP-ALL-1000 (CONDUCT OF OPERATIONS):
	The RO is required to perform an end to end control panel walk-down approximately every hours during the shift.
	2) The walk-down required to be logged in the Narrative Logbook.
Which	ONE of the following completes the statements above?
A.	1. two 2. is
B.	1. two 2. is NOT
C.	1. six 2. is
D.	1. six 2. is NOT

Question: 67

(1 point)

Given the following on Unit 1:

Unit is at 100% RTP

Subsequently:

- NC system Tavg is lowering
- Steam header pressure is lowering
- Excore NI's indicate 101% and slowly rising

Per AD-OP-MNS-1001 (MNS CONDUCT OF ABNORMAL OPERATIONS), for transient load changes:

- The operator will immediately reduce turbine load up to a MAXIMUM of _____ and then reduce as needed to maintain power less than the pre-transient condition.
- 2) To control the plant more precisely, the operators should monitor _____ for reactor response.

- A. 1. 20 MWe
 - 2. Thermal Power Best Estimate (TPBE)
- B. 1. 20 MWe
 - 2. NC Loop delta Ts
- C. 1. 25 MWe
 - 2. Thermal Power Best Estimate (TPBE)
- D. 1. 25 MWe
 - 2. NC Loop delta Ts

ILT22-1 NRC MNS RO NRC Examination

Question: 68

Per AD-	-HS-ALL-0103 (FALL PROTECTION):
0	Continuous Fall Protection (100% tie-off) is required when there is a free-fall risk of greater than or equal to a MINIMUM of feet above a working or valking surface.
	A body belt be used to meet Personal Fall Arrest System (PFAS) equirements.
Which C	ONE of the following completes the statements above?
	1. 4 2. can
	1. 4 2. can NOT
_	1. 10 2. can
	1. 10 2. can NOT

ILT22-1 NRC MNS RO NRC Examination

Question: 69

ILT22-1 NRC MNS RO NRC Examination

Question: 70

(1 point)			

Given	the t	ol	lowing	on	Unit	1:
-------	-------	----	--------	----	------	----

- Unit shutdown and cooldown in progress
- NC System Tavg is 325°F

Per T.S 1.1 (Definitions), Unit 1 is in	(1)	
Based on the current status of Unit 1, _ OPERABLE.	(2)	_ train(s) of ECCS shall be

- A. 1. MODE 3
 - 2. two
- B. 1. MODE 3
 - 2. one
- C. 1. MODE 4
 - 2. two
- D. 1. MODE 4
 - 2. one

ILT22-1 NRC MNS RO NRC Examination

Question: 71

Regard	ding performance of surveillance procedures:					
	o-OP-ALL-0112 (OPERATIONS LOG KEEPING AND CHART RECORDERS), a ry is required for(1) of surveillance testing.					
	Per AD-OP-ALL-0201 (PROTECTED EQUIPMENT), a routine surveillance with a testing interval of six months(2) be performed on protected equipment.					
Which	ONE of the following completes the statements above?					
A.	1. completion ONLY 2. can NOT					
B.	initiation AND completion can NOT					
C.	1. completion ONLY 2. can					
D.	initiation AND completion can					

ILT22-1 NRC MNS RO NRC Examination

Question: 72

Per PD	0-RP-ALL-0001, When exiting the RCA:
	After two consecutive Personnel Contamination Monitor (PCM) alarms, a worker exit the RCA after RP performs a "whole body" frisk.
	2) The preferred method for monitoring hard hats and safety glasses is to
	
Which	ONE of the following completes the statement above?
A.	 can NOT place them in the Tool and Equipment Monitor (TEM)
B.	 can NOT wear them through the PCM
C.	 can place them in the Tool and Equipment Monitor (TEM)
D.	 can wear them through the PCM

Question:	73
-----------	----

	PD-RP-ALL-0001 (RADIATION WORKER RESPONSIBILITIES), regarding the of Self-Reading Dosimeters (SRD):
	 Reading the SRD is required at a MINIMUM of while inside a High Radiation Area (HRA) or Locked High Radiation Area (LHRA).
	If a DOSE RATE alarm setpoint is exceeded, the alarm clear when the dose rate drops below 80% of the setpoint.
Whi	ch ONE of the following completes the statements above?
A.	 once per hour will
В.	 once per hour will NOT
C.	 every 15 minutes will
D.	 every 15 minutes will NOT

II.T22-1	NRC MNS	RO NRC	Examination

Question: 74

Per AF	P-47 (SECURITY EVENTS):
	AP-47 provide operator actions for a confirmed unexploded bomb on site event.
:	2) AP-47 designated as proprietary information.
Which	ONE of the following completes the statements above?
A.	1. does 2. is NOT
B.	1. does 2. is
C.	 does NOT is NOT
D.	1. does NOT 2. is

ILT22-1 NRC MNS RO NRC Examination

Question: 75
(1 point)

Per AP-17 (LOSS	OF	CONTROL	ROOM):
-------------	------	----	---------	------	----

- 1) Prior to control room evacuation, operators _____ required to trip BOTH Main Feed pumps.
- 2) The operator dispatched to the Reactor Trip breakers _____ required to be a Reactor Operator.

- A. 1. are NOT
 - 2. is NOT
- B. 1. are NOT
 - 2. is
- C. 1. are
 - 2. is NOT
- D. 1. are
 - 2. is

Reference List for ILT22-1 NRC MNS RO NRC Examination

Steam Tables

Printed 2/2/2022 2:03:40 PM Page 1 of 1

Examination KEY ILT22-1 NRC MNS RO NRC Examination

Q	\boldsymbol{A}	Q	\boldsymbol{A}	Q	\boldsymbol{A}	Q A
1	D	26	Α	51	С	
2	D	27	В	52	С	
3	В	28	D	53	Α	
4	С	29	Α	54	С	
5	D	30	D	55	В	
6	В	31	Α	56	В	
7	Α	32	В	57	С	
8	С	33	С	58	В	
9	D	34	С	59	В	
10	Α	35	Α	60	Α	
11	D	36	С	61	С	
12	С	37	D	62	С	
13	Α	38	С	63	Α	
14	В	39	D	64	В	
15	D	40	С	65	D	
16	D	41	Α	66	В	
17	Α	42	Α	67	В	
18	С	43	С	68	В	
19	В	44	С	69	С	
20	С	45	Α	70	D	
21	Α	46	D	71	В	
22	D	47	Α	72	В	
23	С	48	D	73	С	
24	С	49	Α	74	В	
25	В	50	Α	75	Α	

Printed 2/2/2022 2:04:21 PM Page 1 of 1