



March 21, 2022

L-2022-048  
10 CFR 50.55a  
10 CFR 50.36

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington DC 20555-0001

RE: St. Lucie Nuclear Plant, Unit 2  
Docket No. 50-389  
Refueling Outage SL2-26  
Steam Generator Tube Inspection Report

Attached is the St. Lucie Unit 2 Technical Specification 6.9.1.12 steam generator tube inspection report for the fall 2021 refueling outage (SL2-26). This submittal is made within 180 days after the initial entry into hot shutdown following the completion of the steam generator inspection that was performed in accordance with TS 6.8.4.I, Steam Generator (SG) Program.

Please contact Tim Falkiewicz at 772-429-3756 should you have any questions regarding this submittal.

Sincerely,

A handwritten signature in black ink that reads "Wyatt Godes".

Wyatt Godes  
Regulatory Affairs Manager  
St. Lucie Nuclear Plant

WG/tf

Enclosure: SL2-26 Steam Generator Tube Inspection Report (86 Pages)

## Enclosure

### SL2-26 Steam Generator Tube Inspection Report

#### Introduction:

The enclosed Steam Generator (SG) Tube Inspection Report for the St. Lucie Unit 2 recirculating steam generators (RSGs) is submitted for the inspection performed during refueling outage 26 (hereafter referred to as the SL2-26 inspection/outage), as required by Technical Specification section 6.9.1.12. The SL2-26 inspection was performed in accordance with Technical Specification 6.8.4.1.1, and was the seventh (and last) inspection of the RSGs in the first sequential period of 144 EFPMs. References to prior SG Tube Inspection Reports for the RSGs in the first period are tabulated in Appendix A along with a list of acronyms and abbreviations used in this report.

At unit shutdown for the SL2-26 inspection, the RSGs had operated for approximately 11.85 EFPY (142.2 EFPM) since installation in December 2007. This included operation for approximately 1.35 EFPY (16.24 EFPM) and 1.43 EFPY (17.13 EFPM) during the two fuel cycles (cycles 24 and 25) leading-up to the SL2-26 inspection. Initial entry into Hot Shutdown following completion of the SL2-26 inspection was made on September 25, 2021.

St. Lucie Unit 2 is a 2-loop Combustion Engineering designed NSSS with Model 86/19TI RSGs manufactured by AREVA. The RSGs were fabricated using thermally-treated Inconel 690 tubing. Each RSG contains 8,999 U-tubes; each tube has a nominal OD of 0.75" and a nominal wall thickness of 0.0429". The tubes have a tri-pitch arrangement and are supported by broached, stainless steel tube support plates (TSPs).

#### A. Scope of Inspections Performed on each SG

The SG inspection scope during the SL2-26 outage met the current requirements of the St. Lucie Unit 2 Technical Specifications, the SG Program Guidelines (NEI 97-06 Rev 3) and its referenced EPRI Guidelines. Since the St. Lucie plant has also submitted a License Amendment Request<sup>1</sup> to adopt "Revised Frequencies for Steam Generator Tube Inspections (TSTF-577)", the scope of inspections performed in SL2-26 was selected to also meet TSTF-577 inspection requirements.

##### Primary-side:

- 100% full-length bobbin probe examination of all active tubes.
- Array probe examination at TTS locations of all tubes in hot and cold leg tube expansion transitions of peripheral high-flow regions, and low-row tubes along the tube-free lane. (Peripheral tubes in each RSG span the 2 outermost tubes (of each row) exposed to the annulus, and all tubes in Rows 1-4 along the tube-free lane.) The exam extent was +/- 3.0" from the TTS.
- Supplemental exam of a 30% tube sample of tight-radius U-bends of Rows 1 & 2 using the array probe. The exam extent was from the uppermost TSP on the hotleg to the uppermost TSP on the cold leg. During the 1<sup>st</sup> sequential period, all U-bends of rows 1 & 2 were examined using the +Point™ or array probes.
- Diagnostic +Point™ probe exam at special interest locations as required based on the results of the bobbin coil and/or array coil data. In addition, array probe exams were completed of all tubes with previously-identified PLP Indications, and adjacent tubes.
- Selected wear indications were profiled with line-by-line sizing to provide additional information for condition monitoring and operational assessment purposes.

---

<sup>1</sup> Reference: "Enclosure 2 – Volume 16 – St. Lucie Plant, Units 1 and 2, Improved Technical Specifications Conversion ITS Chapter 5.0 Administrative Controls, Revision 0", NRC ADAMS Accession Number ML21265A301.

- Visual inspection of all installed tube plugs in each RSG.
- Visual inspection of all channel head components of each SG per recommended actions in Westinghouse NSAL 12-1 Rev 1 "Steam Generator Channel Head Degradation" October 2017.

Secondary-side:

- Visual inspection of all accessible components of the Steam Drum/Upper Internals in both SGs. This included a sample of the primary moisture separator swirl vanes, drains, the loose parts trapping screens, and the feedwater ring and supports in both RSGs.
- At the TTS, visual exams were conducted of the annulus region, the no-tube lane and select in-bundle columns in both legs after upper bundle flush activities. This was completed during FOSAR after sludge lancing in each SG.

**B. Active degradation mechanisms found**

Wear at tube support locations was the only active (existing) degradation mechanism identified during the SL2-26 RSG inspection. This degradation mechanism was found on tubes at the following tube support locations:

- Wear at anti-vibration bar (AVB) contact points
- Wear at V-shaped support pad (V-SSP) contact points<sup>2</sup>
- Wear at tube support plate (TSP) contact points

No degradation was identified that was due to foreign objects or to corrosion degradation mechanisms. No evidence of tube-to-tube wear was found.

**C. Nondestructive examination techniques utilized for each degradation mechanism**

Table 1 is a list of the EPRI Examination Technique Specification Sheets (ETSS) used for degradation detection/sizing during the SL2-26 inspection.

**Table 1**

NDE Technique		Degradation Mechanism			ETSS detection/sizing
		Location/Description	Status	Type	
1	Bobbin	Wear at AVB supports (extended for detection of V-shaped support pad and V-shaped support bar wear)	Existing	Volumetric	I-96041.1 Rev 6
2	Bobbin	Wear at AVB and TSP supports (extended for detection of V-shaped support pad and V-shaped support bar wear)	Existing	Volumetric	96004.1 Rev. 13
3	Bobbin	Wear at AVB and TSP supports	Existing	Volumetric	96004.3 Rev. 13
4	Bobbin	Foreign Object Wear (PLP)	Potential	Volumetric	27091.2 Rev. 2
5	Bobbin	Tube-to-tube Wear	Potential	Volumetric	13091.1 Rev. 0
6	+Point™				13901.1 Rev 1

<sup>2</sup> Wear at V-SSPs is also commonly called "appui" wear. Clarification of V-SSP Wear is documented in the St. Lucie Unit 2 Response to RAIs #10 & 11 (NRC ADAMS Accession No. ML15190A336) on the SL2-21 SG Tube Inspection Report.

NDE Technique		Degradation Mechanism			ETSS detection/sizing
		Location/Description	Status	Type	
7	Array <sup>3</sup>	Wear at broached support plates	Existing	Volumetric	11956.3 Rev 3, 11956.4 Rev 3
8	+Point™				96910.1 Rev. 11
9	+Point™	Wear at AVB supports (extended for detection of V-SSP)	Existing	Volumetric	10908.5, Rev. 0
10	Array	Wear at AVB Supports	Existing	Volumetric	17909.1 Rev. 1, 17909.4 Rev. 1 MAPOD App. I
11	+Point™	PLP Wear (morphology dependent) <sup>4</sup>	Potential	Volumetric	27901.1 Rev 1, 27902.1 Rev 2, 27903.1 Rev 1, 27904.1 Rev 2, 27905.1 Rev 2, 27906.1 Rev 1, 27907.1 Rev 2
12	+Point™	Wear at V-shaped support structure (V-SSP)	Existing	Volumetric	See footnotes <sup>3, 5</sup>
13	Array	Shape-dependent volumetric indications (freSPAN; part not present)	Potential	Volumetric	17901.1/3 Rev 0 17902.1/3 Rev 0 17903.1/3 Rev 0 17904.1/3 Rev 0 17905.1/3 Rev 0 17906.1/3 Rev 0

**D. Location, orientation (if linear), and measured sizes (if available) of service induced indications**

The actual listing of service-induced indications identified during the SL2-26 inspection is attached in Appendix B thru F of this report, and is grouped according to the index Table below (Table 2). Unless noted otherwise, each Appendix contains Indications for both SG-2A and SG-2B.

**Table 2 - Indexed listing of Indications in Appendix B thru F**

Description	Appendix	No. of Pages
Bobbin; All TSP Wear	B	4
+Point™; Wear at V-shaped support pads (V-SSP)	C	2
Bobbin; AVB U-bend Apex Wear <sup>6</sup> (AV4/5, AV3/6)	D	2
Bobbin; AVB Wear ≥40% TWD	E	2
Bobbin; AVB Wear 20-39%, 1-19% TWD	F	70

<sup>3</sup> Array exam extended for detecting foreign object (FO) wear at the TTS and freSPAN, and for detecting FOs.

<sup>4</sup> ETSS 27905.1 Rev. 1 was first used during SL2-21 to provide supplemental V-SSB wear sizing information. ETSSs 27901.1 thru 27907.1 have been extended for sizing V-SSB wear.

<sup>5</sup> Site specific qualification for V-SSP wear per AREVA (proprietary) document 51-9193913, "Appui Wear Detection and Sizing Site Qualification".

<sup>6</sup> Note: AV4/5 and AV3/6 AVB U-bend Apex wear occur on tubes in Rows 69 and 40, respectively. Additional info on AVB U-bend Apex wear is documented in the St. Lucie Unit 2 Response to RAI #10 in NRC ADAMS document, ML15190A336.

**E. Number of tubes plugged during the inspection outage for each active degradation mechanism**

The number of tubes plugged for each active degradation mechanism is summarized below in Table 3:

**Table 3 - Tubes Plugged during SL2-26 inspection outage**

Reason for Plugging	SG 2A	SG 2B	Total
AVB Wear $\geq$ 40% - Tech Spec limit	50	3	53
AVB Wear < 40% - preventive plugging <sup>7</sup>	9	3	12
AVB U-bend Apex Wear (AV4/5, AV3/6) <sup>8</sup>	0	0	0
PLP indications - preventive plugging	0	0	0
Wear at V-shaped support pad (V-SSP)	0	0	0
TSP Wear	0	0	0
<b>Total</b>	<b>59</b>	<b>6</b>	<b>65</b>

**F. Total number and percentage of tubes plugged to date**

The total number and percentage of tubes plugged to-date in each SG is summarized below in Table 4:

**Table 4 - Cumulative Tube Plugging Summary following the SL2-26 Inspection**

SG	Total Plugged	% Plugged
2A	436	4.84%
2B	52	0.58%

**G. The results of condition monitoring, including the results of tube pulls and in-situ testing**

All SG tubes inspected during the SL2-26 outage satisfied the condition monitoring (CM) requirements for structural and leakage integrity. No evidence of corrosion degradation was found, and no indications were found to exceed structural limits. All wear indications detected (at AVB, V-SSP and TSP locations), met CM requirements. Therefore, no tubes required in-situ pressure testing for either tube burst or leakage based on the SL2-26 inspections. No tube pulls were required.

1. The largest TSP Wear (%TWD) indications were 27% and 29%, in SG-2A and SG-2B, respectively. The largest growth (since the last inspection) of all previously-reported TSP indications was 9% TWD. All detected TSP wear indications fell below the CM limit for burst and leakage. The voltages for all TSP indications that were inspected with +Point™ were less than 3.0 volts, confirming the burst and leakage integrity for the tubes and in-situ pressure testing was not required. No tubes were plugged due to TSP Wear. The list of TSP Wear indications identified during SL2-26 is provided in Appendix B.
2. Five (5) previously-identified wear indications were reported during SL2-26 which were associated with V-shaped support pad (V-SSP) locations. Each wear indication was shallow in depth and showed little to no growth since the last inspection. All V-SSP indications were sized with a qualified sizing technique, met the CM margin requirements, and the tubes were returned to service based on a plug-on-NDE sizing approach (See NDE Technique #12 of Table 1). No

<sup>7</sup> These additional tubes were selected for preventive plugging based on a chosen criteria. This preventive measure allows for additional margins on wear rates, and to limit the likelihood that CM screening limits would be exceeded during the next scheduled inspection (SL2-29).

<sup>8</sup> The SG AVB arrangement for St. Lucie 2 is shown in Figure 2 of document with NRC ADAMS Accession No. ML14279A237.

wear indications were identified on tubes *adjacent* to V-SSP location (known as v-shaped support bars or V-SSBs). The list of V-SSP indications is provided in Appendix C.

3. During the primary side ECT examinations, no tube degradation was detected at any of the locations where possible loose parts (PLPs) were reported on the secondary-side of the SGs. None of the PLP signals had associated wear on neighboring tubes as detected using the Array probe and confirmed using the +Point™ probe. These tubes remain in service.
4. Previously-identified AVB U-bend Apex wear was detected on some tubes in Row 69 of both SGs using the bobbin probe, and on 1 tube in Row 40 of SG-2A. Row 69 and Row 40 are located just below the AV4/5 and AV3/6 design depth locations, respectively. AVB U-bend Apex wear indications showed little or no growth since the last inspection. The highest recorded indications of AVB U-bend Apex wear (AV4/5) was 34% TWD in SG-2A and 11% TWD in SG-2B. No indication of AVB U-bend Apex Wear met the criteria for preventive plugging. AVB U-bend Apex Wear indications are provided in Appendix D.
5. Fifty (50) tubes in SG-2A and three (3) in SG-2B were reported as having AVB Wear of 40% TWD or greater. These tubes were plugged based on wear indication depths reaching the plugging limits provided in Technical Specifications. The highest AVB wear indications measured 45% TWD in SG-2A and 42% TWD in SG-2B. The list of AVB Wear indications  $\geq$  40% TWD is provided in Appendix E. To provide added margin on wear rates and to limit the likelihood that the CM screening limits would be exceeded during the next scheduled inspection (SL2-29), 12 additional tubes (9 in SG-2A, 3 in SG-2B) having AVB Wear indications  $<$ 40% TWD were selected for “preventive plugging” based on a developed criteria comprised of indication depths, growth rates and/or number of indications on the tubes. A complete listing of AVB Wear indications (with  $<$ 40% TWD) is provided in Appendix F. All detected wear at AVB supports met the required integrity margins for CM, whether sized by bobbin or +Point™, and AVB wear indications met the CM requirements for burst and leakage.
6. Based on industry operating experience described in Westinghouse NSAL 12-01<sup>9</sup> Rev 1, visual inspection of the primary-side channel head bowl (in both SGs) was performed in accordance with the recommendations presented in the NSAL. The channel head and tubesheet cladding were also inspected for rust stains and loss of material. All previously-installed tube plugs in the HL and CL were visually inspected during the SL2-26 inspection outage. All plugs were confirmed to be in their correct locations, and showed no visible signs of leakage based on the visual examination. No degradation of the tube plugs, tubesheets, divider plate assemblies or primary-side channel head bowl areas were noted apart from that incurred during a historical foreign object event in SG-2B<sup>10</sup>. No corrosion-related degradation was identified in any of the SG channel head components.
7. Sludge lancing the TTS after upper bundle flush (UBF), removed 70 and 83.5 lbs. of sludge from SG-2A and SG-2B, respectively. During secondary-side visual exams and FOSAR at the TTS, two (2) foreign objects (FOs) were removed from the CL of SG-2A. One was a light metallic foil-like object; the other was a small metallic piece of wire that measured approximately 2 inches long by 1/16 inch in diameter. Two objects were also removed from SG-2B: one was a small, irregular-shaped metallic object found in the HL; the other was a light, metallic foil-like object found in the CL. A few small sludge rocks were also identified during FOSAR but were not retrieved.
8. During the inspection of the SG Upper Internals/Steam Drum section, the inner support brackets of the SG-2A feedring and the extrados of the feedring at the 270 deg location were found to be slightly deformed from a pressure transient in the feedring during the last operating cycle. Deformation of the inner support brackets was expected in SG-2A since the water-hammer

---

<sup>9</sup> Westinghouse NSAL-12-1 Rev 1, “Steam Generator Channel Head Degradation”, October 2, 2017.

<sup>10</sup> This event is described in Section G Item #8 of the SL2-22 SG Tube Inspection Report (NRC ADAMS Accession No. ML16111B235).

monitoring criteria established for this phenomenon was met following a unit trip on 1/21/21. All welds of the feedring support system were noted to be intact and no loose parts were generated from the event. Repair ligaments were installed to the support brackets, and the support gaps were restored during repairs. The as-found condition and actions taken on the feedring/supports during SL2-26 were documented in the corrective action program, and the feedring support system was restored to its design condition. No degradation was observed during visual exams of the moisture separator components in the Upper Internals or the loose parts trapping screens.

#### H. The effective plugging percentage for all plugging in each SG

No tube repair methods (such as sleeving) are approved for St. Lucie Unit 2 that would have an effect on the effective plugging percentages. Therefore, the effective plugging percentage for each SG is the same as the Percentage of Tubes Plugged in "Item F" above.

### APPENDIX A - Additional Information

#### References to prior SG Tube Inspection Reports

EOC	Outage	ADAMS Accession No.
EOC-17	SL2-18 (1 <sup>st</sup> ISI)	ML093230226
EOC-18	SL2-19	ML11270A015
EOC-19	SL2-20	ML13141A479
EOC-20	SL2-21	ML14279A237
EOC-21	SL2-22	ML16111B235
EOC-22	SL2-23	ML17257A080
EOC-23	SL2-24	ML19081A146

#### Abbreviations and Acronyms

AVB	Anti-Vibration Bar	OD	Outside Diameter
CL	Cold Leg	PLP	Possible Loose Part
CM	Condition Monitoring	PWSCC	Primary Water Stress Corrosion Cracking
EOC-25	End-of-cycle 23 (SL2-26 inspection)	RSG	Recirculating Steam Generator
EFPM	Effective Full Power Months	SG	Steam Generator
EFPY	Effective Full Power Years	SSI	Secondary Side Inspection
EPRI	Electric Power Research Institute	TSP	Tube Support Plate
ETSS	Exam Technique Specification Sheet	TTS	Top of Tubesheet
FO	Foreign Object	TWD	Through Wall Depth
HL	Hot Leg	V-SSB	V-Shaped Support Bar wear (side bar wear)
ISI	In-service Inspection	V-SSP	V-Shaped Support Pad wear (appui wear)
MAPOD	Model-assisted probability of detection	WAR	Mechanical Wear

SL2-26 - 09/21  
 Bobbin TSP Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
1	2	0.26	13	04C +0.32	30	9	0.11	6	05C -0.65	106	43	0.11	6	04H -0.76
		0.24	12	04H -0.74	30	17	0.12	8	03H -0.58	106	45	0.14	8	04H -0.79
1	52	0.16	9	05C +0.30	31	66	0.08	5	02C +0.42	108	39	0.19	10	04H -0.76
1	60	0.20	11	04C +0.39	35	118	0.08	6	02H -0.23	108	111	0.11	7	03C -0.55
1	62	0.33	16	04C +0.37	37	6	0.08	5	04C +0.42	109	34	0.30	15	04H +0.37
1	80	0.19	11	06C -0.76	47	162	0.10	8	05C +0.48			0.18	10	04H -0.74
1	82	0.18	10	05C +0.32	48	9	0.12	6	04C +0.39	109	40	0.20	10	04H -0.79
		0.17	10	05C -0.67	53	158	0.16	8	05C +0.46	109	42	0.09	5	07C -0.68
1	86	0.30	15	05C +0.25	53	162	0.13	10	05C +0.46	110	39	0.15	8	04H +0.37
		0.15	9	05C -0.72	54	159	0.11	6	05C +0.46	110	43	0.09	5	04H -0.79
		0.32	16	04C +0.25	55	14	0.10	6	04H -0.62	111	36	0.11	6	07H +0.32
		0.21	11	04C -0.69	57	10	0.10	5	04C +0.42			0.21	11	07H -0.67
1	92	0.20	11	04C +0.25	57	14	0.10	6	04H -0.65			0.22	12	04H -0.77
		0.16	9	02C -0.60	58	157	0.12	6	05C +0.44	111	38	0.16	12	04H +0.37
1	96	0.14	8	02C +0.32	59	160	0.13	7	05C +0.46	111	134	0.18	9	04C -0.62
1	140	0.09	6	06C -0.74	60	157	0.14	8	05C -0.69			0.11	6	05C +0.49
		0.15	9	05C -0.70	60	159	0.11	9	05C +0.49	113	38	0.14	8	04H -0.74
		0.26	14	04C +0.30	61	152	0.16	12	05C +0.44	116	41	0.15	11	04H -0.76
		0.28	15	04C -0.65	62	85	0.07	5	03H -0.65	117	42	0.11	6	04H +0.37
1	154	0.22	12	05C +0.35	63	156	0.13	7	05C -0.65	117	128	0.10	6	03C -0.53
		0.31	16	05C -0.74	64	157	0.18	9	05C +0.46	119	42	0.16	9	05H -0.62
		0.18	11	04C +0.35	67	156	0.16	9	05C +0.47			0.18	10	04H -0.76
1	156	0.17	10	04C +0.28	68	157	0.15	8	05C -0.69	119	44	0.14	7	05H -0.67
1	160	0.36	18	05C -0.79	69	16	0.12	6	05H +0.44	120	45	0.16	8	04H +0.37
		0.32	16	04C -0.64	70	151	0.17	12	05C +0.47	120	111	0.12	7	05C +0.44
1	162	0.25	14	05C -0.76	72	155	0.19	11	05C +0.45	121	124	0.16	9	05C -0.58
1	168	0.16	10	05C +0.33	73	18	0.13	8	04H -0.51	122	45	0.09	5	04H +0.42
		0.32	16	05C -0.65	74	71	0.28	16	07C +0.09			0.12	7	04H -0.77
		0.25	13	04C -0.71	75	22	0.18	12	04H -0.56	122	47	0.11	6	05H -0.70
2	1	0.13	8	05C +0.34	77	18	0.12	9	04H +0.44	124	49	0.16	9	04H -0.65
		0.26	13	05C -0.62	77	20	0.23	12	04H -0.63	127	100	0.12	6	05C +0.49
		0.26	13	04C +0.37	79	22	0.09	5	04H -0.72	129	96	0.20	12	05C +0.46
		0.11	6	06H -0.74	79	26	0.09	6	04H -0.65	129	114	0.14	8	06H -0.77
2	5	0.12	7	04C -0.62	79	130	0.15	9	04C +0.37	130	57	0.11	6	04H -0.62
2	61	0.18	10	04C +0.35	80	17	0.17	10	04H -0.53	131	92	0.17	10	05C +0.48
		0.12	7	02C +0.39	81	18	0.19	11	04H -0.51	131	104	0.09	7	04C +0.50
2	91	0.18	10	04C -0.74			0.32	16	04H +0.44	131	108	0.08	7	03C +0.51
2	97	0.16	9	02C +0.37			0.15	9	05H -0.56	131	110	0.10	6	03C +0.48
2	121	0.21	12	04C +0.23	86	21	0.30	16	04H -0.60			0.11	7	05C -0.58
3	2	0.12	11	04H -0.74			0.13	8	05H -0.53			0.15	9	05H +0.35
3	8	0.13	12	04H -0.74	87	26	0.12	9	04H -0.65			0.12	7	04H +0.40
		0.08	8	04H +0.37	87	28	0.12	10	06H -0.74	133	106	0.12	6	05C +0.53
3	158	0.18	11	05C -0.65	88	25	0.21	13	04H -0.56	134	103	0.11	6	06H +0.38
3	168	0.12	8	05C +0.40			0.33	18	04H +0.49			0.26	13	05H +0.40
		0.16	9	05C -0.76	89	22	0.10	6	04H -0.54	134	105	0.19	10	05H +0.35
		0.26	14	04C +0.39			0.35	17	04H +0.44	135	78	0.16	8	04C -0.48
4	5	0.17	9	04C +0.42	90	23	0.10	6	04H -0.56	138	83	0.19	10	05H +0.30
4	73	0.09	6	04C +0.40	90	33	0.18	9	04H -0.65					
4	143	0.10	6	04C -0.65			0.11	6	05H -0.56					
4	151	0.10	6	04C -0.72	92	25	0.14	11	04H +0.39					
5	58	0.15	9	04C -0.72	92	27	0.16	12	04H +0.41					
5	82	0.09	5	03H +0.32	92	29	0.10	6	04H +0.42					
5	164	0.18	10	05C +0.37	93	26	0.13	8	04H -0.67					
		0.14	9	05C -0.74	93	34	0.12	7	04H -0.70					
5	168	0.19	11	05C -0.74	94	31	0.13	10	04H +0.44					
6	7	0.08	6	04C +0.39	94	37	0.14	10	04H -0.78					
6	9	0.17	9	04H -0.76	94	141	0.13	9	03H +0.37					
6	169	0.10	7	04C -0.62	95	36	0.16	12	04H -0.80					
7	2	0.13	9	04C +0.42	96	27	0.09	7	07H -0.76					
7	92	0.10	7	04C +0.35	96	29	0.21	11	04H -0.72					
		0.10	7	01C +0.30	96	31	0.10	6	04H -0.74					
10	1	0.06	5	04H -0.65	98	143	0.12	7	07H -0.76					
10	3	0.12	9	04C -0.71	99	28	0.20	11	04H +0.39					
10	9	0.11	7	04H +0.51			0.15	9	04H -0.74					
12	141	0.12	9	04C -0.74	99	30	0.10	8	04H -0.76					
13	2	0.08	5	04H -0.51	100	29	0.10	6	06H -0.70					
14	13	0.11	8	04H -0.69	100	31	0.15	9	05H -0.69					
14	167	0.10	6	05C -0.66	102	39	0.09	5	04H +0.42					
15	168	0.14	11	05H +0.25			0.18	9	04H -0.77					
17	2	0.16	9	04H +0.51	103	32	0.18	13	04H +0.42					
18	91	0.12	8	03C -0.63			0.15	11	04H -0.81					
23	58	0.14	10	04C +0.35	103	42	0.10	5	04H +0.39					

Total Tubes : 149  
 Total Records: 191

Framatome Inc.

9/13/2021 9:05:54 AM

Customer: FPL

Plant: St Lucie

Unit: 2

Component: S/G A

Page 1 of 1

SL2-26 - 09/21

Bobbin TSP Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION
1	168	0.51	22	04C +0.37
2	1	0.78	27	04C -0.62
2	7	0.57	23	04C -0.65

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

Total Tubes : 3  
 Total Records: 3

SL2-26 - 09/21  
Bobbin TSP Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
1	32	0.16	10	04C -0.60	39	8	0.14	8	04C -0.72	124	103	0.09	6	04C -0.65
1	56	0.31	17	05C -0.51	42	7	0.18	10	04C -0.68	125	54	0.17	11	06C -0.67
1	70	0.19	12	05C -0.62	44	7	0.19	12	04C -0.70	125	68	0.06	4	05C +0.37
1	72	0.15	10	05C +0.30	44	15	0.11	7	04C +0.37	126	51	0.08	5	04H -0.76
1	76	0.17	11	05C +0.19	45	8	0.15	9	04C -0.67	126	75	0.16	9	03C -0.61
		0.12	8	05C -0.67	51	20	0.11	7	04H +0.44	126	113	0.07	5	04H +0.37
1	78	0.16	10	05C +0.19	54	13	0.17	10	04C -0.60	127	58	0.11	7	06C -0.71
1	82	0.28	16	04C +0.19	55	160	0.12	8	04H -0.64	127	70	0.11	7	03C -0.66
		0.10	7	04C -0.74			0.11	7	05H -0.53	128	63	0.17	10	03C -0.61
		0.30	17	06C -0.32	60	159	0.15	10	04H +0.42	128	73	0.09	6	04H +0.35
1	84	0.28	16	04C -0.16	61	12	0.14	9	04C -0.67	129	78	0.13	7	03C -0.59
1	110	0.12	8	04C -0.74	61	160	0.17	11	05C +0.37	129	104	0.13	7	04C -0.58
1	126	0.14	9	04C -0.60	66	153	0.18	11	05C +0.35	130	57	0.11	7	07H +0.25
1	142	0.29	16	05C -0.28	67	14	0.21	13	04C -0.63	130	63	0.13	9	04H +0.35
1	148	0.24	14	05C -0.65	68	19	0.18	11	07C -0.85	130	67	0.08	5	05C +0.46
1	154	0.19	11	05C +0.30			0.19	12	03C -0.70			0.20	11	07C -0.67
		0.21	13	04C -0.23	68	151	0.10	9	05H -0.65	130	99	0.27	13	04C -0.62
1	166	0.22	14	06C +0.28	70	13	0.16	10	05C +0.26	130	103	0.14	7	04H -0.72
1	168	0.27	16	04C +0.28			0.12	8	04C +0.39	131	68	0.10	6	05C +0.44
		0.12	9	05H -0.74			0.17	10	04C -0.63			0.07	5	06C +0.42
2	7	0.12	8	06C -0.62	72	19	0.10	7	07C -0.79	131	82	0.15	8	03C -0.62
		0.26	15	05C +0.12	74	15	0.12	8	05C -0.72	131	96	0.16	9	04C -0.65
2	9	0.17	11	04C +0.32	75	18	0.14	10	05C +0.21	131	98	0.13	8	06C +0.37
		0.14	9	04C -0.62	75	72	0.16	11	04H -0.67	131	106	0.06	4	04H +0.32
2	21	0.15	10	05C +0.30	77	152	0.16	14	05C +0.35	133	66	0.13	8	07C -0.72
2	63	0.21	13	04C +0.35	78	19	0.22	13	07C -0.83	133	76	0.10	6	05C +0.44
		0.28	16	04C -0.70	81	152	0.22	13	04H +0.46	133	92	0.13	7	04C -0.65
		0.12	8	03C +0.37			0.17	11	05H +0.42	133	102	0.08	5	04H +0.35
2	69	0.20	12	04C -0.53	86	21	0.28	16	04H +0.44			0.18	10	04H -0.72
2	75	0.15	10	02C +0.39	86	27	0.11	8	04H +0.44	133	106	0.10	6	04C -0.62
2	89	0.13	9	05C -0.65	86	141	0.12	7	05C +0.32	133	108	0.07	4	04H +0.65
2	91	0.17	11	05C +0.19	87	22	0.10	6	04H +0.44	134	65	0.07	5	05C +0.46
		0.13	9	05C -0.67	89	144	0.15	10	03C -0.60			0.14	9	07H +0.30
2	95	0.08	6	05C -0.60	91	70	0.15	9	07C -0.66	134	71	0.10	6	06C +0.32
2	111	0.11	7	05C -0.79	93	146	0.13	8	05H -0.77	134	83	0.15	8	03C -0.57
2	113	0.08	6	05C -0.65	99	142	0.09	6	05C -0.66	134	89	0.06	4	04H +0.32
2	115	0.20	13	05C +0.16			0.15	9	06C +0.33	134	91	0.17	10	07C +0.26
2	125	0.11	8	05C +0.32			0.15	8	05H -0.72	135	70	0.17	10	05C +0.46
2	157	0.20	12	04C +0.32	100	141	0.13	7	05H -0.70			0.11	7	06C +0.42
2	159	0.13	8	04C +0.39	104	139	0.11	7	06C -0.68	135	74	0.10	6	04H +0.37
2	169	0.14	10	06C +0.32	105	138	0.07	4	05H +0.48	136	71	0.14	9	05C +0.32
		0.21	14	05C +0.21	106	33	0.10	6	04H -0.74	136	73	0.13	8	05C +0.44
3	30	0.10	7	05C -0.65	107	60	0.09	6	05C +0.46	136	77	0.17	9	03C -0.59
3	40	0.18	11	04C +0.23	107	62	0.12	8	05C -0.69			0.08	5	05C +0.44
3	46	0.20	12	04C +0.19	108	137	0.08	5	04C -0.63			0.10	7	04H +0.51
3	52	0.22	13	05C -0.23			0.16	9	05C -0.63	136	91	0.15	8	04C -0.62
3	60	0.16	10	05C +0.28			0.06	4	05C +0.47	137	82	0.25	14	07C +0.35
		0.19	12	05C -0.63	109	56	0.13	9	07C -0.72	137	92	0.06	4	04C +0.44
		0.26	15	04C +0.32	112	37	0.13	7	04H -0.67	138	73	0.07	5	05C +0.44
		0.17	11	04C -0.62	113	54	0.11	7	05C -0.71			0.17	10	04H +0.35
3	70	0.14	9	04C +0.37	113	60	0.06	4	05C +0.49	138	79	0.18	9	03C -0.54
3	82	0.13	8	05C +0.32	114	45	0.07	5	04C +0.51			0.08	5	05C +0.46
3	168	0.12	9	04C +0.32	115	56	0.06	4	06C +0.42	138	81	0.11	6	03C -0.61
		0.23	15	03C -0.62	116	131	0.28	14	05C -0.58	139	86	0.12	7	06C -0.70
4	45	0.29	17	05C +0.18	117	50	0.14	8	04H -0.74			0.14	9	06C +0.40
4	57	0.26	15	05C +0.19	118	41	0.16	10	06C +0.39					
4	71	0.15	10	05C +0.32			0.13	8	04H -0.69					
5	76	0.14	10	05C +0.28	120	127	0.08	5	04C +0.51					
10	53	0.24	15	05H +0.44	121	46	0.12	7	06C +0.39					
11	80	0.17	10	04C +0.39	121	48	0.11	7	05C -0.62					
16	3	0.13	8	04H +0.51	121	126	0.21	11	04C -0.58					
17	36	0.12	7	05C +0.35	122	51	0.23	13	06C -0.70					
17	82	0.11	7	05C +0.35	122	107	0.13	7	04C -0.63					
18	167	0.14	9	05H -0.65	123	46	0.14	8	05C -0.62					
20	17	0.16	10	04H +0.48			0.10	6	04H -0.74					
20	167	0.16	14	05H -0.69	123	50	0.18	10	06C -0.69					
22	45	0.17	11	04H -0.66			0.15	9	06C +0.42					
		0.24	15	04C -0.79	124	51	0.21	13	06C -0.69					
22	85	0.13	9	01C -0.58			0.13	8	04H -0.69					
22	125	0.14	9	03C -0.74	124	55	0.14	8	05C -0.64					
31	10	0.17	11	04C -0.70	124	57	0.09	6	05C -0.69					
36	5	0.17	10	04C -0.61	124	101	0.14	8	04C -0.60					

Total Tubes : 160  
Total Records: 199

SL2-26 - 09/21

Bobbin TSP Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION
1	82	0.65	28	05C +0.21
		0.57	26	05C -0.67
1	84	0.46	23	05C +0.21
1	116	0.56	26	05C -0.26
1	168	0.66	29	05C -0.18

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

Total Tubes : 4  
Total Records: 5

SL2-26 - 09/21  
 Tubes with VPAD (V-SSB/V-SSP) Wear Indications

QUERY: QueryM2[1] .qry

ROW	COL	VOLTS	DEG	CHAN	IND	%TW	LOCATION	EXT	EXT	UTIL 1	UTIL 2	UTIL 3	CAL	LEG	PROBE	IDX
120	43	0.13	102	P1	NQI		AV7 +23.08	TEC	TEH	REV	V-SSP		21	HOT	610HS	I006
		0.13	77	P7	WAR		AV7 +23.57	07C	AV6	17	ARQUAL		53	COLD	5601P	I007
121	44				NDF		AV6 -1.00	07C	AV6				53	COLD	5601P	I008
		0.14	142	P1	DSS		AV6 -1.00	TEC	TEH	REV	V-SSB		19	HOT	610HS	I254
135	102	0.14	90	P7	WAR		AV3 +0.96	AV3	AV3	18	ARQUAL		36	HOT	5601P	I009
		0.13	129	P1	NQI		AV3 +1.05	TEC	TEH	REV	V-SSP		11	HOT	610HS	I047

Total Tubes : 3  
 Total Records: 6

Note: the "UTIL 1" entries contains the %TWD values for V-SSP wear indications.

SL2-26 - 09/21

Tubes with VPAD (V-SSB/V-SSP) Wear Indications

QUERY: QueryM2[1] .qry

ROW	COL	VOLTS	DEG	CHAN	IND	%TW	LOCATION	EXT	EXT	UTIL 1	UTIL 2	UTIL 3	CAL	LEG	PROBE	IDX
73	14	0.15	94	P7	WAR		AV2 +1.63	AV2	AV2	18	ARVQUAL		32	HOT	5601P	I017
		0.12	95	P1	NQI		AV2 +1.70	TEH	TEC	REV	V-SSP		25	COLD	610HS	I154
110	135	0.23	262	P7	WAR		AV8 -1.76	AV8	AV8	24	ARVQUAL		46	COLD	5601P	I018
		0.19	106	P1	NQI		AV8 -1.35	TEC	TEH	REV	V-SSP		12	HOT	610HS	I068
112	133	0.26	120	P1	NQI		AV7 +21.99	TEC	TEH	REV	V-SSP		12	HOT	610HS	I079
		0.25	266	P7	WAR		AV7 +22.40	AV8	AV7	26	ARVQUAL		46	COLD	5601P	I019

Total Tubes : 3

Total Records: 6

SL2-26 - 09/21

Bobbin AVB Wear in AVB Transition Row Tubes (Crossover Tube Locations Row 17 @AV2, Row 40 @AV3 and Row 69 @AV4)

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
40	145	0.18	6	AV3 +1.08										
69	74	0.52	13	AV4 +0.95										
69	98	0.71	13	AV4 +0.45										
69	100	1.20	23	AV4 +0.59										
69	102	1.88	32	AV4 +1.22										
69	104	0.86	21	AV4 +1.14										
69	106	2.21	34	AV4 +1.04										
69	108	2.15	34	AV4 +1.02										
69	110	0.56	16	AV4 +0.87										
69	112	0.97	22	AV4 +0.85										
69	114	0.39	12	AV4 +0.02										
69	116	0.12	4	AV4 +0.65										
69	118	0.25	8	AV4 +0.91										
69	120	0.26	8	AV4 +1.07										
69	122	0.23	7	AV4 +0.25										
69	124	0.17	5	AV4 +0.83										
69	126	0.15	4	AV4 +0.90										
69	128	0.15	4	AV4 +0.91										
69	130	0.20	7	AV4 +0.02										
69	132	0.13	5	AV4 -0.08										
69	136	0.21	7	AV4 +0.70										
69	138	0.26	8	AV4 +0.74										
69	144	0.27	10	AV4 +0.13										

Total Tubes : 23

Total Records: 23

SL2-26 - 09/21

Bobbin AVB Wear in AVB Transition Row Tubes (Crossover Tube Locations Row 17 @AV2, Row 40 @AV3 and Row 69 @AV4)

ROW	COL	%TW	LOCATION
69	18	9	AV4 +0.90
69	20	8	AV4 +0.75
69	24	8	AV4 +0.95
69	36	6	AV4 +0.97
69	44	7	AV4 +0.73
69	46	5	AV4 +0.98
69	52	5	AV4 +0.96
69	56	8	AV4 +1.02
69	62	10	AV4 +1.07
69	78	11	AV4 +1.30
69	84	6	AV4 +0.95
69	92	8	AV4 +0.09
69	98	8	AV4 +0.07

ROW COL %TW LOCATION

ROW COL %TW LOCATION

Total Tubes : 13  
Total Records: 13

SL2-26 - 09/21

Bobbin AVB Wear 40-100%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
74	71	3.45	41	AV6 +0.02										
		3.64	41	AV7 +0.02										
77	104	3.37	40	AV6 +0.02										
77	116	3.43	41	AV5 +0.02										
78	89	3.19	40	AV5 +0.05										
78	97	3.85	42	AV5 +0.07										
79	74	3.19	40	AV6 +0.02										
80	101	3.91	42	AV5 +0.02										
81	102	3.39	41	AV6 +0.02										
82	85	3.33	40	AV6 +0.02										
82	93	3.53	41	AV6 +0.02										
82	95	3.46	41	AV5 +0.02										
82	99	3.92	42	AV5 +0.02										
84	69	3.16	40	AV5 +0.09										
84	87	3.22	40	AV4 +0.03										
		3.27	40	AV5 +0.02										
86	101	3.39	41	AV5 +0.05										
		4.36	44	AV6 +0.07										
87	90	3.30	40	AV5 +0.05										
90	97	3.98	43	AV5 +0.05										
91	80	3.26	40	AV6 +0.00										
91	96	4.60	45	AV5 +0.02										
91	98	3.46	41	AV5 +0.07										
92	79	4.06	43	AV7 +0.00										
		4.59	45	AV6 +0.00										
93	104	3.57	41	AV6 +0.00										
		3.47	41	AV5 -0.03										
95	88	3.45	41	AV5 +0.00										
95	96	3.16	40	AV5 +0.00										
95	100	3.62	41	AV6 +0.02										
96	75	3.23	40	AV7 +0.00										
96	79	4.56	45	AV6 +0.00										
		3.50	41	AV5 +0.02										
96	91	3.27	40	AV5 +0.02										
97	74	3.44	41	AV6 +0.07										
98	73	3.33	40	AV6 +0.00										
		3.94	43	AV5 +0.00										
98	77	3.16	40	AV5 -0.03										
99	78	3.18	40	AV7 +0.00										
100	73	3.42	41	AV7 -0.02										
100	79	3.36	40	AV5 +0.00										
104	75	4.00	43	AV5 +0.02										
106	73	3.47	41	AV7 +0.02										
106	95	3.15	40	AV6 +0.02										
		3.51	41	AV5 +0.00										
108	71	3.52	41	AV5 +0.05										
108	99	3.92	43	AV4 -0.02										
109	100	3.48	41	AV6 +0.05										
112	79	3.37	40	AV6 +0.00										
123	72	4.30	44	AV6 -0.02										
125	90	4.02	43	AV6 +0.02										
127	88	3.74	42	AV6 -0.02										
127	90	3.62	41	AV5 +0.00										
130	79	3.88	42	AV6 +0.10										
135	78	4.31	44	AV5 +0.02										
135	92	3.65	42	AV7 +0.09										
136	93	3.61	41	AV5 +0.02										
137	84	3.19	40	AV5 -0.03										

Total Tubes : 50

Total Records: 58

Framatome Inc.

9/13/2021 9:10:17 AM

Customer: FPL

Plant: St Lucie

Unit: 2

Component: S/G B

Page 1 of 1

SL2-26 - 09/21

Bobbin AVB Wear 40-100%

ROW	COL	VOLTS	%TW	LOCATION
97	76	3.69	42	AV5 +0.00
108	99	3.37	40	AV5 +0.00
130	67	3.28	40	AV6 +0.02

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

ROW	COL	VOLTS	%TW	LOCATION
-----	-----	-------	-----	----------

Total Tubes : 3  
 Total Records: 3

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
24	167	0.14	7	AV7 +0.27	40	145	0.18	6	AV3 +1.08	45	130	0.14	7	AV6 +0.22
25	166	0.28	11	AV7 +0.22	40	161	0.15	8	AV7 -0.22	45	142	0.19	9	AV6 +0.20
26	19	0.07	4	AV1 +0.00	40	163	0.15	7	AV1 +0.18	45	154	0.20	9	AV6 +0.22
27	4	0.16	8	AV7 +0.32	41	6	0.22	10	AV7 -0.24			0.40	15	AV3 -0.25
27	164	0.15	7	AV7 -0.32	41	8	0.08	5	AV7 +0.22	45	156	0.12	6	AV7 +0.29
29	4	0.12	6	AV2 -0.30			0.16	8	AV8 -0.20			0.14	7	AV6 +0.20
		0.14	7	AV7 +0.32			0.16	8	AV2 -0.18	45	158	0.17	8	AV8 +0.16
29	6	0.18	9	AV8 -0.17	41	158	0.16	8	AV8 +0.18			0.19	9	AV6 +0.18
29	166	0.13	7	AV7 +0.32			0.18	8	AV7 -0.18	45	160	0.15	7	AV7 +0.16
30	5	0.12	6	AV2 -0.28	41	162	0.43	15	AV2 +0.15			0.14	7	AV2 -0.21
31	164	0.10	6	AV7 +0.28	41	164	0.22	10	AV7 -0.21	45	162	0.18	8	AV8 -0.26
31	166	0.27	11	AV7 +0.25			0.21	9	AV2 -0.23			0.14	7	AV7 +0.19
		0.18	8	AV2 -0.31	42	7	0.31	12	AV7 -0.20			0.29	12	AV6 +0.23
		0.12	6	AV1 -0.18			0.18	8	AV8 -0.18			0.11	6	AV3 -0.23
32	163	0.15	8	AV7 -0.29	42	9	0.16	8	AV2 -0.23			0.22	10	AV2 -0.18
33	6	0.17	8	AV2 -0.23			0.13	7	AV3 -0.36			0.12	6	AV1 -0.23
		0.28	12	AV7 +0.25			0.43	15	AV7 -0.19	46	7	0.16	8	AV3 -0.23
		0.15	8	AV8 -0.18	42	159	0.19	9	AV7 -0.23			0.29	12	AV7 +0.23
33	8	0.16	8	AV2 +0.23	42	161	0.16	8	AV8 -0.21	46	9	0.11	6	AV2 -0.22
33	162	0.11	6	AV2 -0.20			0.26	11	AV7 -0.21			0.26	11	AV6 +0.22
33	164	0.23	10	AV7 +0.21			0.45	16	AV6 +0.37	46	11	0.25	11	AV2 -0.17
		0.31	12	AV2 -0.23			0.12	6	AV7 +0.23			0.19	9	AV3 -0.25
34	5	0.21	9	AV7 +0.28	42	163	0.15	7	AV8 -0.21			0.18	8	AV6 +0.16
34	7	0.16	8	AV7 +0.23			0.29	12	AV7 -0.23			0.19	9	AV7 +0.18
34	163	0.10	6	AV7 -0.05			0.33	13	AV2 +0.19	46	13	0.11	6	AV2 -0.15
		0.16	8	AV2 -0.20	43	6	0.10	6	AV2 +0.22	46	35	0.09	5	AV3 +0.35
34	165	0.18	9	AV7 +0.21			0.11	6	AV3 -0.29	46	141	0.18	9	AV6 -0.28
35	6	0.19	9	AV7 -0.30			0.14	7	AV6 +0.30	46	157	0.16	8	AV6 -0.32
35	8	0.14	7	AV7 +0.21			0.35	14	AV7 -0.24			0.10	5	AV1 -0.16
35	162	0.11	6	AV2 +0.21			0.22	10	AV7 +0.25	46	159	0.19	9	AV7 +0.23
35	164	0.22	10	AV7 +0.24			0.12	6	AV8 +0.25			0.13	7	AV6 +0.18
36	7	0.16	8	AV2 -0.24	43	8	0.13	7	AV1 +0.22	46	161	0.18	9	AV7 +0.21
		0.17	8	AV7 +0.25			0.13	7	AV6 +0.30			0.49	17	AV6 +0.18
36	161	0.11	6	AV7 +0.14			0.19	9	AV7 +0.23			0.25	11	AV2 -0.18
36	163	0.13	7	AV2 -0.27	43	124	0.09	5	AV2 -0.14	46	163	0.16	8	AV8 +0.22
36	165	0.14	7	AV7 +0.23	43	154	0.13	7	AV6 +0.27			0.35	14	AV7 +0.26
37	6	0.21	9	AV7 +0.28			0.24	10	AV3 -0.29			0.19	9	AV6 +0.18
37	8	0.26	11	AV7 +0.21	43	158	0.12	6	AV6 +0.28			0.15	7	AV2 -0.23
37	158	0.19	9	AV7 -0.25	43	160	0.12	6	AV1 +0.18	47	8	0.10	6	AV2 +0.05
37	162	0.11	6	AV8 +0.14	43	162	0.10	5	AV7 +0.18			0.21	10	AV3 -0.23
		0.16	8	AV7 +0.23			0.21	9	AV6 +0.32			0.37	14	AV6 +0.20
		0.12	6	AV7 -0.31	43	164	0.16	8	AV7 +0.23			0.30	12	AV7 +0.21
		0.12	6	AV2 -0.02			0.17	8	AV6 +0.28			0.12	6	AV8 +0.21
37	164	0.12	6	AV7 -0.28			0.10	5	AV2 -0.28	47	10	0.19	9	AV7 +0.18
38	5	0.19	9	AV7 +0.28	44	7	0.09	5	AV1 -0.22	47	12	0.13	7	AV8 +0.23
38	7	0.11	6	AV2 -0.25			0.14	7	AV2 -0.24	47	44	0.15	7	AV3 -0.21
		0.26	11	AV7 +0.23			0.26	11	AV3 -0.20	47	142	0.15	7	AV6 +0.22
38	9	0.12	6	AV1 +0.22			0.31	12	AV6 +0.26	47	154	0.19	9	AV6 +0.18
		0.12	6	AV2 -0.24			0.20	9	AV7 +0.02			0.53	18	AV3 -0.27
		0.10	6	AV7 -0.26	44	9	0.15	7	AV2 -0.23	47	160	0.18	9	AV8 -0.21
		0.16	8	AV8 -0.18			0.13	7	AV3 -0.27			0.14	7	AV7 +0.26
38	11	0.10	6	AV2 -0.18			0.10	5	AV6 +0.28			0.16	8	AV6 +0.13
		0.10	6	AV7 -0.26			0.21	9	AV8 -0.16			0.27	11	AV2 -0.20
38	161	0.21	9	AV7 -0.28	44	11	0.08	5	AV2 -0.23			0.16	8	AV1 +0.20
		0.14	7	AV2 +0.23			0.10	6	AV8 -0.16	47	162	0.27	11	AV8 -0.23
38	163	0.18	8	AV7 +0.24	44	141	0.15	7	AV6 -0.33			0.31	12	AV7 -0.25
		0.20	9	AV2 -0.26	44	153	0.18	8	AV6 -0.52			0.57	18	AV6 +0.21
38	165	0.30	12	AV7 +0.21	44	157	0.21	10	AV7 -0.22			0.18	8	AV3 -0.20
		0.12	6	AV1 -0.23	44	159	0.16	8	AV7 -0.20			0.23	10	AV2 -0.23
39	6	0.29	12	AV2 -0.21	44	161	0.34	13	AV6 +0.22	48	7	0.24	10	AV3 -0.21
		0.23	10	AV7 +0.25			0.17	8	AV6 -0.47			0.37	14	AV6 +0.20
39	8	0.22	10	AV7 +0.23	44	163	0.21	10	AV8 -0.21			0.18	8	AV7 +0.23
39	10	0.18	9	AV7 +0.18			0.24	10	AV6 +0.20	48	9	0.17	8	AV7 +0.23
39	162	0.24	10	AV7 +0.19			0.17	8	AV6 -0.44			0.17	8	AV8 +0.20
		0.13	7	AV2 -0.23			0.18	9	AV2 +0.20			0.23	10	AV2 -0.23
39	164	0.27	11	AV7 +0.23			0.13	7	AV1 -0.23			0.24	11	AV3 -0.20
		0.26	11	AV2 +0.18	45	8	0.08	5	AV2 -0.23			0.29	12	AV6 +0.22
40	7	0.21	9	AV2 -0.23			0.13	7	AV6 +0.22	48	11	0.15	7	AV2 -0.18
		0.28	12	AV7 +0.23			0.18	8	AV7 +0.25			0.27	11	AV7 +0.23
40	9	0.56	18	AV7 -0.21	45	12	0.12	6	AV2 -0.18	48	13	0.17	8	AV2 -0.14
		0.31	12	AV8 -0.18	45	14	0.07	4	AV3 -0.20			0.15	7	AV3 +0.14
40	11	0.19	9	AV7 -0.21	45	120	0.09	5	AV3 -0.20	48	15	0.14	7	AV3 -0.20

SL2-26 - 09/21

Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
48	35	0.22	10	AV3 +0.29	50	147	0.12	6	AV6 -0.06			0.14	7	AV8 +0.07
48	141	0.14	7	AV6 -0.29	50	153	0.25	11	AV6 -0.34	52	35	0.23	10	AV3 +0.27
48	147	0.24	10	AV6 -0.03			0.39	14	AV3 +0.29			0.10	5	AV6 -0.29
48	153	0.12	6	AV6 -0.36	50	155	0.57	18	AV6 -0.28	52	111	0.11	6	AV3 -0.12
48	157	0.10	6	AV6 +0.16	50	157	0.24	10	AV7 -0.21	52	121	0.12	6	AV3 +0.22
48	159	0.16	8	AV7 +0.16			0.17	8	AV6 -0.06	52	141	0.28	12	AV6 -0.25
		0.17	8	AV3 +0.23	50	159	0.18	9	AV7 +0.24	52	145	0.08	5	AV2 +0.13
48	161	0.30	12	AV7 +0.18			0.19	9	AV6 +0.18			0.14	7	AV1 +0.05
		0.56	18	AV6 +0.25			0.18	8	AV3 +0.26	52	147	0.15	7	AV6 -0.05
		0.38	14	AV2 -0.14			0.20	9	AV2 -0.16	52	149	0.14	7	AV6 +0.16
		0.10	6	AV1 +0.21	50	161	0.25	11	AV7 +0.21	52	151	0.18	9	AV7 -0.15
48	163	0.25	11	AV7 -0.25			0.36	14	AV6 +0.20	52	153	0.49	17	AV3 +0.25
		0.21	9	AV3 +0.36			0.25	11	AV6 -0.34	52	155	0.13	7	AV6 +0.18
		0.18	8	AV2 -0.20			0.17	8	AV3 +0.31	52	157	0.11	6	AV6 +0.18
49	8	0.12	6	AV2 -0.25			0.16	8	AV2 -0.20	52	159	0.16	8	AV7 +0.21
		0.22	10	AV3 -0.29			0.11	6	AV1 -0.23			0.34	13	AV6 -0.36
		0.14	7	AV6 +0.24	50	163	0.45	16	AV7 -0.25			0.23	10	AV3 +0.25
		0.12	6	AV7 +0.23			0.21	9	AV6 +0.21			0.24	10	AV2 -0.19
49	10	0.28	11	AV7 +0.16			0.07	4	AV3 +0.29			0.19	9	AV1 -0.23
		0.22	10	AV2 -0.17	51	8	0.28	12	AV3 -0.21	52	161	0.42	15	AV6 +0.25
		0.14	7	AV3 -0.21			0.37	14	AV6 +0.22			0.19	9	AV3 +0.30
		0.15	7	AV6 +0.25			0.14	7	AV8 +0.23			0.26	11	AV2 -0.21
49	12	0.12	6	AV2 -0.17	51	10	0.18	9	AV2 -0.18			0.21	9	AV1 -0.18
		0.14	7	AV3 -0.25			0.20	9	AV6 +0.22			0.38	14	AV7 -0.21
		0.26	11	AV8 +0.02			0.13	7	AV7 +0.18	53	8	0.46	16	AV2 +0.23
49	16	0.15	7	AV3 +0.33			0.23	10	AV8 +0.20			0.37	14	AV3 -0.23
		0.60	19	AV6 -0.03	51	12	0.15	8	AV3 +0.00			0.23	10	AV6 +0.22
		0.15	8	AV7 +0.02	51	16	0.11	6	AV2 -0.21			0.17	8	AV8 +0.23
49	22	0.08	5	AV2 +0.21			0.38	14	AV6 -0.06	53	10	0.12	6	AV1 +0.25
49	26	0.10	6	AV3 -0.16			0.38	14	AV7 -0.05			0.24	10	AV2 -0.19
49	34	0.15	7	AV3 -0.16			0.23	10	AV8 +0.00			0.17	8	AV3 -0.21
49	128	0.10	5	AV3 -0.14	51	18	0.16	8	AV3 +0.06			0.36	14	AV6 +0.18
49	142	0.14	7	AV6 +0.20	51	34	0.10	5	AV3 -0.13			0.33	13	AV7 -0.02
49	144	0.17	8	AV3 +0.29	51	102	0.15	7	AV6 +0.23			0.23	10	AV8 -0.18
49	154	0.19	9	AV6 +0.18	51	108	0.12	6	AV6 +0.18	53	12	0.19	9	AV3 +0.05
		0.30	12	AV3 -0.23	51	128	0.09	5	AV3 -0.18			0.11	6	AV2 -0.51
49	156	0.14	7	AV7 +0.25	51	144	0.23	10	AV3 +0.27			0.20	9	AV8 -0.14
49	158	0.18	9	AV7 -0.23	51	154	0.09	5	AV7 +0.19	53	16	0.19	9	AV6 -0.03
		0.20	9	AV6 -0.31			0.24	10	AV6 +0.16	53	20	0.16	8	AV3 -0.21
		0.21	9	AV3 +0.31			0.41	15	AV3 -0.20	53	34	0.19	9	AV3 -0.16
49	160	0.13	7	AV8 -0.18	51	156	0.26	11	AV7 +0.23			0.20	9	AV6 +0.18
		0.23	10	AV7 +0.16			0.26	11	AV6 +0.18	53	44	0.07	5	AV3 -0.21
		0.24	10	AV2 -0.21	51	158	0.21	9	AV7 +0.19	53	54	0.09	5	AV3 -0.02
49	162	0.19	9	AV7 +0.21			0.12	6	AV6 -0.25	53	102	0.13	7	AV6 +0.18
		0.34	13	AV6 +0.18			0.15	8	AV3 +0.28	53	110	0.13	7	AV3 +0.06
		0.12	6	AV3 -0.25	51	160	0.24	10	AV8 -0.24	53	124	0.14	7	AV3 +0.06
		0.34	13	AV2 -0.20			0.28	11	AV7 +0.19			0.16	8	AV7 +0.02
50	7	0.14	7	AV2 +0.24			0.22	10	AV3 +0.03	53	128	0.18	9	AV3 -0.12
		0.22	10	AV3 -0.21			0.51	17	AV2 -0.20	53	130	0.15	8	AV6 +0.20
		0.29	12	AV6 +0.22			0.15	7	AV1 +0.18	53	136	0.12	6	AV6 +0.00
		0.20	9	AV7 +0.25	51	162	0.32	13	AV7 -0.23	53	142	0.35	13	AV6 +0.17
50	9	0.20	9	AV7 +0.21			0.51	17	AV2 -0.18	53	144	0.17	8	AV7 +0.15
		0.13	7	AV8 +0.21			0.30	12	AV1 -0.20			0.19	9	AV3 +0.22
		0.13	7	AV2 -0.23			0.38	14	AV3 -0.27			0.10	5	AV8 +0.42
		0.26	11	AV3 -0.21			0.29	12	AV3 +0.28	53	148	0.11	6	AV7 -0.04
		0.32	13	AV6 +0.20	52	9	0.20	9	AV2 -0.22			0.15	7	AV6 -0.06
50	11	0.44	16	AV2 -0.18			0.46	16	AV3 -0.27	53	154	0.26	11	AV6 +0.16
		0.12	6	AV3 -0.25			0.44	16	AV6 +0.24			0.33	13	AV3 -0.23
		0.16	8	AV6 +0.20			0.35	14	AV7 +0.00	53	156	0.19	9	AV8 -0.11
		0.23	10	AV7 +0.21	52	11	0.21	9	AV2 -0.18			0.46	16	AV7 +0.00
50	13	0.11	6	AV2 -0.21			0.36	14	AV6 +0.22			0.30	12	AV6 +0.17
		0.08	5	AV3 -0.18			0.52	17	AV7 +0.18	53	158	0.19	9	AV8 -0.02
		0.09	5	AV6 +0.20			0.13	7	AV8 -0.16			0.39	15	AV7 +0.19
50	15	0.17	8	AV3 -0.19	52	13	0.23	10	AV2 -0.13			0.19	9	AV6 -0.33
		0.09	5	AV6 +0.23			0.28	12	AV6 -0.03			0.15	7	AV3 +0.30
		0.07	4	AV7 -0.27			0.45	16	AV7 +0.00	53	160	0.11	6	AV8 -0.18
		0.12	6	AV8 -0.18			0.33	13	AV8 -0.02			0.30	12	AV7 +0.16
50	19	0.13	7	AV3 -0.21	52	15	0.26	11	AV7 +0.00			0.14	7	AV3 +0.00
50	45	0.11	6	AV3 +0.24			0.11	6	AV8 +0.00			0.24	11	AV2 -0.21
50	111	0.10	5	AV6 -0.25	52	17	0.14	7	AV2 -0.16	53	162	0.39	15	AV7 -0.25
50	125	0.11	6	AV3 +0.00			0.15	7	AV3 -0.14			0.22	10	AV3 -0.20
50	137	0.11	6	AV6 +0.23			0.22	10	AV6 +0.04	54	9	0.12	6	AV2 -0.21

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.54	18	AV6 +0.20	55	118	0.14	7	AV3 +0.05	56	155	0.14	7	AV8 -0.16
		0.29	12	AV8 +0.23	55	120	0.18	8	AV3 -0.21	56	157	0.16	8	AV6 +0.19
54	11	0.16	8	AV3 +0.30	55	122	0.11	6	AV6 -0.24			0.12	6	AV1 +0.18
		0.22	10	AV6 +0.18			0.15	7	AV7 +0.00	56	159	0.10	5	AV8 +0.16
		0.27	11	AV7 +0.18	55	128	0.13	7	AV3 -0.16			0.30	12	AV7 +0.18
54	13	0.53	18	AV6 -0.11	55	130	0.12	6	AV6 +0.18			0.37	14	AV2 -0.14
		0.42	15	AV7 -0.05	55	134	0.13	7	AV6 +0.16			0.24	10	AV1 -0.20
		0.24	10	AV8 +0.02	55	142	0.24	10	AV6 +0.16	56	161	0.29	12	AV7 -0.21
54	15	0.10	6	AV2 -0.17	55	144	0.15	7	AV3 +0.20			0.58	18	AV6 +0.23
		0.26	11	AV3 -0.21	55	148	0.12	6	AV6 +0.16			0.20	9	AV2 +0.18
54	17	0.17	8	AV6 -0.29	55	154	0.16	8	AV6 +0.19	57	10	0.11	6	AV1 -0.26
54	19	0.16	8	AV3 -0.15			0.29	12	AV3 -0.22			0.23	10	AV2 -0.21
54	39	0.12	6	AV3 +0.29			0.13	7	AV1 +0.21			0.15	7	AV3 -0.16
54	101	0.14	7	AV6 -0.20	55	156	0.24	10	AV7 +0.25			0.21	9	AV6 +0.23
54	105	0.11	6	AV3 +0.03			0.17	8	AV6 -0.03			0.17	8	AV7 +0.16
54	109	0.21	9	AV3 +0.03			0.20	9	AV1 +0.23	57	12	0.19	9	AV3 +0.24
54	111	0.10	6	AV6 +0.00	55	158	0.39	14	AV7 +0.20			0.12	6	AV6 +0.00
54	119	0.09	5	AV6 +0.11			0.26	11	AV6 -0.33			0.15	7	AV8 -0.16
54	121	0.12	6	AV3 +0.16			0.14	7	AV3 +0.30	57	14	0.13	7	AV2 +0.05
		0.13	7	AV6 -0.27	55	160	0.45	16	AV7 -0.26			0.18	8	AV3 +0.03
54	125	0.11	6	AV2 -0.02			0.59	19	AV6 -0.27			0.18	8	AV6 +0.05
54	135	0.23	10	AV6 -0.03			0.13	7	AV3 -0.39	57	18	0.13	7	AV2 -0.19
		0.34	13	AV7 +0.02			0.35	13	AV2 -0.18			0.16	8	AV3 -0.10
54	137	0.15	7	AV2 -0.17			0.29	12	AV1 +0.21			0.07	4	AV8 -0.14
54	139	0.16	8	AV6 +0.00	56	9	0.25	11	AV3 -0.21	57	20	0.20	9	AV3 -0.21
54	141	0.21	9	AV6 -0.27			0.22	10	AV7 +0.23	57	22	0.18	8	AV3 -0.12
54	143	0.08	5	AV6 +0.16			0.16	8	AV8 +0.21	57	28	0.13	7	AV3 -0.16
54	145	0.11	6	AV7 +0.25	56	11	0.14	7	AV1 -0.19	57	100	0.13	7	AV3 +0.03
54	147	0.21	9	AV6 +0.18			0.26	11	AV2 -0.21			0.17	8	AV6 +0.14
54	151	0.19	9	AV7 -0.04			0.29	12	AV3 +0.21	57	102	0.19	9	AV6 +0.18
54	153	0.10	5	AV6 +0.23			0.19	9	AV6 +0.31	57	104	0.12	6	AV6 +0.00
		0.21	9	AV3 +0.25			0.38	14	AV7 +0.00	57	108	0.15	7	AV6 +0.15
54	155	0.12	6	AV6 +0.14			0.20	9	AV8 +0.18	57	110	0.11	6	AV7 +0.02
		0.11	6	AV1 +0.18	56	13	0.13	7	AV3 -0.16	57	112	0.12	6	AV6 +0.02
54	157	0.30	12	AV6 +0.16			0.14	7	AV6 +0.22	57	116	0.29	12	AV3 +0.03
		0.43	15	AV3 -0.18			0.19	9	AV8 +0.00	57	120	0.17	8	AV3 -0.16
		0.12	6	AV2 -0.18	56	15	0.10	5	AV3 -0.18			0.13	7	AV6 +0.00
		0.11	6	AV1 +0.21			0.11	6	AV6 +0.20	57	124	0.09	5	AV6 +0.20
54	159	0.20	9	AV8 -0.24			0.11	6	AV7 +0.14	57	126	0.18	8	AV6 +0.02
		0.39	15	AV7 +0.12			0.10	6	AV8 -0.16			0.18	9	AV7 +0.02
		0.42	15	AV6 -0.30	56	17	0.15	8	AV2 +0.00	57	128	0.12	6	AV3 -0.16
		0.15	8	AV3 -0.26			0.12	6	AV3 +0.05			0.09	5	AV6 +0.25
		0.23	10	AV2 -0.14			0.46	16	AV6 -0.03	57	136	0.24	10	AV6 +0.00
		0.17	8	AV6 +0.18			0.14	7	AV7 +0.02			0.15	7	AV7 +0.02
55	10	0.30	12	AV2 -0.18			0.19	9	AV8 +0.02	57	138	0.14	7	AV3 +0.00
		0.45	16	AV3 +0.27	56	19	0.11	6	AV3 -0.19			0.26	11	AV6 -0.03
		0.17	8	AV6 +0.20	56	25	0.11	6	AV3 +0.24	57	142	0.14	7	AV7 -0.02
		0.12	6	AV7 +0.23	56	33	0.13	7	AV6 +0.16			0.26	11	AV6 +0.20
		0.17	8	AV8 -0.18	56	35	0.18	8	AV3 +0.26	57	144	0.10	6	AV3 +0.19
		0.17	8	AV3 -0.18	56	43	0.14	7	AV3 -0.18	57	148	0.21	9	AV6 +0.14
55	12	0.10	5	AV7 +0.19			0.17	8	AV6 -0.13	57	154	0.19	9	AV6 +0.14
		0.24	10	AV8 -0.14	56	107	0.13	7	AV3 +0.03			0.37	14	AV3 -0.23
		0.12	6	AV1 -0.16	56	111	0.17	8	AV6 +0.02			0.22	10	AV2 +0.00
		0.14	7	AV2 -0.18	56	113	0.14	7	AV2 +0.03			0.16	8	AV1 -0.21
		0.23	10	AV3 +0.27	56	121	0.11	6	AV3 +0.21	57	156	0.10	5	AV8 -0.19
		0.14	7	AV6 +0.18			0.17	8	AV6 +0.00			0.28	12	AV7 +0.23
55	14	0.17	8	AV3 +0.03			0.10	5	AV7 +0.00			0.15	8	AV6 +0.19
		0.33	13	AV6 -0.05	56	123	0.09	5	AV3 +0.03			0.20	9	AV1 +0.21
		0.46	16	AV7 -0.02			0.13	7	AV6 -0.03	57	158	0.21	10	AV8 -0.16
		0.22	10	AV8 +0.02	56	125	0.08	5	AV2 -0.16			0.23	10	AV7 +0.16
55	16	0.17	8	AV2 -0.19	56	127	0.12	6	AV6 +0.16			0.37	14	AV3 +0.03
		0.11	6	AV3 -0.13	56	137	0.15	8	AV6 +0.00			0.35	13	AV2 -0.02
		0.38	14	AV7 -0.02			0.30	12	AV7 +0.05	57	160	0.41	15	AV7 -0.02
		0.23	10	AV8 +0.02	56	139	0.12	6	AV7 +0.02			0.47	16	AV6 -0.29
55	20	0.18	9	AV3 -0.15	56	143	0.12	6	AV6 +0.18			0.17	8	AV6 +0.21
55	26	0.11	6	AV3 -0.19			0.37	14	AV3 -0.02			0.47	16	AV3 +0.29
55	34	0.14	7	AV3 -0.17	56	147	0.27	11	AV7 -0.21			0.19	9	AV2 -0.23
		0.13	7	AV6 +0.20			0.42	15	AV6 -0.26			0.17	8	AV1 -0.20
55	38	0.11	6	AV3 -0.17	56	149	0.38	14	AV6 -0.08	58	9	0.34	13	AV3 -0.18
55	108	0.16	8	AV6 +0.18			0.17	8	AV3 +0.05			0.42	15	AV6 +0.20
55	112	0.14	7	AV6 +0.18	56	153	0.17	8	AV6 -0.03			0.51	17	AV7 -0.20
55	116	0.16	8	AV6 +0.00			0.28	12	AV3 +0.24			0.23	10	AV8 +0.20

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
58	11	0.21	10	AV1 -0.14			0.25	11	AV2 -0.19			0.30	12	AV7 +0.24
		0.36	14	AV2 -0.23			0.35	13	AV3 -0.16			0.13	7	AV1 -0.02
		0.23	10	AV3 +0.29			0.22	10	AV6 +0.18	59	160	0.15	7	AV8 +0.19
		0.50	17	AV8 -0.14			0.14	7	AV7 +0.23			0.28	11	AV7 -0.24
58	13	0.11	6	AV1 +0.03			0.39	14	AV8 +0.21			0.22	10	AV3 +0.29
		0.14	7	AV3 -0.18	59	12	0.17	8	AV1 +0.21			0.43	15	AV2 +0.18
		0.48	16	AV6 -0.05			0.13	7	AV2 -0.14	60	11	0.13	7	AV1 -0.23
		0.23	10	AV7 -0.02			0.33	13	AV3 +0.26			0.22	10	AV2 -0.21
58	15	0.12	6	AV1 +0.17			0.50	17	AV7 -0.18			0.37	14	AV3 +0.23
		0.12	6	AV2 +0.16			0.30	12	AV8 -0.18			0.27	11	AV8 +0.20
		0.16	8	AV6 +0.00	59	14	0.13	7	AV2 +0.21	60	13	0.17	8	AV2 -0.18
		0.14	7	AV7 +0.02			0.23	10	AV3 +0.03			0.11	6	AV3 -0.16
58	17	0.09	5	AV8 -0.12			0.29	12	AV6 -0.05			0.41	15	AV6 -0.05
		0.27	11	AV3 -0.14			0.24	10	AV7 -0.05			0.18	9	AV8 +0.05
		0.15	8	AV6 -0.03			0.16	8	AV8 -0.18	60	15	0.09	5	AV3 +0.26
		0.14	7	AV8 -0.14	59	16	0.11	6	AV1 -0.17			0.29	12	AV6 -0.23
58	19	0.19	9	AV6 +0.00	59	18	0.19	9	AV3 -0.16	60	17	0.15	8	AV2 -0.21
		0.18	8	AV7 -0.02			0.16	8	AV6 -0.23			0.13	7	AV3 -0.16
		0.15	7	AV8 +0.05	59	20	0.22	10	AV3 -0.24			0.16	8	AV8 +0.00
58	25	0.11	6	AV3 -0.16	59	22	0.11	6	AV8 +0.16	60	19	0.20	9	AV6 -0.03
58	35	0.16	8	AV3 +0.25	59	24	0.10	6	AV2 +0.16	60	21	0.23	10	AV6 -0.20
		0.16	8	AV6 -0.25			0.10	6	AV3 +0.23	60	31	0.35	13	AV6 -0.03
58	43	0.11	6	AV6 -0.23	59	26	0.09	5	AV2 -0.17			0.14	7	AV7 +0.00
58	73	0.13	7	AV6 +0.00	59	34	0.12	6	AV3 -0.18	60	33	0.15	7	AV6 -0.03
58	75	0.17	8	AV6 +0.00			0.11	6	AV6 +0.16	60	53	0.11	6	AV6 +0.16
		0.19	9	AV7 +0.00	59	44	0.11	6	AV3 -0.18	60	61	0.25	11	AV6 +0.05
58	101	0.09	5	AV6 -0.16	59	58	0.08	5	AV6 -0.46	60	67	0.21	10	AV3 +0.00
58	109	0.10	6	AV6 +0.02	59	68	0.17	8	AV2 +0.02			0.14	7	AV6 +0.02
58	113	0.13	7	AV2 +0.02			0.26	11	AV3 +0.00			0.14	7	AV7 +0.05
		0.20	9	AV7 -0.02			0.27	11	AV6 +0.00	60	103	0.13	7	AV2 +0.00
58	115	0.14	7	AV3 +0.00			0.24	10	AV7 +0.02			0.16	8	AV3 +0.03
58	117	0.14	7	AV2 -0.02	59	76	0.16	8	AV3 +0.03	60	109	0.29	12	AV3 +0.05
58	119	0.14	7	AV3 -0.19			0.13	7	AV6 +0.02			0.21	9	AV7 +0.00
58	121	0.13	7	AV6 -0.03	59	84	0.32	13	AV6 +0.02			0.24	10	AV7 -0.02
58	125	0.11	6	AV6 -0.03			0.46	16	AV7 +0.00	60	111	0.16	8	AV6 +0.00
		0.10	6	AV2 +0.00			0.27	11	AV8 -0.02	60	121	0.11	6	AV3 +0.11
		0.12	6	AV3 +0.05	59	100	0.13	7	AV6 +0.13			0.30	12	AV6 -0.03
58	127	0.12	6	AV6 +0.16	59	102	0.14	7	AV3 +0.00	60	123	0.17	8	AV6 -0.03
58	129	0.18	8	AV2 +0.02			0.21	9	AV6 +0.14	60	127	0.21	9	AV6 +0.00
		0.16	8	AV3 +0.03	59	104	0.13	7	AV3 +0.03	60	129	0.21	9	AV6 -0.20
58	131	0.29	12	AV6 +0.00			0.18	9	AV6 +0.05			0.13	7	AV7 +0.02
58	133	0.35	14	AV6 -0.05	59	106	0.12	6	AV3 +0.00	60	135	0.19	9	AV3 +0.05
58	137	0.18	8	AV3 +0.03			0.21	10	AV6 +0.02			0.52	17	AV6 -0.03
58	141	0.18	9	AV7 +0.14	59	108	0.22	10	AV3 +0.03			0.35	13	AV7 +0.00
58	145	0.22	10	AV6 -0.03			0.17	8	AV6 +0.02	60	137	0.33	13	AV6 -0.03
		0.16	8	AV3 -0.02	59	110	0.50	17	AV3 +0.03			0.41	15	AV7 +0.02
		0.16	8	AV1 +0.47			0.24	10	AV2 -0.02	60	141	0.19	9	AV8 -0.02
58	147	0.16	8	AV7 -0.20			0.48	17	AV6 +0.00			0.30	12	AV7 +0.00
		0.14	7	AV6 +0.00	59	116	0.16	8	AV6 -0.03	60	145	0.15	7	AV8 -0.22
		0.21	10	AV3 +0.03	59	118	0.15	7	AV3 +0.03			0.12	6	AV7 +0.00
58	151	0.25	11	AV7 -0.05	59	120	0.18	9	AV3 -0.16	60	147	0.15	7	AV6 +0.19
		0.17	8	AV1 -0.21	59	124	0.13	7	AV6 +0.18	60	149	0.24	10	AV6 -0.23
58	153	0.17	8	AV6 +0.19	59	128	0.13	7	AV6 +0.20	60	151	0.18	8	AV3 +0.00
		0.15	8	AV3 -0.18	59	132	0.11	6	AV7 +0.18	60	153	0.35	13	AV8 +0.00
		0.13	7	AV1 -0.23	59	140	0.20	9	AV2 +0.02			0.36	14	AV7 -0.02
58	155	0.18	9	AV8 -0.19	59	142	0.21	9	AV6 -0.03			0.32	13	AV3 +0.03
		0.34	13	AV6 -0.05			0.24	10	AV2 +0.00	60	155	0.22	10	AV6 -0.28
		0.08	5	AV2 -0.19	59	144	0.16	8	AV2 -0.02			0.13	7	AV1 -0.20
		0.11	6	AV1 -0.13	59	148	0.23	10	AV6 -0.05			0.11	6	AV7 +0.16
58	157	0.11	6	AV6 +0.19			0.17	8	AV3 -0.02	60	157	0.21	10	AV8 +0.16
		0.15	7	AV3 -0.18			0.20	9	AV2 +0.00			0.37	14	AV3 -0.02
		0.16	8	AV2 -0.16			0.14	7	AV1 -0.02			0.12	6	AV1 -0.20
		0.19	9	AV1 -0.20	59	150	0.37	14	AV3 +0.00	60	159	0.17	8	AV8 +0.16
58	159	0.14	7	AV7 +0.21			0.18	8	AV2 -0.02			0.26	11	AV7 +0.16
		0.19	9	AV6 +0.19	59	152	0.27	11	AV6 -0.05			0.34	13	AV6 -0.05
		0.42	15	AV3 +0.21			0.18	9	AV3 +0.03			0.41	15	AV3 +0.23
		0.20	9	AV1 -0.18			0.18	8	AV2 +0.00			0.17	8	AV2 -0.21
58	161	0.35	14	AV7 -0.21			0.09	5	AV1 -0.25			0.39	14	AV1 -0.18
		0.56	18	AV6 +0.19	59	154	0.14	7	AV6 +0.17	61	10	0.12	7	AV7 +0.21
		0.27	11	AV6 -0.31			0.28	12	AV3 -0.20			0.25	11	AV8 +0.20
		0.22	10	AV3 -0.20			0.13	7	AV1 -0.02			0.08	5	AV2 -0.21
59	10	0.12	6	AV1 -0.19	59	156	0.40	15	AV8 -0.19			0.29	12	AV3 -0.14

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
61	12	0.52	17	AV6 +0.21			0.32	13	AV3 +0.26	62	153	0.52	17	AV3 +0.05
		0.22	10	AV3 +0.23			0.31	12	AV1 +0.00	62	155	0.10	6	AV7 +0.16
		0.22	10	AV6 -0.18			0.31	12	AV2 +0.00	62	157	0.38	14	AV8 +0.16
61	14	0.16	8	AV2 -0.19	61	158	0.38	14	AV7 +0.19			0.28	11	AV7 +0.19
		0.16	8	AV3 -0.21			0.20	9	AV6 -0.03			0.22	10	AV3 +0.03
		0.16	8	AV6 +0.00			0.45	16	AV3 +0.23			0.12	6	AV2 -0.21
		0.26	11	AV7 -0.02			0.37	14	AV2 -0.16			0.17	8	AV1 -0.20
		0.26	11	AV8 +0.00	61	160	0.36	14	AV7 -0.24	62	159	0.22	10	AV8 +0.20
61	16	0.19	9	AV3 -0.22			0.22	10	AV6 -0.31			0.21	9	AV3 +0.21
61	18	0.11	6	AV3 +0.25			0.36	14	AV3 -0.21			0.28	12	AV2 +0.16
		0.55	18	AV6 -0.08	62	11	0.21	9	AV1 -0.17			0.25	11	AV1 -0.21
		0.31	12	AV7 +0.00			0.27	11	AV2 +0.21	63	12	0.18	8	AV1 +0.18
61	20	0.13	7	AV3 -0.18			0.36	14	AV3 +0.31			0.26	11	AV2 +0.05
		0.40	15	AV6 -0.05			0.32	13	AV6 +0.43			0.12	6	AV7 +0.21
		0.15	7	AV7 +0.00			0.22	10	AV8 +0.21	63	14	0.14	7	AV1 +0.00
61	22	0.32	13	AV3 -0.21			0.49	17	AV7 -0.23			0.12	6	AV2 +0.02
		0.16	8	AV6 +0.00	62	13	0.10	5	AV1 -0.19			0.19	9	AV3 -0.18
61	28	0.09	5	AV2 +0.02			0.10	6	AV2 -0.19			0.18	8	AV6 -0.23
61	30	0.13	7	AV3 +0.00			0.29	12	AV3 -0.09			0.16	8	AV7 +0.18
		0.13	7	AV6 -0.03			0.20	9	AV7 +0.21			0.10	6	AV8 +0.20
61	32	0.11	6	AV3 +0.21			0.17	8	AV8 +0.23	63	16	0.16	8	AV2 -0.12
		0.18	8	AV6 -0.03	62	15	0.45	16	AV7 -0.02			0.40	15	AV3 +0.03
61	34	0.19	9	AV3 -0.17			0.13	7	AV8 +0.02			0.18	8	AV6 +0.00
		0.13	7	AV6 +0.21	62	17	0.09	5	AV2 +0.20			0.13	7	AV7 +0.18
61	38	0.26	11	AV6 +0.00			0.13	7	AV3 -0.15			0.24	10	AV8 +0.14
		0.19	9	AV7 -0.02	62	19	0.08	5	AV1 -0.29	63	18	0.16	8	AV3 +0.26
61	44	0.14	7	AV3 -0.23			0.07	4	AV3 +0.05			0.12	6	AV7 +0.00
61	48	0.08	5	AV3 -0.18	62	23	0.14	7	AV1 +0.05			0.24	11	AV8 +0.00
61	50	0.15	8	AV3 +0.03			0.15	8	AV2 +0.05	63	34	0.17	8	AV3 +0.03
61	60	0.16	8	AV3 +0.00	62	25	0.08	5	AV3 -0.14			0.44	16	AV6 +0.16
		0.20	9	AV6 +0.02	62	31	0.09	5	AV3 -0.35	63	38	0.20	9	AV7 -0.18
61	102	0.25	11	AV3 +0.00	62	35	0.13	7	AV3 +0.23			0.14	7	AV8 +0.02
		0.51	17	AV6 +0.02			0.21	9	AV6 -0.23	63	44	0.16	8	AV2 -0.02
61	104	0.14	7	AV2 +0.00	62	45	0.26	11	AV6 +0.00			0.14	7	AV3 -0.02
		0.17	8	AV3 +0.16	62	59	0.27	11	AV3 +0.05	63	46	0.10	6	AV6 +0.00
		0.21	10	AV6 +0.00			0.51	17	AV6 +0.02	63	58	0.15	7	AV3 +0.00
61	106	0.23	10	AV6 +0.02			0.45	16	AV7 +0.00			0.25	11	AV6 +0.05
61	108	0.16	8	AV2 +0.02	62	61	0.17	8	AV6 +0.02	63	60	0.10	6	AV3 -0.14
		0.24	10	AV3 +0.03			0.13	7	AV7 +0.02			0.16	8	AV6 +0.02
		0.23	10	AV6 -0.05	62	65	0.24	11	AV6 +0.05	63	64	0.21	9	AV3 +0.03
61	110	0.18	9	AV3 +0.00	62	73	0.24	11	AV3 +0.03			0.39	14	AV6 +0.02
		0.13	7	AV6 +0.05			0.33	13	AV6 +0.00	63	74	0.32	13	AV6 +0.05
61	112	0.32	13	AV3 +0.00			0.17	8	AV7 +0.05	63	76	0.21	9	AV3 +0.00
		0.13	7	AV6 +0.23	62	95	0.16	8	AV3 -0.14			0.26	11	AV6 +0.05
61	114	0.18	9	AV2 +0.00	62	97	0.09	5	AV6 +0.00	63	78	0.49	17	AV3 +0.03
		0.27	11	AV3 +0.00	62	99	0.09	5	AV6 +0.19			0.23	10	AV6 +0.05
		0.25	11	AV6 +0.00	62	103	0.16	8	AV3 -0.02	63	90	0.10	6	AV2 +0.07
61	116	0.17	8	AV2 -0.02			0.17	8	AV6 +0.05	63	98	0.22	10	AV3 +0.00
		0.47	16	AV3 +0.00	62	105	0.16	8	AV3 +0.03			0.14	7	AV6 +0.00
		0.26	11	AV7 +0.00			0.21	9	AV7 +0.02	63	100	0.44	16	AV6 +0.05
61	118	0.18	8	AV6 -0.05	62	107	0.28	12	AV3 +0.03	63	102	0.13	7	AV2 +0.07
61	126	0.12	6	AV3 +0.03	62	109	0.26	11	AV2 -0.02			0.24	10	AV6 +0.20
		0.10	5	AV6 +0.21			0.34	13	AV3 +0.03	63	104	0.16	8	AV2 +0.00
61	130	0.17	8	AV7 +0.00			0.20	9	AV6 +0.07			0.14	7	AV3 +0.10
		0.11	6	AV3 +0.00	62	111	0.22	10	AV6 +0.00			0.51	17	AV6 +0.05
		0.49	17	AV6 +0.00	62	113	0.11	6	AV2 +0.02			0.20	9	AV7 +0.02
61	134	0.17	8	AV6 +0.16			0.14	7	AV3 +0.00	63	106	0.47	16	AV3 +0.03
		0.12	6	AV7 +0.09			0.15	7	AV6 -0.03			0.29	12	AV6 +0.02
61	140	0.16	8	AV6 +0.14			0.28	12	AV7 -0.05	63	108	0.16	8	AV6 +0.14
61	142	0.56	18	AV6 -0.05	62	115	0.23	10	AV3 +0.00	63	110	0.15	7	AV3 +0.05
		0.09	5	AV2 +0.18			0.26	11	AV6 +0.00			0.41	15	AV6 -0.03
61	144	0.17	8	AV6 -0.08			0.23	10	AV7 -0.05	63	112	0.14	7	AV7 +0.00
61	146	0.34	13	AV6 -0.21	62	117	0.20	9	AV3 +0.00	63	114	0.31	12	AV3 +0.00
		0.14	7	AV3 +0.00	62	119	0.14	7	AV3 -0.19			0.40	15	AV7 +0.00
61	152	0.14	7	AV8 -0.22	62	121	0.32	13	AV6 -0.05	63	116	0.31	12	AV6 -0.03
		0.40	15	AV6 -0.20	62	129	0.16	8	AV6 -0.20	63	118	0.16	8	AV6 -0.03
		0.19	9	AV3 -0.02	62	131	0.59	19	AV6 -0.03	63	128	0.15	7	AV6 +0.18
61	154	0.13	7	AV8 +0.00	62	139	0.15	7	AV2 -0.16	63	130	0.21	9	AV6 +0.16
		0.17	8	AV7 -0.19	62	143	0.24	10	AV7 -0.02	63	132	0.40	15	AV3 +0.08
		0.34	13	AV6 -0.05			0.18	8	AV6 +0.00			0.48	16	AV6 +0.00
		0.11	6	AV3 -0.05	62	151	0.25	11	AV3 +0.03	63	134	0.21	9	AV2 +0.02
61	156	0.34	13	AV7 +0.21			0.19	9	AV1 +0.00			0.16	8	AV3 +0.03

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
63	136	0.53	17	AV6 +0.00	64	105	0.17	8	AV3 -0.02	65	56	0.10	6	AV6 +0.16
		0.16	8	AV7 +0.05			0.61	19	AV6 +0.05	65	58	0.25	11	AV6 +0.00
63	142	0.23	10	AV6 -0.05			0.15	8	AV7 +0.02	65	62	0.13	7	AV3 +0.00
63	144	0.22	10	AV8 -0.02	64	109	0.15	8	AV6 +0.00			0.09	5	AV6 +0.02
		0.13	7	AV7 +0.00	64	111	0.24	10	AV3 -0.02	65	66	0.14	7	AV6 +0.02
		0.38	14	AV3 +0.18			0.37	14	AV6 -0.02	65	68	0.11	6	AV3 +0.18
		0.15	7	AV2 -0.02	64	113	0.12	6	AV2 -0.02	65	70	0.08	5	AV2 +0.00
63	146	0.35	14	AV3 +0.00			0.21	9	AV3 +0.00			0.28	12	AV3 +0.05
		0.11	6	AV2 -0.02			0.09	5	AV6 +0.00			0.31	12	AV6 +0.00
		0.17	8	AV7 -0.02			0.19	9	AV7 +0.00			0.32	13	AV7 +0.00
63	148	0.40	15	AV6 -0.20	64	115	0.45	16	AV3 +0.05	65	74	0.31	12	AV6 +0.02
		0.21	10	AV3 +0.03			0.50	17	AV6 -0.02			0.19	9	AV7 +0.00
		0.14	7	AV1 -0.16	64	117	0.19	9	AV3 +0.03	65	78	0.10	5	AV3 +0.08
63	150	0.20	9	AV7 +0.02	64	119	0.09	5	AV2 -0.02	65	84	0.16	8	AV2 +0.00
		0.17	8	AV6 -0.05			0.24	10	AV3 +0.03			0.24	10	AV3 +0.00
		0.51	17	AV3 +0.03			0.18	8	AV6 +0.02			0.22	10	AV6 +0.02
		0.25	11	AV2 +0.02	64	121	0.15	7	AV6 -0.03	65	86	0.15	8	AV7 +0.05
		0.15	7	AV1 +0.21	64	123	0.13	7	AV6 +0.00	65	90	0.18	8	AV2 +0.02
63	152	0.13	7	AV8 -0.16	64	125	0.10	6	AV2 +0.00	65	94	0.32	13	AV6 +0.00
		0.11	6	AV7 +0.00	64	131	0.27	11	AV6 -0.05	65	96	0.27	11	AV3 +0.03
		0.27	11	AV6 -0.26	64	133	0.26	11	AV6 +0.00	65	98	0.28	12	AV3 +0.03
		0.17	8	AV1 -0.21	64	135	0.46	16	AV6 -0.03			0.36	14	AV6 +0.05
63	154	0.12	6	AV8 -0.18	64	137	0.26	11	AV7 +0.02	65	100	0.15	7	AV6 +0.16
		0.33	13	AV6 -0.05			0.21	10	AV3 +0.00	65	102	0.12	6	AV3 +0.03
		0.25	11	AV3 -0.18			0.36	14	AV6 -0.03			0.52	17	AV6 +0.02
		0.26	11	AV2 +0.02	64	143	0.15	7	AV3 -0.07			0.26	11	AV7 +0.02
		0.17	8	AV1 -0.21	64	145	0.10	6	AV7 -0.13	65	104	0.12	6	AV7 -0.02
63	156	0.30	12	AV8 -0.16			0.14	7	AV3 -0.02			0.20	9	AV3 +0.03
		0.35	13	AV7 +0.18			0.22	10	AV1 +0.00			0.11	6	AV6 +0.05
		0.51	17	AV6 -0.05	64	147	0.12	6	AV1 -0.02	65	106	0.25	11	AV3 +0.00
		0.21	10	AV2 +0.16	64	149	0.28	12	AV2 -0.02			0.27	11	AV6 +0.02
		0.53	18	AV1 -0.18	64	153	0.18	8	AV8 -0.14			0.23	10	AV7 +0.02
64	11	0.17	8	AV3 -0.21			0.25	11	AV6 -0.03	65	108	0.28	12	AV3 +0.00
		0.26	11	AV6 +0.21			0.41	15	AV3 +0.00			0.26	11	AV7 +0.02
		0.32	13	AV7 +0.00	64	155	0.19	9	AV8 -0.16	65	110	0.17	8	AV3 +0.07
64	13	0.46	16	AV3 +0.03			0.24	10	AV7 +0.16			0.49	17	AV7 +0.00
		0.15	7	AV8 -0.18			0.24	10	AV6 -0.03	65	112	0.13	7	AV2 +0.02
		0.12	6	AV1 +0.00			0.12	6	AV2 +0.16			0.08	5	AV3 +0.02
		0.16	8	AV2 -0.12			0.48	17	AV1 -0.20			0.32	13	AV6 +0.16
64	15	0.13	7	AV3 +0.22	64	157	0.18	8	AV8 +0.16			0.26	11	AV7 +0.02
		0.22	10	AV6 -0.22			0.24	10	AV7 +0.21	65	114	0.14	7	AV2 +0.00
64	17	0.29	12	AV3 +0.03			0.27	11	AV6 -0.18			0.53	17	AV3 +0.03
		0.32	13	AV7 +0.00			0.22	10	AV1 +0.21			0.33	13	AV6 -0.05
		0.44	16	AV8 +0.02	64	159	0.21	9	AV7 -0.16	65	116	0.59	19	AV3 +0.02
64	19	0.36	14	AV6 -0.02			0.11	6	AV6 +0.21			0.51	17	AV6 -0.05
64	27	0.29	12	AV6 -0.02	65	12	0.14	7	AV1 -0.17			0.25	11	AV7 +0.02
64	29	0.28	11	AV7 +0.02			0.39	14	AV2 +0.21	65	118	0.11	6	AV2 +0.02
64	33	0.15	7	AV3 -0.18			0.31	12	AV3 +0.22			0.11	6	AV3 -0.18
		0.53	17	AV6 +0.02			0.14	7	AV8 +0.21			0.24	11	AV6 -0.02
64	39	0.15	7	AV6 +0.00	65	14	0.14	7	AV1 +0.21			0.21	9	AV7 +0.05
64	45	0.12	6	AV6 +0.02			0.30	12	AV2 +0.00	65	120	0.22	10	AV3 +0.03
64	55	0.16	8	AV3 -0.02			0.57	18	AV3 +0.05			0.56	18	AV6 -0.03
		0.16	8	AV6 +0.00			0.37	14	AV6 +0.00			0.23	10	AV7 +0.02
64	61	0.13	7	AV6 +0.02			0.19	9	AV7 +0.00	65	126	0.11	6	AV6 +0.14
64	63	0.17	8	AV2 +0.00	65	16	0.14	7	AV2 -0.19	65	128	0.38	14	AV6 +0.00
		0.23	10	AV3 +0.02			0.20	9	AV3 +0.02	65	130	0.19	9	AV2 +0.00
		0.45	16	AV6 +0.02			0.36	14	AV7 +0.00			0.20	9	AV3 -0.02
64	75	0.13	7	AV2 +0.00			0.42	15	AV8 +0.02			0.13	7	AV6 +0.21
		0.31	12	AV3 +0.02	65	18	0.59	19	AV6 -0.02	65	134	0.13	7	AV2 +0.02
		0.18	9	AV7 +0.02			0.28	12	AV7 +0.02			0.39	14	AV7 +0.07
64	87	0.16	8	AV2 -0.16	65	20	0.13	7	AV2 +0.00	65	136	0.33	13	AV6 -0.02
64	91	0.13	7	AV2 -0.07			0.18	8	AV6 +0.00	65	138	0.23	10	AV3 +0.03
64	93	0.15	8	AV6 +0.07	65	22	0.17	8	AV6 -0.02			0.16	8	AV6 +0.02
64	97	0.24	10	AV6 +0.02			0.22	10	AV7 +0.00	65	144	0.21	10	AV8 -0.02
64	99	0.26	11	AV3 +0.03	65	34	0.11	6	AV6 +0.20	65	152	0.48	17	AV8 -0.14
		0.18	8	AV6 +0.02	65	42	0.47	16	AV6 -0.02	65	154	0.61	19	AV7 -0.02
64	101	0.29	12	AV3 +0.03	65	44	0.13	7	AV3 -0.02			0.20	9	AV1 +0.16
		0.62	19	AV6 +0.05			0.17	8	AV7 -0.02			0.27	11	AV8 +0.00
		0.38	14	AV7 +0.00			0.09	5	AV8 +0.05	65	156	0.49	17	AV8 -0.16
64	103	0.13	7	AV6 -0.05	65	48	0.29	12	AV6 +0.02			0.12	6	AV7 +0.20
		0.11	6	AV7 +0.05	65	50	0.22	10	AV6 +0.00			0.15	7	AV6 -0.30
		0.17	8	AV3 -0.02			0.16	8	AV7 +0.00			0.13	7	AV3 +0.23

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.17	8	AV2 +0.16			0.16	8	AV8 +0.05	67	50	0.51	17	AV3 +0.02
		0.22	10	AV1 -0.20								0.14	7	AV7 +0.00
65	158	0.21	9	AV7 -0.02	66	111	0.27	11	AV2 +0.00	67	52	0.23	10	AV3 +0.02
		0.23	10	AV3 +0.28			0.43	15	AV3 +0.02	67	54	0.18	9	AV6 +0.02
		0.17	8	AV8 +0.14	66	115	0.19	9	AV6 +0.05	67	58	0.23	10	AV6 +0.02
66	13	0.29	12	AV7 -0.02			0.33	13	AV3 +0.00	67	60	0.16	8	AV3 +0.00
		0.17	8	AV1 +0.21	66	117	0.13	7	AV1 +0.00	67	62	0.14	7	AV6 +0.00
		0.14	7	AV3 +0.02			0.11	6	AV3 +0.05	67	64	0.17	8	AV3 +0.02
66	15	0.21	9	AV1 +0.05			0.31	12	AV6 -0.02			0.14	7	AV6 +0.02
		0.45	16	AV2 +0.02	66	119	0.15	7	AV3 +0.03	67	66	0.43	15	AV6 +0.00
		0.43	15	AV7 -0.02	66	121	0.27	11	AV7 +0.02	67	68	0.17	8	AV2 +0.00
		0.41	15	AV8 +0.02	66	123	0.11	6	AV3 +0.03			0.46	16	AV3 +0.03
66	17	0.15	7	AV2 +0.16	66	127	0.18	9	AV6 +0.11			0.34	13	AV6 +0.02
66	19	0.14	7	AV3 +0.03	66	129	0.31	12	AV6 +0.00			0.28	12	AV7 +0.02
		0.37	14	AV6 +0.02	66	131	0.16	8	AV3 +0.05	67	70	0.25	11	AV3 +0.00
66	21	0.13	7	AV6 -0.22			0.27	11	AV6 +0.00			0.22	10	AV6 +0.05
		0.14	7	AV3 +0.00	66	135	0.48	16	AV6 -0.02	67	74	0.40	15	AV3 +0.00
66	23	0.51	17	AV6 +0.00	66	137	0.31	13	AV6 +0.00	67	80	0.15	8	AV6 +0.00
66	27	0.23	10	AV2 +0.07			0.27	11	AV7 +0.04	67	88	0.14	7	AV2 -0.16
66	29	0.28	12	AV6 -0.03			0.25	11	AV8 +0.02	67	92	0.13	7	AV2 -0.14
66	31	0.13	7	AV3 +0.07	66	141	0.22	10	AV6 -0.23			0.16	8	AV3 +0.05
		0.56	18	AV6 -0.02			0.13	7	AV3 +0.05	67	94	0.14	7	AV1 +0.00
		0.60	19	AV7 +0.00	66	143	0.16	8	AV3 -0.02			0.29	12	AV2 +0.02
		0.37	14	AV8 +0.02	66	145	0.62	19	AV8 -0.02			0.21	9	AV3 +0.00
66	33	0.11	6	AV2 +0.00			0.59	19	AV6 -0.05	67	96	0.12	6	AV2 +0.02
		0.11	6	AV3 +0.00			0.16	8	AV3 +0.00			0.52	17	AV3 +0.03
		0.26	11	AV6 +0.02			0.16	8	AV1 +0.00			0.24	11	AV7 +0.00
66	41	0.16	8	AV6 -0.02	66	147	0.44	16	AV6 -0.03	67	98	0.10	6	AV2 -0.05
66	43	0.32	13	AV6 -0.12			0.21	9	AV3 +0.00			0.20	9	AV3 +0.03
		0.12	6	AV7 -0.02	66	149	0.19	9	AV6 +0.12			0.12	6	AV6 +0.23
66	45	0.12	6	AV3 +0.02			0.18	9	AV3 +0.03	67	100	0.07	4	AV7 +0.02
66	51	0.14	7	AV3 +0.02			0.25	11	AV2 -0.02			0.20	9	AV3 -0.02
		0.39	14	AV6 +0.02			0.12	6	AV1 -0.02			0.32	13	AV6 +0.02
66	53	0.14	7	AV3 +0.02	66	151	0.15	8	AV8 -0.16	67	102	0.19	9	AV2 +0.02
		0.12	6	AV6 +0.02	66	153	0.18	8	AV1 -0.02	67	104	0.49	17	AV2 +0.00
66	55	0.19	9	AV3 +0.02	66	155	0.16	8	AV8 -0.16	67	106	0.13	7	AV2 +0.02
		0.17	8	AV6 -0.02			0.14	7	AV7 +0.16			0.17	8	AV3 +0.03
66	59	0.17	8	AV3 +0.02			0.20	9	AV3 -0.02			0.18	9	AV6 +0.02
		0.42	15	AV6 +0.00			0.23	10	AV1 +0.21			0.32	13	AV7 +0.05
		0.30	12	AV7 +0.05			0.15	7	AV6 +0.00	67	108	0.27	11	AV6 +0.02
66	61	0.33	13	AV3 +0.00	66	157	0.32	13	AV8 +0.19			0.26	11	AV2 +0.02
		0.19	9	AV7 +0.00			0.30	12	AV7 -0.02			0.45	16	AV3 +0.02
66	65	0.17	8	AV6 +0.02			0.31	12	AV6 -0.25	67	110	0.17	8	AV2 +0.00
66	75	0.40	15	AV6 +0.02			0.36	14	AV3 +0.05			0.61	19	AV3 -0.03
		0.20	9	AV7 +0.02			0.28	12	AV1 -0.20			0.59	19	AV6 +0.00
66	77	0.13	7	AV2 +0.02	67	12	0.24	11	AV6 +0.20			0.13	7	AV7 +0.00
		0.15	7	AV3 +0.00			0.23	10	AV8 +0.16	67	112	0.38	14	AV2 +0.00
		0.13	7	AV6 +0.00	67	14	0.15	7	AV2 +0.00			0.26	11	AV3 +0.05
66	79	0.14	7	AV3 +0.02			0.16	8	AV3 +0.02			0.27	11	AV6 +0.02
66	83	0.15	7	AV2 -0.12			0.20	9	AV6 -0.25			0.24	10	AV7 +0.05
66	87	0.17	8	AV2 -0.14	67	16	0.12	6	AV1 +0.19	67	114	0.16	8	AV3 +0.02
66	93	0.22	10	AV6 +0.05			0.20	9	AV2 +0.03			0.20	9	AV6 -0.05
66	95	0.15	7	AV2 +0.02			0.31	12	AV6 +0.00			0.22	10	AV7 +0.04
		0.24	10	AV3 +0.00			0.45	16	AV7 +0.00	67	116	0.21	9	AV3 +0.02
		0.19	9	AV6 +0.02	67	18	0.11	6	AV1 +0.21			0.27	11	AV6 +0.00
		0.28	11	AV7 -0.02			0.10	6	AV3 -0.08			0.17	8	AV7 +0.02
66	97	0.40	15	AV3 +0.00	67	20	0.29	12	AV3 +0.05			0.20	9	AV2 +0.02
		0.22	10	AV6 +0.00			0.24	10	AV7 +0.02	67	118	0.17	8	AV2 +0.02
66	99	0.18	9	AV2 +0.02	67	34	0.19	9	AV3 +0.02			0.13	7	AV3 +0.15
		0.45	16	AV3 +0.05			0.21	9	AV6 +0.02			0.15	8	AV6 -0.03
		0.38	14	AV7 +0.02	67	38	0.18	8	AV2 +0.03			0.19	9	AV7 +0.02
66	101	0.14	7	AV2 +0.02			0.52	17	AV3 +0.02	67	122	0.13	7	AV6 +0.16
		0.19	9	AV3 +0.03			0.47	16	AV6 +0.00	67	128	0.19	9	AV3 -0.19
66	103	0.57	18	AV3 -0.05			0.22	10	AV7 -0.18			0.20	9	AV7 +0.02
		0.31	12	AV8 +0.02			0.18	8	AV8 +0.02	67	130	0.13	7	AV3 +0.00
66	105	0.23	10	AV2 +0.07	67	40	0.34	13	AV6 -0.02			0.25	11	AV6 +0.18
		0.23	10	AV7 +0.02			0.18	9	AV7 -0.02	67	132	0.22	10	AV2 +0.00
66	107	0.29	12	AV3 +0.00	67	42	0.33	13	AV6 +0.00			0.28	12	AV3 +0.10
		0.32	13	AV6 -0.03			0.32	13	AV7 +0.00	67	134	0.38	14	AV6 -0.05
66	109	0.18	9	AV2 +0.02	67	44	0.23	10	AV2 +0.05	67	138	0.26	11	AV6 +0.00
		0.40	15	AV6 +0.02	67	46	0.29	12	AV6 +0.00	67	140	0.22	10	AV6 -0.03
		0.23	10	AV7 +0.05	67	48	0.13	7	AV8 +0.02			0.09	5	AV1 +0.41

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
67	142	0.12	6	AV8 -0.19	68	89	0.39	14	AV6 +0.02	69	60	0.15	8	AV7 +0.02
		0.15	7	AV6 +0.19	68	93	0.13	7	AV3 +0.03	69	62	0.17	8	AV6 +0.00
		0.28	12	AV3 +0.03	68	95	0.15	7	AV6 +0.00	69	66	0.36	14	AV3 +0.00
		0.44	16	AV2 -0.02	68	97	0.16	8	AV3 +0.03			0.40	15	AV6 +0.07
67	144	0.36	14	AV6 -0.05			0.20	9	AV6 +0.05	69	68	0.19	9	AV2 +0.00
		0.16	8	AV1 +0.16	68	99	0.46	16	AV3 +0.05			0.22	10	AV3 +0.00
67	146	0.58	18	AV6 -0.03			0.20	9	AV7 +0.00			0.15	8	AV6 +0.02
		0.47	16	AV2 +0.00	68	101	0.14	7	AV2 +0.00	69	70	0.18	8	AV3 +0.00
		0.33	13	AV1 +0.00			0.24	10	AV3 +0.00			0.33	13	AV6 -0.05
67	148	0.39	14	AV2 +0.00			0.27	11	AV7 -0.02	69	72	0.12	6	AV3 +0.02
		0.19	9	AV1 +0.00	68	103	0.14	7	AV2 -0.02			0.24	10	AV6 +0.05
		0.34	13	AV7 -0.02			0.35	13	AV3 -0.05			0.23	10	AV7 +0.02
67	150	0.20	9	AV3 +0.03			0.38	14	AV7 +0.07	69	74	0.30	12	AV2 +0.00
		0.17	8	AV1 +0.00	68	105	0.09	5	AV1 +0.19			0.45	16	AV3 +0.06
67	152	0.21	9	AV7 +0.02			0.12	6	AV2 +0.05			0.52	13	AV4 +0.95
		0.49	17	AV6 -0.02			0.36	14	AV3 +0.00			0.31	12	AV7 +0.00
		0.17	8	AV2 +0.00			0.17	8	AV6 +0.07	69	76	0.12	6	AV3 +0.02
		0.18	9	AV1 +0.21	68	107	0.27	11	AV2 +0.00			0.24	10	AV6 +0.02
67	154	0.54	18	AV7 +0.00			0.18	9	AV3 +0.02	69	86	0.21	9	AV6 +0.00
		0.63	19	AV2 +0.02			0.16	8	AV6 +0.00	69	88	0.64	19	AV7 +0.00
		0.23	10	AV1 +0.19	68	109	0.15	7	AV6 +0.02	69	90	0.20	9	AV2 -0.14
67	156	0.46	16	AV8 -0.16			0.13	7	AV7 +0.02			0.20	9	AV6 +0.05
		0.20	9	AV6 -0.30	68	111	0.42	15	AV3 +0.07	69	92	0.20	9	AV3 +0.03
		0.20	9	AV3 +0.25	68	113	0.18	9	AV6 +0.00			0.17	8	AV6 -0.02
		0.31	12	AV2 +0.02			0.37	14	AV7 +0.02	69	94	0.21	10	AV6 +0.02
		0.23	10	AV1 -0.23	68	115	0.22	10	AV2 +0.00	69	96	0.28	12	AV3 +0.00
67	158	0.22	10	AV8 +0.17			0.34	13	AV8 +0.02			0.26	11	AV6 +0.02
		0.31	12	AV7 -0.02	68	117	0.13	7	AV1 +0.02	69	98	0.30	12	AV2 +0.05
		0.51	17	AV6 -0.28			0.17	8	AV3 +0.02			0.36	14	AV3 +0.03
		0.22	10	AV2 +0.16			0.50	17	AV7 +0.00			0.71	13	AV4 +0.45
68	13	0.16	8	AV1 -0.23	68	119	0.22	10	AV6 -0.02			0.40	15	AV6 +0.02
		0.20	9	AV3 +0.02	68	121	0.59	19	AV6 -0.02			0.27	11	AV7 +0.02
		0.14	7	AV6 -0.25	68	123	0.27	11	AV6 +0.02	69	100	0.14	7	AV2 +0.05
		0.08	5	AV7 -0.18			0.25	11	AV7 +0.04			0.34	13	AV3 +0.03
68	15	0.14	7	AV1 +0.16	68	125	0.25	11	AV6 +0.02			0.58	18	AV7 +0.02
68	17	0.15	8	AV1 +0.23			0.26	11	AV7 +0.00	69	102	0.26	11	AV2 +0.05
		0.16	8	AV2 +0.20	68	133	0.13	7	AV2 +0.00			0.29	12	AV3 +0.03
		0.13	7	AV3 +0.05			0.11	6	AV3 +0.05			0.46	16	AV6 +0.02
		0.23	10	AV8 +0.02	68	135	0.21	10	AV2 -0.05			0.20	9	AV7 -0.02
68	19	0.10	6	AV1 +0.00			0.47	16	AV3 +0.02	69	104	0.49	17	AV3 +0.03
68	21	0.16	8	AV6 -0.16			0.59	19	AV6 -0.05	69	106	0.11	6	AV2 +0.16
68	35	0.21	9	AV6 +0.00			0.16	8	AV7 +0.00			0.36	14	AV3 +0.00
		0.15	8	AV3 +0.00	68	139	0.17	8	AV3 +0.02			0.29	12	AV7 +0.05
68	45	0.19	9	AV3 +0.03	68	143	0.13	7	AV6 +0.11	69	108	0.16	8	AV2 +0.00
		0.24	10	AV6 +0.00			0.09	5	AV1 +0.42			0.19	9	AV8 +0.00
68	55	0.20	9	AV3 +0.00	68	145	0.13	7	AV7 -0.02	69	110	0.13	7	AV7 +0.00
		0.16	8	AV6 +0.00			0.35	13	AV6 -0.02			0.34	13	AV6 +0.00
68	59	0.16	8	AV6 +0.00			0.49	17	AV3 +0.00			0.56	16	AV4 +0.87
		0.22	10	AV7 -0.02	68	147	0.15	7	AV3 +0.00	69	112	0.26	11	AV6 +0.11
68	61	0.12	6	AV8 -0.02	68	149	0.34	13	AV7 +0.00			0.11	6	AV7 +0.02
68	63	0.27	11	AV3 +0.00	68	151	0.27	11	AV6 -0.05	69	114	0.35	13	AV1 +0.00
		0.13	7	AV6 +0.05			0.61	19	AV7 -0.02			0.26	11	AV2 +0.02
		0.30	12	AV7 +0.02			0.37	14	AV6 -0.05			0.27	11	AV3 +0.00
68	65	0.11	6	AV6 +0.00			0.38	14	AV3 +0.00			0.39	12	AV4 +0.02
68	67	0.45	16	AV3 +0.00			0.22	10	AV1 +0.19			0.24	10	AV6 -0.04
		0.36	14	AV7 +0.07			0.22	10	AV1 +0.19			0.22	10	AV7 +0.02
68	69	0.16	8	AV2 +0.05	68	155	0.22	10	AV1 -0.02			0.26	11	AV8 +0.00
		0.19	9	AV3 +0.00	68	157	0.63	19	AV8 +0.19	69	116	0.43	15	AV3 +0.03
		0.14	7	AV6 +0.02			0.57	18	AV3 +0.11			0.57	18	AV6 +0.00
68	71	0.22	10	AV2 +0.00			0.24	10	AV1 -0.23			0.12	4	AV4 +0.65
		0.26	11	AV3 +0.02	69	14	0.13	7	AV1 -0.15	69	118	0.07	4	AV2 +0.00
68	77	0.33	13	AV6 +0.00			0.29	12	AV2 +0.00			0.25	8	AV4 +0.91
		0.22	10	AV7 -0.02			0.30	12	AV3 +0.25			0.12	6	AV6 -0.04
68	79	0.12	6	AV3 +0.06			0.30	12	AV6 +0.02	69	120	0.11	6	AV3 -0.05
		0.25	11	AV6 +0.00	69	16	0.15	8	AV7 +0.00			0.26	8	AV4 +1.07
68	81	0.13	7	AV3 -0.02	69	18	0.13	7	AV2 +0.22			0.22	10	AV7 +0.00
		0.25	11	AV6 +0.02			0.12	6	AV3 +0.21	69	122	0.12	6	AV3 +0.06
68	87	0.11	6	AV2 -0.14			0.17	8	AV6 -0.21			0.09	5	AV6 -0.22
		0.15	7	AV3 -0.14	69	36	0.13	7	AV3 +0.20			0.23	7	AV4 +0.25
		0.15	7	AV7 +0.02	69	52	0.23	10	AV6 +0.02	69	124	0.14	7	AV3 +0.00
		0.10	6	AV8 +0.00			0.26	11	AV7 +0.00			0.17	5	AV4 +0.83
					69	56	0.31	12	AV3 +0.02			0.06	4	AV6 -0.38

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
69	126	0.15	4	AV4 +0.90			0.21	9	AV4 +0.06			0.39	14	AV6 -0.20
69	128	0.15	4	AV4 +0.91			0.24	10	AV5 +0.06	70	157	0.13	7	AV6 -0.04
69	130	0.20	7	AV4 +0.02			0.17	8	AV6 +0.05			0.28	12	AV3 -0.11
69	132	0.13	5	AV4 -0.08	70	91	0.58	19	AV3 +0.04	71	14	0.19	9	AV1 -0.17
69	134	0.53	17	AV6 -0.02			0.56	18	AV6 +0.02			0.22	10	AV2 +0.23
		0.16	8	AV3 +0.12			0.36	14	AV7 +0.00			0.56	18	AV3 +0.12
69	136	0.21	7	AV4 +0.70			0.31	12	AV2 +0.02			0.36	14	AV6 -0.14
		0.13	7	AV6 -0.05	70	93	0.15	7	AV3 +0.02			0.15	7	AV8 +0.21
69	138	0.14	7	AV6 +0.00			0.12	6	AV6 +0.02	71	16	0.08	5	AV1 -0.22
		0.26	8	AV4 +0.74	70	95	0.28	12	AV2 +0.00			0.07	4	AV3 -0.12
69	140	0.07	5	AV8 +0.45			0.33	13	AV3 +0.02			0.45	16	AV7 -0.02
		0.17	8	AV7 -0.19			0.17	8	AV6 +0.05			0.10	6	AV8 -0.11
		0.08	5	AV1 +0.16	70	97	0.55	18	AV3 +0.02	71	18	0.17	8	AV4 +0.35
69	144	0.16	8	AV8 -0.21			0.49	17	AV7 -0.02	71	20	0.11	6	AV3 -0.20
		0.27	10	AV4 +0.13	70	99	0.17	8	AV6 +0.02	71	26	0.09	5	AV7 -0.14
69	146	0.14	7	AV6 -0.04			0.35	13	AV7 +0.00	71	34	0.36	14	AV3 +0.00
		0.13	7	AV2 +0.16			0.17	8	AV8 +0.00			0.17	8	AV6 +0.02
		0.14	7	AV1 -0.02			0.12	6	AV1 +0.00	71	40	0.12	6	AV3 +0.00
69	150	0.17	8	AV2 +0.02			0.27	11	AV2 +0.00	71	44	0.12	6	AV5 +0.22
69	152	0.26	11	AV7 -0.05			0.43	15	AV3 +0.02	71	50	0.17	8	AV3 +0.02
		0.47	16	AV6 -0.17			0.17	8	AV5 +0.06	71	62	0.09	5	AV2 +0.00
		0.10	6	AV3 -0.07	70	101	0.15	7	AV1 +0.00	71	66	0.41	15	AV6 +0.05
		0.12	6	AV1 +0.00			0.41	15	AV2 +0.00			0.11	6	AV5 -0.56
		0.26	11	AV8 -0.18	70	103	0.31	12	AV2 +0.05	71	70	0.19	9	AV5 +0.02
69	154	0.40	15	AV8 +0.00			0.29	12	AV3 +0.06			0.40	15	AV6 -0.02
		0.20	9	AV7 +0.00			0.22	10	AV5 +0.37			0.19	9	AV7 +0.00
		0.44	16	AV3 +0.03			0.59	19	AV6 +0.05	71	72	0.14	7	AV4 +0.38
		0.26	11	AV2 +0.00			0.26	11	AV8 +0.02			0.18	9	AV5 -0.13
		0.34	13	AV1 +0.19	70	105	0.49	17	AV6 +0.02			0.53	18	AV6 +0.05
70	13	0.13	7	AV6 +0.00			0.26	11	AV8 +0.02			0.29	12	AV7 -0.02
70	15	0.27	11	AV1 +0.00			0.12	6	AV1 +0.02	71	74	0.15	8	AV3 +0.02
		0.16	8	AV2 -0.12			0.25	11	AV2 -0.05			0.23	10	AV4 -0.04
		0.20	9	AV6 +0.05	70	107	0.18	8	AV2 -0.02			0.17	8	AV5 +0.02
		0.61	19	AV7 +0.00			0.07	4	AV3 +0.02			0.48	17	AV6 +0.02
		0.35	13	AV8 +0.02			0.41	15	AV6 +0.00			0.52	17	AV7 +0.02
70	17	0.16	8	AV1 +0.02	70	109	0.19	9	AV2 +0.02			0.17	8	AV8 +0.02
		0.22	10	AV2 +0.14			0.55	18	AV3 +0.02	71	76	0.25	11	AV3 +0.02
		0.20	9	AV8 +0.05			0.49	17	AV8 +0.02			0.20	9	AV4 -0.02
70	35	0.11	6	AV4 -0.33			0.15	7	AV5 +0.39			0.43	15	AV5 +0.00
		0.09	5	AV6 -0.15	70	111	0.13	7	AV2 +0.00			0.33	13	AV8 +0.00
70	45	0.13	7	AV5 -0.72			0.33	13	AV6 +0.02	71	78	0.29	12	AV2 +0.02
70	53	0.18	9	AV6 +0.02	70	113	0.34	13	AV2 +0.00			0.47	16	AV3 +0.04
		0.21	10	AV7 +0.00			0.08	5	AV3 +0.00			0.19	9	AV4 +0.00
70	57	0.08	5	AV6 +0.16			0.45	16	AV7 +0.00			0.24	10	AV5 +0.06
70	59	0.11	6	AV6 +0.00	70	115	0.21	9	AV2 +0.00			0.18	8	AV7 +0.00
70	63	0.25	11	AV3 +0.00			0.12	6	AV3 +0.00	71	80	0.19	9	AV6 +0.02
		0.39	14	AV6 +0.05			0.23	10	AV6 +0.00	71	84	0.16	8	AV3 +0.02
70	65	0.25	11	AV2 +0.00	70	117	0.22	10	AV3 +0.02			0.22	10	AV4 +0.00
		0.39	14	AV3 +0.02			0.16	8	AV6 +0.00	71	88	0.15	8	AV2 -0.14
70	67	0.27	11	AV6 +0.02			0.30	12	AV7 +0.02			0.36	14	AV4 +0.00
		0.25	11	AV7 +0.05			0.17	8	AV2 +0.07			0.25	11	AV5 -0.51
70	69	0.36	14	AV6 +0.02	70	119	0.11	6	AV2 +0.00			0.35	13	AV6 +0.00
		0.23	10	AV7 +0.04			0.33	13	AV6 +0.00			0.30	12	AV7 +0.02
70	71	0.45	16	AV6 +0.02	70	121	0.16	8	AV2 +0.02	71	90	0.13	7	AV5 +0.06
		0.19	9	AV7 +0.07			0.18	9	AV3 -0.02			0.23	10	AV7 +0.02
70	73	0.43	15	AV6 +0.02			0.23	10	AV6 +0.00	71	92	0.30	12	AV6 +0.02
		0.24	10	AV7 +0.02	70	123	0.15	7	AV3 +0.02			0.23	10	AV2 +0.02
70	75	0.24	10	AV2 +0.00			0.34	13	AV6 +0.00			0.20	9	AV3 +0.02
		0.12	6	AV3 +0.02	70	129	0.22	10	AV6 -0.11			0.32	13	AV4 +0.00
		0.19	9	AV6 +0.07	70	133	0.28	11	AV2 +0.02	71	94	0.11	6	AV3 -0.16
		0.26	11	AV7 +0.02			0.47	16	AV6 -0.02			0.25	11	AV5 +0.04
		0.12	6	AV8 +0.00			0.27	11	AV7 +0.02	71	96	0.42	15	AV2 +0.02
		0.21	10	AV5 -0.07	70	135	0.09	5	AV6 +0.00			0.19	9	AV3 +0.02
70	77	0.25	11	AV3 +0.00	70	151	0.17	8	AV8 -0.16			0.34	13	AV6 +0.02
		0.33	13	AV6 +0.00			0.24	11	AV7 -0.05			0.29	12	AV7 +0.02
70	79	0.19	9	AV6 +0.02			0.18	9	AV1 +0.14	71	98	0.24	10	AV2 +0.02
70	83	0.11	6	AV2 -0.09	70	153	0.20	9	AV8 -0.16			0.36	14	AV3 +0.02
70	85	0.22	10	AV3 +0.02			0.39	14	AV7 -0.02			0.44	16	AV4 +0.04
		0.35	13	AV6 +0.02			0.21	9	AV6 -0.15			0.48	16	AV6 +0.02
70	87	0.48	16	AV7 +0.00			0.25	11	AV3 +0.14			0.19	9	AV7 -0.02
		0.12	6	AV2 -0.21			0.22	10	AV1 +0.19	71	100	0.14	7	AV2 +0.05
		0.52	17	AV3 +0.02	70	155	0.50	17	AV7 -0.12			0.34	13	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.26	11	AV4 +0.00			0.25	11	AV7 +0.00			0.16	8	AV7 +0.05
		0.33	13	AV6 +0.02			0.20	9	AV6 +0.02			0.16	8	AV2 -0.02
		0.45	16	AV7 +0.00			0.13	7	AV6 +0.02			0.35	14	AV4 +0.04
71	102	0.21	10	AV1 +0.00			0.22	10	AV7 +0.02			0.33	13	AV5 +0.00
		0.53	18	AV2 -0.02			0.28	12	AV6 +0.02			0.25	11	AV4 +0.04
		0.26	11	AV5 +0.04			0.18	8	AV3 +0.00			0.35	14	AV7 +0.00
		0.23	10	AV7 +0.02			0.62	19	AV4 +0.00			0.26	11	AV2 -0.02
71	104	0.11	6	AV3 +0.00			0.52	17	AV7 +0.05			0.58	18	AV3 +0.00
		0.40	15	AV5 +0.02			0.13	7	AV2 +0.02			0.23	10	AV3 +0.02
		0.38	14	AV7 -0.02			0.12	6	AV3 +0.02			0.17	8	AV4 +0.04
71	106	0.12	6	AV4 +0.48			0.11	6	AV6 +0.19			0.26	11	AV6 +0.02
		0.17	8	AV5 -0.39			0.23	10	AV7 +0.02			0.21	10	AV7 +0.02
		0.16	8	AV6 +0.07			0.17	8	AV2 +0.00			0.29	12	AV2 +0.02
		0.13	7	AV7 +0.02			0.40	15	AV3 +0.02			0.16	8	AV3 +0.00
71	108	0.19	9	AV2 +0.00			0.60	19	AV4 -0.02			0.63	19	AV6 +0.00
		0.14	7	AV5 -0.47			0.45	16	AV5 +0.04			0.37	14	AV7 +0.00
		0.62	19	AV6 +0.02			0.25	11	AV8 +0.00			0.18	8	AV2 +0.02
		0.52	17	AV7 +0.02			0.10	6	AV2 +0.07			0.12	6	AV5 +0.30
71	110	0.17	8	AV3 +0.06			0.25	11	AV3 +0.00			0.18	8	AV6 -0.02
71	112	0.17	8	AV2 +0.02			0.40	15	AV4 -0.02			0.11	6	AV2 +0.00
		0.21	9	AV3 +0.04			0.38	14	AV5 +0.02			0.14	7	AV3 +0.02
		0.29	12	AV4 +0.00			0.56	18	AV6 -0.02			0.11	6	AV6 -0.02
		0.18	9	AV5 -0.32			0.26	11	AV7 +0.00			0.12	7	AV2 +0.05
71	114	0.16	8	AV4 -0.02			0.16	8	AV1 +0.02			0.16	8	AV5 -0.28
		0.28	12	AV5 +0.02			0.18	8	AV2 +0.02			0.13	7	AV7 +0.16
		0.43	15	AV6 -0.02			0.20	9	AV3 +0.02			0.16	8	AV3 -0.02
71	116	0.41	15	AV4 +0.47			0.17	8	AV4 +0.00			0.18	8	AV8 -0.22
		0.20	9	AV6 +0.00			0.44	16	AV5 +0.00			0.09	5	AV6 -0.20
		0.23	10	AV2 +0.05			0.44	16	AV8 +0.00			0.25	11	AV7 -0.05
		0.58	18	AV3 +0.00			0.24	10	AV2 +0.02			0.49	17	AV6 -0.04
		0.22	10	AV1 +0.00			0.12	6	AV3 +0.00			0.24	10	AV7 -0.02
71	118	0.14	7	AV4 +0.71			0.19	9	AV4 +0.00			0.29	12	AV6 -0.02
		0.37	14	AV6 +0.00			0.50	17	AV5 +0.04			0.16	8	AV5 -0.04
		0.33	13	AV7 +0.02			0.56	18	AV6 +0.00			0.29	12	AV3 +0.04
71	120	0.16	8	AV6 +0.00			0.38	14	AV7 -0.02			0.23	10	AV3 +0.14
71	138	0.26	11	AV3 +0.02			0.46	16	AV2 -0.02			0.24	10	AV1 -0.20
71	144	0.18	8	AV3 +0.14			0.09	5	AV5 -0.35			0.45	16	AV7 +0.00
71	148	0.13	7	AV8 +0.14			0.13	7	AV3 +0.00			0.21	9	AV5 +0.21
		0.14	7	AV1 +0.02			0.11	6	AV3 +0.00			0.13	7	AV3 +0.15
71	150	0.20	9	AV1 +0.19			0.18	8	AV4 -0.02			0.27	11	AV1 -0.20
71	152	0.27	11	AV8 -0.02			0.11	6	AV5 -0.29			0.12	6	AV1 +0.19
		0.17	8	AV7 -0.02			0.12	6	AV6 +0.02			0.24	10	AV2 -0.16
		0.17	8	AV6 -0.16			0.23	10	AV5 +0.04			0.37	14	AV3 +0.02
		0.17	8	AV1 +0.19			0.45	16	AV3 -0.02			0.17	8	AV4 +0.25
71	154	0.14	7	AV8 +0.19			0.29	12	AV5 +0.06			0.12	6	AV8 +0.18
		0.16	8	AV2 -0.02			0.17	8	AV7 +0.02			0.24	11	AV1 +0.19
		0.19	9	AV1 +0.23			0.25	11	AV2 +0.02			0.25	11	AV2 +0.25
71	156	0.33	13	AV8 +0.19			0.54	18	AV4 +0.07			0.53	18	AV8 +0.02
		0.15	8	AV2 +0.16			0.57	18	AV7 +0.00			0.16	8	AV3 +0.02
72	15	0.38	14	AV5 -0.34			0.33	13	AV8 +0.02			0.15	7	AV4 -0.18
		0.38	14	AV6 -0.17			0.50	17	AV3 +0.02			0.27	11	AV5 +0.24
		0.35	14	AV7 -0.11			0.49	17	AV5 +0.09			0.08	5	AV8 +0.05
		0.19	9	AV1 -0.10			0.15	7	AV3 +0.02			0.12	6	AV4 +0.21
		0.22	10	AV2 -0.09			0.33	13	AV4 +0.23			0.16	8	AV3 +0.02
		0.13	7	AV3 +0.24			0.31	12	AV5 +0.05			0.21	9	AV4 +0.00
72	17	0.17	8	AV5 +0.21			0.45	16	AV6 +0.05			0.16	8	AV5 +0.00
		0.11	6	AV4 +0.38			0.23	10	AV2 +0.00			0.22	10	AV6 +0.00
		0.21	9	AV2 +0.12			0.17	8	AV3 +0.00			0.20	9	AV7 +0.00
		0.14	7	AV1 -0.18			0.23	10	AV6 +0.00			0.19	9	AV6 +0.00
72	25	0.42	15	AV3 +0.00			0.32	13	AV2 +0.02			0.20	9	AV7 +0.02
		0.31	13	AV4 +0.26			0.17	8	AV3 +0.04			0.14	7	AV3 +0.00
		0.62	19	AV5 +0.00			0.26	11	AV6 +0.05			0.22	10	AV4 -0.02
72	29	0.11	6	AV7 +0.02			0.19	9	AV5 +0.06			0.21	10	AV5 +0.02
72	31	0.14	7	AV8 +0.00			0.19	9	AV2 -0.02			0.20	9	AV6 +0.02
72	33	0.17	8	AV3 +0.02			0.23	10	AV3 +0.02			0.19	9	AV2 +0.05
		0.14	7	AV4 +0.32			0.32	13	AV4 +0.00			0.22	10	AV4 +0.00
72	35	0.23	10	AV4 -0.17			0.30	12	AV7 +0.00			0.50	17	AV6 +0.05
		0.11	6	AV5 +0.19			0.31	12	AV2 +0.02			0.25	11	AV4 +0.26
		0.12	6	AV6 -0.19			0.46	16	AV4 +0.04			0.19	9	AV3 +0.00
72	37	0.11	6	AV7 +0.14			0.26	11	AV8 +0.05			0.20	9	AV5 +0.02
72	41	0.08	5	AV2 +0.19			0.47	16	AV4 +0.00			0.18	9	AV6 +0.00
72	53	0.19	9	AV6 +0.00			0.23	10	AV6 +0.00			0.16	8	AV7 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
73	72	0.42	15	AV5 +0.04			0.15	8	AV5 +0.02			0.22	10	AV6 +0.02
73	74	0.16	8	AV2 +0.02			0.27	11	AV6 +0.02			0.32	13	AV7 +0.02
		0.47	16	AV3 +0.02			0.09	5	AV7 -0.16	74	71	0.23	10	AV1 +0.00
		0.43	15	AV8 +0.02			0.12	6	AV3 +0.18			0.18	9	AV2 +0.02
73	76	0.24	10	AV1 +0.00	73	136	0.20	9	AV7 +0.02			0.18	8	AV3 +0.02
		0.26	11	AV2 +0.02			0.14	7	AV7 +0.02	74	73	0.12	6	AV1 +0.05
		0.20	9	AV8 +0.02	73	140	0.14	7	AV8 +0.14			0.63	19	AV2 +0.05
73	78	0.14	7	AV3 +0.02			0.10	6	AV6 -0.02			0.14	7	AV8 +0.00
		0.20	9	AV4 +0.00			0.17	8	AV3 +0.02	74	75	0.18	8	AV2 +0.00
		0.27	11	AV5 -0.21	73	144	0.15	7	AV3 +0.04			0.59	19	AV3 +0.00
		0.20	9	AV6 +0.02			0.25	11	AV1 +0.00			0.27	11	AV4 +0.00
73	80	0.17	8	AV3 +0.00	73	152	0.17	8	AV7 -0.05			0.56	18	AV5 +0.00
		0.11	6	AV5 -0.19			0.16	8	AV6 -0.16			0.47	16	AV7 +0.00
		0.20	9	AV6 -0.02			0.18	9	AV4 +0.37	74	77	0.28	12	AV4 +0.03
73	82	0.15	7	AV3 +0.02			0.15	7	AV1 -0.21			0.52	17	AV7 -0.02
		0.19	9	AV4 +0.22	73	154	0.24	10	AV8 -0.16	74	79	0.24	10	AV4 +0.20
		0.27	11	AV5 +0.00			0.13	7	AV6 -0.04			0.13	7	AV5 -0.17
		0.32	13	AV6 +0.02			0.36	14	AV3 +0.02			0.38	14	AV6 +0.00
		0.39	14	AV7 +0.02			0.24	10	AV1 -0.23	74	81	0.45	16	AV2 +0.00
73	84	0.13	7	AV7 +0.04	74	15	0.11	6	AV7 -0.14			0.41	15	AV7 +0.00
		0.21	9	AV3 +0.02	74	17	0.26	11	AV2 +0.13			0.09	5	AV8 -0.02
		0.32	13	AV4 -0.02			0.15	7	AV3 +0.05	74	83	0.35	13	AV6 +0.05
		0.20	9	AV5 -0.15			0.21	9	AV4 +0.29			0.28	12	AV4 +0.03
73	86	0.44	16	AV4 -0.02			0.14	7	AV5 +0.00			0.46	16	AV5 +0.07
		0.17	8	AV6 -0.02			0.19	9	AV6 -0.16			0.19	9	AV7 +0.00
73	88	0.19	9	AV2 +0.02			0.19	9	AV7 +0.00			0.19	9	AV2 +0.00
73	90	0.17	8	AV2 +0.00			0.18	9	AV8 -0.16			0.53	18	AV3 +0.02
		0.31	12	AV5 +0.04			0.17	8	AV1 +0.02	74	85	0.17	8	AV3 +0.00
		0.19	9	AV6 +0.05	74	19	0.08	5	AV1 -0.23			0.37	14	AV4 +0.00
		0.26	11	AV7 +0.02			0.13	7	AV2 +0.02			0.30	12	AV5 -0.19
73	92	0.27	11	AV2 +0.00			0.09	5	AV5 -0.03	74	87	0.25	11	AV2 +0.02
		0.29	12	AV3 +0.02			0.13	7	AV6 +0.00			0.54	18	AV7 +0.05
		0.44	16	AV5 +0.05	74	21	0.14	7	AV4 +0.23	74	89	0.35	13	AV2 +0.00
		0.40	15	AV6 +0.02			0.17	8	AV8 +0.00	74	91	0.14	7	AV2 +0.00
73	94	0.29	12	AV2 +0.02	74	23	0.10	6	AV1 -0.12			0.20	9	AV3 +0.00
		0.30	12	AV3 +0.00			0.13	7	AV4 +0.25			0.20	9	AV4 +0.03
		0.47	16	AV4 +0.03			0.18	9	AV6 +0.00			0.33	13	AV5 +0.05
		0.30	12	AV7 +0.02	74	25	0.09	5	AV5 +0.09	74	93	0.44	16	AV3 +0.00
73	96	0.17	8	AV3 +0.02			0.09	5	AV6 -0.18			0.34	13	AV4 +0.06
		0.51	17	AV7 +0.02			0.20	9	AV7 -0.16			0.53	18	AV6 +0.05
73	98	0.22	10	AV2 +0.00	74	29	0.11	6	AV4 +0.28	74	95	0.26	11	AV2 +0.00
		0.42	15	AV4 -0.02	74	33	0.19	9	AV4 +0.23			0.44	16	AV3 +0.02
		0.47	16	AV6 +0.05			0.23	10	AV6 -0.02			0.49	17	AV4 +0.24
		0.30	12	AV7 +0.05			0.18	9	AV7 +0.02	74	97	0.34	13	AV2 +0.02
73	102	0.21	10	AV2 +0.02			0.17	8	AV8 +0.02			0.39	14	AV7 +0.00
		0.28	11	AV3 +0.00	74	35	0.23	10	AV3 +0.21	74	99	0.20	9	AV1 +0.00
73	104	0.51	17	AV3 +0.02			0.17	8	AV5 +0.02			0.48	16	AV2 +0.02
		0.60	19	AV4 +0.21			0.17	8	AV6 -0.16			0.22	10	AV3 +0.02
		0.13	7	AV7 +0.00			0.11	6	AV4 +0.00			0.45	16	AV5 +0.02
		0.34	13	AV2 +0.02	74	55	0.36	14	AV4 +0.03			0.33	13	AV6 +0.02
73	106	0.35	14	AV5 -0.25			0.35	13	AV5 -0.14			0.25	11	AV7 +0.00
		0.17	8	AV6 +0.07			0.26	11	AV6 +0.02	74	101	0.15	7	AV1 +0.00
		0.21	9	AV7 +0.07			0.25	11	AV7 +0.00			0.47	16	AV2 +0.00
		0.18	8	AV8 +0.02	74	57	0.17	8	AV5 -0.12			0.43	15	AV3 -0.02
		0.32	13	AV1 +0.02			0.36	14	AV6 +0.02	74	103	0.25	11	AV2 +0.02
73	108	0.17	8	AV2 +0.00	74	59	0.16	8	AV6 +0.02			0.11	6	AV4 +0.28
		0.57	18	AV6 +0.00	74	61	0.31	13	AV6 +0.05			0.13	7	AV5 +0.02
		0.25	11	AV7 +0.00			0.16	8	AV7 +0.05			0.21	9	AV6 +0.07
		0.18	8	AV5 +0.09	74	63	0.26	11	AV2 +0.02			0.61	19	AV7 +0.00
73	110	0.44	16	AV5 +0.02			0.16	8	AV3 +0.02			0.40	15	AV8 +0.02
		0.21	10	AV8 +0.02			0.21	10	AV4 +0.03	74	105	0.09	5	AV1 -0.02
73	112	0.09	5	AV1 -0.05			0.26	11	AV5 +0.02			0.13	7	AV2 -0.02
		0.12	6	AV2 -0.02			0.17	8	AV7 +0.02			0.62	19	AV4 +0.00
		0.50	17	AV4 +0.00	74	65	0.13	7	AV2 +0.00			0.16	8	AV5 +0.02
		0.18	9	AV5 -0.13			0.22	10	AV3 +0.02			0.18	8	AV6 +0.02
73	114	0.15	7	AV5 +0.04			0.14	7	AV5 +0.07			0.32	13	AV7 +0.02
73	116	0.28	12	AV4 +0.23			0.62	19	AV6 +0.02			0.09	5	AV8 +0.05
		0.26	11	AV6 -0.02			0.23	10	AV7 -0.07	74	107	0.25	11	AV2 +0.00
73	118	0.08	5	AV2 +0.21	74	67	0.17	8	AV5 -0.28			0.26	11	AV3 +0.02
		0.13	7	AV3 +0.13			0.36	14	AV8 +0.02			0.35	14	AV4 +0.06
73	120	0.14	7	AV3 -0.05	74	69	0.21	9	AV4 +0.00			0.55	18	AV6 -0.02
73	134	0.17	8	AV3 +0.06			0.13	7	AV5 -0.21			0.15	7	AV7 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
74	111	0.20	9	AV3 +0.02						75	124	0.24	10	AV5 -0.15
		0.54	18	AV4 +0.03	75	76	0.16	8	AV2 -0.02	75	134	0.14	7	AV3 +0.04
		0.54	18	AV7 +0.02			0.50	17	AV3 +0.02	75	140	0.13	7	AV6 -0.02
74	113	0.35	13	AV2 +0.02			0.25	11	AV6 +0.02			0.18	9	AV5 -0.31
		0.11	6	AV3 +0.02	75	78	0.61	19	AV3 +0.02	75	142	0.19	9	AV5 -0.20
		0.26	11	AV7 +0.00			0.62	19	AV4 +0.06			0.18	9	AV3 -0.02
74	115	0.30	12	AV4 +0.21			0.52	17	AV5 +0.05	75	144	0.22	10	AV8 +0.00
		0.26	11	AV6 +0.02			0.56	18	AV6 +0.05			0.30	12	AV7 +0.00
		0.34	13	AV7 +0.07			0.25	11	AV7 +0.02			0.15	8	AV6 +0.00
		0.48	16	AV8 +0.02	75	80	0.53	18	AV3 +0.02			0.32	13	AV5 -0.20
74	117	0.25	11	AV2 +0.00			0.62	19	AV6 +0.02	75	146	0.13	7	AV5 -0.26
		0.07	4	AV4 -0.18	75	82	0.34	13	AV5 +0.00			0.11	6	AV4 +0.17
74	119	0.20	9	AV2 +0.02			0.24	10	AV6 +0.02			0.22	10	AV3 +0.02
		0.21	10	AV3 +0.04			0.36	14	AV7 +0.02	75	148	0.23	10	AV5 -0.26
74	123	0.18	8	AV5 +0.00	75	84	0.25	11	AV3 +0.00	75	150	0.15	7	AV6 +0.00
		0.17	8	AV6 +0.02			0.35	14	AV4 -0.02			0.31	12	AV5 -0.26
74	125	0.30	12	AV7 +0.04			0.21	10	AV5 -0.12			0.27	11	AV3 +0.02
74	129	0.24	10	AV3 +0.00	75	86	0.19	9	AV2 +0.00			0.17	8	AV1 +0.00
74	137	0.14	7	AV2 -0.02			0.42	15	AV4 +0.00	75	152	0.26	11	AV8 -0.14
		0.14	7	AV3 +0.00			0.50	17	AV5 +0.00			0.29	12	AV7 -0.05
		0.14	7	AV5 -0.27	75	88	0.35	13	AV3 +0.02			0.12	6	AV4 +0.33
74	139	0.18	8	AV8 -0.18			0.28	12	AV4 +0.14			0.33	13	AV2 +0.00
		0.16	8	AV5 -0.20			0.60	19	AV5 +0.02			0.23	10	AV1 -0.21
		0.15	7	AV2 +0.00	75	90	0.20	9	AV6 +0.02	75	154	0.33	13	AV8 +0.21
74	141	0.09	5	AV7 +0.16			0.24	11	AV7 +0.02			0.23	10	AV7 -0.03
		0.14	7	AV4 -0.04			0.26	11	AV2 +0.00			0.17	8	AV6 -0.02
		0.16	8	AV3 +0.00			0.24	10	AV3 +0.02			0.22	10	AV3 +0.00
74	143	0.33	13	AV5 -0.30			0.38	14	AV4 +0.03			0.10	6	AV2 +0.00
74	145	0.54	18	AV1 -0.02			0.57	18	AV5 +0.02			0.28	12	AV1 -0.16
74	153	0.29	12	AV8 -0.16	75	92	0.15	8	AV2 +0.02	76	17	0.14	7	AV1 -0.16
		0.13	7	AV5 -0.25			0.23	10	AV3 +0.00			0.22	10	AV2 +0.17
		0.32	13	AV1 -0.23			0.61	19	AV4 +0.06			0.20	9	AV6 -0.16
75	16	0.13	7	AV2 +0.16			0.55	18	AV5 +0.00			0.17	8	AV7 +0.00
		0.26	11	AV6 -0.02			0.22	10	AV7 +0.02	76	19	0.16	8	AV4 +0.22
		0.19	9	AV7 -0.05	75	94	0.26	11	AV2 +0.00			0.16	8	AV6 -0.02
		0.18	9	AV8 +0.18	75	96	0.23	10	AV2 +0.00	76	21	0.19	9	AV1 +0.05
75	18	0.45	16	AV4 +0.28			0.49	17	AV3 +0.02			0.28	12	AV4 +0.21
		0.31	12	AV6 -0.05			0.35	13	AV7 +0.02			0.19	9	AV8 -0.02
		0.21	10	AV2 +0.17	75	98	0.49	17	AV2 +0.02	76	27	0.13	7	AV1 +0.00
75	20	0.13	7	AV1 -0.20			0.22	10	AV3 +0.02			0.23	10	AV2 +0.07
75	28	0.11	6	AV5 +0.07			0.50	17	AV6 +0.02			0.15	7	AV5 -0.03
75	30	0.13	7	AV4 +0.23	75	100	0.35	13	AV2 +0.02	76	29	0.16	8	AV4 +0.27
75	44	0.11	6	AV4 -0.16			0.58	18	AV3 +0.02			0.19	9	AV6 +0.05
		0.26	11	AV5 +0.18			0.48	16	AV4 +0.06	76	31	0.15	8	AV4 +0.21
		0.14	7	AV7 +0.00			0.33	13	AV5 -0.12	76	33	0.18	9	AV4 +0.19
		0.15	7	AV8 +0.05			0.17	8	AV8 -0.02	76	35	0.15	8	AV4 -0.19
75	52	0.19	9	AV2 +0.02	75	104	0.63	19	AV4 +0.23	76	41	0.10	6	AV5 -0.14
		0.21	9	AV5 -0.17	75	106	0.31	13	AV3 +0.00	76	45	0.13	7	AV4 +0.30
75	54	0.13	7	AV6 +0.00	75	108	0.16	8	AV2 +0.02	76	55	0.11	6	AV4 -0.12
75	56	0.30	12	AV5 +0.05			0.13	7	AV6 +0.00			0.20	9	AV5 -0.19
		0.30	12	AV6 +0.05			0.26	11	AV7 +0.02	76	59	0.46	16	AV2 +0.02
75	60	0.14	7	AV4 +0.20	75	110	0.17	8	AV3 +0.07			0.34	13	AV3 +0.00
		0.08	5	AV7 +0.00			0.26	11	AV4 +0.06			0.11	6	AV7 +0.00
75	62	0.18	9	AV1 +0.02			0.15	8	AV5 +0.02	76	61	0.09	5	AV5 -0.19
		0.37	14	AV4 +0.03			0.27	11	AV6 +0.02			0.38	14	AV6 +0.02
		0.63	19	AV5 +0.02	75	112	0.12	6	AV1 +0.05			0.33	13	AV7 +0.04
		0.44	16	AV6 +0.00			0.21	10	AV2 +0.05	76	63	0.26	11	AV3 +0.02
75	64	0.23	10	AV5 +0.02			0.21	10	AV4 +0.03			0.52	17	AV4 +0.03
75	66	0.49	17	AV4 +0.00			0.31	12	AV6 +0.05			0.44	16	AV5 -0.03
		0.36	14	AV7 +0.02			0.48	16	AV7 +0.04			0.57	18	AV6 +0.02
75	68	0.21	9	AV5 -0.20			0.32	13	AV8 +0.00			0.22	10	AV7 +0.02
75	70	0.22	10	AV5 +0.02	75	114	0.23	10	AV5 +0.00	76	65	0.46	16	AV2 +0.00
		0.38	14	AV6 +0.07	75	116	0.29	12	AV7 +0.02			0.21	10	AV3 +0.02
		0.61	19	AV7 +0.02			0.26	11	AV2 +0.02			0.44	16	AV7 +0.09
		0.21	10	AV8 +0.02			0.34	13	AV3 +0.02	76	67	0.26	11	AV7 +0.00
75	72	0.19	9	AV2 +0.02			0.37	14	AV4 +0.25			0.13	7	AV3 +0.02
		0.27	11	AV3 -0.02			0.38	14	AV6 -0.02			0.19	9	AV5 -0.23
75	74	0.11	6	AV1 +0.00	75	118	0.22	10	AV4 +0.23			0.48	16	AV6 +0.00
		0.16	8	AV3 +0.02			0.20	9	AV5 +0.05	76	69	0.11	6	AV3 +0.00
		0.43	15	AV4 +0.03			0.11	6	AV7 +0.05			0.31	12	AV4 +0.03
		0.55	18	AV5 +0.02	75	120	0.16	8	AV6 -0.02			0.08	5	AV5 -0.22
		0.60	19	AV6 +0.02			0.36	14	AV7 +0.00			0.26	11	AV6 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.15	7	AV7 +0.02			0.20	9	AV8 +0.00	77	74	0.15	8	AV3 +0.02
76	71	0.47	16	AV2 +0.02	76	113	0.56	18	AV6 +0.00			0.49	17	AV7 +0.02
		0.53	17	AV5 +0.05			0.32	13	AV7 +0.02	77	76	0.62	19	AV7 -0.02
		0.52	17	AV6 +0.02			0.13	7	AV8 -0.02			0.10	5	AV1 +0.05
		0.19	9	AV7 +0.04	76	115	0.25	11	AV3 +0.02			0.40	15	AV2 +0.00
76	73	0.25	11	AV3 +0.02			0.18	8	AV7 +0.02	77	78	0.51	17	AV3 +0.02
		0.19	9	AV4 +0.06	76	117	0.11	6	AV2 +0.00			0.40	15	AV6 +0.02
		0.30	12	AV6 +0.00			0.30	12	AV4 +0.08	77	80	0.19	9	AV2 +0.02
		0.18	9	AV7 +0.00			0.30	12	AV5 +0.02			0.40	15	AV8 +0.00
76	75	0.59	19	AV2 +0.00			0.18	8	AV6 -0.02	77	82	0.20	9	AV4 +0.03
		0.34	13	AV8 +0.02	76	119	0.22	10	AV6 +0.02			0.34	13	AV5 +0.00
76	77	0.18	9	AV2 +0.02	76	121	0.24	10	AV5 -0.20			0.13	7	AV6 +0.02
		0.18	8	AV3 +0.02	76	125	0.14	7	AV7 +0.02			0.36	14	AV7 +0.00
		0.24	10	AV4 +0.03	76	137	0.12	6	AV2 -0.21			0.12	6	AV3 +0.00
		0.20	9	AV5 +0.00	76	139	0.13	7	AV5 -0.24	77	84	0.21	10	AV2 +0.00
		0.63	19	AV6 +0.00	76	143	0.38	14	AV5 -0.25			0.22	10	AV3 +0.05
		0.42	15	AV7 -0.02	76	145	0.16	8	AV6 +0.00			0.49	17	AV4 +0.03
76	79	0.12	6	AV2 +0.00			0.27	11	AV5 -0.17			0.34	13	AV5 +0.05
		0.53	18	AV4 +0.03	76	147	0.17	8	AV3 +0.02	77	86	0.52	17	AV4 +0.00
		0.23	10	AV5 +0.05			0.56	18	AV2 +0.02			0.53	18	AV5 -0.20
		0.38	14	AV6 +0.02			0.23	10	AV1 +0.00			0.48	17	AV6 -0.02
76	81	0.40	15	AV2 +0.00			0.19	9	AV5 -0.20			0.34	13	AV7 +0.02
76	83	0.22	10	AV3 +0.02			0.12	6	AV4 +0.17	77	88	0.33	13	AV2 +0.02
		0.22	10	AV5 +0.02	76	151	0.26	11	AV2 +0.02			0.27	11	AV3 +0.00
		0.29	12	AV6 +0.02			0.16	8	AV1 -0.18			0.56	18	AV4 +0.05
		0.34	13	AV7 +0.02	76	153	0.40	15	AV8 -0.16			0.33	13	AV5 +0.00
		0.10	6	AV2 +0.00			0.28	12	AV7 +0.00	77	90	0.35	13	AV2 +0.05
76	85	0.20	9	AV3 +0.02			0.28	12	AV5 -0.22			0.57	18	AV7 +0.00
		0.40	15	AV4 +0.06			0.54	18	AV4 +0.03	77	92	0.56	18	AV2 +0.02
		0.27	11	AV5 +0.05			0.24	10	AV3 +0.05	77	94	0.39	14	AV2 +0.05
		0.12	6	AV6 +0.02			0.17	8	AV1 -0.20			0.39	14	AV3 +0.02
76	87	0.16	8	AV2 +0.00	77	16	0.12	6	AV1 -0.21			0.59	19	AV7 +0.02
		0.48	17	AV7 +0.02			0.11	6	AV6 -0.16	77	96	0.36	14	AV2 +0.00
76	89	0.32	13	AV2 -0.02	77	18	0.15	7	AV1 +0.21			0.34	13	AV3 +0.00
		0.53	17	AV4 +0.00			0.27	11	AV2 +0.21			0.20	9	AV4 +0.06
		0.18	9	AV7 +0.02			0.22	10	AV5 -0.14			0.54	18	AV5 +0.05
76	91	0.51	17	AV5 -0.17			0.13	7	AV7 +0.00	77	100	0.17	8	AV1 +0.00
		0.17	8	AV2 +0.00	77	20	0.12	6	AV4 +0.22			0.22	10	AV2 +0.02
		0.16	8	AV7 +0.05	77	22	0.17	8	AV4 +0.25			0.54	18	AV4 +0.03
		0.39	14	AV3 +0.02	77	26	0.07	4	AV1 +0.19			0.20	9	AV8 +0.00
		0.59	19	AV4 +0.03			0.10	6	AV2 +0.02			0.59	19	AV5 +0.02
76	93	0.18	9	AV2 +0.05			0.11	6	AV3 +0.02	77	102	0.45	16	AV7 -0.02
		0.43	15	AV3 +0.00			0.13	7	AV4 +0.00			0.17	8	AV3 -0.02
		0.16	8	AV4 +0.20	77	30	0.11	6	AV4 +0.05	77	104	0.17	8	AV1 +0.00
		0.15	7	AV5 +0.07	77	36	0.24	10	AV4 +0.24			0.55	18	AV2 +0.00
76	95	0.18	8	AV2 +0.00	77	44	0.16	8	AV5 +0.21			0.54	18	AV4 +0.23
		0.40	15	AV4 +0.20	77	46	0.12	6	AV4 +0.19	77	106	0.41	15	AV2 +0.02
		0.29	12	AV5 +0.05	77	50	0.09	5	AV5 -0.19			0.39	14	AV7 +0.02
		0.20	9	AV6 +0.02	77	54	0.10	5	AV4 +0.24	77	108	0.22	10	AV2 +0.02
		0.47	16	AV7 +0.05			0.31	12	AV6 +0.02			0.30	12	AV7 +0.05
76	99	0.12	6	AV1 +0.02			0.22	10	AV7 +0.00	77	110	0.11	6	AV7 +0.02
		0.56	18	AV3 +0.02	77	56	0.32	13	AV4 +0.24			0.13	7	AV8 +0.02
		0.36	14	AV4 +0.19			0.07	4	AV5 +0.14			0.20	9	AV5 +0.00
		0.18	8	AV8 +0.02			0.09	5	AV6 +0.05			0.26	11	AV6 +0.00
76	101	0.16	8	AV2 +0.00	77	60	0.14	7	AV3 +0.00	77	112	0.39	15	AV3 +0.02
		0.22	10	AV3 -0.02			0.20	9	AV4 +0.16			0.25	11	AV8 +0.02
		0.13	7	AV4 +0.06			0.40	15	AV5 +0.02			0.12	6	AV2 +0.05
		0.45	16	AV6 +0.05			0.43	15	AV6 +0.02	77	114	0.35	13	AV3 +0.00
76	103	0.12	6	AV8 +0.05			0.21	9	AV7 +0.00			0.36	14	AV6 +0.00
		0.15	7	AV3 +0.07	77	62	0.10	6	AV3 +0.00			0.48	16	AV7 +0.02
		0.09	5	AV1 -0.07			0.16	8	AV5 +0.02	77	116	0.20	9	AV2 +0.05
76	105	0.54	18	AV2 +0.00	77	64	0.40	15	AV5 +0.00	77	118	0.20	9	AV3 -0.02
		0.36	14	AV8 +0.05			0.26	11	AV6 +0.02			0.51	17	AV4 +0.22
76	107	0.24	10	AV7 +0.02			0.32	13	AV7 +0.00			0.49	17	AV5 +0.02
		0.12	6	AV1 +0.02	77	70	0.20	9	AV2 +0.00			0.24	10	AV6 -0.02
		0.26	11	AV2 +0.02			0.40	15	AV3 +0.02			0.08	5	AV7 -0.17
76	109	0.63	19	AV3 +0.02			0.38	14	AV4 +0.03	77	120	0.21	9	AV6 +0.00
		0.11	6	AV2 +0.00			0.22	10	AV5 +0.02	77	122	0.09	5	AV4 +0.25
		0.61	19	AV7 +0.02	77	72	0.21	10	AV2 +0.02			0.10	6	AV5 +0.26
		0.45	16	AV4 +0.06			0.18	8	AV3 +0.02			0.46	16	AV6 +0.02
76	111	0.32	13	AV2 +0.07			0.62	19	AV4 +0.03	77	124	0.11	6	AV4 +0.03
		0.60	19	AV3 +0.05			0.29	12	AV7 +0.02			0.18	8	AV5 -0.11

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.17	8	AV6 -0.05										
77	130	0.14	7	AV6 +0.19	78	83	0.11	6	AV1 -0.19			0.15	8	AV5 -0.16
77	134	0.23	10	AV3 +0.07			0.17	8	AV2 -0.02			0.16	8	AV6 -0.19
		0.13	7	AV4 +0.03			0.53	18	AV3 +0.00	79	20	0.13	7	AV1 -0.16
		0.11	6	AV5 -0.16			0.50	17	AV4 -0.02			0.18	8	AV2 +0.05
77	138	0.40	15	AV5 -0.19			0.61	19	AV7 +0.00			0.12	6	AV4 +0.19
77	140	0.10	6	AV8 -0.14	78	85	0.19	9	AV3 +0.02			0.17	8	AV7 +0.02
		0.14	7	AV5 -0.31			0.44	16	AV4 +0.00			0.13	7	AV8 +0.02
		0.20	9	AV4 +0.00			0.38	14	AV5 +0.02	79	22	0.18	9	AV2 +0.02
77	142	0.14	7	AV5 +0.01			0.20	9	AV6 +0.07			0.21	9	AV4 +0.00
77	144	0.25	11	AV5 -0.22	78	87	0.17	8	AV2 -0.02			0.14	7	AV7 +0.05
77	146	0.11	6	AV5 -0.17			0.60	19	AV3 +0.02	79	24	0.15	7	AV4 +0.05
		0.43	15	AV3 +0.02			0.38	14	AV7 +0.02			0.15	8	AV7 +0.00
		0.30	12	AV2 +0.00	78	91	0.35	13	AV4 +0.03	79	30	0.13	7	AV1 +0.02
		0.23	10	AV1 +0.02			0.16	8	AV5 -0.17			0.26	11	AV2 +0.00
77	148	0.14	7	AV1 -0.18			0.47	16	AV6 +0.05			0.14	7	AV4 -0.02
77	152	0.22	10	AV8 +0.19	78	93	0.30	12	AV3 -0.02	79	34	0.09	5	AV5 +0.18
		0.20	9	AV7 -0.05			0.35	13	AV4 +0.06	79	36	0.23	10	AV4 +0.21
		0.23	10	AV6 -0.05			0.21	9	AV5 +0.07	79	46	0.22	10	AV1 -0.03
		0.19	9	AV2 +0.00			0.13	7	AV2 +0.00			0.12	6	AV4 +0.00
77	154	0.21	10	AV1 -0.16	78	95	0.57	18	AV7 +0.07	79	50	0.13	7	AV4 +0.27
78	17	0.14	7	AV1 -0.19			0.12	6	AV1 +0.05	79	56	0.18	9	AV6 +0.02
		0.23	10	AV2 +0.17			0.37	14	AV2 +0.00	79	60	0.18	9	AV6 -0.02
		0.18	9	AV8 +0.18	78	97	0.23	10	AV2 -0.02			0.20	9	AV7 +0.00
		0.17	8	AV6 -0.14	78	101	0.32	13	AV2 +0.00			0.19	9	AV8 +0.02
78	21	0.13	7	AV8 -0.02			0.35	13	AV3 +0.02	79	62	0.47	16	AV4 +0.03
78	23	0.16	8	AV4 +0.08			0.34	13	AV7 +0.02			0.38	14	AV6 +0.02
78	31	0.13	7	AV5 +0.00	78	107	0.18	8	AV2 +0.02	79	64	0.30	12	AV5 +0.02
78	35	0.13	7	AV5 +0.18			0.52	17	AV3 +0.02	79	66	0.16	8	AV6 +0.02
78	45	0.36	14	AV4 +0.24			0.43	15	AV5 +0.05	79	68	0.37	14	AV3 +0.00
78	47	0.09	5	AV4 +0.05			0.18	9	AV7 +0.05			0.55	18	AV5 +0.07
78	49	0.18	8	AV4 -0.16			0.13	7	AV8 +0.02	79	70	0.16	8	AV3 +0.00
		0.14	7	AV5 +0.16	78	111	0.11	6	AV7 +0.16			0.45	16	AV7 +0.00
78	53	0.34	13	AV5 -0.03			0.22	10	AV3 +0.05	79	72	0.39	15	AV3 +0.05
		0.37	14	AV6 +0.02	78	113	0.26	11	AV2 +0.02			0.63	19	AV4 +0.03
78	55	0.14	7	AV6 +0.00			0.61	19	AV5 +0.02	79	74	0.25	11	AV2 +0.05
78	57	0.20	9	AV5 +0.02			0.62	19	AV7 +0.02			0.46	16	AV3 +0.02
		0.24	10	AV6 +0.00	78	115	0.17	8	AV4 +0.03			0.32	13	AV8 +0.02
78	59	0.22	10	AV6 +0.00			0.35	14	AV5 -0.22	79	76	0.21	9	AV1 +0.00
		0.34	13	AV7 +0.00			0.55	18	AV6 +0.00			0.13	7	AV2 +0.05
78	61	0.54	18	AV6 +0.02			0.16	8	AV7 +0.00			0.32	13	AV3 +0.02
78	63	0.17	8	AV1 +0.02			0.23	10	AV8 +0.00			0.22	10	AV8 +0.00
		0.20	9	AV2 +0.05			0.43	15	AV3 +0.02	79	78	0.40	15	AV8 +0.02
		0.37	14	AV3 +0.05	78	121	0.34	13	AV5 +0.02			0.22	10	AV2 +0.00
		0.33	13	AV4 +0.03	78	123	0.19	9	AV3 +0.02			0.45	16	AV3 +0.02
		0.19	9	AV5 +0.02			0.15	7	AV5 +0.14	79	82	0.33	13	AV3 +0.00
		0.41	15	AV6 +0.05	78	125	0.48	16	AV6 +0.02			0.62	19	AV6 -0.02
78	67	0.13	7	AV3 +0.02			0.31	12	AV7 +0.00			0.34	13	AV7 +0.02
		0.45	16	AV5 +0.05			0.11	6	AV8 +0.05	79	84	0.10	6	AV3 +0.00
		0.42	15	AV7 +0.02	78	133	0.20	9	AV3 +0.00			0.11	6	AV4 +0.03
78	69	0.16	8	AV1 +0.00	78	137	0.21	9	AV5 -0.22			0.13	7	AV5 +0.02
		0.26	11	AV2 +0.00	78	139	0.17	8	AV5 -0.16			0.15	7	AV6 +0.02
		0.24	10	AV7 +0.05			0.13	7	AV3 +0.00	79	86	0.20	9	AV2 +0.02
		0.23	10	AV8 -0.02	78	143	0.33	13	AV5 -0.22			0.59	19	AV5 +0.02
78	71	0.32	13	AV1 +0.02			0.17	8	AV3 -0.02			0.28	12	AV6 +0.07
		0.40	15	AV2 +0.00	78	145	0.21	10	AV5 -0.25			0.28	11	AV7 +0.02
		0.29	12	AV3 +0.00			0.27	11	AV2 -0.02	79	88	0.22	10	AV4 +0.03
		0.44	16	AV4 +0.00	78	147	0.15	7	AV4 +0.00			0.27	11	AV5 +0.00
		0.21	9	AV5 +0.02	78	149	0.16	8	AV8 +0.12	79	90	0.27	11	AV2 +0.02
		0.50	17	AV7 +0.02			0.30	12	AV7 -0.02			0.61	19	AV3 +0.00
78	73	0.19	9	AV2 -0.05	78	151	0.20	9	AV3 +0.00			0.27	11	AV4 +0.03
		0.58	19	AV4 +0.00			0.15	7	AV2 +0.02			0.41	15	AV5 +0.05
78	75	0.32	13	AV2 +0.00			0.20	9	AV1 -0.20			0.54	18	AV7 +0.05
		0.52	17	AV4 +0.03	78	153	0.25	11	AV8 +0.14	79	92	0.40	15	AV2 +0.00
78	77	0.53	17	AV3 +0.00			0.62	19	AV7 -0.02			0.59	19	AV7 +0.05
		0.47	16	AV7 +0.05			0.23	10	AV6 -0.07	79	94	0.41	15	AV2 +0.02
		0.35	14	AV2 +0.02			0.13	7	AV5 +0.00			0.33	13	AV8 +0.00
78	79	0.18	8	AV3 +0.05			0.17	8	AV3 +0.21	79	96	0.53	18	AV2 +0.00
		0.49	17	AV7 +0.00			0.13	7	AV2 +0.16			0.23	10	AV3 +0.00
78	81	0.17	8	AV3 +0.02			0.46	16	AV1 -0.23			0.22	10	AV7 +0.05
		0.14	7	AV5 +0.02	79	18	0.16	8	AV1 +0.21			0.20	9	AV8 +0.02
		0.18	8	AV6 +0.00			0.12	7	AV2 +0.22	79	102	0.20	9	AV2 +0.02
							0.16	8	AV3 +0.05			0.20	9	AV7 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
79	104	0.36	14	AV1 +0.00	80	73	0.35	13	AV3 +0.00			0.15	7	AV5 -0.03
		0.61	19	AV4 +0.06			0.63	19	AV7 -0.02			0.10	5	AV1 +0.16
		0.34	13	AV7 +0.05	80	75	0.15	7	AV3 +0.05	80	147	0.08	5	AV8 +0.19
		0.39	14	AV8 +0.02			0.18	9	AV2 +0.00	80	149	0.18	8	AV8 +0.12
79	106	0.24	10	AV2 +0.02	80	77	0.30	12	AV2 +0.02			0.15	7	AV4 +0.00
		0.54	18	AV7 +0.02			0.13	7	AV7 -0.05	81	18	0.11	6	AV1 -0.14
79	108	0.16	8	AV1 +0.00	80	79	0.37	14	AV4 +0.03			0.11	6	AV8 +0.18
		0.23	10	AV2 +0.02			0.44	16	AV6 +0.00	81	22	0.16	8	AV4 -0.02
		0.61	19	AV5 +0.00	80	81	0.21	9	AV3 +0.00	81	26	0.07	4	AV5 -0.16
		0.27	11	AV8 +0.05			0.22	10	AV4 +0.03	81	32	0.16	8	AV4 +0.16
79	110	0.56	18	AV2 +0.02			0.14	7	AV5 -0.03			0.13	7	AV7 +0.00
		0.09	5	AV4 +0.08			0.26	11	AV6 +0.02	81	34	0.14	7	AV3 +0.00
		0.14	7	AV5 +0.23			0.54	18	AV7 +0.00			0.12	6	AV4 +0.00
		0.41	15	AV6 +0.02			0.13	7	AV8 +0.05			0.11	6	AV5 +0.16
		0.32	13	AV7 +0.02	80	83	0.20	9	AV2 +0.00	81	36	0.28	12	AV4 +0.18
79	112	0.18	9	AV2 +0.00			0.46	16	AV3 +0.02			0.18	8	AV5 -0.21
		0.21	9	AV4 +0.03			0.63	19	AV4 +0.03	81	38	0.13	7	AV4 +0.05
		0.27	11	AV5 +0.00	80	85	0.37	14	AV5 +0.02	81	40	0.16	8	AV4 +0.21
		0.24	10	AV6 +0.05			0.48	17	AV7 +0.00	81	44	0.13	7	AV2 +0.05
79	114	0.30	12	AV3 +0.05			0.33	13	AV3 +0.05	81	46	0.13	7	AV2 -0.02
		0.34	13	AV6 +0.02			0.27	11	AV4 +0.03			0.21	10	AV4 +0.03
		0.25	11	AV7 +0.02	80	87	0.21	9	AV2 +0.02	81	50	0.22	10	AV4 +0.24
79	116	0.14	7	AV3 +0.02	80	91	0.16	8	AV2 +0.02	81	52	0.20	9	AV4 +0.21
		0.17	8	AV1 +0.02			0.38	14	AV4 -0.15	81	54	0.16	8	AV6 +0.00
		0.17	8	AV2 +0.05			0.44	16	AV5 +0.05	81	56	0.13	7	AV4 +0.16
		0.20	9	AV5 +0.19			0.10	6	AV7 +0.05	81	58	0.17	8	AV6 +0.00
79	118	0.12	6	AV2 +0.05	80	93	0.27	11	AV3 +0.00	81	60	0.17	8	AV7 +0.00
		0.35	13	AV5 +0.19			0.38	14	AV7 +0.02	81	64	0.26	11	AV3 +0.00
		0.56	18	AV6 -0.02	80	95	0.18	9	AV2 +0.00			0.16	8	AV5 +0.00
		0.34	13	AV7 +0.05			0.33	13	AV7 +0.02			0.38	14	AV6 +0.00
79	130	0.13	7	AV6 +0.05	80	99	0.54	18	AV2 +0.00	81	66	0.20	9	AV2 +0.00
79	132	0.14	7	AV2 +0.02			0.30	12	AV3 +0.00			0.27	11	AV3 +0.02
		0.22	10	AV7 -0.02			0.32	13	AV4 +0.00			0.26	11	AV4 +0.05
79	134	0.29	12	AV3 +0.04	80	101	0.58	18	AV7 -0.02			0.35	13	AV7 +0.00
		0.16	8	AV4 +0.06			0.28	12	AV8 +0.02	81	68	0.14	7	AV3 +0.02
		0.28	12	AV5 +0.07			0.26	11	AV1 +0.00			0.17	8	AV4 +0.03
		0.22	10	AV6 +0.02	80	105	0.49	17	AV2 -0.02	81	70	0.20	9	AV1 +0.00
		0.14	7	AV7 -0.05			0.22	10	AV3 +0.00			0.35	14	AV4 +0.03
79	138	0.20	9	AV5 -0.20			0.22	10	AV4 -0.17			0.61	19	AV7 +0.02
		0.16	8	AV2 -0.02			0.12	6	AV6 -0.12			0.18	8	AV8 +0.02
79	144	0.16	8	AV5 -0.19			0.35	13	AV7 +0.05	81	74	0.40	15	AV2 +0.00
79	146	0.19	9	AV8 -0.14	80	107	0.20	9	AV2 -0.02			0.25	11	AV3 +0.00
		0.19	9	AV3 -0.02			0.49	17	AV3 +0.00			0.42	15	AV5 +0.00
79	148	0.16	8	AV3 -0.05			0.39	14	AV4 +0.03			0.54	18	AV7 +0.02
79	150	0.16	8	AV3 +0.02			0.62	19	AV5 +0.02	81	76	0.12	6	AV1 +0.00
79	152	0.13	7	AV8 +0.19			0.42	15	AV7 +0.05			0.19	9	AV2 +0.02
80	19	0.17	8	AV1 -0.17	80	111	0.17	8	AV2 +0.07			0.53	17	AV3 +0.00
80	21	0.17	8	AV1 +0.02			0.37	14	AV3 +0.07			0.25	11	AV6 +0.02
		0.15	7	AV4 +0.11			0.18	8	AV7 +0.02			0.57	18	AV7 +0.02
80	25	0.16	8	AV6 -0.19	80	113	0.34	13	AV2 +0.02	81	80	0.12	6	AV3 +0.00
80	27	0.08	5	AV1 +0.00			0.29	12	AV3 +0.02			0.21	9	AV4 +0.00
		0.06	4	AV2 +0.05			0.50	17	AV4 +0.03			0.54	18	AV5 +0.02
		0.09	5	AV4 +0.21			0.45	16	AV5 +0.02	81	82	0.35	13	AV2 +0.02
80	29	0.15	8	AV4 +0.19			0.27	11	AV6 -0.05	81	84	0.21	9	AV3 +0.00
80	31	0.11	6	AV4 +0.21	80	115	0.23	10	AV1 +0.00			0.14	7	AV4 +0.06
80	33	0.14	7	AV4 +0.13			0.23	10	AV2 +0.05			0.18	9	AV5 +0.02
80	35	0.20	9	AV4 -0.14			0.43	15	AV3 +0.02			0.44	16	AV6 +0.05
		0.17	8	AV5 +0.19			0.24	10	AV8 +0.00			0.17	8	AV1 +0.02
80	41	0.18	8	AV3 +0.02	80	117	0.17	8	AV3 +0.00	81	86	0.13	7	AV2 -0.02
80	43	0.13	7	AV3 +0.00			0.28	12	AV4 +0.08			0.26	11	AV3 +0.05
80	45	0.24	10	AV4 +0.24			0.22	10	AV8 +0.02			0.15	7	AV5 -0.03
80	51	0.24	10	AV5 +0.00	80	121	0.17	8	AV5 +0.05			0.51	17	AV7 +0.02
80	59	0.15	8	AV5 +0.05	80	123	0.19	9	AV5 +0.05	81	88	0.16	8	AV2 +0.02
80	61	0.29	12	AV5 +0.00	80	125	0.14	7	AV2 +0.17	81	90	0.27	11	AV2 +0.00
		0.58	18	AV6 +0.02			0.14	7	AV3 +0.05			0.14	7	AV4 +0.00
		0.26	11	AV4 +0.03	80	133	0.22	10	AV2 +0.00			0.54	18	AV6 +0.05
80	67	0.15	7	AV3 +0.00			0.24	10	AV5 -0.03			0.29	12	AV7 +0.07
		0.37	14	AV4 +0.03	80	135	0.24	10	AV2 +0.02	81	92	0.50	17	AV2 +0.02
		0.48	16	AV7 +0.00			0.14	7	AV4 +0.00			0.31	12	AV4 +0.19
		0.33	13	AV8 +0.05	80	137	0.30	12	AV5 -0.24			0.35	14	AV7 +0.02
80	69	0.08	5	AV1 -0.05			0.27	11	AV3 -0.02	81	94	0.54	18	AV6 +0.02
		0.25	11	AV8 +0.02	80	145	0.12	6	AV6 +0.00			0.51	17	AV7 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.16	8	AV1 +0.00	82	45	0.19	9	AV4 +0.21			0.18	9	AV4 -0.02
		0.42	15	AV2 +0.02	82	53	0.16	8	AV6 +0.00	82	141	0.13	7	AV2 -0.19
81	96	0.17	8	AV2 -0.02	82	55	0.17	8	AV4 -0.14	82	143	0.16	8	AV3 +0.02
		0.41	15	AV3 +0.02	82	59	0.09	5	AV4 +0.03	82	149	0.15	8	AV3 -0.02
		0.30	12	AV7 +0.05			0.18	9	AV6 +0.02	83	20	0.16	8	AV1 -0.17
81	100	0.16	8	AV1 +0.00			0.33	13	AV7 +0.00			0.14	7	AV2 +0.05
		0.44	16	AV2 +0.02	82	65	0.20	9	AV6 +0.02	83	26	0.12	6	AV3 +0.05
81	102	0.18	9	AV1 +0.02	82	67	0.48	16	AV1 +0.02			0.13	7	AV5 -0.03
		0.28	12	AV2 +0.02	82	77	0.21	10	AV2 +0.00	83	36	0.20	9	AV4 +0.23
		0.61	19	AV3 +0.02			0.44	16	AV3 +0.02	83	38	0.15	7	AV5 +0.00
		0.60	19	AV5 +0.02			0.14	7	AV4 +0.00	83	40	0.10	6	AV5 +0.00
81	106	0.45	16	AV3 +0.05			0.53	18	AV8 +0.00	83	46	0.13	7	AV4 +0.23
		0.60	19	AV5 +0.00	82	79	0.60	19	AV2 +0.00	83	50	0.29	12	AV4 +0.16
		0.18	9	AV6 +0.02			0.10	6	AV8 +0.00	83	60	0.26	11	AV6 +0.02
		0.13	7	AV7 +0.18	82	81	0.17	8	AV2 +0.02			0.27	11	AV7 +0.00
		0.13	7	AV1 +0.00			0.49	17	AV3 +0.02	83	62	0.17	8	AV7 +0.02
		0.33	13	AV2 +0.02			0.48	16	AV4 +0.03			0.17	8	AV2 +0.00
81	108	0.40	15	AV2 +0.02	82	83	0.20	9	AV2 +0.00			0.19	9	AV5 +0.02
		0.47	16	AV4 +0.03			0.29	12	AV3 +0.05	83	64	0.31	12	AV4 +0.03
		0.48	16	AV6 +0.05	82	85	0.11	6	AV2 -0.02			0.23	10	AV8 +0.09
		0.17	8	AV7 +0.05			0.20	9	AV3 +0.02	83	66	0.17	8	AV4 +0.00
81	110	0.19	9	AV3 +0.00	82	87	0.27	11	AV3 +0.00			0.09	5	AV3 +0.02
		0.63	19	AV4 +0.00			0.43	15	AV5 +0.05	83	68	0.11	6	AV3 +0.00
		0.46	16	AV6 +0.02			0.23	10	AV6 +0.05			0.43	15	AV4 +0.03
		0.33	13	AV7 +0.02	82	91	0.14	7	AV2 +0.00	83	70	0.16	8	AV3 +0.02
81	112	0.14	7	AV2 -0.16			0.42	15	AV7 +0.00			0.16	8	AV5 +0.21
		0.33	13	AV3 +0.05	82	93	0.11	6	AV1 +0.05			0.23	10	AV1 +0.00
		0.11	6	AV4 +0.03			0.20	9	AV2 +0.00			0.54	18	AV6 +0.05
		0.18	9	AV6 +0.18			0.31	12	AV3 +0.02	83	72	0.26	11	AV2 +0.00
81	114	0.10	6	AV1 -0.02	82	95	0.21	9	AV1 +0.02			0.57	18	AV3 +0.02
		0.29	12	AV2 +0.02	82	97	0.15	7	AV1 +0.02			0.61	19	AV4 +0.03
		0.41	15	AV3 +0.00			0.60	19	AV2 +0.00			0.48	17	AV8 +0.02
		0.40	15	AV6 +0.00			0.21	9	AV3 +0.05	83	74	0.16	8	AV2 +0.00
81	116	0.36	14	AV2 +0.05	82	99	0.45	16	AV3 +0.02			0.57	18	AV3 +0.00
		0.36	14	AV4 +0.05			0.63	19	AV8 +0.00			0.62	19	AV4 +0.03
		0.52	17	AV5 +0.02	82	107	0.37	14	AV3 +0.02	83	78	0.12	6	AV2 +0.00
		0.63	19	AV6 -0.02			0.24	10	AV5 +0.05			0.64	19	AV3 +0.02
		0.23	10	AV7 +0.04			0.18	8	AV2 +0.02	83	80	0.21	9	AV3 +0.05
81	118	0.22	10	AV5 +0.05	82	109	0.37	14	AV7 +0.05			0.26	11	AV8 +0.00
81	122	0.15	7	AV3 +0.00			0.27	11	AV8 +0.05	83	82	0.31	12	AV3 +0.00
81	128	0.14	7	AV3 -0.02			0.21	10	AV1 -0.02			0.22	10	AV4 +0.03
		0.10	5	AV5 -0.14			0.33	13	AV2 +0.00			0.20	9	AV6 +0.02
81	130	0.13	7	AV5 -0.16			0.49	17	AV3 +0.02			0.37	14	AV7 +0.05
81	132	0.24	10	AV3 +0.05	82	111	0.28	12	AV4 +0.08	83	84	0.17	8	AV2 +0.00
		0.32	13	AV5 +0.00			0.17	8	AV5 +0.07			0.57	18	AV4 +0.03
		0.60	19	AV7 +0.02			0.55	18	AV6 +0.05			0.60	19	AV7 +0.02
81	134	0.17	8	AV2 +0.02			0.16	8	AV7 +0.05	83	86	0.35	14	AV3 +0.02
		0.21	9	AV3 +0.02			0.15	7	AV2 +0.05			0.16	8	AV4 +0.05
		0.16	8	AV4 +0.05	82	113	0.15	7	AV2 +0.05	83	88	0.16	8	AV2 +0.02
81	138	0.14	7	AV5 -0.19			0.19	9	AV3 +0.05			0.25	11	AV3 +0.00
		0.12	6	AV3 +0.00			0.11	6	AV5 +0.05	83	92	0.39	14	AV2 +0.02
81	140	0.08	5	AV8 -0.21			0.21	10	AV8 +0.05			0.28	12	AV8 +0.02
		0.12	6	AV4 +0.13	82	115	0.19	9	AV3 +0.02	83	96	0.34	13	AV2 +0.02
81	146	0.17	8	AV4 +0.00			0.20	9	AV4 +0.05	83	100	0.25	11	AV1 +0.00
		0.15	7	AV1 -0.21	82	117	0.25	11	AV3 +0.02			0.55	18	AV2 +0.02
81	148	0.19	9	AV8 +0.16			0.53	18	AV4 +0.05			0.38	14	AV3 +0.02
		0.30	12	AV7 +0.00			0.44	16	AV7 +0.02	83	106	0.27	11	AV2 +0.00
		0.13	7	AV5 -0.06	82	123	0.12	6	AV5 +0.19			0.26	11	AV3 +0.02
		0.13	7	AV3 -0.02			0.14	7	AV7 +0.05	83	108	0.11	6	AV7 +0.02
		0.16	8	AV1 -0.18	82	127	0.15	7	AV2 +0.00	83	110	0.23	10	AV3 +0.05
81	150	0.15	7	AV1 -0.21			0.16	8	AV3 +0.02			0.50	17	AV6 +0.02
81	152	0.13	7	AV1 -0.20			0.11	6	AV4 -0.02			0.30	12	AV7 +0.05
82	19	0.12	6	AV1 -0.17			0.09	5	AV5 +0.00	83	112	0.26	11	AV2 +0.05
82	25	0.10	6	AV3 -0.02	82	131	0.25	11	AV2 +0.02			0.53	18	AV3 +0.02
82	27	0.11	6	AV4 +0.13	82	133	0.24	11	AV3 +0.00			0.26	11	AV6 +0.07
		0.12	6	AV5 +0.00			0.23	10	AV4 +0.08			0.52	17	AV5 +0.02
82	35	0.11	6	AV4 -0.19			0.46	16	AV5 +0.02	83	114	0.14	7	AV1 +0.02
		0.23	10	AV5 +0.19			0.13	7	AV6 +0.00			0.27	11	AV2 +0.02
		0.25	11	AV6 +0.00	82	135	0.16	8	AV2 +0.05			0.25	11	AV4 +0.05
		0.15	7	AV7 -0.02	82	137	0.12	6	AV5 -0.19	83	116	0.24	11	AV2 +0.05
		0.12	6	AV3 +0.02			0.17	8	AV3 +0.02			0.16	8	AV5 -0.14
82	41	0.11	6	AV3 +0.02	82	139	0.15	7	AV5 -0.22			0.30	12	AV7 +0.05

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
83	122	0.12	6	AV6 +0.05										
83	124	0.13	7	AV4 +0.08	84	109	0.39	15	AV1 +0.00	85	112	0.15	7	AV1 +0.05
		0.10	6	AV5 +0.00			0.51	17	AV4 +0.00			0.37	14	AV2 +0.05
83	132	0.20	9	AV2 +0.02			0.47	16	AV5 +0.05			0.22	10	AV3 +0.05
		0.25	11	AV5 +0.02			0.37	14	AV7 +0.02			0.36	14	AV4 +0.05
		0.19	9	AV8 +0.05	84	111	0.44	16	AV2 +0.05			0.18	8	AV5 +0.05
83	134	0.15	7	AV3 +0.09			0.48	17	AV3 +0.07	85	114	0.27	11	AV3 +0.00
		0.18	9	AV4 +0.00			0.13	7	AV4 +0.05			0.14	7	AV4 +0.00
		0.17	8	AV6 -0.05			0.42	15	AV5 +0.02			0.22	10	AV5 -0.03
83	136	0.15	7	AV5 -0.16			0.47	16	AV6 +0.02			0.29	12	AV6 +0.02
83	138	0.15	8	AV7 -0.05	84	113	0.53	18	AV6 -0.02	85	116	0.14	7	AV1 +0.02
		0.18	9	AV6 -0.05			0.30	12	AV2 +0.02			0.23	10	AV3 +0.05
		0.16	8	AV4 -0.02			0.20	9	AV1 +0.02			0.37	14	AV4 +0.08
		0.13	7	AV3 +0.00	84	115	0.59	19	AV3 +0.02			0.46	16	AV5 +0.05
		0.15	7	AV2 -0.05			0.32	13	AV7 +0.02			0.38	14	AV6 +0.02
83	140	0.30	12	AV8 +0.02	84	117	0.12	6	AV8 +0.00	85	118	0.10	6	AV4 +0.18
		0.47	16	AV6 +0.00			0.57	18	AV7 +0.02			0.46	16	AV6 +0.00
		0.16	8	AV5 +0.00			0.17	8	AV1 +0.00			0.54	18	AV7 +0.05
		0.18	9	AV4 -0.02			0.39	14	AV2 +0.02			0.21	9	AV8 +0.02
		0.23	10	AV3 -0.02			0.48	16	AV3 +0.02	85	122	0.15	7	AV3 +0.02
		0.12	6	AV2 +0.00	84	121	0.10	6	AV4 -0.02	85	124	0.16	8	AV4 +0.05
83	142	0.45	16	AV7 +0.00			0.17	8	AV6 -0.02	85	128	0.13	7	AV1 +0.02
83	146	0.20	9	AV8 -0.19	84	123	0.09	5	AV5 +0.17	85	130	0.25	11	AV6 +0.00
		0.17	8	AV3 +0.02	84	125	0.18	8	AV2 +0.00	85	132	0.17	8	AV3 +0.02
83	148	0.11	6	AV8 +0.17	84	131	0.32	13	AV2 +0.05	85	134	0.16	8	AV4 +0.00
83	150	0.25	11	AV1 -0.18	84	133	0.23	10	AV3 +0.02			0.26	11	AV5 +0.02
84	35	0.15	8	AV3 +0.00	84	137	0.27	11	AV5 -0.24			0.27	11	AV6 +0.00
		0.10	6	AV4 +0.18	84	139	0.16	8	AV8 -0.19			0.14	7	AV8 +0.12
		0.17	8	AV5 +0.02	84	141	0.13	7	AV2 -0.02	85	138	0.16	8	AV3 +0.00
84	45	0.24	10	AV4 +0.21			0.14	7	AV1 -0.05			0.14	7	AV2 +0.02
84	47	0.12	6	AV4 +0.21	84	143	0.12	6	AV3 +0.02	85	142	0.09	5	AV8 +0.21
84	51	0.18	8	AV4 +0.03	84	145	0.17	8	AV7 -0.02	86	23	0.07	4	AV1 -0.17
84	59	0.21	9	AV6 +0.02			0.15	7	AV3 +0.00	86	41	0.19	9	AV3 +0.00
84	61	0.36	14	AV6 +0.05	84	147	0.17	8	AV7 -0.05	86	43	0.20	9	AV4 +0.05
		0.21	9	AV8 +0.02	85	22	0.16	8	AV2 +0.00	86	45	0.19	9	AV4 +0.21
84	63	0.37	14	AV2 +0.00			0.15	8	AV3 +0.02			0.17	8	AV5 -0.13
		0.18	8	AV3 +0.05			0.16	8	AV6 +0.00	86	51	0.12	6	AV4 +0.03
		0.35	13	AV5 -0.03	85	36	0.16	8	AV4 +0.21	86	53	0.17	8	AV2 -0.02
		0.37	14	AV6 +0.00	85	40	0.14	7	AV4 +0.13	86	55	0.11	6	AV1 +0.00
		0.20	9	AV7 +0.02	85	48	0.13	7	AV4 +0.05	86	57	0.19	9	AV6 +0.00
84	65	0.14	7	AV5 +0.05	85	50	0.12	6	AV4 +0.26	86	59	0.13	7	AV3 +0.00
84	67	0.15	8	AV8 +0.12	85	56	0.22	10	AV4 +0.18			0.17	8	AV4 +0.00
		0.12	6	AV7 +0.02			0.10	6	AV5 +0.05	86	63	0.17	8	AV1 +0.02
		0.39	14	AV3 +0.02			0.18	9	AV7 +0.00			0.14	7	AV6 +0.00
84	69	0.15	7	AV1 +0.18	85	60	0.14	7	AV4 +0.05			0.18	8	AV7 +0.02
		0.21	9	AV2 +0.05			0.32	13	AV6 +0.00	86	65	0.18	8	AV1 +0.00
		0.35	13	AV3 +0.05			0.32	13	AV7 +0.00			0.12	6	AV2 +0.05
		0.57	18	AV8 +0.02	85	66	0.15	7	AV3 +0.03			0.20	9	AV4 +0.03
84	71	0.13	7	AV2 -0.02	85	68	0.57	18	AV3 +0.00			0.17	8	AV5 +0.05
84	73	0.34	13	AV2 +0.02			0.31	12	AV4 +0.06			0.27	11	AV6 +0.02
		0.30	12	AV8 +0.00	85	70	0.12	6	AV2 +0.02	86	69	0.25	11	AV3 +0.00
84	75	0.10	6	AV1 +0.00	85	78	0.08	5	AV8 +0.02	86	75	0.24	10	AV1 +0.05
		0.57	18	AV2 +0.02			0.24	11	AV2 +0.02			0.58	19	AV6 +0.05
		0.48	17	AV6 +0.02			0.54	18	AV3 +0.02			0.52	17	AV7 +0.05
84	79	0.27	11	AV2 +0.00	85	80	0.33	13	AV3 +0.05	86	79	0.31	12	AV2 +0.00
		0.43	15	AV7 +0.00	85	82	0.55	18	AV3 +0.02			0.15	7	AV4 +0.03
84	81	0.19	9	AV3 +0.02	85	88	0.21	10	AV2 +0.02			0.37	14	AV5 +0.02
		0.38	14	AV7 +0.00			0.16	8	AV3 +0.02			0.41	15	AV6 +0.07
84	83	0.12	6	AV1 +0.02			0.13	7	AV6 +0.00	86	83	0.36	14	AV2 +0.00
		0.37	14	AV2 +0.02			0.42	15	AV7 +0.02			0.45	16	AV3 -0.02
		0.17	8	AV4 +0.00	85	90	0.25	11	AV2 +0.05			0.52	17	AV7 +0.02
		0.53	18	AV7 +0.02			0.26	11	AV4 +0.05	86	87	0.21	9	AV2 +0.00
84	87	0.40	15	AV2 +0.00	85	92	0.19	9	AV2 +0.02			0.27	11	AV7 +0.02
84	89	0.14	7	AV1 +0.00			0.58	19	AV8 +0.00	86	89	0.43	15	AV2 +0.00
		0.47	16	AV2 -0.05	85	94	0.17	8	AV1 +0.02	86	91	0.37	14	AV3 +0.02
84	91	0.12	6	AV2 -0.02			0.31	12	AV2 +0.02			0.47	16	AV7 +0.02
		0.21	9	AV3 +0.00			0.26	11	AV8 +0.05			0.16	8	AV8 +0.05
		0.21	9	AV7 +0.00	85	100	0.48	16	AV7 +0.00	86	97	0.31	12	AV2 +0.00
84	95	0.18	9	AV1 +0.02	85	106	0.14	7	AV1 +0.02			0.52	17	AV4 +0.05
		0.61	19	AV3 +0.05			0.50	17	AV5 +0.00	86	99	0.24	11	AV2 +0.02
		0.27	11	AV7 +0.07			0.26	11	AV7 +0.02			0.34	13	AV3 +0.05
84	107	0.44	16	AV5 +0.02	85	108	0.15	8	AV1 +0.00			0.28	11	AV4 +0.06

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.19	9	AV7 +0.05			0.12	6	AV1 +0.05			0.29	12	AV3 +0.00
		0.16	8	AV8 +0.07			0.15	7	AV2 +0.02	88	67	0.10	6	AV2 +0.02
86	101	0.32	13	AV2 +0.05			0.17	8	AV3 -0.02			0.17	8	AV3 +0.00
86	105	0.10	6	AV6 +0.05			0.52	17	AV5 +0.02			0.22	10	AV5 +0.00
		0.46	16	AV4 +0.05			0.17	8	AV6 +0.02			0.11	6	AV6 +0.05
86	107	0.15	8	AV1 +0.00			0.53	18	AV7 +0.02			0.27	11	AV7 +0.07
		0.33	13	AV2 +0.02			0.12	6	AV8 +0.02	88	69	0.25	11	AV3 +0.00
		0.32	13	AV4 +0.08	87	78	0.17	8	AV2 +0.00			0.07	4	AV4 -0.19
		0.21	10	AV5 +0.05			0.33	13	AV3 -0.02			0.36	14	AV5 +0.00
		0.22	10	AV6 +0.02			0.39	14	AV4 +0.00	88	71	0.17	8	AV1 +0.00
		0.23	10	AV7 +0.07			0.31	12	AV5 +0.00			0.42	15	AV2 +0.05
86	109	0.61	19	AV3 +0.02			0.28	11	AV7 +0.02			0.48	17	AV3 +0.05
		0.51	17	AV4 +0.03	87	80	0.33	13	AV2 +0.05			0.17	8	AV8 +0.02
86	111	0.23	10	AV3 +0.02			0.35	14	AV7 +0.00	88	73	0.30	12	AV1 +0.00
		0.13	7	AV4 +0.05	87	82	0.17	8	AV2 +0.05			0.49	17	AV5 +0.00
		0.13	7	AV6 +0.02	87	84	0.25	11	AV2 +0.00			0.10	6	AV7 -0.02
86	113	0.09	5	AV1 +0.00			0.58	19	AV3 +0.02	88	75	0.20	9	AV3 +0.02
		0.58	18	AV3 +0.02	87	86	0.54	18	AV7 +0.00			0.23	10	AV4 +0.00
		0.30	12	AV4 +0.03	87	88	0.21	9	AV2 +0.02			0.61	19	AV5 +0.02
		0.12	6	AV8 +0.07			0.18	9	AV3 +0.02	88	79	0.07	4	AV2 -0.14
86	115	0.10	6	AV2 +0.02			0.26	11	AV6 +0.00			0.09	5	AV3 +0.00
		0.23	10	AV3 +0.02			0.17	8	AV7 +0.02			0.17	8	AV4 +0.03
		0.13	7	AV4 +0.03	87	90	0.21	9	AV2 +0.02			0.42	15	AV7 +0.02
		0.25	11	AV5 +0.02			0.27	11	AV8 +0.05			0.12	6	AV8 +0.00
86	117	0.20	9	AV3 +0.00	87	100	0.20	9	AV1 +0.02	88	81	0.13	7	AV2 +0.07
		0.42	15	AV4 -0.02			0.25	11	AV7 +0.02	88	83	0.40	15	AV2 +0.00
		0.23	10	AV5 +0.00	87	106	0.13	7	AV1 +0.00			0.26	11	AV4 +0.08
		0.11	6	AV6 -0.02			0.42	15	AV5 +0.07			0.50	17	AV5 +0.05
		0.22	10	AV7 +0.05			0.14	7	AV7 +0.09			0.21	9	AV6 +0.05
86	121	0.22	10	AV4 +0.08	87	108	0.19	9	AV1 +0.00			0.22	10	AV8 +0.02
86	125	0.17	8	AV2 +0.00			0.57	18	AV2 +0.02	88	85	0.18	8	AV3 +0.00
86	129	0.12	6	AV5 -0.13			0.41	15	AV5 +0.05			0.58	19	AV4 +0.00
86	135	0.18	9	AV5 -0.03			0.11	6	AV6 +0.05	88	87	0.19	9	AV2 +0.02
		0.15	7	AV3 +0.00	87	110	0.18	9	AV1 +0.02			0.32	13	AV5 +0.07
		0.49	17	AV2 +0.00			0.34	13	AV2 +0.00			0.26	11	AV7 +0.05
86	139	0.15	7	AV4 -0.02			0.20	9	AV4 +0.03	88	89	0.26	11	AV3 +0.02
86	147	0.22	10	AV7 -0.02			0.54	18	AV5 +0.02	88	91	0.10	6	AV1 +0.00
		0.12	6	AV3 +0.00	87	112	0.35	13	AV2 +0.05			0.44	16	AV2 +0.02
87	26	0.09	5	AV1 +0.19			0.15	7	AV3 +0.05			0.09	5	AV8 -0.14
87	36	0.17	8	AV4 +0.20			0.13	7	AV6 +0.05	88	93	0.22	10	AV3 +0.02
87	42	0.16	8	AV4 +0.00			0.22	10	AV7 +0.02			0.49	17	AV4 +0.03
87	44	0.19	9	AV3 +0.02	87	114	0.13	7	AV1 +0.05			0.25	11	AV7 +0.02
87	46	0.15	8	AV3 +0.02			0.18	8	AV2 +0.02	88	95	0.37	14	AV2 +0.05
		0.25	11	AV4 +0.03			0.15	7	AV4 +0.00			0.28	12	AV6 +0.02
87	52	0.17	8	AV3 +0.02			0.18	8	AV5 +0.02			0.33	13	AV7 +0.00
		0.15	8	AV4 +0.05	87	116	0.11	6	AV7 +0.13	88	97	0.17	8	AV2 -0.02
		0.20	9	AV7 +0.02			0.12	6	AV2 +0.02			0.21	9	AV3 +0.02
87	54	0.11	6	AV3 +0.05			0.18	9	AV5 -0.13	88	99	0.39	14	AV2 +0.05
		0.08	5	AV4 +0.08			0.15	8	AV6 -0.02			0.31	12	AV5 +0.09
		0.10	6	AV5 +0.05	87	118	0.16	8	AV2 +0.00			0.31	12	AV7 +0.02
87	60	0.14	7	AV4 +0.18	87	120	0.14	7	AV3 -0.02	88	101	0.22	10	AV1 +0.02
87	62	0.16	8	AV7 +0.00			0.11	6	AV4 +0.21			0.50	17	AV2 +0.02
87	64	0.23	10	AV3 +0.02	87	122	0.27	11	AV6 +0.02	88	107	0.20	9	AV2 +0.02
		0.24	10	AV4 +0.03	87	126	0.24	10	AV3 +0.02			0.45	16	AV4 +0.08
		0.26	11	AV5 +0.00	87	130	0.28	11	AV5 +0.00			0.21	10	AV5 +0.05
87	66	0.22	10	AV4 +0.05	87	132	0.29	12	AV5 +0.02			0.25	11	AV6 +0.07
		0.18	8	AV6 +0.07	87	148	0.17	8	AV8 +0.22	88	109	0.31	12	AV2 +0.03
87	68	0.16	8	AV8 +0.00			0.15	8	AV6 +0.00			0.42	15	AV5 +0.02
		0.29	12	AV6 +0.05			0.14	7	AV1 -0.18			0.15	7	AV7 +0.02
		0.16	8	AV7 +0.02	88	25	0.12	6	AV1 +0.05	88	111	0.11	6	AV4 +0.00
		0.35	14	AV5 +0.05	88	33	0.07	4	AV5 -0.21			0.22	10	AV5 +0.00
87	70	0.19	9	AV3 +0.02	88	35	0.12	6	AV4 +0.23	88	113	0.22	10	AV1 +0.00
		0.18	9	AV8 +0.02	88	37	0.14	7	AV6 +0.00			0.18	8	AV3 +0.02
87	72	0.15	8	AV1 -0.02	88	39	0.10	6	AV5 -0.03			0.13	7	AV4 +0.05
		0.16	8	AV2 +0.02	88	45	0.14	7	AV5 -0.18	88	115	0.22	10	AV5 -0.16
		0.29	12	AV3 +0.05	88	55	0.17	8	AV4 +0.03	88	117	0.16	8	AV2 +0.02
		0.28	12	AV8 +0.05	88	61	0.42	15	AV6 +0.02			0.09	5	AV5 +0.21
87	74	0.17	8	AV2 +0.02			0.40	15	AV7 +0.02			0.11	6	AV6 +0.05
		0.62	19	AV3 +0.02	88	63	0.21	9	AV2 -0.02			0.32	13	AV3 +0.05
		0.62	19	AV4 +0.00			0.21	9	AV6 +0.02			0.26	11	AV4 +0.00
		0.56	18	AV6 +0.05			0.45	16	AV7 +0.02	88	121	0.27	11	AV3 +0.00
		0.61	19	AV7 +0.00	88	65	0.16	8	AV2 +0.02	88	123	0.29	12	AV4 +0.08

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
88	129	0.27	11	AV2 +0.05						90	139	0.14	7	AV8 +0.01
88	137	0.14	7	AV7 +0.00	89	118	0.17	8	AV5 +0.02			0.13	7	AV2 -0.02
		0.18	9	AV3 +0.00			0.25	11	AV6 +0.00	91	56	0.13	7	AV7 -0.02
		0.18	9	AV2 +0.02	89	120	0.18	9	AV5 +0.00			0.11	6	AV5 +0.07
		0.15	8	AV1 -0.05	89	148	0.12	6	AV1 -0.21	91	58	0.15	7	AV2 -0.05
88	147	0.17	8	AV8 +0.20	90	37	0.10	5	AV2 +0.05	91	62	0.19	9	AV5 +0.00
		0.23	10	AV7 -0.05			0.20	9	AV6 +0.00			0.38	14	AV6 +0.00
		0.13	7	AV3 +0.18	90	41	0.19	9	AV4 +0.08	91	64	0.62	19	AV7 -0.05
89	26	0.08	5	AV2 -0.02	90	43	0.15	7	AV2 +0.00			0.61	19	AV6 -0.02
		0.14	7	AV6 +0.00			0.13	7	AV5 +0.00			0.51	17	AV4 +0.03
		0.17	8	AV7 +0.00	90	51	0.17	8	AV5 +0.02			0.16	8	AV2 -0.02
89	40	0.09	5	AV5 +0.00	90	53	0.12	6	AV3 +0.02	91	66	0.32	13	AV6 +0.05
89	46	0.14	7	AV2 +0.00			0.10	6	AV4 -0.02			0.16	8	AV4 +0.00
		0.09	5	AV3 +0.00	90	55	0.13	7	AV4 +0.05	91	68	0.13	7	AV4 +0.05
89	48	0.13	7	AV4 +0.03	90	57	0.29	12	AV5 +0.05			0.18	9	AV3 +0.02
89	50	0.14	7	AV4 +0.10	90	59	0.15	8	AV3 +0.02			0.25	11	AV2 +0.00
		0.17	8	AV5 -0.15	90	61	0.16	8	AV4 +0.05	91	70	0.27	11	AV7 -0.02
89	54	0.17	8	AV4 +0.03	90	63	0.28	12	AV3 +0.00			0.19	9	AV3 -0.02
89	62	0.14	7	AV3 +0.00			0.20	9	AV6 +0.00			0.16	8	AV1 +0.00
89	66	0.11	6	AV4 +0.03	90	65	0.13	7	AV1 +0.00	91	72	0.45	16	AV4 +0.00
		0.11	6	AV7 +0.00			0.36	14	AV2 +0.02			0.43	15	AV2 +0.00
89	68	0.41	15	AV4 +0.05			0.35	14	AV3 +0.00	91	80	0.13	7	AV8 +0.00
		0.44	16	AV6 +0.07	90	67	0.27	11	AV6 -0.02			0.50	17	AV3 +0.00
		0.62	19	AV7 +0.02	90	75	0.20	9	AV1 +0.00	91	82	0.58	18	AV3 -0.02
89	70	0.11	6	AV4 +0.26			0.37	14	AV2 +0.02			0.18	9	AV2 +0.02
		0.08	5	AV5 +0.17			0.46	16	AV3 +0.05	91	90	0.54	18	AV3 -0.02
		0.16	8	AV6 -0.02			0.51	17	AV4 +0.03			0.12	6	AV2 -0.02
		0.12	6	AV3 -0.02			0.61	19	AV5 +0.02	91	92	0.59	19	AV2 +0.00
89	72	0.41	15	AV2 +0.02			0.58	19	AV8 +0.05	91	96	0.15	8	AV8 +0.00
89	74	0.13	7	AV2 +0.02	90	79	0.28	12	AV3 +0.02			0.23	10	AV1 +0.00
89	78	0.12	6	AV6 +0.18			0.37	14	AV4 +0.03	91	98	0.61	19	AV2 +0.05
		0.23	10	AV7 +0.05			0.62	19	AV6 +0.02	91	100	0.52	17	AV2 -0.02
		0.09	5	AV2 +0.02	90	83	0.18	9	AV2 +0.00			0.15	7	AV1 +0.00
		0.24	10	AV3 +0.02			0.47	16	AV4 +0.03			0.38	14	AV5 +0.05
89	80	0.10	6	AV2 +0.00			0.63	19	AV6 +0.02			0.44	16	AV4 +0.03
		0.20	9	AV3 +0.00	90	85	0.15	8	AV2 -0.02	91	106	0.11	6	AV7 +0.02
		0.20	9	AV4 +0.00			0.32	13	AV3 +0.03			0.41	15	AV5 +0.00
		0.50	17	AV6 +0.05			0.12	6	AV8 +0.00			0.49	17	AV2 -0.02
89	82	0.40	15	AV2 +0.00	90	87	0.25	11	AV2 +0.02	91	108	0.50	17	AV2 +0.00
		0.52	17	AV3 +0.02	90	91	0.30	12	AV2 +0.00			0.07	4	AV1 +0.13
		0.58	19	AV8 +0.00	90	99	0.29	12	AV1 +0.02	91	110	0.56	18	AV3 +0.02
89	84	0.37	14	AV3 +0.02			0.38	14	AV6 +0.02			0.25	11	AV2 -0.02
		0.20	9	AV4 +0.05			0.45	16	AV7 +0.00	91	112	0.12	6	AV6 +0.21
		0.19	9	AV2 -0.05	90	103	0.60	19	AV2 +0.02			0.11	6	AV5 +0.00
		0.16	8	AV8 +0.02	90	105	0.59	19	AV8 +0.05			0.37	14	AV3 +0.05
89	92	0.46	16	AV2 +0.00			0.47	16	AV3 +0.05	91	114	0.19	9	AV7 +0.00
		0.32	13	AV7 +0.05	90	107	0.16	8	AV2 +0.07			0.13	7	AV5 -0.05
		0.32	13	AV5 +0.02			0.24	10	AV3 +0.05			0.13	7	AV2 -0.05
89	96	0.26	11	AV2 +0.05			0.18	8	AV4 +0.10	91	116	0.17	8	AV7 +0.00
		0.29	12	AV4 +0.05			0.36	14	AV5 +0.05			0.36	14	AV3 +0.00
		0.19	9	AV5 +0.05			0.32	13	AV6 +0.02	91	118	0.10	6	AV6 -0.05
		0.60	19	AV6 +0.05			0.62	19	AV7 +0.07			0.13	7	AV2 +0.00
89	102	0.41	15	AV1 +0.02	90	109	0.14	7	AV3 +0.00	92	45	0.14	7	AV5 -0.03
		0.30	12	AV5 +0.16			0.13	7	AV6 +0.07	92	47	0.14	7	AV4 -0.02
89	106	0.14	7	AV3 -0.02			0.22	10	AV7 +0.02			0.14	7	AV2 -0.02
		0.40	15	AV6 +0.05	90	111	0.16	8	AV4 +0.00	92	49	0.16	8	AV4 +0.00
		0.26	11	AV7 +0.09			0.12	6	AV6 +0.02	92	51	0.16	8	AV5 +0.02
89	108	0.18	9	AV1 +0.00			0.24	10	AV7 +0.05			0.14	7	AV2 +0.05
		0.32	13	AV2 +0.02	90	113	0.21	10	AV3 +0.02	92	53	0.13	7	AV4 +0.03
		0.22	10	AV3 +0.02			0.30	12	AV6 -0.07	92	55	0.25	11	AV4 +0.00
		0.24	10	AV5 +0.05			0.15	7	AV1 +0.00	92	59	0.15	7	AV7 -0.03
		0.36	14	AV6 +0.05	90	115	0.15	7	AV5 +0.07			0.13	7	AV4 -0.05
		0.22	10	AV8 +0.02			0.15	8	AV6 +0.02			0.15	7	AV3 -0.02
89	110	0.24	11	AV6 -0.02			0.14	7	AV2 +0.00	92	61	0.09	5	AV5 -0.03
		0.41	15	AV7 +0.05	90	117	0.13	7	AV4 +0.00	92	65	0.25	11	AV8 +0.02
		0.14	7	AV8 +0.02			0.20	9	AV6 +0.00	92	67	0.34	13	AV7 -0.02
89	112	0.34	13	AV2 +0.02	90	121	0.20	9	AV3 +0.07			0.28	11	AV6 +0.02
		0.27	11	AV7 +0.02	90	125	0.18	9	AV2 +0.02			0.27	11	AV5 +0.02
89	114	0.21	10	AV4 +0.00			0.13	7	AV3 +0.05			0.32	13	AV4 +0.03
		0.15	7	AV5 -0.16	90	129	0.15	7	AV2 +0.05	92	69	0.15	7	AV7 +0.02
89	116	0.13	7	AV2 +0.05	90	131	0.15	8	AV3 +0.02			0.22	10	AV5 -0.03
		0.16	8	AV4 +0.03	90	133	0.17	8	AV3 +0.00			0.14	7	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
92	79	0.42	15	AV8 -0.02			0.29	12	AV2 -0.02			0.27	11	AV6 +0.00
		0.19	9	AV4 -0.05	93	88	0.31	12	AV8 +0.00			0.36	14	AV5 +0.00
		0.26	11	AV2 +0.02			0.57	18	AV4 -0.02			0.50	17	AV4 +0.00
92	85	0.14	7	AV8 -0.02			0.29	12	AV3 -0.02	94	71	0.22	10	AV8 -0.02
		0.38	14	AV2 -0.07			0.27	11	AV2 +0.00			0.47	16	AV3 +0.00
92	87	0.53	18	AV7 +0.00			0.22	10	AV1 -0.02			0.13	7	AV2 -0.02
		0.18	8	AV2 -0.05	93	98	0.17	8	AV4 +0.03	94	77	0.46	16	AV8 +0.00
92	89	0.44	16	AV3 -0.05			0.23	10	AV3 +0.02			0.50	17	AV3 -0.02
92	99	0.35	13	AV8 +0.00			0.31	12	AV2 +0.00			0.22	10	AV2 -0.02
		0.44	16	AV2 -0.02			0.24	10	AV5 -0.19	94	79	0.26	11	AV7 -0.05
92	101	0.18	8	AV7 -0.02	93	100	0.25	11	AV5 +0.00			0.59	19	AV5 -0.03
92	103	0.17	8	AV2 +0.00			0.23	10	AV3 +0.05			0.13	7	AV4 -0.02
		0.35	13	AV8 +0.02			0.11	6	AV2 +0.00			0.24	10	AV3 +0.00
		0.19	9	AV7 +0.05	93	102	0.44	16	AV7 -0.02			0.53	17	AV2 +0.00
92	105	0.50	17	AV3 -0.02			0.48	17	AV2 -0.04	94	81	0.17	8	AV8 +0.00
		0.12	6	AV1 -0.02			0.28	12	AV1 -0.02			0.11	6	AV4 -0.02
		0.37	14	AV7 +0.05	93	104	0.30	12	AV1 -0.05			0.20	9	AV3 +0.00
		0.23	10	AV8 +0.05			0.37	14	AV2 +0.00	94	95	0.54	18	AV8 +0.00
92	107	0.20	9	AV7 +0.02			0.24	11	AV8 +0.02			0.29	12	AV5 +0.02
		0.13	7	AV5 +0.00	93	106	0.32	13	AV5 +0.00			0.50	17	AV2 +0.00
		0.36	14	AV4 +0.00			0.37	14	AV2 -0.02	94	97	0.25	11	AV7 +0.00
92	109	0.43	15	AV7 +0.00	93	108	0.33	13	AV7 +0.00			0.46	16	AV5 +0.02
		0.22	10	AV4 -0.02			0.51	17	AV5 +0.00			0.20	9	AV3 +0.00
		0.16	8	AV3 +0.00			0.30	12	AV3 +0.00	94	107	0.15	8	AV5 +0.00
92	111	0.27	11	AV6 -0.03			0.22	10	AV2 -0.02			0.32	13	AV4 +0.00
		0.33	13	AV5 +0.00	93	110	0.42	15	AV6 +0.00			0.25	11	AV3 +0.00
		0.27	11	AV4 +0.03			0.16	8	AV3 +0.02	94	109	0.17	8	AV7 +0.00
		0.22	10	AV3 +0.00	93	112	0.29	12	AV3 -0.02			0.27	11	AV4 +0.00
92	113	0.11	6	AV4 +0.03			0.59	19	AV5 -0.03	94	111	0.58	19	AV6 -0.05
		0.14	7	AV3 +0.02			0.29	12	AV4 +0.00			0.25	11	AV5 -0.03
92	115	0.25	11	AV5 -0.03	93	114	0.19	9	AV7 +0.02			0.14	7	AV3 +0.02
		0.17	8	AV3 -0.02			0.44	16	AV6 +0.00	94	113	0.16	8	AV6 -0.07
92	117	0.35	14	AV7 +0.00			0.11	6	AV5 -0.19			0.11	6	AV3 +0.02
		0.22	10	AV6 -0.05			0.42	15	AV4 +0.03	94	115	0.10	6	AV5 +0.00
		0.21	9	AV4 -0.02	93	116	0.10	6	AV7 +0.02			0.17	8	AV4 +0.00
		0.11	6	AV3 +0.00			0.19	9	AV5 +0.00			0.14	7	AV3 -0.02
92	119	0.16	8	AV4 +0.00			0.25	11	AV4 +0.05	94	117	0.13	7	AV5 -0.21
92	121	0.11	6	AV3 +0.02			0.09	5	AV3 +0.02	94	121	0.08	5	AV6 -0.02
92	123	0.11	6	AV5 +0.05			0.10	6	AV2 -0.02			0.10	6	AV5 -0.05
92	125	0.09	5	AV4 +0.08	93	118	0.11	6	AV3 +0.02	94	139	0.17	8	AV8 -0.16
92	131	0.15	7	AV3 -0.02			0.13	7	AV2 -0.05	95	48	0.10	6	AV5 -0.03
92	135	0.11	6	AV5 -0.03	93	122	0.10	5	AV5 +0.12	95	50	0.11	6	AV4 +0.13
92	137	0.16	8	AV4 +0.00	93	124	0.13	7	AV3 +0.02	95	52	0.18	9	AV5 +0.00
93	42	0.13	7	AV2 +0.00	93	126	0.15	8	AV4 +0.03	95	54	0.16	8	AV4 +0.03
		0.10	6	AV5 -0.03	93	128	0.15	7	AV5 +0.00			0.09	5	AV3 -0.02
93	44	0.14	7	AV5 -0.03			0.14	7	AV2 -0.02			0.10	6	AV2 -0.02
93	48	0.16	8	AV5 -0.05	93	132	0.17	8	AV3 +0.02	95	60	0.12	6	AV3 +0.00
93	50	0.15	7	AV5 -0.03	94	37	0.16	8	AV5 -0.03	95	62	0.19	9	AV3 +0.00
		0.13	7	AV2 -0.02	94	53	0.18	9	AV4 +0.03			0.13	7	AV2 +0.02
93	52	0.11	6	AV4 -0.02			0.13	7	AV2 -0.07	95	64	0.38	14	AV7 -0.02
93	56	0.15	8	AV4 +0.18	94	55	0.38	14	AV7 -0.07			0.55	18	AV6 +0.00
93	60	0.13	7	AV3 -0.02			0.36	14	AV6 -0.02			0.58	18	AV5 +0.00
93	62	0.24	10	AV5 -0.03			0.20	9	AV4 +0.00			0.24	10	AV4 -0.02
		0.13	7	AV3 -0.02	94	57	0.17	8	AV8 +0.00			0.18	8	AV3 +0.00
93	64	0.17	8	AV7 +0.00			0.14	7	AV5 -0.03	95	66	0.33	13	AV7 +0.02
		0.40	15	AV6 -0.02	94	59	0.20	9	AV4 +0.03			0.21	9	AV6 +0.05
93	68	0.50	17	AV8 +0.02	94	61	0.54	18	AV7 +0.00			0.16	8	AV4 +0.00
		0.59	19	AV7 -0.02			0.57	18	AV6 +0.02	95	68	0.31	12	AV4 +0.03
		0.36	14	AV6 +0.02			0.28	12	AV5 +0.00			0.40	15	AV3 +0.00
		0.33	13	AV5 -0.03			0.24	10	AV4 +0.00			0.23	10	AV2 -0.02
		0.34	13	AV4 +0.00			0.24	11	AV3 +0.00			0.51	17	AV6 +0.02
		0.24	10	AV3 -0.02			0.15	7	AV2 +0.00	95	70	0.25	11	AV8 +0.05
93	70	0.51	17	AV7 -0.02	94	63	0.36	14	AV6 +0.00			0.35	13	AV7 +0.02
		0.53	18	AV4 -0.05			0.20	9	AV4 -0.02			0.32	13	AV5 +0.05
93	78	0.54	18	AV3 +0.00			0.33	13	AV3 -0.02			0.11	6	AV4 -0.02
93	80	0.22	10	AV8 -0.02			0.15	8	AV2 -0.05			0.24	10	AV2 +0.02
		0.19	9	AV7 +0.00	94	65	0.31	12	AV7 +0.07			0.14	7	AV1 -0.02
		0.17	8	AV6 -0.02			0.16	8	AV4 +0.00	95	74	0.40	15	AV7 +0.02
		0.24	10	AV5 +0.00	94	67	0.38	14	AV8 +0.02			0.39	14	AV5 +0.00
		0.54	18	AV4 +0.00			0.54	18	AV5 +0.02			0.43	15	AV4 +0.00
		0.19	9	AV3 -0.02			0.18	9	AV4 +0.00			0.29	12	AV3 +0.00
93	82	0.25	11	AV3 -0.05	94	69	0.16	8	AV7 +0.02			0.28	12	AV2 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
95	78	0.48	16	AV6 +0.00			0.21	10	AV1 -0.05	97	82	0.47	16	AV6 +0.00
		0.28	12	AV4 -0.02	96	81	0.33	13	AV3 +0.00			0.24	10	AV5 +0.00
		0.31	12	AV3 +0.00			0.15	8	AV2 +0.00			0.27	11	AV3 +0.00
		0.34	13	AV2 -0.02	96	91	0.20	9	AV2 -0.02			0.31	12	AV2 -0.02
95	80	0.40	15	AV3 +0.02	96	95	0.18	8	AV7 +0.00	97	94	0.13	7	AV8 +0.02
		0.11	6	AV2 +0.00			0.44	16	AV4 +0.05			0.29	12	AV7 +0.00
95	82	0.37	14	AV3 -0.02			0.27	11	AV3 +0.00			0.39	15	AV6 +0.02
		0.31	12	AV2 +0.00			0.47	16	AV2 +0.02			0.50	17	AV5 +0.02
95	84	0.49	17	AV7 +0.00	96	97	0.25	11	AV8 +0.00			0.17	8	AV4 -0.16
		0.49	17	AV6 +0.00			0.37	14	AV7 +0.02			0.33	13	AV3 -0.02
95	88	0.29	12	AV3 -0.02			0.15	8	AV6 +0.00			0.15	7	AV1 -0.02
		0.22	10	AV2 -0.02			0.48	17	AV5 +0.05	97	96	0.27	11	AV7 +0.00
95	96	0.50	17	AV7 +0.02			0.40	15	AV3 +0.02			0.21	9	AV2 -0.02
95	98	0.48	16	AV7 +0.00			0.12	6	AV2 +0.00	97	98	0.12	6	AV8 +0.02
		0.29	12	AV4 +0.03	96	103	0.47	16	AV7 +0.00			0.15	7	AV7 -0.05
		0.43	15	AV2 +0.00			0.22	10	AV5 -0.03			0.15	8	AV6 -0.02
95	100	0.29	12	AV8 +0.02			0.13	7	AV1 -0.14	97	106	0.19	9	AV7 +0.00
		0.62	19	AV4 -0.02	96	105	0.54	18	AV3 +0.05			0.21	10	AV6 +0.02
		0.19	9	AV3 -0.02			0.13	7	AV2 +0.07			0.57	18	AV4 +0.03
		0.12	6	AV2 +0.02			0.23	10	AV8 +0.00			0.42	15	AV3 +0.02
95	104	0.53	17	AV7 +0.02			0.20	9	AV4 +0.05			0.23	10	AV2 +0.00
		0.22	10	AV6 +0.02	96	107	0.22	10	AV7 +0.05	97	108	0.21	10	AV7 +0.05
		0.28	11	AV2 +0.00			0.27	11	AV6 +0.00			0.58	19	AV4 +0.00
		0.41	15	AV4 +0.00			0.31	13	AV5 +0.00			0.23	10	AV3 -0.02
95	106	0.27	11	AV7 +0.05			0.34	13	AV4 +0.00			0.11	6	AV2 +0.14
		0.41	15	AV5 +0.00			0.22	10	AV3 -0.02	97	110	0.09	5	AV4 -0.02
		0.30	12	AV4 +0.03	96	109	0.16	8	AV7 +0.02	97	112	0.22	10	AV5 -0.03
		0.17	8	AV3 +0.00			0.16	8	AV4 +0.00			0.13	7	AV4 +0.00
95	108	0.14	7	AV6 +0.00	96	111	0.23	10	AV7 +0.02			0.13	7	AV2 -0.02
		0.19	9	AV5 +0.00			0.31	12	AV6 +0.02	97	114	0.14	7	AV4 +0.00
		0.33	13	AV4 +0.00			0.27	11	AV5 +0.02	97	116	0.20	9	AV5 -0.03
		0.26	11	AV3 +0.00			0.14	7	AV3 +0.02			0.32	13	AV4 +0.00
95	110	0.22	10	AV6 +0.02	96	113	0.11	6	AV5 +0.00			0.31	13	AV3 +0.02
		0.16	8	AV4 +0.03	96	115	0.11	6	AV5 +0.14			0.26	11	AV2 -0.02
95	112	0.22	10	AV7 +0.02	96	117	0.15	7	AV4 -0.07	97	120	0.18	8	AV6 +0.00
		0.17	8	AV3 +0.05	96	119	0.17	8	AV7 +0.02	98	45	0.12	6	AV4 -0.02
		0.16	8	AV2 -0.05	96	121	0.13	7	AV5 +0.00	98	53	0.15	7	AV4 +0.03
95	114	0.14	7	AV4 +0.00	96	125	0.13	7	AV6 +0.00			0.11	6	AV2 -0.07
95	116	0.16	8	AV4 +0.03	96	127	0.21	9	AV2 +0.00	98	55	0.14	7	AV5 -0.03
		0.13	7	AV3 -0.05	96	133	0.18	8	AV4 +0.03			0.16	8	AV4 +0.00
		0.16	8	AV2 +0.02	96	143	0.11	6	AV8 +0.17			0.16	8	AV6 -0.05
95	120	0.13	7	AV3 -0.21	97	46	0.21	9	AV5 -0.03	98	57	0.13	7	AV4 +0.03
95	122	0.10	6	AV5 -0.03			0.14	7	AV2 -0.02	98	59	0.15	7	AV3 +0.02
95	128	0.20	9	AV5 +0.02	97	50	0.16	8	AV5 +0.00	98	61	0.12	6	AV4 +0.00
		0.30	12	AV4 +0.00			0.15	8	AV4 +0.00	98	63	0.16	8	AV4 -0.05
		0.12	6	AV3 +0.00	97	52	0.17	8	AV4 +0.05			0.19	9	AV3 -0.02
95	130	0.13	7	AV3 +0.07	97	56	0.11	6	AV5 +0.07			0.13	7	AV2 -0.02
		0.15	7	AV2 +0.02	97	60	0.10	6	AV5 +0.02	98	65	0.20	9	AV3 -0.02
96	27	0.09	5	AV6 -0.02			0.13	7	AV3 -0.02	98	67	0.32	13	AV7 +0.00
		0.14	7	AV4 +0.05	97	62	0.17	8	AV6 +0.00			0.36	14	AV6 -0.02
		0.16	8	AV2 +0.07			0.17	8	AV5 +0.02			0.45	16	AV5 -0.05
96	49	0.16	8	AV4 -0.02			0.13	7	AV3 +0.00	98	69	0.42	15	AV7 +0.00
96	53	0.16	8	AV5 +0.02	97	64	0.17	8	AV5 -0.05			0.29	12	AV5 -0.03
		0.09	5	AV2 -0.16			0.12	6	AV4 -0.05			0.17	8	AV3 +0.00
96	55	0.11	6	AV5 -0.05			0.21	9	AV3 +0.00	98	71	0.21	10	AV7 +0.02
		0.18	8	AV4 -0.02	97	66	0.20	9	AV4 +0.06			0.53	18	AV6 +0.02
96	59	0.12	6	AV7 -0.02			0.36	14	AV3 +0.02			0.53	18	AV4 -0.02
		0.16	8	AV4 -0.05	97	68	0.53	17	AV3 +0.00			0.19	9	AV2 +0.00
96	61	0.18	9	AV8 +0.00	97	70	0.28	12	AV7 +0.00	98	73	0.36	14	AV2 +0.02
		0.27	11	AV7 +0.02			0.63	19	AV5 +0.02			0.14	7	AV1 +0.00
96	63	0.18	8	AV7 +0.00			0.19	9	AV4 -0.02	98	77	0.41	15	AV7 +0.00
		0.15	7	AV4 +0.03	97	72	0.22	10	AV8 +0.02			0.33	13	AV3 -0.02
96	65	0.47	16	AV6 -0.02			0.51	17	AV3 +0.05			0.24	10	AV2 +0.00
		0.24	10	AV4 +0.03			0.14	7	AV2 +0.00	98	79	0.25	11	AV2 -0.02
		0.52	17	AV3 +0.02	97	74	0.23	10	AV8 +0.00			0.24	10	AV7 +0.02
96	67	0.58	18	AV4 +0.00			0.32	13	AV4 -0.03	98	81	0.44	16	AV4 -0.05
96	69	0.33	13	AV6 +0.02			0.13	7	AV1 -0.02			0.39	14	AV2 +0.00
		0.29	12	AV3 +0.00	97	78	0.21	9	AV6 +0.02			0.13	7	AV1 +0.02
96	71	0.43	15	AV3 -0.02			0.59	19	AV5 +0.00	98	93	0.23	10	AV2 +0.00
96	75	0.31	12	AV3 -0.02			0.38	14	AV4 +0.00	98	97	0.43	15	AV6 +0.02
		0.29	12	AV2 +0.00			0.60	19	AV3 +0.00			0.20	9	AV4 +0.03
96	79	0.59	19	AV2 +0.00			0.48	16	AV2 -0.02			0.18	8	AV3 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
98	99	0.13	7	AV6 -0.16			0.61	19	AV2 +0.02	100	121	0.22	10	AV5 +0.00
		0.62	19	AV5 +0.00	99	104	0.23	10	AV4 +0.05			0.14	7	AV4 -0.02
		0.31	12	AV7 +0.00			0.13	7	AV3 +0.16			0.22	10	AV3 +0.00
		0.32	13	AV2 +0.00			0.08	5	AV2 +0.02			0.19	9	AV2 +0.00
98	105	0.17	8	AV8 +0.00	99	106	0.32	13	AV8 +0.02			0.12	6	AV1 -0.02
98	107	0.14	7	AV7 +0.05			0.11	6	AV4 +0.03	100	125	0.14	7	AV2 +0.00
		0.30	12	AV5 +0.00			0.11	6	AV3 +0.02	100	129	0.19	9	AV5 +0.00
		0.54	18	AV4 +0.03	99	108	0.32	13	AV5 +0.02	101	52	0.17	8	AV5 -0.03
		0.48	17	AV3 +0.00			0.28	12	AV4 +0.00			0.23	10	AV4 +0.03
		0.25	11	AV2 +0.00			0.16	8	AV3 +0.02			0.14	7	AV3 -0.02
98	109	0.23	10	AV8 +0.02	99	110	0.32	13	AV6 +0.05	101	58	0.13	7	AV4 +0.00
		0.26	11	AV7 +0.00			0.13	7	AV5 +0.07	101	60	0.12	6	AV5 +0.02
		0.14	7	AV4 +0.03			0.20	9	AV4 +0.05	101	64	0.16	8	AV4 -0.16
		0.11	6	AV3 +0.00	99	112	0.16	8	AV6 +0.00	101	70	0.37	14	AV5 +0.00
98	111	0.26	11	AV6 -0.02			0.18	9	AV4 +0.03			0.40	15	AV4 +0.03
		0.15	8	AV3 -0.02			0.15	8	AV2 -0.02			0.22	10	AV2 +0.00
98	113	0.09	5	AV4 +0.03	99	114	0.29	12	AV8 +0.02	101	74	0.30	12	AV2 +0.00
		0.16	8	AV3 +0.00			0.31	13	AV4 +0.03			0.29	12	AV8 +0.00
		0.16	8	AV2 -0.02			0.08	5	AV3 +0.00			0.26	11	AV7 +0.02
		0.18	8	AV5 +0.00	99	116	0.10	6	AV5 +0.00	101	78	0.11	6	AV4 -0.18
98	117	0.14	7	AV7 +0.02			0.08	5	AV3 -0.02			0.48	17	AV3 +0.00
		0.13	7	AV6 +0.00	99	118	0.13	7	AV5 +0.02			0.26	11	AV2 +0.00
98	119	0.15	7	AV3 -0.05			0.10	6	AV2 +0.00	101	88	0.30	12	AV1 -0.02
98	121	0.13	7	AV5 +0.00	99	122	0.12	6	AV5 +0.02			0.37	14	AV8 -0.02
		0.10	6	AV4 +0.00	99	126	0.08	5	AV2 +0.00			0.58	19	AV7 +0.00
98	123	0.16	8	AV6 +0.00	99	130	0.13	7	AV3 +0.02	101	94	0.12	6	AV6 -0.19
		0.12	6	AV5 +0.02	100	49	0.12	6	AV5 +0.00			0.26	11	AV4 -0.02
98	141	0.23	10	AV6 -0.02	100	63	0.16	8	AV2 -0.02			0.44	16	AV3 -0.02
		0.15	7	AV1 +0.18	100	65	0.16	8	AV7 +0.02			0.46	16	AV2 -0.02
98	143	0.11	6	AV1 +0.18			0.15	7	AV4 +0.03			0.16	8	AV1 +0.00
99	54	0.12	6	AV3 +0.00			0.40	15	AV3 +0.00	101	96	0.61	19	AV7 +0.02
		0.09	5	AV2 +0.00	100	67	0.16	8	AV4 -0.02			0.29	12	AV6 +0.02
99	56	0.12	6	AV4 +0.18			0.35	13	AV3 -0.05			0.23	10	AV5 +0.05
99	62	0.11	6	AV5 -0.03			0.14	7	AV1 -0.05			0.47	16	AV4 +0.03
99	64	0.18	9	AV7 -0.02	100	69	0.26	11	AV8 +0.00	101	98	0.33	13	AV7 +0.02
		0.19	9	AV6 +0.00			0.32	13	AV5 +0.02			0.24	10	AV6 -0.02
		0.23	10	AV4 +0.05			0.21	10	AV3 +0.02			0.58	18	AV5 +0.00
		0.15	7	AV3 -0.02	100	71	0.35	14	AV4 +0.00			0.39	14	AV4 +0.00
		0.16	8	AV2 -0.02			0.49	17	AV3 +0.02			0.41	15	AV3 +0.00
99	66	0.17	8	AV5 -0.05			0.16	8	AV2 +0.00	101	100	0.16	8	AV7 +0.00
		0.23	10	AV4 +0.00	100	73	0.25	11	AV4 +0.00			0.27	11	AV5 +0.00
		0.17	8	AV2 -0.02	100	75	0.21	10	AV8 +0.02			0.16	8	AV4 +0.03
		0.19	9	AV7 +0.02	100	77	0.59	19	AV2 +0.00			0.25	11	AV3 +0.00
		0.26	11	AV6 +0.00	100	79	0.45	16	AV7 +0.00			0.12	6	AV1 +0.00
99	68	0.57	18	AV5 -0.03	100	81	0.36	14	AV8 -0.02	101	106	0.12	6	AV5 -0.18
		0.24	10	AV3 -0.02			0.26	11	AV4 -0.02			0.12	6	AV4 -0.02
		0.11	6	AV2 -0.05			0.31	12	AV2 +0.00	101	108	0.33	13	AV5 +0.02
99	70	0.23	10	AV7 +0.02	100	91	0.21	10	AV8 +0.02			0.24	10	AV4 -0.05
		0.29	12	AV4 +0.03			0.46	16	AV3 -0.02	101	110	0.20	9	AV5 +0.02
		0.38	14	AV3 +0.02			0.42	15	AV2 -0.02			0.35	13	AV4 +0.03
99	72	0.34	13	AV7 +0.00	100	95	0.52	17	AV4 +0.00			0.30	12	AV3 +0.00
99	76	0.19	9	AV7 +0.02			0.12	7	AV3 -0.02			0.11	6	AV2 -0.02
		0.52	17	AV3 +0.02	100	97	0.12	6	AV7 +0.02	101	112	0.10	5	AV7 +0.02
99	78	0.40	15	AV8 +0.00			0.50	17	AV5 +0.02	101	116	0.17	8	AV4 +0.03
		0.64	19	AV5 +0.05			0.38	14	AV4 +0.00	101	120	0.14	7	AV5 +0.00
99	80	0.27	11	AV6 +0.02			0.44	16	AV3 +0.02	101	128	0.15	7	AV5 -0.03
		0.17	8	AV5 -0.03			0.14	7	AV2 +0.00	102	39	0.14	7	AV6 -0.02
		0.27	11	AV3 -0.02	100	99	0.48	16	AV8 +0.00	102	43	0.15	7	AV5 -0.03
		0.11	6	AV2 -0.02			0.19	9	AV4 +0.03	102	45	0.15	7	AV5 +0.00
99	82	0.28	12	AV7 -0.02			0.60	19	AV3 +0.00	102	51	0.19	9	AV6 -0.02
		0.17	8	AV6 -0.02			0.27	11	AV2 -0.02			0.13	7	AV5 +0.00
		0.53	18	AV4 -0.05	100	105	0.45	16	AV3 +0.00			0.14	7	AV4 +0.00
		0.12	6	AV3 +0.00			0.22	10	AV8 +0.02	102	55	0.20	9	AV4 +0.03
		0.15	8	AV2 +0.00	100	107	0.43	15	AV2 +0.00	102	59	0.23	10	AV4 +0.00
		0.09	5	AV1 -0.02	100	109	0.18	8	AV7 +0.02			0.25	11	AV3 +0.02
99	96	0.11	6	AV7 +0.05			0.24	10	AV4 +0.03			0.14	7	AV2 -0.02
		0.26	11	AV6 +0.00			0.16	8	AV3 -0.02	102	71	0.48	17	AV3 -0.02
		0.13	7	AV2 +0.02	100	111	0.16	8	AV7 +0.02			0.23	10	AV2 +0.00
99	98	0.18	8	AV6 +0.02			0.31	12	AV6 +0.02	102	73	0.22	10	AV7 +0.02
		0.27	11	AV5 +0.00			0.22	10	AV4 +0.00			0.45	16	AV4 -0.02
		0.53	18	AV4 +0.03	100	115	0.10	6	AV5 -0.03			0.55	18	AV3 +0.02
		0.47	16	AV3 +0.05			0.23	10	AV4 -0.02			0.38	14	AV2 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
102	77	0.47	16	AV7 -0.02			0.57	18	AV4 +0.00	105	60	0.13	7	AV3 -0.02
		0.59	19	AV3 -0.05			0.29	12	AV3 -0.02	105	62	0.09	5	AV7 -0.16
		0.47	16	AV2 -0.05			0.18	8	AV7 +0.02	105	66	0.17	8	AV3 -0.02
102	79	0.42	15	AV6 +0.05	103	100	0.16	8	AV7 +0.00	105	70	0.27	11	AV5 +0.05
		0.19	9	AV4 +0.05			0.31	12	AV2 +0.02	105	72	0.20	9	AV7 +0.00
102	91	0.40	15	AV3 -0.02	103	104	0.09	5	AV3 -0.02			0.57	18	AV6 +0.02
		0.24	10	AV2 -0.02	103	106	0.10	5	AV6 +0.03			0.48	16	AV3 -0.02
		0.10	5	AV1 -0.02			0.20	9	AV4 -0.02			0.26	11	AV2 +0.00
102	95	0.44	16	AV5 +0.00			0.33	13	AV3 -0.02	105	74	0.27	11	AV2 +0.00
		0.24	10	AV3 +0.00			0.10	6	AV2 -0.02	105	76	0.16	8	AV8 +0.00
		0.35	14	AV2 +0.02	103	108	0.10	6	AV5 +0.00			0.46	16	AV3 -0.02
102	97	0.12	6	AV7 -0.02			0.18	9	AV4 -0.02			0.17	8	AV2 +0.00
		0.18	8	AV6 +0.02	103	110	0.12	6	AV6 +0.05	105	78	0.19	9	AV7 +0.02
		0.59	19	AV5 +0.02	103	112	0.24	11	AV3 +0.02			0.27	11	AV5 -0.03
		0.35	14	AV3 +0.00			0.16	8	AV4 +0.03			0.45	16	AV3 -0.02
102	99	0.09	5	AV8 -0.05			0.33	13	AV2 +0.00			0.11	6	AV2 -0.02
		0.23	10	AV7 +0.05	103	114	0.17	8	AV3 +0.00	105	80	0.34	13	AV8 +0.00
		0.38	14	AV3 +0.00			0.37	14	AV6 +0.02			0.28	12	AV4 -0.02
		0.25	11	AV2 +0.00			0.11	6	AV5 +0.09			0.20	9	AV3 -0.02
102	105	0.21	9	AV3 +0.02	103	116	0.12	6	AV7 +0.02			0.11	6	AV2 -0.02
		0.54	18	AV7 +0.02	104	49	0.28	11	AV5 -0.03	105	82	0.46	16	AV7 +0.00
		0.63	19	AV6 +0.03	104	71	0.14	7	AV6 +0.00			0.29	12	AV2 -0.02
		0.36	14	AV4 +0.03			0.41	15	AV4 -0.05	105	96	0.35	13	AV6 +0.00
102	107	0.11	6	AV7 +0.05			0.16	8	AV3 +0.00			0.58	19	AV4 +0.00
		0.10	6	AV6 +0.19			0.27	11	AV2 -0.02			0.32	13	AV3 +0.00
		0.13	7	AV3 +0.00	104	73	0.44	16	AV5 -0.03	105	98	0.55	18	AV7 +0.02
102	111	0.21	9	AV6 -0.05			0.61	19	AV3 +0.00			0.57	18	AV4 +0.00
		0.07	5	AV5 -0.03			0.28	12	AV2 -0.05			0.56	18	AV3 +0.00
		0.13	7	AV4 -0.02			0.60	19	AV7 -0.02			0.11	6	AV2 -0.02
		0.13	7	AV3 -0.05	104	75	0.31	12	AV8 +0.05	105	100	0.16	8	AV8 +0.05
		0.10	6	AV2 -0.05			0.59	19	AV2 +0.00			0.23	10	AV7 +0.00
102	113	0.12	6	AV4 -0.02	104	77	0.54	18	AV7 +0.00			0.45	16	AV6 +0.07
		0.24	10	AV3 +0.07			0.51	17	AV5 +0.00			0.15	8	AV3 -0.02
102	115	0.21	9	AV5 -0.03			0.45	16	AV3 +0.00	105	104	0.22	10	AV4 +0.05
		0.15	7	AV3 -0.02	104	79	0.50	17	AV6 +0.02			0.18	9	AV3 +0.00
102	123	0.25	11	AV6 +0.00			0.52	17	AV5 +0.00			0.56	18	AV6 +0.02
102	125	0.11	6	AV6 -0.02			0.41	15	AV3 +0.00			0.39	14	AV5 +0.00
103	44	0.13	7	AV5 +0.00			0.37	14	AV2 -0.02	105	106	0.23	10	AV5 +0.00
103	46	0.30	12	AV5 +0.00	104	81	0.39	15	AV6 +0.00			0.11	6	AV3 +0.02
103	48	0.17	8	AV5 +0.05			0.13	7	AV5 -0.03	105	108	0.12	6	AV5 +0.02
103	54	0.16	8	AV5 +0.05			0.32	13	AV4 -0.02			0.16	8	AV4 +0.03
103	56	0.15	7	AV5 +0.18			0.15	8	AV2 +0.00	105	112	0.12	6	AV5 +0.02
		0.24	10	AV4 +0.08	104	91	0.34	13	AV1 +0.00			0.18	8	AV4 +0.03
		0.46	16	AV3 +0.05	104	95	0.21	10	AV6 +0.02			0.21	9	AV3 +0.02
		0.41	15	AV2 +0.02			0.23	10	AV5 +0.05			0.21	10	AV2 +0.00
103	60	0.17	8	AV4 -0.02			0.60	19	AV4 +0.05			0.16	8	AV1 +0.02
		0.08	5	AV3 -0.02			0.14	7	AV3 +0.00	105	114	0.16	8	AV5 -0.03
103	64	0.14	7	AV7 +0.02			0.26	11	AV2 +0.00			0.24	10	AV4 +0.03
		0.15	7	AV4 -0.02			0.14	7	AV1 +0.00			0.14	7	AV3 -0.02
103	66	0.16	8	AV6 -0.02	104	97	0.19	9	AV7 +0.02	105	122	0.17	8	AV5 +0.02
103	70	0.51	17	AV6 -0.02			0.22	10	AV3 +0.02	106	45	0.11	6	AV5 +0.05
		0.49	17	AV5 +0.02	104	99	0.18	8	AV8 +0.00	106	53	0.13	7	AV6 +0.05
		0.50	17	AV4 +0.03			0.25	11	AV7 +0.02			0.23	10	AV5 +0.00
103	72	0.39	15	AV3 +0.00			0.30	12	AV6 +0.05	106	57	0.13	7	AV5 +0.05
		0.19	9	AV2 -0.05			0.32	13	AV5 +0.02			0.17	8	AV4 +0.00
103	78	0.18	9	AV7 +0.00			0.21	9	AV3 +0.02	106	63	0.16	8	AV3 +0.02
103	80	0.18	9	AV5 +0.02			0.26	11	AV2 +0.00	106	67	0.16	8	AV6 -0.02
		0.47	16	AV4 +0.03	104	105	0.50	17	AV4 +0.03			0.16	8	AV5 -0.03
		0.62	19	AV3 +0.02			0.12	6	AV3 -0.05	106	69	0.20	9	AV7 +0.02
		0.10	6	AV2 +0.00			0.09	5	AV2 -0.05			0.17	8	AV5 +0.02
		0.49	17	AV8 +0.02	104	107	0.20	9	AV7 +0.05	106	71	0.55	18	AV6 +0.00
103	82	0.63	19	AV3 +0.02			0.17	8	AV4 +0.03			0.46	16	AV4 -0.02
		0.41	15	AV2 +0.00			0.16	8	AV3 +0.00			0.16	8	AV3 -0.02
103	92	0.34	13	AV8 +0.02			0.09	5	AV2 +0.02			0.22	10	AV2 +0.00
		0.63	19	AV2 -0.02	104	109	0.11	6	AV4 +0.00	106	73	0.46	16	AV3 -0.02
		0.17	8	AV1 -0.02	104	111	0.10	6	AV6 +0.00			0.18	9	AV2 +0.00
103	96	0.25	11	AV8 +0.02	104	117	0.09	5	AV5 -0.03			0.18	8	AV1 -0.02
		0.56	18	AV4 +0.00			0.21	9	AV3 -0.05	106	75	0.58	19	AV4 +0.00
		0.58	18	AV3 +0.02	105	52	0.26	11	AV5 +0.02			0.22	10	AV3 -0.02
		0.13	7	AV2 +0.00			0.46	16	AV4 +0.03	106	77	0.16	8	AV7 +0.02
103	98	0.16	8	AV6 -0.02			0.48	16	AV3 +0.02			0.16	8	AV2 -0.05
		0.53	18	AV5 +0.02			0.52	17	AV2 +0.00	106	93	0.23	10	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	
		0.26	11	AV2 -0.02			0.08	5	AV2 -0.20			109 54	0.18	9	AV4 -0.02
		0.20	9	AV8 +0.02	107 104		0.13	7	AV7 +0.00			109 56	0.17	8	AV5 +0.05
		0.32	13	AV7 +0.05			0.21	9	AV5 +0.00			109 58	0.17	8	AV4 -0.02
106 95		0.61	19	AV3 -0.02			0.33	13	AV4 +0.03			109 60	0.10	5	AV5 +0.00
		0.52	17	AV2 +0.00			0.40	15	AV3 +0.02				0.13	7	AV3 +0.00
		0.15	7	AV1 +0.00	107 106		0.11	6	AV7 +0.05			109 64	0.17	8	AV4 +0.00
		0.32	13	AV8 +0.05			0.11	6	AV3 +0.00			109 66	0.12	6	AV5 -0.03
106 97		0.37	14	AV7 +0.00	107 108		0.22	10	AV6 -0.02			109 68	0.34	13	AV8 +0.05
		0.48	17	AV4 +0.00	107 110		0.11	6	AV6 +0.07				0.50	17	AV4 +0.06
		0.26	11	AV2 +0.02	107 112		0.13	7	AV7 +0.02				0.21	9	AV1 +0.00
		0.19	9	AV1 -0.02			0.06	4	AV5 -0.03			109 70	0.55	18	AV7 +0.02
106 99		0.14	7	AV3 +0.00			0.14	7	AV3 -0.02				0.21	10	AV4 +0.03
		0.15	8	AV1 -0.05			0.18	9	AV2 -0.02				0.16	8	AV3 -0.02
		0.54	18	AV7 +0.02	107 114		0.09	5	AV4 +0.16				0.14	7	AV2 +0.00
106 101		0.14	7	AV3 -0.05	107 120		0.32	13	AV2 +0.05				0.13	7	AV1 -0.05
		0.39	14	AV7 +0.00			0.22	10	AV6 +0.02			109 76	0.23	10	AV5 +0.05
		0.40	15	AV6 +0.02	108 35		0.21	9	AV8 +0.02				0.49	17	AV3 +0.00
106 103		0.16	8	AV7 +0.05			0.25	11	AV5 +0.00				0.21	10	AV2 +0.00
		0.59	19	AV3 -0.05	108 37		0.14	7	AV8 +0.05			109 82	0.18	9	AV8 +0.02
		0.09	5	AV2 -0.02	108 49		0.22	10	AV5 +0.02				0.29	12	AV1 -0.02
106 105		0.19	9	AV4 -0.02	108 51		0.11	6	AV5 -0.03			109 88	0.47	16	AV8 +0.02
106 107		0.14	7	AV5 -0.03	108 53		0.17	8	AV4 -0.02				0.33	13	AV3 -0.05
		0.14	7	AV3 -0.02	108 67		0.16	8	AV7 +0.05				0.24	10	AV2 +0.00
106 111		0.15	8	AV4 -0.02			0.16	8	AV6 -0.05			109 92	0.28	11	AV8 +0.02
106 113		0.30	12	AV4 +0.00	108 69		0.47	16	AV7 +0.05				0.18	8	AV5 +0.00
		0.10	6	AV3 -0.02			0.16	8	AV4 -0.02				0.22	10	AV2 +0.00
		0.12	6	AV2 -0.05			0.17	8	AV3 -0.02			109 94	0.15	8	AV7 +0.02
106 115		0.19	9	AV2 -0.05			0.35	13	AV2 -0.02				0.07	4	AV4 -0.21
106 121		0.14	7	AV5 +0.00	108 71		0.19	9	AV7 +0.05				0.30	12	AV3 -0.02
106 133		0.13	7	AV5 +0.00			0.63	19	AV4 +0.00				0.53	18	AV2 +0.02
107 34		0.15	7	AV1 +0.11			0.52	17	AV3 +0.02				0.10	6	AV1 +0.02
107 44		0.17	8	AV5 -0.03			0.54	18	AV2 +0.00			109 96	0.20	9	AV5 -0.03
107 50		0.11	6	AV5 -0.03	108 73		0.34	13	AV5 +0.00				0.49	17	AV4 -0.02
		0.27	11	AV4 -0.02			0.48	17	AV4 -0.02				0.36	14	AV3 -0.02
		0.24	10	AV3 +0.00			0.47	16	AV3 +0.00			109 98	0.14	7	AV7 +0.00
		0.21	9	AV2 +0.00			0.46	16	AV2 -0.02				0.58	18	AV5 +0.00
107 66		0.14	7	AV3 +0.00			0.27	11	AV1 +0.00				0.17	8	AV4 -0.02
		0.16	8	AV6 -0.05	108 75		0.43	15	AV4 -0.05				0.54	18	AV3 -0.02
		0.14	7	AV4 +0.00			0.12	6	AV3 +0.00				0.13	7	AV2 +0.02
107 68		0.27	11	AV5 -0.03	108 77		0.16	8	AV8 +0.02			109 100	0.42	15	AV8 +0.05
		0.30	12	AV4 -0.02	108 79		0.49	17	AV5 +0.00				0.11	6	AV3 +0.02
		0.22	10	AV8 +0.00			0.48	17	AV4 -0.02			109 104	0.32	13	AV7 +0.02
		0.15	7	AV3 +0.00			0.16	8	AV3 +0.00				0.31	12	AV6 +0.03
107 76		0.26	11	AV8 +0.02			0.42	15	AV6 -0.02				0.19	9	AV5 -0.03
		0.22	10	AV5 -0.03	108 91		0.27	11	AV1 +0.00				0.33	13	AV4 +0.00
		0.29	12	AV4 +0.00	108 93		0.14	7	AV1 -0.02				0.28	12	AV3 -0.02
		0.19	9	AV2 -0.02			0.17	8	AV8 +0.02			109 106	0.09	5	AV5 -0.18
107 78		0.50	17	AV7 -0.02	108 97		0.34	13	AV6 +0.02				0.15	8	AV3 -0.02
		0.54	18	AV6 +0.00			0.37	14	AV5 +0.00			109 108	0.18	8	AV5 -0.03
		0.20	9	AV5 -0.05			0.53	18	AV4 +0.00			109 112	0.13	7	AV3 +0.00
		0.26	11	AV4 -0.02			0.16	8	AV3 +0.00			109 116	0.09	5	AV5 -0.03
		0.51	17	AV3 -0.05	108 99		0.34	13	AV7 +0.00				0.14	7	AV4 +0.05
		0.22	10	AV2 -0.02			0.33	13	AV1 -0.02			110 45	0.23	10	AV5 +0.00
107 86		0.39	15	AV2 -0.02	108 101		0.38	14	AV7 +0.00			110 47	0.22	10	AV5 +0.00
107 90		0.51	17	AV3 -0.02			0.13	7	AV6 +0.07			110 57	0.13	7	AV4 -0.07
		0.30	12	AV2 -0.04			0.32	13	AV4 +0.03			110 65	0.19	9	AV6 +0.02
		0.55	18	AV8 +0.02			0.20	9	AV1 -0.02				0.20	9	AV4 +0.03
107 96		0.17	8	AV8 +0.05	108 103		0.19	9	AV8 +0.05				0.16	8	AV2 -0.02
		0.12	6	AV5 +0.02			0.45	16	AV7 +0.05			110 67	0.12	6	AV6 +0.02
		0.53	18	AV4 +0.03			0.36	14	AV5 -0.05				0.14	7	AV2 -0.02
		0.37	14	AV2 +0.00			0.16	8	AV2 -0.02			110 69	0.18	8	AV4 -0.02
		0.21	9	AV1 +0.00	108 105		0.27	11	AV7 +0.00				0.15	7	AV3 -0.02
107 98		0.59	19	AV6 +0.02			0.54	18	AV5 -0.03				0.17	8	AV2 -0.05
		0.35	14	AV4 +0.00			0.35	14	AV4 +0.00			110 73	0.17	8	AV8 +0.02
		0.18	9	AV2 +0.02			0.09	5	AV3 +0.02				0.17	8	AV1 -0.02
107 100		0.17	8	AV7 +0.00	108 107		0.11	6	AV4 +0.05			110 75	0.15	7	AV8 +0.02
		0.24	10	AV6 +0.03			0.15	8	AV3 -0.02				0.38	14	AV6 +0.02
		0.27	11	AV3 -0.02	108 109		0.11	6	AV5 +0.02			110 77	0.39	14	AV8 +0.02
		0.14	7	AV2 +0.00			0.14	7	AV3 -0.02				0.16	8	AV7 +0.02
107 102		0.08	5	AV7 +0.00	108 127		0.17	8	AV4 +0.00				0.32	13	AV2 +0.02
		0.57	18	AV5 +0.02	108 131		0.15	7	AV5 -0.03			110 79	0.43	15	AV2 -0.02
		0.45	16	AV4 +0.00	108 135		0.11	6	AV8 +0.21				0.31	13	AV8 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
110	81	0.35	13	AV3 +0.00	111	126	0.19	9	AV5 +0.00	113	62	0.16	8	AV3 -0.02
		0.57	18	AV6 +0.00	112	41	0.17	8	AV6 -0.02	113	70	0.15	7	AV3 -0.02
		0.23	10	AV3 +0.00			0.10	6	AV5 -0.03	113	74	0.30	12	AV7 +0.05
		0.19	9	AV2 -0.02			0.12	7	AV3 +0.00			0.42	15	AV2 +0.00
110	93	0.14	7	AV1 -0.02	112	43	0.08	5	AV5 +0.02	113	76	0.24	10	AV4 +0.00
		0.17	8	AV7 +0.00			0.10	6	AV2 -0.02			0.23	10	AV2 +0.00
110	97	0.17	8	AV6 +0.00	112	45	0.15	7	AV5 -0.03	113	78	0.35	13	AV8 +0.05
110	99	0.15	8	AV7 -0.02	112	49	0.16	8	AV5 -0.03			0.39	14	AV3 +0.00
		0.55	18	AV3 -0.02	112	51	0.25	11	AV5 -0.03			0.34	13	AV2 -0.02
		0.15	7	AV2 +0.00			0.10	6	AV4 -0.02	113	80	0.42	15	AV2 +0.00
110	101	0.50	17	AV5 +0.00	112	53	0.16	8	AV4 +0.00			0.18	8	AV5 +0.00
110	103	0.44	16	AV2 +0.00	112	61	0.14	7	AV5 +0.00			0.63	19	AV4 +0.03
		0.12	6	AV1 -0.07	112	67	0.11	6	AV6 -0.14	113	88	0.62	19	AV3 -0.05
110	105	0.25	11	AV6 +0.00			0.10	6	AV5 -0.14			0.22	10	AV2 -0.02
110	109	0.11	6	AV5 -0.03			0.17	8	AV3 -0.02	113	90	0.31	12	AV2 -0.04
		0.11	6	AV4 -0.02	112	69	0.36	14	AV7 +0.02	113	94	0.13	7	AV7 +0.00
		0.11	6	AV3 +0.00			0.54	18	AV5 +0.00			0.32	13	AV4 -0.05
110	111	0.11	6	AV6 -0.02			0.19	9	AV4 -0.02			0.20	9	AV3 -0.02
110	113	0.26	11	AV3 +0.00			0.16	8	AV3 -0.02			0.12	6	AV1 -0.02
110	115	0.21	10	AV4 +0.03	112	71	0.14	7	AV4 -0.02	113	96	0.22	10	AV3 +0.00
110	117	0.12	6	AV6 +0.00			0.13	7	AV3 -0.02			0.16	8	AV2 -0.16
110	119	0.13	7	AV5 +0.07	112	73	0.45	16	AV8 +0.02	113	98	0.42	15	AV5 -0.03
		0.11	6	AV3 -0.02			0.48	17	AV7 -0.02			0.16	8	AV4 -0.05
110	123	0.12	6	AV2 +0.00			0.54	18	AV5 +0.00			0.12	6	AV3 -0.02
111	46	0.14	7	AV5 +0.05			0.24	10	AV3 -0.02	113	100	0.07	5	AV7 -0.43
111	56	0.32	13	AV7 -0.02			0.13	7	AV2 -0.02			0.19	9	AV6 +0.05
111	62	0.18	9	AV7 +0.05	112	75	0.46	16	AV7 +0.02			0.11	6	AV5 +0.02
		0.17	8	AV3 +0.02			0.44	16	AV6 +0.02			0.44	16	AV4 +0.00
111	66	0.18	9	AV3 +0.02			0.39	15	AV4 +0.00			0.11	6	AV3 +0.00
111	70	0.19	9	AV6 +0.05			0.19	9	AV3 -0.02			0.10	6	AV1 -0.02
		0.24	10	AV4 -0.02			0.14	7	AV2 -0.05	113	102	0.22	10	AV4 +0.00
		0.18	8	AV3 +0.00	112	77	0.56	18	AV4 -0.05			0.20	9	AV7 +0.00
111	72	0.42	15	AV5 -0.03			0.09	5	AV3 +0.00			0.38	14	AV5 +0.00
		0.21	10	AV4 -0.05	112	79	0.54	18	AV2 +0.00	113	108	0.28	12	AV6 +0.05
		0.20	9	AV3 +0.00			0.08	5	AV1 +0.14			0.26	11	AV2 +0.02
111	74	0.43	15	AV7 +0.02			0.44	16	AV8 +0.05	113	110	0.16	8	AV6 +0.03
		0.61	19	AV4 -0.02	112	81	0.24	10	AV7 +0.02	113	114	0.11	6	AV6 +0.00
111	76	0.50	17	AV4 -0.02			0.59	19	AV4 -0.02			0.14	7	AV4 -0.02
		0.15	8	AV3 -0.05			0.47	16	AV3 -0.05	113	120	0.19	9	AV4 +0.03
		0.13	7	AV2 -0.05			0.16	8	AV2 +0.00			0.14	7	AV3 -0.02
111	80	0.59	19	AV4 -0.05	112	83	0.30	12	AV8 +0.02			0.10	5	AV2 -0.05
111	82	0.57	18	AV6 +0.00			0.32	13	AV2 -0.02	113	122	0.26	11	AV4 +0.00
		0.44	16	AV3 -0.02	112	87	0.33	13	AV8 +0.02	113	124	0.20	9	AV4 +0.03
		0.13	7	AV2 +0.00			0.17	8	AV1 -0.02			0.13	7	AV3 -0.02
111	86	0.32	13	AV7 +0.02	112	95	0.33	13	AV4 -0.02	114	41	0.23	10	AV5 -0.03
		0.36	14	AV1 -0.05			0.21	9	AV3 +0.00	114	49	0.16	8	AV7 +0.02
		0.17	8	AV8 +0.00			0.17	8	AV1 +0.00			0.12	6	AV4 +0.00
111	98	0.23	10	AV7 +0.02	112	97	0.25	11	AV5 +0.02	114	59	0.38	14	AV5 -0.03
		0.18	9	AV6 +0.02			0.61	19	AV4 +0.00	114	65	0.17	8	AV4 -0.05
		0.23	10	AV4 +0.00			0.43	15	AV2 -0.02	114	67	0.55	18	AV6 +0.02
		0.17	8	AV3 +0.05			0.12	6	AV1 +0.00	114	69	0.14	7	AV7 +0.18
		0.13	7	AV2 +0.02	112	99	0.57	18	AV7 +0.02	114	71	0.27	11	AV5 -0.03
		0.14	7	AV1 +0.00			0.58	19	AV5 +0.07			0.18	8	AV4 -0.02
111	100	0.28	12	AV5 +0.00			0.41	15	AV4 +0.05			0.18	8	AV3 -0.02
		0.20	9	AV4 +0.00			0.14	7	AV1 -0.02	114	75	0.12	6	AV8 -0.02
		0.18	9	AV3 +0.00	112	103	0.21	9	AV6 +0.00			0.45	16	AV7 +0.02
		0.12	6	AV2 +0.02			0.35	13	AV2 +0.00			0.54	18	AV6 +0.00
111	104	0.06	4	AV8 -0.26	112	105	0.20	9	AV5 +0.09			0.27	11	AV3 +0.00
		0.09	5	AV7 +0.05	112	107	0.25	11	AV3 +0.00	114	77	0.21	10	AV7 +0.05
		0.19	9	AV5 +0.02	112	109	0.17	8	AV8 +0.07			0.40	15	AV6 +0.00
		0.26	11	AV4 +0.03			0.16	8	AV3 +0.00			0.44	16	AV5 +0.00
		0.26	11	AV3 +0.02			0.14	7	AV2 +0.00			0.51	17	AV4 -0.02
		0.08	5	AV2 +0.05	112	115	0.14	7	AV5 +0.02			0.32	13	AV2 +0.00
111	106	0.37	14	AV7 +0.07	112	121	0.14	7	AV5 +0.00	114	79	0.34	13	AV3 -0.02
		0.19	9	AV6 +0.03	112	127	0.18	8	AV5 +0.00			0.17	8	AV8 +0.02
		0.11	6	AV5 +0.00	113	50	0.12	6	AV5 -0.05	114	81	0.24	10	AV7 +0.00
		0.20	9	AV4 +0.00			0.14	7	AV4 -0.02			0.48	16	AV6 +0.00
		0.15	7	AV3 -0.02			0.08	5	AV2 -0.02			0.41	15	AV5 +0.00
		0.07	4	AV2 -0.02	113	54	0.19	9	AV4 -0.02			0.54	18	AV4 -0.02
111	108	0.14	7	AV6 +0.00	113	56	0.16	8	AV6 +0.00			0.55	18	AV2 -0.02
111	110	0.11	6	AV3 +0.02			0.18	9	AV4 +0.05	114	87	0.55	18	AV7 +0.02
		0.13	7	AV2 +0.00			0.12	6	AV2 -0.02			0.53	18	AV6 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.63	19	AV2 -0.02			0.14	7	AV5 -0.03	117	46	0.20	9	AV6 +0.02
114	91	0.53	18	AV2 +0.00			0.36	14	AV4 +0.00	117	48	0.19	9	AV5 -0.03
114	93	0.15	7	AV7 +0.02			0.27	11	AV3 +0.00			0.10	6	AV4 +0.00
		0.32	13	AV6 +0.14			0.22	10	AV2 -0.02	117	58	0.22	10	AV5 -0.03
		0.31	13	AV4 -0.02			0.16	8	AV1 -0.02	117	62	0.10	6	AV7 +0.00
		0.30	12	AV3 +0.00	115	102	0.28	12	AV6 +0.07	117	64	0.20	9	AV6 -0.02
		0.41	15	AV2 -0.02			0.60	19	AV5 +0.05	117	68	0.18	8	AV8 +0.02
114	95	0.11	6	AV2 -0.02			0.61	19	AV4 +0.05			0.44	16	AV4 +0.03
		0.22	10	AV7 +0.02			0.48	16	AV1 +0.00			0.35	14	AV3 +0.00
		0.14	7	AV5 -0.05	115	104	0.08	5	AV1 +0.00			0.39	15	AV2 +0.00
		0.37	14	AV3 -0.02			0.13	7	AV8 +0.07	117	70	0.14	7	AV5 -0.06
114	97	0.15	8	AV6 -0.02			0.25	11	AV7 +0.05			0.17	8	AV4 -0.02
		0.38	14	AV5 -0.03			0.40	15	AV6 +0.02			0.12	6	AV3 +0.05
		0.17	8	AV4 -0.05			0.19	9	AV4 +0.03	117	72	0.18	8	AV8 +0.05
		0.30	12	AV3 -0.02			0.14	7	AV3 +0.16	117	74	0.19	9	AV7 -0.02
114	101	0.18	8	AV3 +0.02	115	126	0.20	9	AV4 +0.05	117	76	0.18	8	AV8 +0.02
		0.14	7	AV2 +0.02			0.13	7	AV3 +0.02			0.54	18	AV7 +0.00
114	103	0.13	7	AV8 +0.05	115	130	0.14	7	AV7 +0.02			0.35	13	AV5 -0.03
		0.50	17	AV7 +0.05			0.17	8	AV4 +0.03	117	80	0.31	12	AV8 +0.02
		0.44	16	AV6 -0.02	116	41	0.13	7	AV6 -0.02			0.15	8	AV4 +0.00
		0.26	11	AV5 +0.00	116	47	0.11	6	AV5 -0.03			0.17	8	AV3 -0.05
		0.14	7	AV4 +0.00			0.13	7	AV3 +0.00			0.30	12	AV2 -0.02
114	105	0.26	11	AV6 +0.03	116	51	0.10	6	AV7 +0.02	117	92	0.14	7	AV1 -0.02
114	107	0.11	6	AV5 -0.03	116	57	0.19	9	AV5 +0.07			0.48	16	AV7 -0.02
		0.21	9	AV4 +0.03			0.19	9	AV4 +0.00	117	94	0.62	19	AV4 +0.05
		0.07	4	AV3 +0.00			0.23	10	AV3 +0.00			0.26	11	AV3 +0.02
114	111	0.09	5	AV6 +0.00	116	59	0.26	11	AV5 -0.03			0.13	7	AV2 -0.02
		0.16	8	AV3 -0.02	116	61	0.23	10	AV6 +0.00	117	96	0.24	10	AV6 +0.00
114	119	0.12	6	AV7 +0.02			0.08	5	AV4 +0.00	117	120	0.08	5	AV7 +0.02
114	125	0.14	7	AV5 +0.00			0.19	9	AV5 +0.03			0.12	6	AV6 +0.00
		0.13	7	AV4 +0.05			0.15	7	AV3 +0.00			0.20	9	AV4 -0.02
		0.11	6	AV2 +0.00			0.12	6	AV2 -0.02			0.18	8	AV3 -0.02
115	40	0.22	10	AV6 +0.02	116	69	0.20	9	AV6 +0.00	117	124	0.44	16	AV6 +0.05
		0.15	7	AV5 +0.02			0.22	10	AV4 -0.02	118	69	0.12	6	AV7 +0.18
		0.16	8	AV2 +0.02			0.14	7	AV3 +0.00	118	71	0.17	8	AV4 -0.02
115	42	0.14	7	AV6 -0.05	116	73	0.21	9	AV6 +0.14	118	73	0.33	13	AV5 -0.03
		0.14	7	AV4 -0.02			0.16	8	AV4 -0.02	118	75	0.15	8	AV7 -0.17
115	48	0.26	11	AV5 +0.00	116	75	0.25	11	AV2 +0.00	118	77	0.60	19	AV7 +0.05
115	52	0.18	9	AV6 +0.00			0.15	8	AV7 +0.00			0.38	14	AV4 -0.02
115	56	0.19	9	AV4 +0.00			0.22	10	AV6 +0.00			0.23	10	AV3 +0.00
115	58	0.18	8	AV3 +0.02			0.34	13	AV5 -0.05			0.39	14	AV2 -0.02
		0.13	7	AV2 +0.00			0.18	8	AV4 -0.05			0.18	8	AV1 -0.05
115	60	0.13	7	AV5 +0.05			0.27	11	AV3 -0.02	118	79	0.48	17	AV6 +0.00
115	66	0.27	11	AV8 +0.07	116	77	0.45	16	AV7 +0.02			0.17	8	AV5 -0.05
		0.62	19	AV5 +0.14			0.57	18	AV6 +0.02	118	81	0.43	15	AV7 +0.00
		0.36	14	AV4 +0.10			0.50	17	AV5 -0.03			0.36	14	AV4 -0.05
		0.52	17	AV3 +0.07			0.09	5	AV4 -0.02			0.24	10	AV3 -0.05
		0.16	8	AV1 +0.02	116	81	0.36	14	AV7 +0.02			0.20	9	AV2 -0.02
115	70	0.17	8	AV3 -0.02			0.27	11	AV2 +0.00	118	91	0.29	12	AV8 +0.05
		0.30	12	AV2 +0.00	116	91	0.45	16	AV7 +0.02			0.12	6	AV7 +0.05
		0.28	12	AV6 +0.02			0.60	19	AV4 -0.02			0.61	19	AV4 -0.02
		0.32	13	AV5 +0.02			0.31	13	AV3 -0.02			0.55	18	AV2 +0.02
		0.19	9	AV4 +0.00			0.29	12	AV2 -0.02	118	93	0.37	14	AV7 +0.02
115	72	0.47	16	AV8 +0.07	116	93	0.16	8	AV4 +0.00			0.41	15	AV6 +0.00
		0.23	10	AV3 +0.00			0.33	13	AV2 -0.02			0.39	15	AV5 -0.05
		0.16	8	AV2 -0.02			0.16	8	AV1 -0.02			0.28	12	AV3 -0.05
		0.12	6	AV1 -0.02	116	95	0.24	10	AV4 +0.00	118	101	0.18	8	AV4 -0.02
115	74	0.33	13	AV7 +0.02			0.62	19	AV3 -0.05	118	109	0.19	9	AV6 +0.02
		0.30	12	AV5 +0.00	116	97	0.25	11	AV3 +0.00	118	127	0.13	7	AV7 +0.02
		0.54	18	AV4 +0.00			0.16	8	AV2 +0.00			0.17	8	AV5 +0.05
		0.33	13	AV1 +0.00	116	99	0.16	8	AV6 +0.02			0.15	8	AV4 +0.05
115	76	0.19	9	AV7 +0.00			0.17	8	AV3 +0.02			0.16	8	AV3 +0.02
115	80	0.14	7	AV3 -0.02			0.18	8	AV2 -0.02			0.23	10	AV2 -0.02
		0.11	6	AV2 +0.00			0.11	6	AV1 +0.00	119	54	0.12	7	AV7 +0.00
115	82	0.32	13	AV2 +0.00	116	103	0.15	7	AV2 -0.02			0.10	6	AV6 -0.02
		0.24	10	AV8 +0.05	116	129	0.16	8	AV8 +0.07	119	72	0.23	10	AV6 +0.05
115	92	0.53	18	AV7 +0.02			0.15	7	AV6 +0.00			0.61	19	AV5 +0.09
		0.51	17	AV3 -0.05			0.22	10	AV5 -0.03			0.29	12	AV3 +0.05
		0.56	18	AV2 -0.02			0.12	6	AV4 +0.03			0.26	11	AV2 +0.00
115	94	0.20	9	AV6 -0.16	117	44	0.15	7	AV6 -0.02			0.15	7	AV1 -0.02
		0.15	7	AV3 -0.19			0.25	11	AV5 +0.00	119	74	0.20	9	AV8 +0.02
115	96	0.16	8	AV6 +0.00			0.14	7	AV2 -0.02			0.34	13	AV7 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.26	11	AV4 -0.05			0.23	10	AV4 +0.02			0.23	10	AV4 +0.08
		0.19	9	AV3 +0.00			0.15	7	AV3 +0.00			0.12	6	AV6 +0.00
		0.28	12	AV2 +0.00			0.15	7	AV5 +0.02			0.54	18	AV4 -0.05
		0.25	11	AV1 -0.02			0.11	6	AV8 +0.00			0.37	14	AV3 +0.00
119	76	0.57	18	AV4 +0.00	120	123	0.39	15	AV6 +0.02	123	74	0.39	14	AV7 +0.05
119	78	0.43	15	AV8 +0.02			0.25	11	AV5 +0.00			0.27	11	AV6 +0.00
		0.44	16	AV7 +0.02			0.18	8	AV4 +0.10			0.18	8	AV5 -0.03
		0.26	11	AV6 +0.00			0.37	14	AV3 +0.02			0.19	9	AV4 +0.00
		0.08	5	AV5 -0.18			0.10	6	AV2 -0.02			0.16	8	AV3 +0.00
		0.11	6	AV4 -0.05	121	76	0.12	6	AV6 +0.00	123	76	0.17	8	AV8 +0.07
		0.11	6	AV3 -0.02	121	78	0.33	13	AV7 +0.05			0.46	16	AV7 +0.07
119	80	0.40	15	AV5 -0.03			0.21	10	AV4 +0.05			0.14	7	AV6 +0.07
		0.17	8	AV4 -0.02			0.20	9	AV3 +0.05			0.17	8	AV5 +0.05
		0.20	9	AV2 +0.00			0.16	8	AV2 -0.02			0.16	8	AV4 +0.05
119	88	0.11	6	AV2 +0.16	121	80	0.35	14	AV8 +0.02			0.14	7	AV3 +0.00
		0.30	12	AV1 -0.02			0.21	9	AV7 +0.00	123	78	0.23	10	AV7 +0.05
		0.35	13	AV8 +0.02			0.28	11	AV6 +0.00			0.18	8	AV6 +0.02
		0.57	18	AV6 +0.02			0.19	9	AV5 -0.05			0.16	8	AV3 -0.05
		0.25	11	AV5 +0.00			0.15	7	AV4 +0.00	123	80	0.21	9	AV6 +0.00
119	94	0.14	7	AV6 +0.00			0.10	6	AV2 -0.05			0.39	15	AV5 +0.02
		0.19	9	AV2 -0.05	121	82	0.25	11	AV8 +0.02			0.14	7	AV4 +0.21
119	96	0.42	15	AV6 +0.07			0.49	17	AV7 +0.00			0.20	9	AV3 +0.00
		0.30	12	AV4 +0.10			0.19	9	AV5 +0.00	123	88	0.61	19	AV4 -0.05
		0.29	12	AV3 +0.07			0.34	13	AV4 -0.02			0.32	13	AV2 +0.00
		0.35	13	AV2 +0.05			0.28	11	AV3 -0.02			0.27	11	AV7 +0.02
		0.23	10	AV1 +0.00			0.10	6	AV2 -0.07			0.44	16	AV6 -0.02
119	100	0.35	13	AV5 +0.02	121	90	0.16	8	AV7 +0.02	123	90	0.45	16	AV5 +0.00
		0.33	13	AV4 +0.03			0.39	15	AV2 +0.14			0.32	13	AV1 -0.02
		0.28	12	AV3 +0.02			0.25	11	AV1 -0.02	123	92	0.22	10	AV7 +0.00
		0.10	6	AV2 +0.00	121	92	0.18	9	AV8 +0.07			0.48	17	AV5 -0.03
119	106	0.14	7	AV5 +0.05			0.27	11	AV5 +0.00			0.30	12	AV4 +0.00
		0.18	8	AV4 -0.05			0.11	6	AV1 +0.00			0.56	18	AV3 -0.02
119	122	0.11	6	AV7 +0.00	121	94	0.47	16	AV8 +0.05			0.47	16	AV2 -0.02
		0.21	9	AV6 -0.02			0.15	7	AV3 -0.02			0.21	9	AV1 -0.02
		0.15	8	AV4 +0.03	121	96	0.10	6	AV2 -0.20	123	94	0.24	10	AV8 +0.07
		0.14	7	AV3 -0.02	121	102	0.19	9	AV4 -0.02			0.58	18	AV5 +0.02
		0.11	6	AV2 +0.02			0.35	14	AV3 -0.05			0.28	12	AV3 -0.02
120	71	0.15	7	AV7 -0.02	121	108	0.08	5	AV6 +0.02			0.22	10	AV2 +0.00
120	73	0.19	9	AV7 +0.00			0.17	8	AV5 +0.02			0.12	6	AV1 -0.02
		0.31	13	AV6 +0.00			0.12	6	AV3 +0.02	123	96	0.14	7	AV6 -0.02
120	75	0.19	9	AV7 +0.02	121	110	0.18	9	AV5 +0.02	123	98	0.10	5	AV6 +0.02
120	77	0.10	6	AV2 +0.00			0.10	6	AV4 +0.05			0.11	6	AV2 -0.20
120	79	0.17	8	AV8 +0.00	122	61	0.19	9	AV7 +0.02	123	100	0.13	7	AV8 +0.05
		0.45	16	AV6 +0.02	122	65	0.12	6	AV5 -0.08			0.16	8	AV7 +0.00
		0.11	6	AV4 -0.05			0.30	12	AV4 -0.02	123	104	0.20	9	AV6 +0.00
		0.11	6	AV3 +0.00			0.21	9	AV3 -0.02			0.26	11	AV4 +0.00
120	81	0.17	8	AV4 -0.02			0.23	10	AV2 +0.00			0.29	12	AV3 -0.02
		0.18	8	AV3 +0.00	122	67	0.25	11	AV7 +0.02	123	106	0.13	7	AV7 +0.02
120	91	0.48	17	AV7 +0.02			0.19	9	AV6 +0.02			0.25	11	AV6 +0.05
		0.41	15	AV6 +0.02			0.19	9	AV4 -0.02			0.22	10	AV5 +0.00
		0.62	19	AV3 -0.05	122	73	0.14	7	AV7 -0.16			0.12	6	AV4 -0.02
120	93	0.24	10	AV5 +0.02	122	75	0.34	13	AV7 +0.00	124	55	0.19	9	AV7 +0.02
		0.38	14	AV2 -0.02			0.28	12	AV5 -0.05			0.19	9	AV6 +0.02
120	95	0.29	12	AV7 +0.05	122	77	0.29	12	AV7 +0.05			0.30	12	AV5 +0.05
		0.13	7	AV2 +0.00			0.16	8	AV6 -0.02			0.36	14	AV4 +0.05
120	97	0.62	19	AV7 +0.02	122	79	0.27	11	AV2 +0.00			0.12	6	AV8 +0.00
		0.61	19	AV5 -0.03	122	81	0.24	10	AV4 -0.07	124	63	0.16	8	AV5 +0.00
		0.19	9	AV4 -0.07			0.26	11	AV3 -0.05			0.28	11	AV2 +0.00
		0.57	18	AV3 -0.02			0.13	7	AV2 -0.02	124	69	0.46	16	AV8 +0.05
		0.30	12	AV2 -0.05	122	83	0.27	11	AV1 -0.05			0.50	17	AV4 +0.00
120	99	0.18	9	AV1 +0.00	122	87	0.48	17	AV4 -0.05			0.31	12	AV1 -0.02
120	103	0.30	12	AV6 -0.02			0.15	7	AV3 -0.02	124	71	0.27	11	AV7 +0.02
		0.47	16	AV4 +0.00			0.19	9	AV2 -0.05			0.22	10	AV6 +0.00
		0.14	7	AV3 -0.02			0.30	12	AV8 +0.05			0.30	12	AV5 +0.00
		0.51	17	AV2 -0.02			0.46	16	AV7 +0.02			0.14	7	AV2 +0.00
120	105	0.25	11	AV6 +0.02	122	93	0.11	6	AV1 +0.02			0.23	10	AV4 -0.02
		0.18	8	AV5 +0.05	122	95	0.16	8	AV2 -0.02			0.27	11	AV3 -0.02
		0.20	9	AV4 +0.05	122	101	0.15	7	AV6 +0.02	124	73	0.24	10	AV5 -0.03
120	107	0.25	11	AV7 +0.07			0.17	8	AV5 -0.05			0.27	11	AV3 -0.02
		0.15	8	AV6 +0.05	122	115	0.17	8	AV7 +0.02	124	75	0.39	14	AV7 +0.02
		0.15	7	AV5 +0.05			0.14	7	AV5 +0.02			0.29	12	AV6 +0.02
		0.19	9	AV4 +0.05	123	54	0.14	7	AV6 +0.05			0.20	9	AV5 -0.03

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.16	8	AV4 -0.02			0.20	9	AV5 -0.03			0.21	10	AV5 +0.07
124	77	0.13	7	AV5 -0.05			0.49	17	AV4 -0.02			0.27	11	AV4 +0.08
		0.13	7	AV4 -0.05			0.18	8	AV3 -0.02			0.14	7	AV3 +0.05
124	87	0.18	8	AV3 -0.02			0.12	6	AV2 -0.02	127	72	0.16	8	AV7 +0.00
		0.33	13	AV2 +0.00	125	108	0.16	8	AV6 +0.00			0.13	7	AV6 +0.00
		0.34	13	AV7 +0.05			0.17	8	AV3 -0.02	127	74	0.29	12	AV7 +0.00
		0.60	19	AV6 +0.00	125	112	0.18	9	AV7 +0.07	127	76	0.46	16	AV7 +0.11
124	91	0.39	15	AV7 +0.00	125	120	0.20	9	AV6 +0.02			0.32	13	AV4 +0.08
		0.17	8	AV6 -0.02			0.17	8	AV5 +0.00	127	80	0.12	6	AV6 +0.00
124	93	0.31	12	AV6 +0.19	126	55	0.22	10	AV8 +0.05			0.14	7	AV5 -0.03
		0.54	18	AV5 +0.00			0.13	7	AV5 +0.02			0.15	7	AV4 +0.00
		0.16	8	AV4 -0.02			0.13	7	AV4 -0.02			0.09	5	AV3 -0.02
		0.14	7	AV3 -0.02	126	67	0.44	16	AV6 +0.09	127	88	0.58	19	AV4 -0.07
		0.09	5	AV2 -0.02			0.28	12	AV5 +0.07			0.18	9	AV1 -0.05
124	95	0.18	9	AV7 +0.05			0.31	12	AV4 +0.10	127	90	0.59	19	AV3 -0.05
		0.15	7	AV6 +0.05			0.17	8	AV3 +0.05			0.60	19	AV2 -0.05
		0.34	13	AV4 +0.00	126	69	0.14	7	AV8 +0.07			0.33	13	AV1 -0.02
		0.37	14	AV3 +0.00			0.32	13	AV5 +0.02	127	92	0.21	9	AV1 -0.05
		0.13	7	AV2 +0.02			0.37	14	AV4 +0.05	127	94	0.15	7	AV7 +0.05
124	97	0.11	6	AV2 -0.18	126	71	0.15	7	AV7 +0.00			0.18	8	AV6 -0.19
124	99	0.23	10	AV6 +0.07			0.15	7	AV4 -0.02			0.35	13	AV5 -0.03
		0.33	13	AV3 +0.02	126	73	0.15	8	AV7 +0.00			0.33	13	AV4 -0.02
		0.26	11	AV2 -0.02			0.15	7	AV2 +0.02			0.23	10	AV3 -0.02
124	105	0.22	10	AV4 +0.05	126	75	0.23	10	AV8 +0.07			0.11	6	AV2 -0.02
124	113	0.13	7	AV3 -0.05			0.28	11	AV7 +0.05			0.17	8	AV1 -0.02
		0.15	7	AV1 -0.02			0.14	7	AV6 +0.02	127	96	0.14	7	AV6 +0.00
125	50	0.30	12	AV8 +0.02			0.19	9	AV5 +0.02			0.28	11	AV3 +0.00
		0.21	10	AV7 -0.03			0.26	11	AV4 +0.00			0.13	7	AV2 -0.02
		0.15	7	AV6 -0.02	126	77	0.19	9	AV8 +0.07			0.21	10	AV1 +0.00
125	66	0.17	8	AV4 +0.13			0.26	11	AV4 -0.02	127	100	0.49	17	AV4 +0.03
125	68	0.17	8	AV3 -0.02			0.19	9	AV3 -0.05			0.19	9	AV2 -0.05
		0.16	8	AV2 -0.02	126	79	0.45	16	AV7 +0.00	127	102	0.16	8	AV7 +0.05
		0.17	8	AV7 +0.00			0.13	7	AV6 +0.00			0.31	12	AV4 +0.05
		0.18	9	AV4 +0.00			0.35	14	AV5 -0.03			0.23	10	AV3 +0.00
125	72	0.25	11	AV7 +0.05			0.18	8	AV4 -0.02			0.19	9	AV2 +0.02
		0.14	7	AV5 +0.02	126	93	0.16	8	AV6 +0.16	127	108	0.10	6	AV6 +0.02
125	74	0.55	18	AV6 +0.02			0.40	15	AV5 +0.00			0.16	8	AV5 -0.03
		0.48	16	AV5 +0.05			0.18	8	AV4 -0.02			0.14	7	AV3 -0.02
		0.42	15	AV4 +0.03			0.17	8	AV3 -0.02			0.10	6	AV2 -0.02
		0.13	7	AV2 -0.02			0.29	12	AV2 -0.02	127	110	0.15	7	AV5 +0.00
125	76	0.14	7	AV7 +0.24	126	95	0.21	9	AV4 +0.03	127	118	0.13	7	AV8 +0.00
		0.18	8	AV3 +0.00			0.26	11	AV3 +0.00	128	53	0.12	6	AV8 +0.00
125	78	0.16	8	AV7 -0.14			0.30	12	AV2 +0.00	128	67	0.13	7	AV1 -0.02
125	80	0.43	15	AV6 +0.10			0.40	15	AV8 +0.10			0.32	13	AV7 +0.02
		0.57	18	AV4 +0.08			0.29	12	AV7 +0.07	128	69	0.23	10	AV5 +0.00
		0.56	18	AV3 +0.02			0.24	10	AV6 +0.02	128	73	0.41	15	AV7 +0.05
		0.15	7	AV2 +0.00			0.17	8	AV5 +0.02			0.25	11	AV5 +0.00
125	82	0.59	19	AV3 -0.05	126	97	0.25	11	AV5 +0.05	128	75	0.12	6	AV7 -0.16
		0.18	8	AV2 -0.02			0.40	15	AV4 +0.03			0.14	7	AV6 -0.02
125	88	0.34	13	AV3 -0.05			0.23	10	AV2 +0.00	128	77	0.16	8	AV7 +0.02
		0.43	15	AV2 -0.05	126	99	0.10	5	AV5 -0.03	128	79	0.15	8	AV8 +0.02
125	90	0.36	14	AV8 +0.05	126	101	0.13	7	AV5 -0.05			0.47	16	AV7 +0.00
		0.58	19	AV3 -0.05			0.22	10	AV4 -0.05			0.22	10	AV5 -0.03
		0.49	17	AV2 -0.05			0.12	6	AV3 -0.02	128	87	0.54	18	AV8 +0.05
125	92	0.18	8	AV8 +0.07	126	103	0.11	6	AV7 +0.05			0.52	17	AV7 +0.02
		0.11	6	AV7 -0.14			0.49	17	AV5 -0.05			0.58	19	AV6 +0.02
		0.46	16	AV4 -0.05			0.31	12	AV4 -0.05	128	95	0.19	9	AV8 +0.09
		0.29	12	AV3 -0.02			0.49	17	AV3 -0.05			0.40	15	AV5 -0.03
		0.11	6	AV2 +0.00			0.39	14	AV2 -0.05			0.23	10	AV4 -0.05
125	98	0.26	11	AV4 -0.02			0.21	9	AV1 +0.00			0.10	6	AV3 +0.00
		0.19	9	AV3 -0.02	126	105	0.21	9	AV8 +0.07			0.17	8	AV2 +0.14
		0.09	5	AV2 -0.05			0.16	8	AV6 +0.05	128	97	0.14	7	AV6 +0.02
125	100	0.14	7	AV5 +0.00			0.16	8	AV5 +0.00			0.24	10	AV4 -0.02
		0.08	5	AV4 -0.02			0.45	16	AV4 -0.05	128	99	0.50	17	AV8 +0.05
125	102	0.15	7	AV7 +0.05			0.49	17	AV3 -0.05			0.31	13	AV5 -0.03
		0.23	10	AV6 +0.10	126	109	0.11	6	AV4 +0.00			0.48	16	AV3 +0.00
		0.26	11	AV5 +0.09	127	52	0.21	9	AV4 -0.05			0.51	17	AV2 -0.05
		0.19	9	AV4 +0.08	127	68	0.19	9	AV7 +0.00	128	101	0.22	10	AV6 +0.02
		0.13	7	AV3 +0.02			0.31	12	AV4 +0.08			0.37	14	AV5 -0.03
		0.09	5	AV2 +0.18			0.12	6	AV3 +0.00			0.23	10	AV4 -0.05
125	104	0.31	12	AV6 +0.07			0.27	11	AV1 +0.00			0.11	6	AV3 -0.05
125	106	0.22	10	AV6 +0.00	127	70	0.14	7	AV7 +0.12	128	103	0.10	5	AV4 -0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
128	107	0.17	8	AV2 +0.00	130	79	0.51	17	AV8 +0.07	132	79	0.14	7	AV3 +0.00
		0.30	12	AV7 +0.07			0.25	11	AV4 +0.03			0.29	12	AV8 +0.07
		0.57	18	AV6 +0.00			0.32	13	AV3 +0.02			0.40	15	AV4 -0.07
		0.16	8	AV5 +0.00	130	93	0.52	17	AV8 +0.10			0.25	11	AV3 -0.05
		0.16	8	AV4 -0.02			0.57	18	AV6 +0.09	132	81	0.34	13	AV5 -0.03
		0.11	6	AV3 -0.02			0.34	13	AV5 +0.07	132	85	0.27	11	AV6 -0.02
		0.11	6	AV2 -0.05	130	95	0.47	16	AV4 +0.03	132	87	0.35	14	AV7 +0.07
128	109	0.17	8	AV5 -0.05			0.42	15	AV3 +0.02			0.39	15	AV5 +0.02
		0.14	7	AV4 -0.02			0.19	9	AV2 +0.00			0.13	7	AV4 +0.00
128	117	0.28	12	AV5 +0.02			0.15	7	AV1 -0.02			0.10	5	AV3 +0.00
		0.37	14	AV4 +0.00			0.39	14	AV8 +0.07			0.08	5	AV2 -0.02
		0.17	8	AV2 -0.02			0.20	9	AV5 +0.07	132	93	0.34	13	AV5 -0.03
129	66	0.24	10	AV5 +0.05	130	97	0.16	8	AV1 +0.00			0.44	16	AV4 -0.05
		0.22	10	AV3 +0.02			0.32	13	AV4 +0.05			0.54	18	AV3 -0.05
129	68	0.17	8	AV8 +0.02			0.62	19	AV5 +0.07			0.36	14	AV2 -0.05
		0.17	8	AV7 +0.05	130	101	0.13	7	AV6 +0.10	132	95	0.12	6	AV2 -0.02
		0.18	9	AV6 +0.02			0.26	11	AV5 +0.00			0.25	11	AV7 +0.02
		0.19	9	AV2 +0.00			0.47	16	AV4 +0.03			0.09	5	AV5 -0.03
129	70	0.18	8	AV7 +0.05			0.29	12	AV3 +0.00			0.14	7	AV4 +0.00
129	72	0.15	7	AV7 +0.18			0.19	9	AV2 -0.05	132	97	0.31	12	AV7 +0.05
129	74	0.31	12	AV7 +0.05	130	109	0.16	8	AV5 -0.05			0.14	7	AV6 +0.05
		0.62	19	AV5 +0.05	130	113	0.20	9	AV8 -0.14			0.20	9	AV5 -0.05
		0.41	15	AV4 +0.03	131	68	0.12	6	AV3 +0.00			0.49	17	AV4 -0.07
		0.21	9	AV2 -0.02			0.13	7	AV2 -0.02			0.34	13	AV3 -0.02
129	78	0.37	14	AV8 +0.09	131	70	0.34	13	AV7 +0.05			0.13	7	AV2 -0.04
		0.07	5	AV2 -0.16			0.17	8	AV5 -0.03	132	99	0.16	8	AV6 +0.07
129	86	0.16	8	AV8 +0.05	131	74	0.55	18	AV8 +0.07			0.34	13	AV4 +0.08
		0.17	8	AV5 +0.00			0.13	7	AV3 +0.02			0.13	7	AV2 -0.16
129	94	0.15	8	AV7 +0.05			0.25	11	AV2 -0.02	132	101	0.24	10	AV4 -0.02
		0.14	7	AV5 -0.08	131	76	0.18	9	AV6 +0.05	133	68	0.25	11	AV5 -0.08
		0.21	10	AV3 -0.02			0.42	15	AV5 +0.05			0.29	12	AV4 -0.05
		0.25	11	AV2 -0.05			0.26	11	AV4 +0.00			0.54	18	AV3 -0.05
129	96	0.19	9	AV5 -0.03	131	78	0.21	9	AV7 +0.07			0.21	10	AV1 -0.07
		0.25	11	AV4 -0.02			0.51	17	AV3 +0.00	133	70	0.52	17	AV8 +0.05
		0.10	6	AV2 +0.16	131	82	0.33	13	AV5 -0.03			0.19	9	AV6 -0.02
		0.14	7	AV1 +0.00	131	88	0.16	8	AV8 +0.05	133	72	0.63	19	AV6 -0.02
129	98	0.23	10	AV7 +0.00			0.23	10	AV6 +0.05			0.48	17	AV5 -0.05
		0.55	18	AV5 +0.00			0.46	16	AV3 -0.05			0.51	17	AV4 -0.07
		0.21	10	AV4 -0.02	131	92	0.49	17	AV4 -0.02	133	74	0.36	14	AV8 +0.07
		0.21	10	AV3 -0.02	131	94	0.46	16	AV8 +0.10			0.20	9	AV6 -0.18
		0.19	9	AV2 +0.16			0.20	9	AV5 +0.00			0.30	12	AV4 -0.02
129	100	0.23	10	AV6 +0.05			0.41	15	AV2 -0.05			0.13	7	AV2 -0.05
129	102	0.11	6	AV6 +0.05			0.18	9	AV1 -0.02	133	76	0.19	9	AV7 +0.09
		0.13	7	AV5 +0.02	131	96	0.17	8	AV6 +0.05			0.49	17	AV5 +0.02
		0.22	10	AV4 -0.02			0.18	9	AV5 -0.03			0.11	6	AV3 +0.16
129	104	0.18	8	AV4 +0.00			0.16	8	AV4 -0.02			0.11	6	AV2 +0.02
		0.15	7	AV3 -0.07			0.13	7	AV2 +0.14			0.10	6	AV1 -0.02
		0.15	8	AV2 -0.05	131	98	0.15	7	AV7 -0.02	133	78	0.28	12	AV8 +0.09
		0.13	7	AV1 -0.05			0.13	7	AV6 +0.05			0.15	8	AV7 +0.07
		0.20	9	AV8 +0.07			0.17	8	AV4 -0.02			0.18	9	AV6 +0.05
		0.26	11	AV5 -0.03			0.09	5	AV2 -0.05			0.38	14	AV5 +0.02
129	106	0.11	6	AV7 +0.07	131	100	0.17	8	AV6 +0.02			0.10	6	AV4 -0.02
		0.10	6	AV6 +0.09			0.12	6	AV5 +0.00			0.13	7	AV3 -0.05
		0.40	15	AV5 +0.00	131	102	0.53	17	AV7 +0.02	133	86	0.51	17	AV4 -0.02
		0.19	9	AV4 -0.02			0.16	8	AV6 +0.02			0.19	9	AV1 -0.05
		0.12	6	AV3 +0.00			0.15	7	AV5 +0.02	133	88	0.19	9	AV4 -0.12
		0.11	6	AV2 -0.02			0.14	7	AV3 -0.02			0.14	7	AV3 -0.09
129	108	0.10	5	AV6 +0.00	132	69	0.19	9	AV5 +0.12			0.13	7	AV2 -0.09
		0.10	6	AV5 -0.03			0.34	13	AV4 +0.13			0.46	16	AV7 -0.02
130	69	0.11	6	AV6 +0.02	132	71	0.21	10	AV5 +0.02			0.17	8	AV5 -0.08
		0.22	10	AV5 +0.02			0.14	7	AV3 +0.00			0.15	7	AV8 +0.05
130	71	0.21	10	AV3 +0.00			0.44	16	AV8 +0.07	133	92	0.42	15	AV8 +0.10
		0.42	15	AV6 +0.02	132	73	0.33	13	AV8 +0.07			0.44	16	AV6 +0.02
		0.16	8	AV5 +0.00			0.45	16	AV7 +0.04			0.29	12	AV5 -0.03
		0.21	9	AV4 +0.00			0.17	8	AV6 -0.18			0.15	8	AV1 -0.05
130	73	0.21	9	AV8 +0.05	132	75	0.28	11	AV8 +0.07	133	94	0.22	10	AV7 +0.05
		0.31	12	AV7 +0.02			0.46	16	AV7 +0.02			0.45	16	AV6 +0.02
		0.16	8	AV6 -0.18			0.22	10	AV6 +0.07			0.32	13	AV5 +0.02
130	75	0.27	11	AV3 +0.00	132	77	0.14	7	AV8 +0.07			0.54	18	AV4 +0.00
		0.36	14	AV7 +0.05			0.08	5	AV7 +0.07			0.33	13	AV3 -0.02
		0.19	9	AV5 +0.00			0.40	15	AV6 +0.02	133	102	0.12	6	AV7 +0.07
		0.61	19	AV4 -0.05			0.15	7	AV5 +0.00	134	65	0.18	8	AV8 -0.09

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
134	67	0.23	10	AV7 +0.11			0.15	7	AV3 -0.05			0.31	12	AV5 +0.00
		0.16	8	AV6 +0.00			0.16	8	AV2 -0.05			0.15	8	AV4 -0.07
		0.44	16	AV5 +0.12			0.21	9	AV1 -0.05			0.12	6	AV3 -0.07
		0.62	19	AV4 +0.00			0.26	11	AV7 +0.05	138	79	0.23	10	AV7 +0.25
		0.16	8	AV2 -0.02	135	96	0.35	14	AV6 +0.02			0.60	19	AV6 -0.02
134	69	0.22	10	AV8 +0.07			0.13	7	AV2 -0.02			0.20	9	AV4 -0.02
		0.24	10	AV7 +0.20	136	71	0.28	12	AV8 +0.07			0.17	8	AV3 -0.02
		0.28	11	AV6 +0.05			0.25	11	AV5 +0.00			0.14	7	AV8 -0.02
134	71	0.24	10	AV7 +0.02	136	73	0.42	15	AV7 -0.07	138	81	0.19	9	AV8 +0.00
		0.16	8	AV6 +0.00			0.13	7	AV6 -0.20	138	83	0.24	11	AV8 +0.07
134	73	0.57	18	AV5 -0.08			0.21	10	AV5 +0.00			0.17	8	AV7 +0.05
		0.20	9	AV3 -0.05			0.41	15	AV4 -0.02			0.34	13	AV5 -0.05
		0.36	14	AV2 -0.07			0.12	6	AV3 +0.02	138	85	0.15	7	AV8 +0.20
134	75	0.16	8	AV7 -0.19			0.21	10	AV2 -0.02			0.23	10	AV7 +0.05
		0.39	14	AV6 -0.02			0.17	8	AV8 +0.05			0.38	14	AV6 +0.02
		0.23	10	AV5 -0.03	136	75	0.12	6	AV8 -0.11			0.18	8	AV4 -0.05
		0.14	7	AV4 -0.07			0.23	10	AV4 -0.02			0.18	9	AV5 -0.03
134	77	0.21	9	AV7 +0.05			0.20	9	AV3 -0.05	138	87	0.18	8	AV7 +0.05
		0.23	10	AV6 +0.02			0.13	7	AV2 -0.07	138	89	0.26	11	AV8 +0.07
134	79	0.42	15	AV8 +0.05			0.15	8	AV1 -0.07	138	93	0.10	6	AV8 +0.07
		0.35	14	AV7 +0.02	136	79	0.14	7	AV8 -0.12			0.31	13	AV7 +0.07
134	83	0.21	9	AV8 +0.07			0.29	12	AV7 +0.00			0.15	7	AV5 +0.05
		0.47	16	AV4 -0.05	136	81	0.08	5	AV2 -0.02	139	78	0.22	10	AV7 +0.23
		0.17	8	AV3 -0.05			0.37	14	AV8 +0.07			0.41	15	AV3 +0.00
134	85	0.28	12	AV7 +0.05			0.46	16	AV7 +0.07			0.16	8	AV2 -0.07
		0.40	15	AV6 +0.05			0.23	10	AV5 +0.02			0.13	7	AV1 -0.21
		0.25	11	AV5 +0.02			0.13	7	AV3 +0.14	139	86	0.26	11	AV8 +0.10
		0.23	10	AV4 -0.05	136	85	0.45	16	AV7 +0.07			0.40	15	AV7 +0.07
		0.37	14	AV3 -0.07			0.34	13	AV6 +0.02			0.14	7	AV6 +0.09
134	87	0.27	11	AV4 +0.00			0.25	11	AV4 -0.05	139	92	0.14	7	AV3 -0.02
		0.49	17	AV3 +0.00			0.12	6	AV3 -0.05			0.31	12	AV2 -0.23
		0.29	12	AV2 -0.05	136	91	0.53	17	AV8 +0.07			0.11	6	AV8 +0.10
134	89	0.45	16	AV6 +0.07			0.34	13	AV6 +0.07			0.40	15	AV6 +0.09
		0.18	8	AV5 +0.00			0.63	19	AV4 +0.00			0.21	10	AV5 +0.07
		0.14	7	AV8 +0.05			0.54	18	AV2 -0.05			0.43	15	AV4 +0.03
		0.46	16	AV7 +0.09			0.17	8	AV1 -0.05					
134	93	0.13	7	AV8 +0.07	136	93	0.14	7	AV8 +0.07					
		0.15	7	AV6 +0.19			0.42	15	AV2 -0.02					
		0.53	18	AV5 +0.02			0.30	12	AV1 -0.02					
		0.40	15	AV4 +0.03	136	95	0.15	7	AV6 +0.00					
		0.18	8	AV3 +0.00			0.19	9	AV4 -0.05					
		0.22	10	AV2 -0.11			0.11	6	AV2 -0.20					
134	95	0.15	7	AV6 +0.05	137	74	0.60	19	AV8 +0.09					
		0.29	12	AV4 -0.02			0.23	10	AV7 +0.09					
134	97	0.14	7	AV6 +0.05			0.60	19	AV6 +0.02					
		0.35	14	AV5 -0.05			0.17	8	AV5 +0.00					
		0.34	13	AV2 -0.05	137	76	0.22	10	AV7 +0.07					
		0.35	14	AV1 -0.02			0.26	11	AV6 +0.02					
134	103	0.17	8	AV7 +0.05			0.25	11	AV5 +0.00					
		0.26	11	AV6 +0.00			0.21	10	AV4 -0.05					
		0.32	13	AV5 +0.07			0.27	11	AV3 -0.02					
		0.28	11	AV4 -0.05			0.16	8	AV2 -0.05					
135	70	0.18	8	AV7 +0.07			0.14	7	AV1 -0.07					
		0.14	7	AV2 -0.02	137	78	0.18	8	AV7 -0.16					
135	72	0.23	10	AV7 +0.23	137	84	0.39	14	AV8 +0.07					
		0.16	8	AV6 +0.02	137	86	0.29	12	AV8 +0.07					
		0.16	8	AV5 +0.07			0.29	12	AV7 +0.00					
		0.15	7	AV4 +0.03	137	92	0.54	18	AV7 +0.02					
135	74	0.10	6	AV8 +0.28			0.31	12	AV6 +0.00					
		0.23	10	AV7 +0.23			0.12	6	AV3 -0.23					
		0.11	6	AV6 -0.18	137	94	0.28	12	AV8 +0.07					
		0.21	9	AV5 +0.07			0.36	14	AV7 +0.05					
		0.12	6	AV2 +0.00			0.15	7	AV6 -0.18					
		0.15	7	AV1 -0.05			0.15	7	AV5 +0.02					
135	76	0.17	8	AV7 +0.07	137	96	0.28	12	AV6 +0.07					
135	78	0.49	17	AV7 +0.09	138	73	0.24	10	AV7 +0.21					
135	80	0.28	12	AV7 +0.02			0.35	14	AV6 +0.21					
		0.07	4	AV2 -0.18	138	75	0.30	12	AV8 +0.02					
135	92	0.12	6	AV1 -0.02			0.21	10	AV7 +0.23					
135	94	0.36	14	AV8 +0.10			0.17	8	AV6 +0.05					
		0.21	9	AV6 +0.00			0.15	8	AV3 -0.05					
		0.19	9	AV4 +0.00	138	77	0.36	14	AV7 +0.23					

Total Tubes : 2611  
 Total Records: 6443

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
44	163	0.95	24	AV7 -0.22	66	103	1.54	30	AV6 +0.04	70	101	0.70	21	AV3 +0.00
46	7	0.64	20	AV6 +0.22			2.01	34	AV7 +0.05			2.91	38	AV6 +0.05
51	162	1.05	25	AV6 +0.23	66	105	0.70	21	AV3 +0.03			0.94	24	AV7 +0.02
52	153	0.77	22	AV6 -0.25			1.30	28	AV6 +0.05	70	103	0.83	23	AV7 -0.02
52	161	1.02	25	AV6 -0.33	66	113	0.67	20	AV3 +0.02	70	105	0.82	22	AV3 +0.04
53	162	0.70	21	AV6 +0.19			0.77	22	AV6 +0.00	70	109	1.42	29	AV6 +0.02
54	9	0.70	21	AV3 -0.21	66	121	0.65	20	AV6 -0.05			1.32	28	AV7 +0.00
		0.74	21	AV7 -0.22	66	145	0.69	20	AV7 -0.02	70	113	0.69	20	AV6 -0.02
55	10	0.89	23	AV6 -0.38	66	153	1.71	32	AV8 +0.00	71	76	0.86	23	AV6 +0.02
		0.67	20	AV7 -0.23			1.53	30	AV7 +0.00			1.25	28	AV7 +0.02
55	16	0.95	24	AV6 -0.03			1.02	25	AV6 -0.05	71	98	0.92	24	AV5 +0.04
55	160	0.84	23	AV3 +0.30			0.96	24	AV3 +0.03	71	102	0.94	24	AV3 +0.02
56	9	0.81	22	AV6 +0.20	67	20	0.87	23	AV6 -0.02			1.20	27	AV4 +0.00
56	11	0.96	24	AV6 -0.27	67	44	0.90	24	AV6 +0.00			0.64	20	AV6 +0.07
56	161	1.55	30	AV6 -0.33	67	50	0.67	20	AV6 +0.02	71	104	0.96	24	AV6 +0.02
57	116	0.70	21	AV6 -0.03	67	52	1.52	30	AV6 +0.02	71	108	0.73	21	AV3 +0.02
57	158	0.74	21	AV6 -0.27			0.77	22	AV7 -0.02			0.73	21	AV4 -0.02
58	11	0.83	23	AV6 -0.03	67	74	1.27	28	AV6 +0.02	71	116	0.65	20	AV5 +0.02
		1.19	27	AV7 +0.00			0.77	22	AV7 -0.02	72	15	0.64	20	AV4 +0.51
59	12	0.69	20	AV6 -0.18	67	76	0.64	20	AV3 +0.00	72	25	0.86	23	AV6 +0.00
59	16	0.73	21	AV6 +0.00			0.82	22	AV6 +0.00	72	67	1.10	26	AV5 +0.08
59	156	0.68	20	AV6 -0.05	67	102	1.13	26	AV3 +0.03			1.20	27	AV6 +0.05
59	160	1.16	27	AV6 -0.29			0.91	24	AV6 +0.02			0.83	23	AV2 +0.05
60	11	1.04	25	AV6 -0.26	67	104	1.15	27	AV3 +0.00			1.11	26	AV3 +0.02
		0.66	20	AV7 -0.21			1.74	32	AV6 +0.02	72	71	1.42	29	AV6 +0.00
60	141	0.65	20	AV6 -0.05	67	132	0.75	21	AV6 -0.05			1.23	27	AV7 +0.02
60	153	1.23	27	AV6 -0.05	67	146	1.65	31	AV3 +0.03	72	75	1.52	30	AV6 +0.02
60	157	1.24	28	AV7 +0.00	67	148	1.16	27	AV6 -0.05			1.05	25	AV7 +0.02
		1.41	29	AV6 -0.05			1.10	26	AV3 +0.00	72	79	0.68	20	AV4 -0.02
61	16	0.85	23	AV6 -0.03	67	154	2.29	35	AV6 -0.03			0.73	21	AV5 +0.05
61	116	1.08	26	AV6 -0.05			1.90	33	AV3 +0.03			1.98	33	AV6 +0.02
61	156	0.98	25	AV8 -0.16	68	17	0.98	25	AV6 -0.02			1.25	28	AV7 +0.02
		1.99	34	AV6 -0.05	68	67	0.77	22	AV6 +0.05			1.34	28	AV8 +0.02
62	11	1.37	29	AV6 -0.23	68	75	0.71	21	AV2 +0.00	72	89	0.77	22	AV6 +0.00
		0.69	20	AV7 +0.28			0.93	24	AV3 +0.03	72	91	0.91	24	AV3 +0.04
62	13	0.78	22	AV6 +0.00			2.40	36	AV6 +0.05			0.71	21	AV5 +0.11
62	15	0.80	22	AV6 -0.03			0.91	24	AV7 +0.00			0.96	24	AV6 +0.05
62	105	0.88	23	AV6 +0.05	68	89	0.77	22	AV3 +0.00	72	101	0.81	22	AV5 +0.02
62	107	1.09	26	AV6 +0.02	68	99	0.70	21	AV6 +0.05			1.68	31	AV6 +0.02
62	153	0.68	20	AV8 +0.00	68	101	1.23	27	AV6 +0.02	72	103	1.02	25	AV3 +0.02
		0.76	21	AV7 +0.00	68	111	1.95	33	AV6 +0.00			2.13	34	AV5 +0.09
		0.72	21	AV6 -0.03			0.90	24	AV7 +0.00			1.46	30	AV6 +0.07
62	157	0.66	20	AV6 -0.05	68	115	0.66	20	AV3 +0.00			0.94	24	AV7 +0.05
63	12	2.22	35	AV3 +0.08			1.60	31	AV6 +0.00	72	105	0.79	22	AV3 +0.02
		1.22	27	AV6 -0.25			1.77	32	AV7 +0.05	72	107	1.63	31	AV6 +0.02
63	38	0.67	20	AV6 +0.02	68	147	1.18	27	AV6 -0.02	72	109	1.48	30	AV5 +0.06
63	114	0.93	24	AV6 -0.05	68	149	0.83	23	AV6 -0.05			1.21	27	AV6 +0.02
63	134	0.83	23	AV6 -0.05	68	155	1.06	26	AV8 -0.16	73	18	1.22	27	AV4 +0.37
63	144	0.89	23	AV6 -0.03			2.81	38	AV7 -0.02			0.79	22	AV6 -0.02
63	146	1.17	27	AV6 -0.05			1.73	32	AV6 -0.05			0.79	22	AV7 +0.02
64	13	0.90	24	AV6 -0.05			1.03	25	AV3 +0.00	73	68	0.67	20	AV5 +0.02
64	17	0.99	25	AV6 -0.05	68	157	1.00	25	AV7 -0.02	73	72	0.64	20	AV6 +0.02
64	29	1.07	26	AV6 +0.02			2.32	35	AV6 -0.02	73	74	2.35	36	AV4 -0.11
64	75	0.71	21	AV6 +0.05	69	74	0.67	20	AV6 +0.02			1.88	33	AV5 +0.04
64	155	1.11	26	AV3 +0.03	69	88	0.64	20	AV3 +0.03			2.47	36	AV6 +0.02
65	12	0.95	24	AV6 -0.22			1.58	31	AV6 +0.02			1.55	30	AV7 +0.00
65	108	0.87	23	AV6 +0.02	69	100	1.20	23	AV4 +0.59	73	76	0.82	22	AV3 +0.04
65	110	0.84	23	AV6 +0.00			0.97	24	AV6 +0.05			1.15	27	AV4 +0.06
65	134	1.31	28	AV6 +0.00	69	102	1.88	32	AV4 +1.22			2.05	34	AV5 +0.07
65	144	0.81	22	AV6 -0.05	69	104	0.64	20	AV2 +0.02			1.39	29	AV6 +0.05
65	152	0.71	21	AV7 -0.05			2.19	35	AV6 +0.02			1.42	29	AV7 +0.02
		1.39	29	AV6 -0.20			0.69	20	AV7 +0.02	73	88	1.00	25	AV3 +0.02
65	154	1.58	31	AV6 -0.03			0.86	21	AV4 +1.14			0.72	21	AV4 -0.02
		0.98	25	AV3 +0.05	69	106	2.21	34	AV4 +1.04			1.44	29	AV5 +0.02
65	158	0.67	20	AV6 -0.23			0.84	23	AV6 +0.02			1.23	27	AV6 +0.00
66	13	1.49	30	AV6 -0.02	69	108	0.84	23	AV3 +0.03			0.96	24	AV7 +0.00
66	15	1.05	25	AV3 +0.07			2.15	34	AV4 +1.02	73	92	0.68	20	AV4 +0.17
		2.13	34	AV6 -0.02			2.01	34	AV6 +0.02	73	94	0.89	23	AV5 +0.05
66	35	0.98	25	AV6 +0.00			1.01	25	AV7 +0.00			0.84	23	AV6 +0.00
66	61	0.86	23	AV6 +0.00	69	112	0.97	22	AV4 +0.85	73	96	0.85	23	AV4 +0.03
66	99	1.12	26	AV6 +0.05	69	154	1.42	29	AV6 -0.02			0.92	24	AV5 +0.05
66	101	0.67	20	AV6 +0.05	70	97	0.68	20	AV6 +0.02			0.88	23	AV6 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
73	98	0.89	23	AV5 +0.02			0.81	22	AV7 +0.02			2.40	36	AV5 +0.05
73	102	2.12	34	AV4 -0.02	75	92	0.81	22	AV6 +0.02			2.30	35	AV6 +0.02
		3.07	39	AV5 +0.02	75	94	0.65	20	AV3 +0.00			1.24	27	AV7 +0.02
		1.76	32	AV6 +0.02			1.46	30	AV4 +0.03	76	115	0.77	22	AV4 +0.06
		0.86	23	AV7 +0.00			1.05	25	AV5 +0.05			0.66	20	AV5 +0.02
73	104	2.64	37	AV5 +0.04			0.92	24	AV6 +0.00			1.21	27	AV6 -0.02
		2.57	37	AV6 +0.02	75	96	1.87	33	AV4 +0.03	77	18	0.87	23	AV4 +0.22
73	106	0.74	21	AV4 +0.04			1.89	33	AV5 +0.05			0.66	20	AV6 -0.05
		0.69	20	AV2 +0.02			2.05	34	AV6 +0.02	77	64	0.64	20	AV3 +0.02
		1.10	26	AV3 +0.02	75	98	1.01	25	AV4 +0.06	77	72	1.61	31	AV5 +0.00
73	108	0.83	23	AV3 +0.02			0.84	23	AV5 +0.02			1.36	29	AV6 +0.00
		0.71	21	AV4 +0.03			0.75	21	AV7 +0.00	77	74	1.40	29	AV4 +0.00
73	110	0.81	22	AV6 +0.00	75	100	0.97	24	AV6 +0.02			1.68	31	AV5 +0.05
		0.76	22	AV7 +0.02			1.07	26	AV7 +0.00			1.30	28	AV6 +0.00
73	116	1.18	27	AV5 +0.00	75	104	0.75	21	AV2 +0.02	77	76	0.81	22	AV3 +0.00
74	67	1.20	27	AV6 +0.02			1.01	25	AV3 +0.02			2.47	36	AV4 +0.00
		1.08	26	AV7 +0.00			3.00	39	AV5 +0.00			2.82	38	AV5 +0.02
74	71	1.46	30	AV4 +0.03			2.85	38	AV6 +0.02			1.31	28	AV6 +0.00
		1.12	26	AV5 +0.02	75	106	0.89	23	AV4 +0.03	77	78	1.09	26	AV4 +0.03
		1.39	29	AV8 +0.02			0.95	24	AV5 +0.00			1.01	25	AV5 +0.05
74	73	1.13	26	AV3 +0.02			0.77	22	AV6 +0.02	77	80	1.68	31	AV3 +0.02
		1.48	30	AV4 +0.03	75	108	1.14	26	AV3 +0.02			1.41	29	AV4 +0.00
		1.43	29	AV5 +0.02			1.46	30	AV4 +0.03			2.65	37	AV5 +0.00
		1.18	27	AV6 +0.00			0.70	21	AV5 +0.02			2.08	34	AV6 +0.00
		1.14	26	AV7 -0.05	75	116	1.00	25	AV5 -0.11			2.14	34	AV7 +0.02
74	75	0.73	21	AV6 +0.02	76	59	0.80	22	AV4 +0.00	77	88	0.70	21	AV6 +0.02
74	77	0.73	21	AV5 +0.00			1.37	29	AV5 +0.00			0.93	24	AV7 +0.02
		1.05	25	AV6 +0.00			1.58	31	AV6 +0.00	77	90	0.75	21	AV3 +0.05
74	81	0.87	23	AV3 +0.02	76	65	0.75	21	AV5 +0.02			1.07	26	AV4 +0.06
		0.89	23	AV4 -0.04			0.83	23	AV6 +0.02			1.62	31	AV5 +0.05
		0.74	21	AV5 +0.00	76	71	0.71	21	AV3 +0.02			0.72	21	AV6 +0.05
		0.95	24	AV6 +0.02			1.00	25	AV4 +0.03	77	92	1.58	31	AV3 +0.02
74	87	0.90	24	AV3 +0.02	76	75	0.85	23	AV3 +0.02			1.93	33	AV4 +0.06
		0.78	22	AV4 +0.00			0.90	24	AV4 +0.03			2.87	38	AV5 +0.02
		1.47	30	AV5 +0.04			2.93	39	AV5 +0.05			2.03	34	AV6 +0.02
		1.00	25	AV6 +0.02			2.73	38	AV6 +0.02			1.28	28	AV7 +0.00
74	89	1.70	32	AV3 +0.02			1.11	26	AV7 +0.00	77	94	0.72	21	AV4 +0.03
		0.87	23	AV4 +0.03	76	81	1.37	29	AV7 -0.02			1.21	27	AV5 +0.02
		1.19	27	AV5 +0.05			1.04	25	AV3 +0.02			1.42	29	AV6 +0.02
		1.91	33	AV6 +0.02			1.76	32	AV4 +0.00	77	96	0.98	25	AV6 +0.02
		0.78	22	AV7 +0.00			2.51	37	AV5 +0.02	77	100	1.01	25	AV3 +0.02
74	91	0.78	22	AV6 +0.05			2.39	36	AV6 +0.00			1.17	27	AV6 +0.02
		0.70	21	AV7 +0.00	76	87	1.09	26	AV6 +0.05			0.85	23	AV7 +0.02
74	93	1.15	27	AV5 +0.07			1.10	26	AV3 +0.02	77	102	1.87	33	AV5 +0.05
		0.72	21	AV7 +0.02			0.83	23	AV4 +0.05			2.26	35	AV6 +0.02
74	95	0.68	20	AV5 +0.00			1.42	29	AV5 +0.02			1.33	28	AV4 +0.03
		1.43	29	AV6 +0.02	76	89	0.81	22	AV3 +0.00	77	104	0.72	21	AV3 +0.02
		0.94	24	AV7 +0.05			0.72	21	AV5 +0.02			3.07	39	AV5 +0.02
74	97	1.08	26	AV3 +0.02			0.73	21	AV6 +0.00	77	106	0.67	20	AV3 +0.00
		0.71	21	AV4 +0.06	76	91	0.76	21	AV6 +0.05			2.71	38	AV4 +0.03
		1.50	30	AV5 +0.07	76	95	0.73	21	AV3 +0.02			2.47	36	AV5 +0.02
		1.06	26	AV6 +0.02	76	99	0.83	23	AV2 +0.02			2.07	34	AV6 +0.02
74	101	0.97	24	AV4 +0.03			2.70	37	AV5 +0.05	77	108	0.64	20	AV3 +0.02
		1.35	29	AV5 +0.02			1.46	30	AV6 +0.05			1.45	29	AV4 +0.03
		1.95	33	AV6 +0.05			0.84	23	AV7 +0.02			1.39	29	AV5 +0.02
74	103	0.89	23	AV3 +0.05	76	103	0.68	20	AV2 +0.02			1.00	25	AV6 +0.02
74	111	1.19	27	AV5 +0.07			1.14	26	AV4 +0.06	77	112	1.06	26	AV4 +0.06
		1.04	25	AV6 +0.05			1.14	26	AV5 +0.05			1.14	26	AV5 +0.00
74	145	0.80	22	AV3 +0.00			0.88	23	AV6 +0.02			1.70	31	AV6 +0.00
		1.15	27	AV2 +0.00			0.94	24	AV7 -0.02			1.32	28	AV7 +0.02
75	56	0.74	21	AV4 +0.22	76	105	1.08	26	AV7 +0.02	77	114	1.28	28	AV4 +0.05
75	66	0.95	24	AV5 +0.02			1.21	27	AV3 +0.02			2.51	37	AV5 +0.00
		0.82	22	AV6 +0.02			2.41	36	AV4 +0.06	77	116	1.42	29	AV6 -0.02
75	72	0.78	22	AV4 +0.03			2.01	34	AV5 +0.05			0.81	22	AV7 +0.02
		1.71	32	AV5 +0.05			0.76	22	AV6 +0.05			0.83	23	AV3 +0.02
		1.35	29	AV6 +0.05	76	107	0.77	22	AV5 +0.02			1.44	29	AV4 +0.06
75	76	0.83	23	AV4 +0.00			1.51	30	AV6 +0.02	78	67	0.77	22	AV6 +0.02
		1.13	26	AV5 +0.02			0.78	22	AV3 +0.02	78	69	0.88	23	AV3 +0.00
75	80	0.73	21	AV4 +0.00			1.45	29	AV4 +0.06			1.71	32	AV4 +0.00
		0.96	24	AV5 +0.02	76	109	1.91	33	AV5 +0.02			1.76	32	AV5 +0.02
75	86	1.05	25	AV3 +0.00			1.25	28	AV6 +0.02			1.25	28	AV6 +0.02
		0.75	21	AV6 +0.02	76	111	1.57	30	AV4 +0.08	78	71	0.72	21	AV6 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
78	73	0.82	22	AV3 +0.02	79	92	1.69	31	AV3 +0.02			0.80	22	AV2 +0.00
		1.18	27	AV5 +0.02			1.35	29	AV4 +0.03			1.21	27	AV3 +0.00
		1.57	31	AV6 +0.00			1.43	29	AV5 +0.05	80	105	1.06	26	AV5 +0.05
		0.97	24	AV7 +0.07			2.06	34	AV6 +0.02	80	107	1.33	28	AV6 +0.05
78	75	0.77	22	AV3 +0.00	79	94	0.82	22	AV3 +0.02	80	111	1.41	29	AV4 +0.08
		1.57	30	AV5 +0.00			0.89	23	AV4 +0.03			0.82	22	AV5 +0.05
		1.54	30	AV6 +0.02			0.88	23	AV5 +0.02			0.77	22	AV6 +0.02
		1.92	33	AV7 +0.02			0.66	20	AV6 +0.02	80	115	0.64	20	AV5 +0.02
		0.67	20	AV8 +0.00			1.17	27	AV7 +0.00			1.28	28	AV6 +0.00
78	77	0.93	24	AV4 +0.00	79	96	0.67	20	AV5 +0.05	80	117	0.85	23	AV5 +0.21
		1.54	30	AV5 +0.02			1.84	32	AV6 +0.02			0.72	21	AV6 -0.02
		1.47	30	AV6 +0.00	79	102	1.61	31	AV3 +0.02			0.96	24	AV7 +0.00
78	79	0.78	22	AV4 +0.03			2.74	38	AV4 +0.03	81	66	0.70	21	AV5 +0.05
		0.73	21	AV5 +0.05			2.61	37	AV5 +0.02			0.70	21	AV6 +0.07
		1.85	33	AV6 +0.05			1.64	31	AV6 +0.02	81	70	0.80	22	AV3 +0.00
78	83	0.70	21	AV5 +0.00	79	104	0.90	24	AV2 +0.02			0.70	21	AV5 +0.02
		0.65	20	AV6 +0.02			1.12	26	AV3 +0.02			1.26	28	AV6 +0.05
78	87	0.79	22	AV4 +0.03			1.32	28	AV5 +0.02	81	74	0.70	21	AV4 +0.08
		0.75	21	AV5 +0.05	79	106	0.72	21	AV3 +0.00			1.09	26	AV6 +0.02
		0.83	23	AV6 +0.02			2.26	35	AV4 +0.06	81	76	1.96	33	AV4 +0.00
78	89	2.19	35	AV4 +0.03			2.42	36	AV5 +0.05			2.02	34	AV5 +0.02
		2.61	37	AV6 +0.02			1.82	32	AV6 +0.02	81	78	0.72	21	AV3 +0.02
		0.76	22	AV7 +0.00	79	108	0.87	23	AV3 +0.02			2.87	38	AV4 +0.03
		1.56	30	AV3 +0.02			1.68	31	AV4 +0.03			2.88	38	AV5 +0.05
78	95	0.87	23	AV5 +0.05			1.37	29	AV6 +0.05			1.43	29	AV6 +0.07
		0.67	20	AV6 +0.05			1.44	29	AV7 +0.05			0.76	22	AV7 +0.02
		1.12	26	AV3 +0.05	79	110	0.69	20	AV3 +0.05	81	80	0.79	22	AV6 +0.02
		1.06	26	AV4 +0.06	80	67	0.80	22	AV5 +0.00			0.67	20	AV7 +0.00
78	97	1.07	26	AV3 +0.02			0.91	24	AV6 +0.05	81	82	1.00	25	AV3 +0.02
		0.98	25	AV4 +0.08	80	69	0.77	22	AV3 +0.02			2.18	35	AV4 +0.05
		2.25	35	AV6 +0.02			1.48	30	AV4 +0.05			2.01	34	AV5 +0.05
		0.75	21	AV7 +0.05			1.97	33	AV5 +0.02			2.15	35	AV6 +0.02
78	101	1.96	33	AV4 +0.05			1.94	33	AV6 +0.05			1.62	31	AV7 +0.02
		2.99	39	AV5 +0.02			1.40	29	AV7 +0.02	81	88	0.91	24	AV5 +0.02
		2.89	38	AV6 +0.05	80	73	0.67	20	AV4 +0.00			0.76	21	AV6 +0.02
78	107	1.46	30	AV6 +0.02			0.92	24	AV5 +0.02			0.81	22	AV7 +0.02
78	111	0.92	24	AV4 +0.05			1.19	27	AV6 +0.05	81	90	0.80	22	AV3 +0.00
		1.34	28	AV5 +0.02	80	75	0.70	21	AV4 +0.00			0.81	22	AV5 +0.07
		1.53	30	AV6 +0.02			1.71	32	AV5 +0.02	81	92	0.93	24	AV3 +0.02
78	113	1.30	28	AV6 -0.02			1.78	32	AV6 +0.00			0.81	22	AV5 +0.00
78	117	0.73	21	AV5 +0.26			2.13	34	AV7 +0.02			1.03	25	AV6 +0.05
		0.83	23	AV6 -0.02	80	77	1.25	28	AV3 +0.02	81	94	0.96	24	AV3 +0.02
		0.72	21	AV7 +0.02			1.60	31	AV4 +0.03			1.06	26	AV4 +0.03
79	62	0.86	23	AV5 +0.02			1.01	25	AV5 +0.05			1.42	29	AV5 +0.05
79	68	0.91	24	AV6 +0.07			1.44	29	AV6 +0.00	81	96	1.06	26	AV4 +0.05
		0.80	22	AV7 +0.05	80	83	1.39	29	AV5 +0.02			0.97	25	AV5 +0.05
79	70	0.64	20	AV5 +0.05			1.50	30	AV6 +0.02			2.87	38	AV6 +0.05
		0.95	24	AV6 +0.05			1.33	28	AV7 +0.04	81	100	0.65	20	AV7 +0.02
79	72	1.80	32	AV5 +0.02	80	85	0.76	21	AV6 +0.05			0.92	24	AV3 +0.02
		2.33	36	AV6 +0.02	80	87	0.70	21	AV3 +0.00			2.66	37	AV4 +0.05
		0.84	23	AV7 +0.00			1.45	29	AV4 +0.03			1.77	32	AV5 +0.05
79	74	0.80	22	AV4 +0.00			1.11	26	AV5 +0.02			2.15	35	AV6 +0.05
		2.09	34	AV5 +0.02			1.16	27	AV6 +0.02	81	102	1.91	33	AV4 +0.03
		1.89	33	AV7 +0.00			0.75	21	AV7 +0.00			0.79	22	AV7 +0.00
79	76	1.09	26	AV4 +0.03	80	89	1.52	30	AV3 +0.00	81	106	0.83	23	AV4 +0.03
		3.02	39	AV5 +0.05			1.72	32	AV4 +0.03	81	108	0.93	24	AV3 +0.02
		1.68	31	AV6 +0.02			2.34	36	AV5 +0.02	81	110	1.42	29	AV5 +0.02
		1.43	29	AV7 +0.02			1.99	34	AV6 +0.02	81	114	0.77	22	AV5 +0.02
79	78	1.41	29	AV7 +0.00			0.66	20	AV7 +0.02	82	67	1.27	28	AV2 +0.00
		0.78	22	AV4 +0.03	80	91	0.86	23	AV6 +0.05			1.37	29	AV3 +0.02
		0.77	22	AV5 -0.03	80	93	1.62	31	AV4 +0.05			1.23	27	AV4 +0.03
		1.01	25	AV6 +0.00			2.46	36	AV5 +0.07			2.15	35	AV5 +0.02
79	80	0.73	21	AV3 +0.02			0.82	22	AV6 +0.05			3.12	39	AV6 +0.00
		0.80	22	AV4 +0.03	80	95	1.12	26	AV3 +0.00			0.88	23	AV7 +0.05
		1.81	32	AV5 +0.02			1.71	32	AV4 +0.03	82	69	1.09	26	AV4 +0.03
		1.59	31	AV6 +0.00			2.06	34	AV5 +0.02			2.03	34	AV5 +0.02
		0.79	22	AV7 +0.00			0.70	21	AV6 +0.02			1.35	29	AV6 +0.00
79	82	0.86	23	AV4 -0.02	80	99	1.95	33	AV5 +0.00			1.13	26	AV7 +0.00
		0.86	23	AV5 -0.03			1.84	32	AV6 +0.02	82	77	0.92	24	AV5 +0.02
79	86	1.84	32	AV3 +0.02			1.27	28	AV7 +0.00			2.93	39	AV6 +0.00
		0.64	20	AV4 +0.03	80	101	2.74	38	AV4 +0.05			2.00	34	AV7 -0.05
79	90	0.80	22	AV6 +0.05			2.92	39	AV6 +0.02	82	79	1.64	31	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		1.26	28	AV4 +0.05	83	88	1.21	27	AV4 +0.03	84	95	1.06	26	AV2 +0.02
		2.00	34	AV5 +0.05			2.23	35	AV5 +0.05			1.32	28	AV4 +0.09
		2.95	39	AV6 +0.05			1.52	30	AV6 +0.05			1.74	32	AV5 +0.05
		0.65	20	AV7 +0.02			1.35	29	AV7 +0.00			1.04	25	AV6 +0.05
82	81	0.93	24	AV5 +0.02	83	92	2.04	34	AV3 +0.02	84	107	0.73	21	AV3 +0.02
		0.75	21	AV6 +0.02			1.90	33	AV4 +0.03			0.76	22	AV4 +0.03
		1.15	27	AV7 +0.00			2.48	36	AV5 +0.02			1.21	27	AV6 +0.02
82	83	1.25	28	AV4 +0.03			2.98	39	AV6 +0.02			1.17	27	AV7 +0.02
		1.99	34	AV5 +0.02			1.64	31	AV7 +0.02	84	109	0.67	20	AV2 +0.00
		1.70	31	AV6 +0.02	83	96	2.76	38	AV3 +0.05			1.36	29	AV3 +0.02
		1.26	28	AV7 +0.02			2.27	35	AV4 +0.05	84	113	0.92	24	AV5 +0.02
82	85	3.08	39	AV5 +0.00			2.38	36	AV5 +0.05			0.66	20	AV3 +0.02
		1.06	26	AV7 +0.00			2.00	34	AV6 +0.05			0.70	21	AV4 +0.03
		1.61	31	AV4 +0.00			0.67	20	AV7 +0.02	84	115	0.70	21	AV4 +0.03
82	87	1.03	25	AV4 +0.03	83	100	0.93	24	AV4 +0.06			1.70	31	AV5 +0.02
82	89	1.50	30	AV3 +0.00			2.27	35	AV5 +0.05			1.43	29	AV6 +0.00
		1.81	32	AV4 +0.03			1.91	33	AV6 +0.05	84	117	1.00	25	AV6 -0.02
		1.26	28	AV5 +0.05	83	106	0.94	24	AV4 +0.05			0.85	23	AV4 +0.08
		0.66	20	AV6 +0.02			1.18	27	AV5 +0.05			1.18	27	AV5 +0.02
82	91	1.09	26	AV4 +0.03			1.60	31	AV6 +0.05	85	68	0.91	24	AV2 +0.02
		1.36	29	AV5 +0.00	83	108	0.81	22	AV3 +0.02			0.90	24	AV5 +0.02
		1.19	27	AV6 +0.02			0.96	24	AV4 +0.05			0.87	23	AV6 -0.02
82	93	1.63	31	AV4 +0.05			1.38	29	AV5 +0.05			1.05	25	AV7 +0.00
		2.16	35	AV5 +0.05			1.85	33	AV6 +0.05	85	70	0.77	22	AV3 +0.03
		1.88	33	AV7 +0.02	83	110	0.65	20	AV4 +0.08			1.45	29	AV4 +0.00
82	95	0.70	21	AV2 +0.00			1.08	26	AV5 +0.07			1.48	30	AV5 +0.02
		1.48	30	AV3 +0.02	83	112	0.71	21	AV4 +0.03			1.51	30	AV6 +0.05
		3.01	39	AV4 +0.03	83	132	0.77	22	AV7 +0.02			0.77	22	AV7 +0.02
		1.52	30	AV6 +0.02	83	140	0.68	20	AV7 -0.02	85	78	2.58	37	AV4 +0.00
		1.37	29	AV7 +0.02	84	61	0.65	20	AV7 +0.05			1.52	30	AV5 +0.02
		0.67	20	AV8 +0.02	84	67	1.14	26	AV4 +0.05			1.14	26	AV6 +0.02
82	97	1.81	32	AV5 +0.05			1.16	27	AV5 +0.02			0.94	24	AV7 +0.05
		1.00	25	AV6 +0.05			1.01	25	AV6 +0.05	85	80	0.79	22	AV7 +0.02
82	99	0.76	22	AV2 +0.00	84	69	1.41	29	AV4 +0.09			0.64	20	AV4 +0.03
		1.88	33	AV4 +0.05			2.85	38	AV6 +0.05			0.83	23	AV5 +0.05
		3.11	39	AV6 +0.05			2.38	36	AV7 +0.02			1.54	30	AV6 +0.02
		1.46	30	AV7 +0.02	84	71	1.06	26	AV3 +0.00	85	82	0.85	23	AV4 +0.05
82	107	2.21	35	AV6 +0.02			1.50	30	AV4 +0.00			0.95	24	AV5 +0.05
		1.88	33	AV7 +0.02			1.36	29	AV5 +0.00			1.19	27	AV6 +0.05
		0.68	20	AV8 +0.05	84	73	0.95	24	AV3 +0.00			1.46	30	AV7 +0.02
82	109	0.77	22	AV5 +0.07			1.59	31	AV4 +0.03	85	88	0.97	24	AV4 +0.03
		0.93	24	AV6 +0.05			1.46	30	AV5 +0.02			1.22	27	AV5 +0.05
82	115	0.68	20	AV5 +0.02			2.81	38	AV6 +0.02	85	90	1.05	25	AV3 +0.02
		0.70	21	AV6 +0.00			1.26	28	AV7 +0.04			1.35	29	AV5 +0.05
82	117	1.29	28	AV5 +0.05	84	75	1.36	29	AV3 +0.02			0.81	22	AV6 +0.07
		1.08	26	AV6 +0.00			1.67	31	AV4 +0.00	85	92	0.64	20	AV3 +0.02
83	64	1.13	26	AV5 +0.02			0.94	24	AV5 +0.02			1.41	29	AV4 +0.00
		2.24	35	AV6 +0.02	84	79	1.08	26	AV3 +0.00			2.28	35	AV5 +0.00
		0.98	25	AV7 -0.02			0.71	21	AV4 +0.00			1.98	33	AV6 +0.02
83	68	0.83	23	AV5 +0.05			2.18	35	AV5 +0.00			2.88	38	AV7 +0.00
		1.58	31	AV6 +0.02			2.52	37	AV6 +0.00	85	94	0.68	20	AV3 +0.02
		1.06	25	AV7 +0.05	84	81	0.67	20	AV4 +0.03			1.84	32	AV4 +0.03
83	72	2.63	37	AV5 +0.02			2.63	37	AV5 +0.02			3.14	39	AV5 +0.05
		1.86	33	AV6 +0.02			1.06	26	AV6 +0.05			1.15	27	AV6 +0.05
		1.88	33	AV7 -0.02	84	83	0.96	24	AV5 +0.02			0.75	21	AV7 +0.02
83	74	1.72	32	AV5 +0.02			1.20	27	AV6 +0.02	85	100	0.71	21	AV2 +0.02
		2.07	34	AV6 +0.00	84	85	0.88	23	AV3 +0.05			1.91	33	AV3 +0.02
		0.97	25	AV7 +0.02			1.81	32	AV4 +0.03			1.87	33	AV4 +0.03
83	78	2.61	37	AV4 +0.05			2.27	35	AV5 +0.02			2.40	36	AV5 +0.02
		2.05	34	AV5 +0.02			2.53	37	AV6 +0.05			1.19	27	AV6 +0.05
		1.32	28	AV6 +0.05			1.19	27	AV7 +0.02	85	106	1.85	33	AV4 +0.00
		1.13	26	AV7 +0.05	84	87	1.81	32	AV3 +0.02			0.85	23	AV6 +0.00
83	80	0.67	20	AV4 +0.00			2.54	37	AV6 +0.02			1.43	29	AV2 +0.02
		1.01	25	AV5 +0.02			0.86	23	AV7 +0.02			1.97	33	AV3 +0.02
		1.97	33	AV6 +0.00	84	89	2.68	37	AV3 -0.05	85	108	0.65	20	AV2 +0.02
		1.37	29	AV7 +0.00			2.83	38	AV4 +0.00			1.48	30	AV3 +0.02
83	84	0.79	22	AV3 +0.00			2.65	37	AV5 -0.03			0.95	24	AV4 +0.03
		0.84	23	AV5 +0.02			1.98	33	AV6 +0.00			0.64	20	AV5 +0.02
		0.64	20	AV6 +0.05			0.80	22	AV7 +0.02			1.14	26	AV6 +0.02
83	86	1.09	26	AV5 +0.02	84	91	1.44	29	AV4 +0.05	85	118	0.76	22	AV5 +0.02
		1.30	28	AV6 +0.05			1.59	31	AV5 +0.02	86	69	1.42	29	AV4 +0.03
		1.05	25	AV7 +0.02			0.95	24	AV6 +0.02			2.75	38	AV5 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		2.73	38	AV6 +0.02	87	100	1.68	31	AV2 +0.02			0.83	23	AV7 +0.02
		1.06	26	AV7 +0.05			1.46	30	AV3 +0.02			0.68	20	AV3 +0.02
86	71	1.31	28	AV7 +0.02			1.72	32	AV4 +0.05	89	74	0.73	21	AV3 +0.05
		0.79	22	AV4 +0.03			0.94	24	AV5 +0.02			0.74	21	AV4 +0.03
		1.88	33	AV5 +0.02	87	106	0.78	22	AV2 +0.02			1.58	31	AV5 +0.05
		2.12	34	AV6 +0.02			0.81	22	AV4 +0.08			2.68	37	AV6 +0.07
86	75	1.39	29	AV2 +0.02			1.29	28	AV6 +0.05			1.84	32	AV7 +0.02
		1.16	27	AV3 +0.05	87	108	1.22	27	AV3 +0.05	89	78	1.06	26	AV4 +0.03
		2.50	36	AV4 +0.03			0.78	22	AV4 +0.08			0.91	24	AV5 +0.02
		1.86	33	AV5 +0.05	87	114	1.46	30	AV6 +0.02	89	80	0.75	21	AV7 +0.02
86	79	0.90	24	AV3 +0.00			1.94	33	AV7 +0.05	89	82	1.79	32	AV4 +0.03
86	83	1.12	26	AV4 +0.00			0.92	24	AV8 +0.02			0.82	22	AV5 +0.00
		1.80	32	AV5 +0.00	88	69	1.58	31	AV6 +0.00			0.86	23	AV6 +0.02
		1.62	31	AV6 +0.00			0.92	24	AV7 +0.02			2.55	37	AV7 +0.02
86	87	1.21	27	AV3 +0.00	88	71	1.29	28	AV4 +0.03	89	84	0.90	24	AV5 +0.02
		2.18	35	AV4 +0.05			2.47	36	AV5 +0.02			1.41	29	AV6 +0.02
		1.79	32	AV5 +0.05			2.53	37	AV6 +0.02			2.41	36	AV7 +0.02
		0.91	24	AV6 +0.08			1.40	29	AV7 +0.04	89	92	0.65	20	AV4 +0.05
86	89	0.95	24	AV3 +0.00	88	73	1.46	30	AV2 +0.05			0.74	21	AV6 +0.05
		2.12	34	AV4 +0.03			0.74	21	AV3 +0.02			1.17	27	AV3 +0.02
		2.10	34	AV5 +0.02			0.83	23	AV4 +0.03	89	96	0.68	20	AV3 +0.07
		2.44	36	AV6 +0.05			1.31	28	AV6 +0.00	89	102	1.87	33	AV2 +0.02
		0.78	22	AV7 +0.05			0.92	24	AV8 +0.05			1.94	33	AV3 +0.05
86	91	2.42	36	AV4 +0.06	88	75	1.37	29	AV6 +0.00			1.70	32	AV4 +0.08
		2.48	36	AV5 +0.05			1.99	34	AV7 +0.00			0.86	23	AV6 +0.05
		2.75	38	AV6 +0.05			1.07	26	AV8 +0.02			0.76	22	AV7 +0.02
86	97	1.33	28	AV3 +0.02	88	79	0.99	25	AV5 +0.02	89	106	0.76	21	AV4 +0.08
		2.19	35	AV5 +0.05			0.69	20	AV6 +0.02	90	75	1.19	27	AV6 +0.00
		1.63	31	AV6 +0.02	88	81	0.98	25	AV3 +0.00			0.98	25	AV7 +0.02
		0.81	22	AV7 +0.02			0.96	24	AV4 -0.02	90	79	1.36	29	AV5 +0.02
86	99	0.85	23	AV5 +0.02			2.50	36	AV5 +0.02	90	83	0.79	22	AV5 +0.09
		1.21	27	AV6 +0.07			1.19	27	AV6 +0.02	90	85	0.78	22	AV4 +0.03
86	101	1.08	26	AV3 +0.02	88	83	0.76	22	AV3 +0.00			2.51	37	AV5 +0.02
		1.43	29	AV4 +0.05	88	85	0.70	21	AV5 +0.05			1.69	31	AV6 +0.05
		1.47	30	AV7 +0.02			0.68	20	AV6 +0.02			1.55	30	AV7 +0.05
86	105	0.75	21	AV5 +0.07	88	87	0.78	22	AV3 +0.00	90	87	0.94	24	AV3 +0.02
		0.68	20	AV7 +0.05			0.80	22	AV4 +0.08			0.90	23	AV4 +0.05
		0.83	23	AV3 +0.02			0.73	21	AV6 +0.07			2.27	35	AV5 +0.05
87	66	0.70	21	AV5 +0.05	88	89	1.79	32	AV4 +0.03			1.74	32	AV6 +0.05
87	70	0.92	24	AV4 +0.03			1.30	28	AV5 +0.05	90	91	1.47	30	AV3 +0.00
		2.16	35	AV5 +0.05			1.42	29	AV6 +0.02			1.89	33	AV4 +0.05
		2.37	36	AV6 +0.09			0.73	21	AV7 +0.02			2.86	38	AV5 +0.02
		2.28	35	AV7 +0.02	88	91	0.69	20	AV3 +0.02			3.01	39	AV6 +0.02
87	72	2.49	36	AV7 +0.02			1.26	28	AV4 +0.03			0.70	21	AV7 +0.02
		0.70	21	AV4 +0.03			0.93	24	AV5 +0.02	90	97	1.46	30	AV2 +0.00
		3.14	39	AV5 +0.05			2.29	35	AV6 +0.05			1.64	31	AV3 +0.02
		0.88	23	AV6 +0.02			0.83	23	AV7 +0.02			2.44	36	AV4 +0.03
87	74	1.26	28	AV5 +0.02	88	93	1.40	29	AV5 +0.05			2.92	38	AV6 +0.02
87	80	1.96	33	AV6 +0.02			2.49	36	AV6 +0.02			1.77	32	AV7 +0.02
		0.72	21	AV3 +0.05	88	95	1.35	29	AV3 +0.00	90	99	1.09	26	AV2 +0.00
		2.40	36	AV4 +0.05			2.63	37	AV4 +0.03			1.21	27	AV3 +0.02
		1.91	33	AV5 +0.07			1.40	29	AV5 +0.02			1.99	34	AV4 +0.05
87	82	1.01	25	AV3 +0.05	88	97	0.97	24	AV4 +0.05			1.59	31	AV5 +0.02
		1.74	32	AV4 +0.03			0.66	20	AV5 +0.05	90	103	1.93	33	AV3 +0.00
		1.12	26	AV5 +0.02			0.74	21	AV6 +0.02			1.77	32	AV4 +0.05
		1.29	28	AV6 +0.02	88	99	0.81	22	AV3 +0.05			1.88	33	AV5 +0.07
		1.60	31	AV7 +0.02			1.46	30	AV4 +0.05			1.60	31	AV6 +0.05
87	84	1.25	28	AV4 +0.03			1.30	28	AV6 +0.05			1.56	30	AV7 +0.00
		2.48	36	AV5 +0.02	88	101	1.65	31	AV3 +0.02	90	105	2.38	36	AV6 +0.07
		2.21	35	AV6 +0.02			0.72	21	AV4 +0.05			2.95	39	AV7 +0.02
		0.68	20	AV7 +0.02			1.49	30	AV5 +0.05			0.96	24	AV4 +0.05
87	86	0.72	21	AV2 +0.00			1.33	28	AV6 +0.07			2.31	35	AV5 +0.05
		1.51	30	AV3 +0.00			0.81	22	AV7 +0.02	91	64	1.05	25	AV5 +0.00
		1.05	25	AV4 +0.03	88	107	0.80	22	AV3 +0.05	91	66	0.84	23	AV5 +0.05
		2.39	36	AV5 +0.02			0.95	24	AV7 +0.05	91	68	0.76	22	AV7 +0.00
		2.18	35	AV6 +0.00	88	109	1.25	28	AV3 +0.02			0.87	23	AV6 +0.00
87	88	1.25	28	AV4 +0.03			0.72	21	AV4 +0.03			0.84	23	AV5 +0.05
		1.22	27	AV5 +0.02	89	68	0.68	20	AV5 +0.05	91	70	0.98	25	AV6 -0.02
87	90	0.76	22	AV3 +0.00	89	70	0.93	24	AV7 +0.00			0.95	24	AV5 -0.05
		0.88	23	AV4 +0.05	89	72	0.84	23	AV4 +0.00	91	72	1.40	29	AV7 +0.00
		3.06	39	AV6 +0.07			2.60	37	AV5 +0.00			1.99	34	AV6 -0.02
		1.01	25	AV7 +0.02			1.21	27	AV6 +0.02			3.01	39	AV5 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		1.06	26	AV3 +0.00			2.10	34	AV4 +0.00			0.84	23	AV5 +0.00
91	80	1.47	30	AV7 +0.00			2.06	34	AV3 +0.00			2.00	34	AV4 +0.00
		2.24	35	AV5 -0.03	92	105	2.93	39	AV5 +0.02	95	82	1.47	30	AV7 +0.02
		1.65	31	AV4 +0.00			1.39	29	AV4 +0.00			1.03	25	AV6 +0.02
91	82	1.14	26	AV7 +0.02			0.99	25	AV6 +0.03			2.18	35	AV5 -0.03
		1.17	27	AV6 +0.00	93	70	0.98	25	AV6 +0.00			2.48	36	AV4 -0.02
		1.66	31	AV5 -0.03			0.97	24	AV5 +0.02	95	84	2.56	37	AV5 +0.00
		1.90	33	AV4 -0.05	93	78	1.56	30	AV7 +0.00			2.09	34	AV4 -0.02
91	90	1.41	29	AV7 +0.00			1.04	25	AV6 +0.00			0.88	23	AV3 -0.02
		2.86	38	AV6 +0.02			1.97	33	AV5 +0.02			0.92	24	AV2 -0.05
		2.64	37	AV5 +0.02			0.68	20	AV4 +0.00	95	88	1.69	31	AV6 +0.02
		1.33	28	AV4 +0.00			0.73	21	AV2 -0.02			2.20	35	AV4 -0.02
91	92	1.28	28	AV7 +0.00	93	82	1.56	30	AV7 +0.00			1.75	32	AV7 +0.00
		1.89	33	AV6 +0.02			0.92	24	AV6 +0.00	95	96	1.88	33	AV6 +0.00
		0.66	20	AV5 +0.05			1.17	27	AV5 -0.03			0.71	21	AV4 +0.00
		1.57	30	AV4 +0.03			1.06	26	AV4 -0.02			0.65	20	AV3 +0.02
91	96	1.79	32	AV3 +0.02	93	88	2.34	36	AV7 +0.00	95	98	1.33	28	AV6 +0.02
		1.66	31	AV7 +0.02			1.18	27	AV6 +0.00			1.95	33	AV5 +0.05
		1.92	33	AV6 +0.05			1.28	28	AV5 +0.02			0.86	23	AV3 +0.00
		1.98	33	AV4 +0.03	93	100	0.65	20	AV6 +0.05	95	100	2.70	37	AV5 +0.00
		2.61	37	AV3 +0.07	93	102	2.45	36	AV6 +0.00			1.30	28	AV7 +0.00
		0.68	20	AV2 -0.02			2.92	39	AV5 +0.00	95	104	1.18	27	AV5 -0.03
91	98	1.36	29	AV6 +0.05			2.54	37	AV4 +0.00			0.74	21	AV3 +0.02
		1.85	33	AV4 +0.03			0.65	20	AV3 -0.02	95	106	0.75	21	AV6 +0.00
		2.20	35	AV3 +0.00	93	104	1.62	31	AV3 -0.02	96	65	0.74	21	AV5 +0.02
91	100	0.99	25	AV3 +0.00			1.85	33	AV7 +0.00	96	67	0.77	22	AV7 +0.00
		0.79	22	AV7 +0.00			1.20	27	AV4 -0.02			1.46	30	AV6 +0.00
		1.67	31	AV6 +0.02	93	106	1.21	27	AV7 +0.00			1.48	30	AV5 +0.00
91	106	0.95	24	AV6 +0.00			0.76	22	AV6 -0.02	96	71	2.17	35	AV7 +0.00
		2.44	36	AV4 +0.00			1.37	29	AV4 +0.00			2.03	34	AV6 -0.02
		0.79	22	AV3 -0.05			0.68	20	AV3 -0.02			2.53	37	AV5 +0.00
91	108	0.72	21	AV7 +0.02	93	108	0.92	24	AV6 +0.00			0.82	22	AV4 -0.02
		2.78	38	AV6 +0.00	93	110	1.71	32	AV5 +0.00	96	75	0.79	22	AV8 +0.02
		2.00	34	AV5 -0.03			1.20	27	AV4 +0.00			2.89	38	AV6 +0.10
		0.65	20	AV4 +0.00	93	112	0.72	21	AV6 -0.02			2.50	36	AV5 +0.00
		0.72	21	AV3 +0.00			0.85	23	AV7 +0.00			1.07	26	AV4 -0.05
91	110	0.93	24	AV6 +0.00	94	67	1.39	29	AV7 +0.00	96	79	1.50	30	AV7 +0.00
		2.71	38	AV5 +0.00			1.36	29	AV6 +0.00			2.08	34	AV4 +0.00
		1.39	29	AV4 +0.00	94	71	2.39	36	AV7 +0.02			2.55	37	AV3 +0.00
91	112	1.09	26	AV2 +0.02			1.15	27	AV6 +0.00	96	81	0.93	24	AV5 +0.00
91	116	1.08	26	AV6 -0.05			0.88	23	AV5 +0.00	96	91	1.17	27	AV7 +0.00
		0.78	22	AV5 -0.03			1.21	27	AV4 +0.03			2.54	37	AV6 +0.02
		0.70	21	AV4 +0.00	94	77	0.99	25	AV7 -0.02			1.85	33	AV4 +0.03
92	69	0.87	23	AV6 +0.00			2.83	38	AV6 +0.00			0.98	25	AV3 +0.00
92	79	2.26	35	AV5 +0.00			0.92	24	AV5 +0.00	96	95	1.76	32	AV6 +0.09
		0.76	22	AV3 -0.02			1.09	26	AV4 -0.02			1.18	27	AV5 +0.05
92	83	2.34	36	AV6 +0.02	94	79	0.91	24	AV6 +0.00	96	97	0.93	24	AV4 +0.05
		2.23	35	AV5 -0.03	94	81	1.71	32	AV7 -0.02	96	103	1.59	31	AV6 -0.02
		1.94	33	AV4 -0.05			1.82	32	AV6 +0.00			0.84	23	AV4 -0.02
		0.82	22	AV3 -0.02			1.29	28	AV5 -0.05			2.54	37	AV3 +0.00
		0.66	20	AV2 -0.05	94	95	2.60	37	AV6 +0.02			0.89	23	AV2 -0.02
92	85	1.57	30	AV7 +0.00			1.25	28	AV4 +0.03	96	105	1.80	32	AV7 +0.02
		1.32	28	AV6 +0.00			1.10	26	AV3 +0.02			2.32	36	AV6 +0.05
		1.53	30	AV5 -0.03			1.72	32	AV7 -0.02			1.89	33	AV5 +0.07
		1.28	28	AV4 +0.00	94	97	0.76	21	AV6 +0.02	97	66	0.76	22	AV2 +0.00
		1.59	31	AV3 -0.02			0.90	24	AV4 +0.03	97	68	0.99	25	AV7 +0.00
92	87	0.88	23	AV6 +0.02	94	101	0.83	23	AV7 +0.02			1.74	32	AV6 +0.07
		1.31	28	AV5 +0.00			1.13	26	AV6 +0.07			1.03	25	AV5 +0.00
		0.76	21	AV4 +0.00			2.27	35	AV5 +0.09			2.08	34	AV4 +0.00
		0.65	20	AV3 -0.02			0.69	20	AV4 +0.05	97	70	0.64	20	AV6 +0.02
92	89	1.50	30	AV6 +0.00			0.83	23	AV3 +0.02	97	72	0.72	21	AV7 +0.00
		0.73	21	AV5 +0.00			0.95	24	AV2 +0.00			2.77	38	AV6 +0.00
		1.19	27	AV4 -0.02	94	103	0.71	21	AV2 -0.05			3.01	39	AV5 +0.00
92	99	2.61	37	AV6 +0.00			1.77	32	AV5 -0.03			1.05	25	AV4 +0.03
		1.54	30	AV5 +0.00			2.87	38	AV4 -0.02	97	74	2.07	34	AV7 +0.05
		1.46	30	AV4 +0.00			2.80	38	AV3 -0.02			1.12	26	AV5 +0.00
		0.96	24	AV3 -0.02			2.54	37	AV6 +0.00			1.07	26	AV3 -0.02
		2.34	36	AV7 +0.00	95	68	0.76	22	AV5 +0.02	97	82	0.82	23	AV7 +0.00
92	101	0.99	25	AV5 +0.00	95	74	0.80	22	AV6 +0.00			1.48	30	AV4 +0.03
		1.12	26	AV3 +0.02	95	78	0.89	23	AV7 +0.00	97	96	1.07	26	AV6 +0.00
92	103	0.88	23	AV6 +0.09			0.99	25	AV5 -0.05			2.52	37	AV5 +0.00
		1.02	25	AV5 +0.00	95	80	1.04	25	AV6 +0.00			1.95	33	AV4 -0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		1.42	29	AV3 -0.02			2.71	38	AV7 +0.02			2.45	36	AV6 +0.02
97	98	1.39	29	AV5 -0.03			2.31	35	AV6 +0.05			0.94	24	AV4 -0.02
		1.90	33	AV4 -0.02			2.34	36	AV5 -0.03	102	97	1.25	28	AV4 +0.03
		1.85	33	AV3 -0.02			2.10	34	AV4 -0.05	102	99	1.07	26	AV5 +0.02
		1.64	31	AV2 +0.00			2.59	37	AV3 +0.02			1.53	30	AV4 +0.03
97	108	0.67	20	AV5 +0.02			1.76	32	AV2 +0.00	103	72	0.86	23	AV6 -0.02
98	71	0.90	24	AV5 +0.00	100	77	1.10	26	AV8 +0.00			2.03	34	AV5 +0.00
		0.74	21	AV3 -0.02			2.64	37	AV7 -0.02			2.61	37	AV4 +0.00
98	73	2.58	37	AV7 -0.05			2.87	38	AV6 +0.00	103	78	0.77	22	AV6 +0.00
		1.27	28	AV4 +0.03			0.99	25	AV5 -0.03			2.95	39	AV5 -0.03
		0.81	22	AV3 -0.02			1.23	27	AV4 -0.02			1.35	29	AV4 -0.05
98	77	2.91	38	AV6 -0.02			0.72	21	AV3 +0.00			1.00	25	AV3 -0.02
		1.85	33	AV4 -0.02	100	79	2.49	36	AV6 +0.00			0.68	20	AV2 +0.00
98	79	1.63	31	AV3 -0.02			1.33	28	AV4 -0.02	103	80	0.98	25	AV7 +0.05
		1.24	27	AV6 +0.00			2.33	36	AV3 +0.00			1.23	27	AV6 +0.05
		2.13	34	AV5 +0.00			2.07	34	AV2 -0.02	103	82	0.82	22	AV8 +0.02
		0.71	21	AV4 -0.02	100	81	2.25	35	AV7 -0.02			2.17	35	AV7 +0.00
98	81	0.71	21	AV8 +0.00			2.78	38	AV6 -0.02			2.13	34	AV6 +0.02
		1.86	33	AV7 -0.02			3.07	39	AV5 -0.05			1.74	32	AV5 +0.02
		2.03	34	AV6 +0.00			0.70	21	AV3 -0.02			1.58	31	AV4 +0.05
		1.20	27	AV5 -0.03	100	91	2.04	34	AV6 +0.02	103	92	2.21	35	AV7 +0.00
		1.03	25	AV3 +0.00			2.36	36	AV5 -0.03			3.06	39	AV6 +0.02
98	93	0.91	24	AV7 -0.02			0.98	25	AV7 +0.00			1.61	31	AV5 +0.02
		1.15	27	AV6 -0.02			1.02	25	AV4 -0.02			1.21	27	AV4 -0.02
		2.49	36	AV4 -0.02	100	95	1.95	33	AV6 +0.05			1.84	33	AV3 +0.00
		0.70	21	AV3 +0.00			0.88	23	AV5 +0.02	103	96	2.86	38	AV7 +0.02
		0.90	24	AV5 +0.00			0.70	21	AV2 +0.00			1.76	32	AV6 +0.00
98	99	1.79	32	AV4 +0.00	100	99	1.47	30	AV7 +0.00			2.39	36	AV5 +0.00
		1.66	31	AV3 -0.02			0.86	23	AV6 +0.00	103	100	1.89	33	AV6 +0.02
98	105	1.28	28	AV7 +0.00	100	105	1.38	29	AV7 +0.00			1.42	29	AV5 +0.00
		2.11	34	AV6 +0.00			1.61	31	AV6 +0.00			1.10	26	AV4 +0.00
		1.40	29	AV5 +0.00			2.49	36	AV5 -0.03			0.78	22	AV3 +0.00
		2.95	39	AV4 +0.00			1.56	30	AV4 -0.02	103	104	0.80	22	AV4 -0.02
		1.62	31	AV3 -0.02	100	107	0.95	24	AV7 +0.02	103	106	0.86	23	AV5 +0.00
		0.74	21	AV2 -0.02			1.75	32	AV6 +0.03	104	71	0.75	21	AV5 -0.03
98	107	0.90	24	AV6 +0.02			0.74	21	AV4 +0.03	104	73	0.81	22	AV6 +0.00
99	68	0.66	20	AV7 +0.00			0.98	25	AV3 +0.00			0.75	21	AV4 -0.02
		1.34	29	AV6 +0.00	101	74	2.24	35	AV6 +0.00	104	75	2.53	37	AV7 +0.02
		0.77	22	AV4 -0.02			3.04	39	AV5 +0.00			2.08	34	AV6 +0.07
99	72	1.42	29	AV6 +0.00			1.07	26	AV4 -0.02			2.18	35	AV4 +0.00
		1.44	29	AV5 +0.02			0.78	22	AV3 -0.02			1.95	33	AV3 +0.00
		0.71	21	AV4 +0.03	101	78	0.99	25	AV7 -0.02	104	77	1.24	27	AV6 +0.00
99	76	1.42	29	AV6 +0.05			1.02	25	AV6 +0.00			1.66	31	AV4 -0.02
		2.82	38	AV5 +0.02			0.71	21	AV5 -0.03	104	79	0.89	23	AV4 -0.02
		1.92	33	AV4 +0.00	101	88	2.30	35	AV6 -0.02	104	91	0.87	23	AV7 +0.00
99	78	1.40	29	AV6 +0.02			2.85	38	AV5 -0.03			1.36	29	AV6 +0.02
		0.64	20	AV4 +0.03			0.88	23	AV4 -0.02			0.92	24	AV5 -0.03
		0.93	24	AV3 +0.00			2.39	36	AV3 -0.02			0.82	22	AV4 -0.02
		0.90	24	AV2 +0.00			1.46	30	AV2 +0.00			1.12	26	AV3 -0.02
99	80	1.15	27	AV4 -0.02	101	94	1.08	26	AV8 +0.02			1.37	29	AV2 -0.02
99	82	0.74	21	AV5 +0.00			1.12	26	AV7 +0.00	104	97	1.03	25	AV6 +0.02
99	96	1.22	27	AV5 -0.03			0.65	20	AV5 -0.03			1.10	26	AV5 +0.00
		0.64	20	AV4 +0.00	101	96	0.74	21	AV2 +0.00			1.84	33	AV4 +0.00
		0.99	25	AV3 +0.00			1.20	27	AV3 +0.00	104	99	0.65	20	AV4 +0.05
99	98	0.85	23	AV8 +0.05	101	98	0.78	22	AV8 +0.02	104	105	1.27	28	AV7 +0.05
		0.98	25	AV7 +0.00	101	100	1.19	27	AV6 +0.02			1.14	26	AV6 +0.05
99	104	0.89	23	AV7 +0.02	102	71	1.00	25	AV7 +0.00			0.87	23	AV5 +0.00
		0.89	23	AV5 +0.05			2.65	37	AV6 -0.02	105	72	1.50	30	AV5 +0.02
99	106	0.80	22	AV7 +0.02			2.40	36	AV5 +0.00			1.29	28	AV4 +0.03
		2.03	34	AV6 +0.02			0.87	23	AV4 -0.02	105	74	2.34	36	AV6 +0.02
		1.06	26	AV5 +0.02	102	73	0.74	21	AV6 +0.00			2.78	38	AV5 +0.00
100	67	0.69	20	AV6 -0.02			1.33	28	AV5 +0.02			1.43	29	AV4 -0.02
		0.66	20	AV5 -0.05	102	77	2.36	36	AV6 -0.02			0.68	20	AV3 +0.00
100	69	2.08	34	AV7 +0.02			2.31	35	AV5 +0.00	105	76	1.04	25	AV7 +0.02
		0.97	24	AV6 +0.00			1.48	30	AV4 +0.00			1.88	33	AV6 +0.00
100	71	1.59	31	AV7 +0.00	102	79	0.95	24	AV8 +0.05			1.46	30	AV5 +0.00
		2.96	39	AV6 +0.00			1.32	28	AV7 +0.02			2.02	34	AV4 +0.00
		1.48	30	AV5 +0.02			2.07	34	AV5 +0.05	105	78	0.77	22	AV6 +0.00
100	73	1.03	25	AV8 +0.05	102	91	0.69	20	AV6 +0.02	105	80	0.86	23	AV7 -0.02
		2.67	37	AV6 +0.02			1.75	32	AV5 +0.00			0.85	23	AV6 -0.02
		2.23	35	AV5 +0.00			1.60	31	AV4 +0.00			1.15	27	AV5 -0.03
		0.76	22	AV3 -0.05	102	95	0.71	21	AV7 +0.00	105	82	1.39	29	AV6 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		2.11	34	AV5 -0.03	108	91	0.92	24	AV7 +0.00			0.75	21	AV5 -0.03
		1.77	32	AV4 +0.00			2.19	35	AV6 +0.00	110	99	0.72	21	AV4 -0.02
		0.78	22	AV3 -0.05			2.71	38	AV5 +0.02	110	101	1.01	25	AV4 -0.02
105	96	0.97	24	AV5 +0.02			2.14	34	AV4 +0.00	110	103	0.69	20	AV6 +0.00
105	98	1.07	26	AV6 +0.00			1.85	33	AV3 -0.05			1.70	32	AV5 +0.00
		1.02	25	AV5 +0.00			1.08	26	AV2 -0.02			0.86	23	AV4 -0.02
105	100	0.76	22	AV5 +0.00	108	93	0.77	22	AV4 -0.02			0.90	24	AV3 -0.02
		0.69	20	AV4 +0.00			1.49	30	AV3 +0.00	111	70	0.68	20	AV5 +0.05
106	71	1.08	26	AV5 +0.02			0.71	21	AV2 +0.00	111	72	1.46	30	AV6 +0.00
106	73	0.71	21	AV8 +0.02			0.78	22	AV7 +0.02	111	74	1.48	30	AV6 +0.00
		2.71	38	AV6 +0.00			1.37	29	AV6 +0.02			0.97	24	AV5 -0.03
		2.25	35	AV5 +0.00			1.04	25	AV5 +0.00	111	76	0.87	23	AV6 +0.00
		1.19	27	AV4 +0.00	108	99	2.02	34	AV6 +0.02			0.67	20	AV5 -0.03
106	75	0.68	20	AV8 +0.02			2.12	34	AV5 -0.03	111	80	1.61	31	AV7 +0.00
		2.17	35	AV7 +0.00			1.71	32	AV3 +0.00			1.00	25	AV6 +0.00
		0.81	22	AV6 +0.02			1.35	29	AV2 -0.02			1.51	30	AV5 -0.05
		1.33	28	AV5 +0.00	108	101	1.11	26	AV3 +0.02	111	82	0.76	22	AV7 +0.00
106	77	0.82	22	AV6 +0.00			1.25	28	AV2 +0.00			2.22	35	AV5 +0.00
		1.53	30	AV5 +0.02	108	103	1.02	25	AV4 -0.05			1.43	29	AV4 -0.02
		1.28	28	AV4 -0.02			0.97	24	AV3 -0.05	111	86	2.18	35	AV4 +0.00
106	93	2.03	34	AV6 +0.05	108	105	0.96	24	AV6 +0.00			1.36	29	AV3 -0.02
		1.83	32	AV5 +0.05	109	68	0.87	23	AV6 +0.00			1.31	28	AV2 -0.02
		1.56	30	AV4 +0.03			1.02	25	AV5 +0.05			1.41	29	AV6 +0.00
106	95	2.26	35	AV4 +0.00			1.23	27	AV3 +0.02			1.71	32	AV5 +0.00
106	97	1.03	25	AV3 +0.00			2.50	36	AV2 +0.00	111	98	0.83	23	AV5 +0.05
106	99	0.66	20	AV4 -0.02	109	70	0.67	20	AV6 +0.02	112	69	0.78	22	AV6 +0.00
		1.27	28	AV6 +0.02	109	76	1.15	27	AV7 +0.02	112	73	0.69	20	AV4 -0.02
		0.72	21	AV5 +0.00			1.74	32	AV6 +0.07	112	75	1.01	25	AV5 +0.02
106	101	0.69	20	AV5 +0.00			1.36	29	AV4 +0.05	112	77	1.15	27	AV6 +0.05
		1.09	26	AV4 -0.02	109	82	2.55	37	AV5 +0.02			1.03	25	AV5 -0.03
106	103	1.15	27	AV6 +0.00			0.77	22	AV4 +0.00	112	79	1.08	26	AV7 +0.00
		0.98	25	AV5 -0.03			1.31	28	AV3 +0.00			2.01	34	AV5 +0.00
107	68	1.51	30	AV7 +0.00			0.78	22	AV2 -0.02			0.94	24	AV4 -0.02
		0.93	24	AV6 -0.02			1.45	29	AV7 +0.02			0.75	21	AV3 -0.02
107	70	1.00	25	AV5 +0.00			2.88	38	AV6 +0.02	112	81	0.93	24	AV6 +0.00
		1.46	30	AV4 -0.02	109	88	2.26	35	AV7 +0.00			1.23	27	AV5 -0.03
		0.71	21	AV3 -0.02			2.08	34	AV6 -0.02	112	83	1.21	27	AV7 +0.00
107	76	0.67	20	AV6 +0.00			1.34	28	AV5 -0.03			1.23	27	AV6 +0.00
107	86	0.79	22	AV7 +0.02			0.74	21	AV4 -0.02			1.06	26	AV5 -0.03
		1.42	29	AV6 -0.02	109	92	1.09	26	AV7 +0.00			2.35	36	AV4 -0.07
		0.68	20	AV5 -0.03			1.32	28	AV6 +0.00			0.85	23	AV3 -0.05
		1.02	25	AV4 -0.02			0.89	23	AV4 +0.00	112	87	2.05	34	AV7 +0.00
		0.85	23	AV3 -0.02			1.32	28	AV3 +0.00			2.30	35	AV6 +0.00
107	90	2.54	37	AV7 +0.00	109	94	0.76	22	AV6 +0.02			1.92	33	AV5 +0.00
		1.62	31	AV6 +0.00	109	98	0.87	23	AV6 +0.00			1.23	27	AV4 -0.02
		2.47	36	AV5 -0.03	109	100	3.01	39	AV7 +0.05			1.37	29	AV3 -0.02
		0.88	23	AV4 -0.02			1.38	29	AV5 +0.05			1.01	25	AV2 -0.02
107	96	1.61	31	AV7 +0.07			1.34	28	AV4 +0.05	112	93	0.84	23	AV7 +0.02
		0.75	21	AV6 +0.05	110	69	1.55	30	AV7 +0.00			0.81	22	AV6 +0.07
		0.76	22	AV3 +0.02			1.88	33	AV6 -0.02			0.65	20	AV5 +0.00
107	98	0.73	21	AV5 +0.00			0.82	22	AV5 +0.00			1.15	27	AV4 +0.00
		0.66	20	AV3 +0.00	110	73	1.31	28	AV5 +0.00			1.20	27	AV3 -0.02
107	100	1.13	26	AV5 +0.02			1.13	26	AV4 -0.02			0.78	22	AV2 +0.00
		0.81	22	AV4 -0.02			0.79	22	AV3 +0.02	112	95	0.78	22	AV2 +0.02
107	102	0.68	20	AV6 +0.02			0.90	24	AV2 -0.05			0.83	23	AV7 -0.02
		0.90	24	AV3 +0.00	110	75	1.30	28	AV5 +0.00			1.83	32	AV6 +0.02
108	71	1.21	27	AV6 +0.00			1.18	27	AV4 +0.00			0.76	21	AV5 +0.00
108	75	0.87	23	AV7 +0.02			1.09	26	AV3 +0.02	112	97	1.34	28	AV3 +0.02
		0.89	23	AV6 +0.05	110	77	1.60	31	AV6 +0.05	112	99	0.98	25	AV6 +0.07
		2.89	38	AV5 +0.00			2.50	36	AV5 +0.02			1.51	30	AV3 +0.02
108	77	1.61	31	AV7 +0.02			2.66	37	AV4 +0.00			1.53	30	AV2 +0.02
		2.56	37	AV6 +0.02			1.58	31	AV3 +0.02	112	103	1.87	33	AV5 +0.07
		1.42	29	AV5 +0.00	110	79	1.45	29	AV7 +0.05			0.96	24	AV4 +0.00
		0.89	23	AV4 -0.02			2.86	38	AV6 +0.07			0.84	23	AV3 -0.02
		0.89	23	AV3 +0.00			1.37	29	AV5 +0.02	113	74	2.27	35	AV6 +0.07
108	81	0.65	20	AV8 +0.02			0.79	22	AV4 +0.03			2.01	34	AV5 +0.09
		1.37	29	AV7 +0.02	110	81	1.25	28	AV5 +0.00			2.18	35	AV4 +0.03
		0.75	21	AV6 +0.02			0.75	21	AV4 +0.00			0.69	20	AV3 +0.05
		0.91	24	AV5 +0.02	110	93	1.33	28	AV4 -0.02	113	76	0.86	23	AV6 +0.02
		0.66	20	AV4 -0.02			1.84	33	AV3 -0.02			0.76	22	AV3 +0.00
		1.54	30	AV3 +0.00			0.81	22	AV2 -0.02	113	78	1.63	31	AV7 +0.02
		0.88	23	AV2 +0.00			1.19	27	AV6 +0.02			1.55	30	AV6 +0.00

SL2-26 - 09/21  
Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		1.82	32	AV5 +0.00			0.82	22	AV7 +0.02			0.88	23	AV5 -0.03
		1.07	26	AV4 +0.00	117	68	0.79	22	AV7 +0.05	122	79	1.00	25	AV7 +0.05
113	80	0.68	20	AV3 +0.00			1.70	32	AV6 +0.00			2.49	36	AV6 +0.02
		1.46	30	AV7 +0.02	117	70	0.72	21	AV7 +0.02			2.13	34	AV5 +0.00
		1.38	29	AV6 +0.02			1.15	27	AV6 +0.00			0.92	24	AV4 -0.05
113	88	1.20	27	AV7 +0.00	117	76	0.96	24	AV6 +0.00			0.90	24	AV3 -0.02
		1.56	30	AV6 -0.02	117	80	1.11	26	AV7 +0.00	122	81	1.12	26	AV8 +0.10
		1.05	25	AV5 -0.03			1.55	30	AV6 +0.00			1.61	31	AV7 +0.00
		1.69	31	AV4 -0.02			2.68	37	AV5 -0.03			2.04	34	AV6 -0.02
113	90	1.50	30	AV7 +0.00	117	92	0.75	21	AV6 +0.00			0.92	24	AV5 -0.05
		1.34	28	AV6 +0.00			0.68	20	AV5 -0.05	122	83	1.59	31	AV7 +0.02
		1.88	33	AV5 -0.03			0.90	24	AV4 -0.05			0.64	20	AV6 +0.05
		1.30	28	AV4 -0.05			1.13	26	AV3 -0.05			2.06	34	AV5 +0.02
		0.92	24	AV3 -0.05			0.94	24	AV2 -0.05			1.29	28	AV4 -0.02
113	94	0.70	21	AV6 +0.00	117	94	0.71	21	AV7 +0.05			1.99	34	AV3 -0.02
		0.73	21	AV5 -0.05			2.12	34	AV6 +0.07			0.95	24	AV2 -0.05
		0.73	21	AV6 +0.02			2.31	35	AV5 +0.07	122	87	0.69	20	AV6 +0.02
114	67	0.74	21	AV7 +0.02	118	73	0.64	20	AV6 +0.00			1.24	28	AV5 -0.03
114	75	1.04	25	AV5 +0.00	118	77	1.84	33	AV6 +0.02	122	101	2.37	36	AV4 +0.00
114	77	1.22	27	AV3 +0.00			1.88	33	AV5 -0.03			1.22	27	AV3 +0.00
114	79	1.54	30	AV7 +0.00	118	81	2.09	34	AV6 +0.00			1.06	26	AV2 -0.02
		1.85	33	AV6 +0.02			2.47	36	AV5 -0.03	123	72	1.40	29	AV7 +0.02
		1.35	29	AV5 +0.00	118	91	0.68	20	AV6 +0.05			2.03	34	AV5 -0.05
		0.66	20	AV4 -0.02			1.00	25	AV5 +0.02	123	80	0.70	21	AV8 +0.07
114	81	1.35	29	AV3 -0.02			0.94	24	AV3 +0.00			1.44	29	AV7 +0.05
114	87	1.25	28	AV5 -0.03	119	72	2.22	35	AV4 +0.05	123	88	1.18	27	AV3 -0.02
		1.80	32	AV4 -0.02	119	74	0.70	21	AV6 +0.05			2.04	34	AV5 -0.03
		1.54	30	AV3 -0.02	119	76	1.09	26	AV7 +0.05	123	90	0.81	22	AV8 +0.07
114	91	0.75	21	AV8 +0.05			2.27	35	AV6 +0.05			1.35	29	AV7 +0.02
		1.26	28	AV7 +0.02			1.21	27	AV5 +0.02			0.87	23	AV6 +0.00
		1.95	33	AV6 +0.02	119	80	0.76	22	AV8 +0.05			1.13	26	AV4 -0.05
		2.06	34	AV5 +0.00			1.40	29	AV7 +0.05			1.98	33	AV3 -0.02
		0.68	20	AV4 -0.05			1.39	29	AV6 +0.00			1.00	25	AV2 -0.05
		0.84	23	AV3 -0.02	119	88	0.79	22	AV7 +0.02	123	92	0.77	22	AV6 +0.00
114	93	0.64	20	AV5 -0.03			1.25	28	AV4 -0.05	123	94	1.27	28	AV7 +0.05
114	101	2.85	38	AV5 +0.02			0.77	22	AV3 -0.02			1.10	26	AV6 +0.05
		1.16	27	AV4 +0.00	119	96	0.97	25	AV5 +0.12			0.71	21	AV4 +0.00
		0.90	24	AV7 +0.02	120	79	0.97	24	AV7 +0.02	124	63	1.29	28	AV4 +0.00
		1.02	25	AV6 +0.02	120	81	0.64	20	AV8 +0.05			0.78	22	AV3 +0.00
115	66	1.23	27	AV7 +0.10			1.08	26	AV7 +0.00	124	69	2.07	34	AV7 +0.05
		2.25	35	AV6 +0.12			2.25	35	AV6 +0.00			2.26	35	AV6 +0.02
		1.35	29	AV2 +0.05			1.34	28	AV5 -0.05			0.87	23	AV5 +0.00
115	72	0.79	22	AV7 +0.07	120	91	1.35	29	AV5 -0.03			1.38	29	AV3 +0.02
		1.48	30	AV6 +0.02			0.75	21	AV4 -0.05			1.16	27	AV2 -0.02
115	74	0.87	23	AV6 +0.02			0.65	20	AV2 +0.00	124	73	0.72	21	AV7 +0.02
		2.13	34	AV3 +0.00	120	93	1.41	29	AV8 +0.07			1.40	29	AV6 +0.02
		1.57	30	AV2 -0.02			1.66	31	AV7 +0.05			1.26	28	AV4 -0.02
115	80	1.49	30	AV7 +0.02			0.97	25	AV6 +0.05	124	77	0.90	24	AV7 +0.05
		2.08	34	AV6 +0.00			1.26	28	AV4 +0.03			0.70	21	AV6 +0.05
		1.98	33	AV5 -0.03			1.17	27	AV3 +0.02	124	87	0.82	22	AV5 -0.03
115	82	0.70	21	AV7 +0.00	120	97	1.06	26	AV6 +0.00	124	91	1.35	29	AV5 -0.03
		1.04	25	AV6 +0.00	120	99	0.65	20	AV7 +0.05			2.33	36	AV4 -0.07
		2.01	34	AV5 -0.03			1.44	29	AV6 +0.00			0.64	20	AV3 -0.05
		1.27	28	AV4 -0.02			1.42	29	AV5 -0.03			0.77	22	AV2 +0.00
		1.26	28	AV3 -0.02			2.06	34	AV4 -0.05	124	99	0.99	25	AV5 +0.05
115	92	0.64	20	AV6 +0.02			0.96	24	AV3 +0.00			0.84	23	AV4 +0.08
		0.87	23	AV5 -0.03			1.09	26	AV2 +0.00	125	72	0.95	24	AV6 +0.02
		1.33	28	AV4 -0.07	120	103	1.64	31	AV5 -0.05	125	76	1.35	29	AV6 +0.07
115	102	1.48	30	AV3 +0.02	121	78	2.31	35	AV6 +0.05			2.72	38	AV5 +0.09
		1.40	29	AV2 +0.02			0.95	24	AV5 +0.07			1.02	25	AV4 +0.05
116	81	2.32	36	AV6 -0.02	121	82	2.54	37	AV6 +0.00	125	80	1.18	27	AV8 +0.10
		2.88	38	AV5 -0.03	121	90	1.62	31	AV6 +0.00			2.78	38	AV7 +0.09
		1.04	25	AV4 -0.02			0.82	22	AV5 -0.05			0.84	23	AV5 +0.09
		0.86	23	AV3 -0.02			0.89	23	AV4 -0.05	125	82	1.21	27	AV7 +0.00
116	91	0.85	23	AV6 +0.00			0.90	24	AV3 -0.05			2.61	37	AV6 -0.02
		1.14	26	AV5 +0.00	121	92	1.87	33	AV7 +0.02			2.18	35	AV5 -0.05
116	93	0.79	22	AV7 +0.05			1.70	32	AV6 +0.02			2.61	37	AV4 -0.02
		0.72	21	AV6 +0.05			0.81	22	AV4 -0.02	125	88	2.53	37	AV7 +0.02
		1.37	29	AV5 +0.00			1.31	28	AV3 -0.02			2.60	37	AV6 +0.02
		0.79	22	AV3 -0.02			0.85	23	AV2 -0.02			2.54	37	AV5 -0.03
116	95	1.49	30	AV6 +0.02	121	94	1.67	31	AV7 +0.05			1.30	28	AV4 -0.07
		1.33	28	AV5 +0.00			2.27	35	AV6 +0.02	125	90	1.26	28	AV7 +0.02

SL2-26 - 09/21  
Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		2.69	37	AV5 -0.03			1.34	28	AV4 +0.00			1.82	32	AV6 +0.00
		2.82	38	AV4 -0.05	131	82	0.76	21	AV8 +0.07	135	92	1.98	33	AV5 -0.03
125	92	0.93	24	AV6 +0.02			1.44	29	AV7 +0.02			0.83	23	AV4 -0.05
		0.69	20	AV5 -0.03			1.01	25	AV6 -0.02			1.42	29	AV3 -0.05
126	69	1.57	30	AV7 +0.07			0.69	20	AV4 -0.02			0.99	25	AV2 -0.02
		0.76	22	AV6 +0.05	131	88	0.87	23	AV7 +0.05	135	94	1.01	25	AV7 +0.05
		0.82	22	AV3 +0.02			0.79	22	AV5 -0.03	135	96	0.78	22	AV8 +0.07
		0.79	22	AV2 +0.00			1.23	27	AV4 -0.02	136	75	1.52	30	AV7 +0.04
126	77	1.78	32	AV6 +0.00	131	92	0.81	22	AV7 +0.05			2.66	37	AV6 +0.07
		2.30	35	AV5 +0.00			0.88	23	AV5 -0.03			1.11	26	AV5 +0.02
126	97	0.64	20	AV3 +0.02			0.72	21	AV3 -0.02	136	81	0.65	20	AV6 +0.07
		0.64	20	AV6 +0.05			1.74	32	AV2 -0.02	136	85	0.67	20	AV2 -0.05
127	76	1.01	25	AV6 +0.09	131	94	2.55	37	AV7 +0.07	136	91	2.01	34	AV7 +0.07
		0.84	23	AV5 +0.12			0.93	24	AV6 +0.02			1.69	31	AV5 +0.02
127	80	0.85	23	AV7 +0.02			1.83	32	AV4 -0.05			0.96	24	AV3 +0.00
127	88	0.81	22	AV7 +0.05			0.74	21	AV3 -0.05	136	93	1.62	31	AV7 +0.09
		0.86	23	AV5 -0.08	132	69	0.67	20	AV7 +0.07			2.53	37	AV6 +0.05
		1.07	26	AV3 -0.07			1.47	30	AV6 +0.09			1.28	28	AV4 +0.00
		0.72	21	AV2 -0.07			0.85	23	AV3 +0.07			1.06	26	AV3 -0.02
127	90	0.99	25	AV8 +0.07	132	71	0.66	20	AV7 +0.02	137	84	0.69	20	AV7 +0.05
		2.04	34	AV7 +0.02	132	79	2.04	34	AV7 +0.04			1.56	30	AV6 +0.00
		2.20	35	AV6 +0.00			2.39	36	AV6 +0.00			1.31	28	AV4 -0.05
		1.18	27	AV4 -0.02			1.05	25	AV5 -0.03	137	92	0.88	23	AV2 -0.07
127	92	0.64	20	AV7 +0.02	132	81	1.38	29	AV6 +0.00	138	79	1.19	27	AV5 -0.05
		0.84	23	AV6 +0.00			0.81	22	AV8 +0.07	138	93	0.66	20	AV6 +0.05
		0.83	23	AV3 -0.07			0.78	22	AV7 +0.05	139	78	0.90	24	AV6 +0.05
		0.94	24	AV2 -0.02	132	87	0.66	20	AV6 +0.02			2.11	34	AV5 +0.00
127	96	1.35	29	AV5 +0.00	132	93	1.69	31	AV8 +0.09			1.14	26	AV4 -0.02
		0.80	22	AV4 +0.00			2.36	36	AV7 +0.05	139	92	1.31	28	AV7 +0.09
128	67	0.98	25	AV2 -0.07			1.68	31	AV6 +0.02					
		1.50	30	AV5 -0.08	132	99	0.73	21	AV5 +0.09					
		0.82	22	AV4 -0.12	133	68	0.92	24	AV8 +0.05					
		1.60	31	AV3 -0.09			0.93	24	AV7 +0.02					
128	73	1.03	25	AV6 +0.02			1.15	27	AV6 -0.05					
128	87	0.75	21	AV3 -0.02			0.83	23	AV2 -0.05					
		0.74	21	AV2 +0.00	133	70	1.25	28	AV7 -0.02					
		1.29	28	AV5 -0.03	133	72	1.06	26	AV7 +0.02					
		0.80	22	AV4 -0.02			0.75	21	AV3 -0.05					
128	95	1.13	26	AV7 +0.05	133	74	1.24	28	AV7 +0.04					
		2.64	37	AV6 +0.02	133	76	0.68	20	AV4 +0.03					
128	99	2.73	38	AV7 +0.07	133	86	1.36	29	AV7 +0.05					
		1.18	27	AV6 +0.02			1.68	31	AV6 +0.02					
		0.79	22	AV4 -0.02			2.16	35	AV5 +0.00					
128	117	2.63	37	AV7 +0.05			1.29	28	AV3 -0.02					
		1.18	27	AV6 +0.02			1.59	31	AV2 -0.07					
		1.02	25	AV8 +0.09	133	88	0.73	21	AV6 -0.02					
129	66	1.06	26	AV6 +0.07	133	92	1.10	26	AV7 +0.02					
129	74	0.64	20	AV6 +0.05			1.99	33	AV4 -0.02					
129	78	0.97	24	AV7 +0.05			1.87	33	AV3 -0.02					
		1.10	26	AV6 +0.05			1.10	26	AV2 -0.02					
		0.64	20	AV5 +0.02	134	73	0.79	22	AV7 +0.02					
129	86	0.97	24	AV7 +0.02			1.15	27	AV6 -0.05					
		0.73	21	AV6 +0.00			0.64	20	AV4 -0.07					
129	104	1.07	26	AV7 +0.05	134	79	2.52	37	AV6 -0.02					
		0.88	23	AV6 +0.00			1.98	33	AV5 -0.08					
130	79	1.61	31	AV7 +0.07			2.96	39	AV4 -0.09					
		1.67	31	AV5 +0.05			2.19	35	AV3 -0.05					
130	93	0.66	20	AV4 +0.08	134	83	1.73	32	AV7 +0.05					
		2.16	35	AV3 +0.00			1.16	27	AV6 +0.02					
		2.34	36	AV2 -0.02			2.87	38	AV5 -0.03					
130	95	1.54	30	AV7 +0.07	134	87	0.72	21	AV7 +0.09					
		2.37	36	AV6 +0.09			2.50	36	AV6 +0.07					
130	97	0.96	24	AV6 +0.07			2.32	35	AV5 +0.02					
		0.75	21	AV2 +0.02	134	97	0.75	21	AV4 -0.07					
		0.80	22	AV3 +0.02			0.68	20	AV3 -0.05					
131	70	1.31	28	AV4 +0.00	135	70	1.50	30	AV4 +0.03					
131	74	2.74	38	AV7 +0.07			1.01	25	AV3 +0.00					
		2.12	34	AV6 +0.12	135	74	1.06	25	AV4 +0.10					
		1.84	33	AV5 +0.11			1.06	26	AV3 +0.02					
		1.92	33	AV4 +0.10	135	78	1.41	29	AV6 +0.05					
131	78	2.91	38	AV6 +0.05			1.26	28	AV4 +0.00					
		2.13	34	AV5 +0.07			0.98	25	AV3 +0.00					

Total Tubes : 784  
Total Records: 2117

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
33	164	0.12	6	AV7 +0.24	47	14	0.07	4	AV2 +0.00			0.15	8	AV3 -0.24
34	165	0.16	8	AV2 -0.28			0.13	7	AV3 +0.33	51	16	0.18	8	AV3 +0.34
		0.17	8	AV7 +0.25	47	16	0.13	7	AV3 +0.32	51	24	0.35	13	AV3 +0.28
35	6	0.20	9	AV7 -0.20	47	24	0.17	8	AV3 +0.34	51	156	0.15	7	AV3 +0.26
36	159	0.10	6	AV2 +0.25	47	158	0.13	7	AV6 +0.23			0.21	9	AV6 -0.03
36	163	0.15	8	AV7 +0.25	47	160	0.10	5	AV1 +0.02	51	158	0.15	7	AV3 -0.19
36	165	0.11	6	AV2 -0.27			0.12	6	AV2 -0.23			0.12	6	AV6 +0.21
37	6	0.25	11	AV7 -0.24			0.12	6	AV3 -0.17	51	160	0.14	7	AV2 -0.23
37	164	0.13	7	AV2 -0.23			0.12	6	AV7 +0.18			0.13	7	AV7 +0.18
38	163	0.16	8	AV2 -0.24	47	162	0.14	7	AV2 -0.23	51	162	0.11	6	AV1 +0.17
		0.14	7	AV7 +0.25			0.20	9	AV3 -0.26			0.19	9	AV2 -0.26
38	165	0.13	7	AV7 +0.25			0.30	12	AV6 +0.19			0.25	11	AV3 -0.22
39	6	0.15	7	AV2 -0.21	48	7	0.32	13	AV3 -0.23			0.20	9	AV7 -0.25
		0.15	7	AV7 -0.20			0.19	9	AV7 +0.23			0.19	9	AV7 +0.25
39	8	0.17	8	AV7 +0.20			0.12	6	AV8 +0.18	52	9	0.20	9	AV2 -0.18
		0.10	6	AV8 -0.16	48	9	0.24	10	AV2 -0.23			0.25	11	AV7 +0.21
39	162	0.10	6	AV2 -0.16			0.12	6	AV3 -0.22			0.16	8	AV8 +0.20
39	164	0.12	6	AV8 +0.18			0.14	7	AV6 +0.18	52	11	0.10	6	AV1 -0.03
		0.28	12	AV2 -0.24			0.18	9	AV7 +0.20			0.22	10	AV3 -0.24
		0.19	9	AV7 +0.23	48	11	0.17	8	AV3 -0.22			0.17	8	AV6 +0.16
40	161	0.14	7	AV7 +0.20	48	161	0.07	4	AV2 -0.02			0.22	10	AV7 +0.19
40	163	0.13	7	AV2 -0.26			0.31	12	AV6 +0.21	52	13	0.20	9	AV2 -0.23
		0.26	11	AV7 +0.22			0.14	7	AV7 +0.21			0.14	7	AV3 +0.33
41	6	0.12	6	AV2 -0.26	48	163	0.42	15	AV2 -0.21	52	17	0.11	6	AV3 -0.19
41	8	0.13	7	AV7 +0.23			0.13	7	AV3 +0.38	52	19	0.14	7	AV3 +0.03
41	164	0.18	9	AV7 -0.19	49	8	0.14	7	AV2 -0.21	52	23	0.23	10	AV3 -0.17
42	7	0.13	7	AV7 +0.02			0.22	10	AV6 +0.21	52	39	0.11	6	AV3 -0.05
42	9	0.11	6	AV2 -0.19			0.21	9	AV7 +0.18	52	151	0.15	7	AV6 +0.16
42	163	0.15	8	AV7 -0.21	49	10	0.34	13	AV3 +0.40	52	159	0.13	7	AV1 +0.19
43	6	0.14	7	AV2 +0.20	49	12	0.08	5	AV2 -0.14			0.20	9	AV6 -0.03
		0.21	9	AV3 -0.29			0.25	11	AV3 -0.23			0.13	7	AV8 +0.21
43	162	0.12	6	AV6 +0.33	49	14	0.12	6	AV3 +0.33	52	161	0.37	14	AV6 +0.18
43	164	0.16	8	AV6 +0.29	49	24	0.16	8	AV3 +0.30			0.15	7	AV7 +0.20
		0.16	8	AV7 -0.22	49	156	0.11	6	AV3 +0.38	53	8	0.13	7	AV1 -0.23
44	7	0.26	11	AV3 -0.20	49	158	0.15	8	AV6 +0.23			0.10	5	AV2 -0.20
		0.18	8	AV7 +0.23			0.17	8	AV7 +0.23			0.22	10	AV3 -0.22
44	9	0.15	8	AV2 -0.19	49	160	0.16	8	AV2 -0.21			0.25	11	AV7 +0.21
44	11	0.11	6	AV8 +0.18			0.17	8	AV7 +0.16			0.13	7	AV8 +0.18
		0.08	5	AV1 +0.05	49	162	0.16	8	AV2 -0.22	53	10	0.20	9	AV2 -0.19
44	161	0.09	5	AV6 +0.29			0.16	8	AV3 -0.24			0.31	12	AV3 +0.30
44	163	0.29	12	AV2 -0.24			0.13	7	AV7 +0.20			0.17	8	AV6 -0.06
		0.31	12	AV3 -0.22	50	7	0.33	13	AV2 +0.19	53	14	0.14	7	AV2 -0.17
		0.25	11	AV6 +0.29			0.27	11	AV3 -0.19			0.18	8	AV3 -0.25
		0.19	9	AV8 +0.18			0.29	12	AV7 +0.23			0.13	7	AV8 +0.02
45	8	0.16	8	AV6 +0.21			0.17	8	AV7 -0.20	53	16	0.27	11	AV3 +0.31
		0.11	6	AV7 +0.23	50	9	0.26	11	AV7 +0.18			0.32	13	AV6 -0.25
45	12	0.20	9	AV3 -0.19			0.12	6	AV2 -0.20			0.34	13	AV7 +0.00
45	160	0.13	7	AV3 -0.19	50	11	0.14	7	AV1 -0.16	53	24	0.24	10	AV3 +0.31
45	162	0.11	6	AV1 +0.19			0.13	7	AV3 -0.21	53	154	0.16	8	AV6 -0.22
		0.13	7	AV2 -0.23			0.14	7	AV7 +0.16	53	158	0.08	5	AV2 -0.16
		0.18	9	AV3 -0.21	50	13	0.13	7	AV3 +0.35			0.25	11	AV3 +0.03
		0.13	7	AV6 +0.27			0.15	7	AV7 +0.21			0.18	9	AV6 -0.03
		0.13	7	AV7 -0.22	50	15	0.12	6	AV3 +0.39			0.21	10	AV7 +0.23
		0.14	7	AV8 +0.00	50	157	0.30	12	AV6 -0.32	53	160	0.25	11	AV2 -0.19
46	7	0.37	14	AV3 -0.22			0.15	7	AV7 -0.16			0.12	6	AV3 -0.20
		0.27	11	AV7 +0.18	50	159	0.17	8	AV3 +0.26			0.17	8	AV7 +0.20
46	9	0.09	5	AV3 -0.23			0.18	8	AV6 -0.29			0.17	8	AV8 +0.18
		0.12	6	AV7 +0.16			0.12	6	AV7 -0.21	53	162	0.47	16	AV3 -0.20
		0.14	7	AV6 +0.20	50	161	0.12	6	AV2 -0.24			0.16	8	AV6 +0.23
46	11	0.13	7	AV3 -0.23			0.34	13	AV6 +0.23			0.21	10	AV7 -0.25
46	17	0.15	7	AV3 -0.17			0.18	8	AV7 +0.20	54	9	0.15	8	AV1 -0.11
46	161	0.20	9	AV2 -0.26	50	163	0.21	9	AV2 -0.21			0.42	15	AV2 -0.19
		0.26	11	AV6 +0.23			0.22	10	AV3 +0.38			0.35	13	AV3 -0.20
46	163	0.16	8	AV2 -0.26			0.18	8	AV7 -0.23			0.19	9	AV6 +0.26
		0.12	6	AV3 -0.19	51	8	0.22	10	AV3 -0.26			0.19	9	AV8 +0.18
		0.27	11	AV6 +0.21			0.60	19	AV6 -0.31	54	11	0.14	7	AV2 -0.19
		0.16	8	AV8 +0.20			0.24	10	AV7 +0.23			0.16	8	AV3 +0.03
47	8	0.17	8	AV2 -0.18			0.11	6	AV8 +0.18			0.15	7	AV7 +0.21
		0.17	8	AV6 +0.23			0.19	9	AV2 -0.17			0.11	6	AV8 +0.16
47	10	0.31	12	AV3 +0.34	51	10	0.26	11	AV3 +0.30	54	13	0.12	6	AV1 -0.18
47	12	0.16	8	AV3 -0.27			0.15	7	AV8 -0.14			0.21	9	AV3 +0.30
		0.12	6	AV7 +0.20	51	14	0.23	10	AV2 -0.16			0.15	7	AV7 +0.23

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
54	15	0.15	7	AV7 +0.18	56	161	0.31	12	AV3 -0.18			0.13	7	AV3 -0.19
54	29	0.15	7	AV3 -0.21			0.15	7	AV7 -0.23	59	12	0.11	6	AV2 -0.20
54	153	0.28	11	AV6 -0.22			0.55	18	AV6 +0.21			0.17	8	AV3 -0.22
54	155	0.23	10	AV6 -0.28			0.38	14	AV6 -0.30			0.12	6	AV6 +0.21
54	157	0.13	7	AV7 +0.18	57	10	0.19	9	AV1 -0.15			0.32	13	AV7 +0.18
54	159	0.09	5	AV1 +0.21			0.17	8	AV2 -0.21	59	14	0.09	5	AV2 -0.15
		0.17	8	AV3 +0.33			0.16	8	AV3 +0.34			0.38	14	AV3 -0.14
		0.23	10	AV6 -0.25			0.45	16	AV6 -0.25			0.11	6	AV6 +0.21
		0.14	7	AV7 +0.20			0.33	13	AV7 +0.14			0.10	6	AV7 +0.21
		0.10	6	AV8 +0.21			0.22	10	AV8 +0.18	59	16	0.15	8	AV7 +0.19
54	161	0.14	7	AV1 -0.26	57	12	0.15	7	AV7 +0.21	59	28	0.18	9	AV2 -0.16
		0.14	7	AV2 -0.21			0.14	7	AV3 +0.34	59	152	0.18	8	AV8 +0.00
		0.23	10	AV3 -0.20	57	14	0.18	8	AV3 +0.03	59	154	0.20	9	AV7 +0.02
		0.51	17	AV6 +0.23	57	16	0.10	5	AV3 -0.14			0.15	7	AV6 -0.03
55	10	0.20	9	AV1 -0.22	57	20	0.12	6	AV3 +0.03	59	156	0.16	8	AV2 -0.19
		0.12	6	AV7 +0.19	57	24	0.38	14	AV3 +0.24			0.07	5	AV3 +0.26
55	12	0.17	8	AV1 -0.17	57	130	0.12	6	AV6 -0.27			0.15	8	AV6 +0.23
		0.12	6	AV2 -0.16	57	144	0.33	13	AV6 +0.00			0.14	7	AV7 +0.20
		0.25	11	AV3 -0.19	57	148	0.12	6	AV1 -0.02	59	158	0.21	9	AV1 -0.14
		0.19	9	AV6 +0.00	57	152	0.23	10	AV6 -0.03			0.24	10	AV2 -0.21
		0.27	11	AV7 +0.00			0.10	5	AV8 -0.29			0.29	12	AV3 +0.03
		0.22	10	AV8 -0.07	57	154	0.12	6	AV3 +0.05			0.18	8	AV6 +0.23
55	14	0.31	12	AV3 -0.21			0.16	8	AV6 +0.21			0.35	13	AV7 +0.20
55	16	0.21	10	AV3 +0.26			0.19	9	AV7 +0.16	59	160	0.22	10	AV1 -0.17
		0.32	13	AV6 -0.06	57	156	0.11	6	AV7 +0.23			0.35	13	AV7 +0.20
		0.44	16	AV7 -0.02			0.17	8	AV2 -0.16			0.28	12	AV8 +0.21
		0.14	7	AV8 +0.02			0.16	8	AV6 +0.18	60	11	0.15	8	AV1 -0.15
55	22	0.16	8	AV6 +0.21	57	158	0.11	6	AV1 +0.02			0.12	6	AV2 -0.19
55	24	0.16	8	AV3 +0.28			0.17	8	AV2 -0.17			0.36	14	AV3 +0.27
55	146	0.16	8	AV6 +0.21			0.25	11	AV3 -0.15			0.17	8	AV6 -0.25
55	154	0.09	5	AV7 +0.18			0.23	10	AV6 +0.21			0.29	12	AV7 +0.18
55	156	0.12	6	AV6 -0.24			0.26	11	AV7 +0.23			0.14	7	AV8 +0.18
		0.15	7	AV7 +0.23	57	160	0.31	12	AV2 -0.19	60	13	0.11	6	AV1 -0.16
55	158	0.11	6	AV3 -0.21			0.20	9	AV7 +0.23			0.16	8	AV2 -0.17
		0.19	9	AV6 +0.21			0.21	10	AV8 +0.21			0.23	10	AV3 -0.17
		0.15	7	AV7 +0.23	58	9	0.22	10	AV3 -0.19			0.23	10	AV7 +0.00
55	160	0.09	5	AV1 -0.14			0.41	15	AV6 -0.24			0.25	11	AV8 +0.05
		0.26	11	AV2 -0.24			0.47	16	AV7 +0.19	60	15	0.14	7	AV2 +0.00
		0.14	7	AV3 -0.19			0.18	8	AV8 +0.22			0.24	10	AV3 +0.24
		0.43	15	AV7 +0.18	58	11	0.13	7	AV2 +0.00	60	17	0.18	8	AV3 +0.00
		0.17	8	AV8 +0.18			0.21	9	AV3 -0.21			0.24	10	AV6 -0.21
56	9	0.14	7	AV2 -0.17			0.22	10	AV7 +0.19			0.15	8	AV7 -0.16
		0.47	16	AV3 -0.24	58	13	0.16	8	AV3 -0.19			0.29	12	AV8 +0.02
		0.43	15	AV7 +0.18			0.25	11	AV7 +0.16	60	21	0.08	5	AV1 +0.27
		0.12	6	AV8 +0.23	58	15	0.10	6	AV2 +0.19	60	23	0.10	6	AV2 -0.18
56	11	0.13	7	AV2 -0.17			0.15	7	AV3 -0.22			0.20	9	AV3 -0.19
		0.23	10	AV3 -0.21			0.20	9	AV7 -0.15	60	25	0.12	6	AV3 -0.09
		0.13	7	AV6 +0.19	58	17	0.10	6	AV3 -0.22			0.24	10	AV7 +0.02
		0.12	6	AV7 +0.18	58	19	0.12	6	AV8 -0.02			0.26	11	AV8 +0.02
		0.11	6	AV8 +0.20	58	23	0.15	7	AV3 -0.16	60	29	0.17	8	AV7 +0.02
56	13	0.12	6	AV2 -0.18	58	33	0.17	8	AV6 -0.03	60	51	0.08	5	AV3 +0.15
		0.14	7	AV3 +0.30			0.18	8	AV7 +0.02	60	139	0.11	6	AV6 +0.19
		0.13	7	AV7 +0.19	58	51	0.13	7	AV3 -0.16	60	143	0.12	6	AV6 +0.16
56	15	0.26	11	AV7 +0.02	58	65	0.11	6	AV3 +0.03	60	145	0.17	8	AV6 +0.19
56	17	0.15	7	AV3 +0.27	58	143	0.19	9	AV6 +0.02	60	149	0.47	16	AV6 +0.00
		0.53	17	AV7 +0.00	58	153	0.14	7	AV6 -0.26	60	151	0.17	8	AV6 -0.24
		0.13	7	AV8 +0.00	58	155	0.16	8	AV8 +0.02	60	153	0.54	18	AV6 -0.24
56	23	0.13	7	AV3 -0.21	58	157	0.15	8	AV8 -0.02	60	157	0.14	7	AV1 +0.05
56	25	0.11	6	AV3 -0.21			0.11	6	AV6 -0.32			0.15	8	AV2 -0.19
56	51	0.13	7	AV3 -0.16			0.35	13	AV7 +0.18			0.12	7	AV3 +0.24
56	139	0.14	7	AV6 +0.18	58	159	0.12	6	AV1 +0.05			0.10	6	AV6 +0.21
56	145	0.14	7	AV7 +0.02			0.12	6	AV2 -0.12			0.25	11	AV7 +0.20
56	153	0.21	10	AV6 -0.03			0.12	6	AV3 +0.03			0.14	7	AV8 +0.21
56	155	0.14	7	AV6 +0.16			0.28	12	AV6 -0.03	60	159	0.28	12	AV1 +0.02
		0.11	6	AV7 +0.16			0.16	8	AV7 +0.18			0.48	16	AV3 +0.32
56	157	0.11	6	AV2 -0.17			0.13	7	AV8 +0.21			0.35	13	AV6 +0.02
		0.22	10	AV6 -0.27	58	161	0.18	8	AV3 -0.22			0.14	7	AV7 +0.20
		0.23	10	AV7 +0.18	59	10	0.39	15	AV7 +0.16			0.16	8	AV8 +0.23
56	159	0.18	8	AV3 +0.30			0.20	9	AV8 +0.18	61	10	0.36	14	AV3 -0.14
		0.27	11	AV6 -0.27			0.62	19	AV6 -0.29			0.22	10	AV6 -0.26
		0.10	5	AV7 +0.14			0.20	9	AV1 -0.16			0.43	15	AV7 +0.12
		0.19	9	AV8 +0.23			0.16	8	AV2 -0.18			0.15	7	AV8 +0.20

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
61	12	0.26	11	AV2 -0.16			0.23	10	AV7 +0.23			0.25	11	AV6 +0.00
		0.14	7	AV1 -0.20			0.32	13	AV8 +0.00			0.10	6	AV8 +0.00
		0.32	13	AV3 +0.26	62	159	0.22	10	AV2 +0.22			0.24	11	AV7 +0.18
		0.10	6	AV6 +0.19			0.26	11	AV3 +0.34	64	159	0.26	11	AV2 +0.17
		0.20	9	AV7 +0.19			0.21	9	AV6 -0.23			0.19	9	AV3 -0.15
61	14	0.09	5	AV2 -0.18			0.15	7	AV7 +0.20			0.26	11	AV6 -0.21
		0.47	16	AV3 -0.16	63	12	0.19	9	AV3 -0.17			0.21	9	AV7 -0.19
		0.27	11	AV6 -0.03			0.19	9	AV7 +0.19	65	12	0.20	9	AV1 -0.16
		0.19	9	AV7 +0.23	63	14	0.16	8	AV2 -0.16			0.20	9	AV3 +0.28
61	16	0.11	6	AV1 +0.05			0.34	13	AV3 -0.17			0.12	6	AV6 -0.23
		0.12	6	AV2 +0.00			0.40	15	AV6 -0.05			0.16	8	AV8 +0.20
		0.25	11	AV3 +0.25			0.15	7	AV3 +0.32			0.11	6	AV2 +0.17
		0.24	10	AV6 -0.03	63	16	0.11	6	AV1 -0.02	65	14	0.42	15	AV3 +0.03
		0.14	7	AV8 +0.02			0.18	8	AV3 +0.03	65	16	0.10	6	AV1 -0.46
61	18	0.15	7	AV2 +0.05			0.39	14	AV6 -0.05			0.26	11	AV3 +0.05
61	24	0.16	8	AV3 +0.29			0.19	9	AV7 +0.02	65	18	0.11	6	AV3 +0.00
61	26	0.08	5	AV1 +0.00			0.19	9	AV8 +0.02	65	20	0.11	6	AV2 -0.17
		0.08	5	AV3 -0.16	63	18	0.10	5	AV2 +0.05	65	22	0.15	7	AV3 -0.02
61	54	0.08	5	AV3 +0.03	63	22	0.30	12	AV3 +0.05	65	24	0.31	12	AV3 +0.23
61	142	0.17	8	AV6 +0.00			0.24	10	AV6 +0.05			0.53	18	AV6 -0.05
61	146	0.48	16	AV6 -0.03	63	26	0.14	7	AV6 +0.16	65	32	0.17	8	AV3 +0.00
		0.40	15	AV7 +0.00	63	32	0.11	6	AV3 -0.02	65	34	0.14	7	AV2 +0.00
		0.20	9	AV8 +0.02			0.17	8	AV6 +0.02			0.20	9	AV3 +0.05
61	152	0.19	9	AV6 -0.05	63	68	0.18	9	AV2 +0.02			0.61	19	AV6 -0.03
61	154	0.37	14	AV6 -0.05	63	110	0.18	8	AV6 +0.02	65	38	0.09	5	AV3 +0.00
		0.39	14	AV7 +0.00	63	150	0.29	12	AV6 -0.05			0.12	6	AV6 +0.00
		0.17	8	AV8 +0.02	63	152	0.30	12	AV6 -0.03	65	52	0.11	6	AV3 +0.05
61	156	0.11	6	AV3 +0.00			0.15	8	AV7 -0.19			0.22	10	AV6 +0.00
		0.17	8	AV6 +0.00	63	154	0.48	16	AV6 +0.00			0.11	6	AV7 +0.02
		0.23	10	AV7 +0.20			0.31	12	AV7 +0.00	65	62	0.11	6	AV6 +0.05
61	158	0.12	6	AV2 -0.20	63	156	0.27	11	AV7 +0.18	65	64	0.16	8	AV3 +0.03
		0.45	16	AV3 +0.32			0.13	7	AV1 +0.16	65	68	0.16	8	AV3 -0.05
		0.43	15	AV6 -0.24			0.29	12	AV3 +0.25			0.14	7	AV6 +0.02
		0.18	9	AV7 +0.20			0.18	8	AV6 +0.21	65	86	0.12	6	AV3 +0.03
61	160	0.26	11	AV3 -0.18	63	158	0.27	11	AV3 -0.15	65	104	0.24	10	AV6 +0.03
		0.29	12	AV7 -0.19			0.44	16	AV7 +0.20	65	110	0.12	6	AV6 +0.02
62	11	0.19	9	AV1 -0.18			0.16	8	AV8 +0.19	65	130	0.11	6	AV2 +0.04
		0.15	8	AV2 -0.03	64	11	0.38	14	AV3 -0.19			0.34	13	AV3 +0.05
		0.36	14	AV3 +0.26			0.16	8	AV6 -0.21			0.53	18	AV7 +0.02
		0.56	18	AV6 -0.21			0.16	8	AV7 +0.21	65	132	0.10	6	AV6 -0.18
		0.33	13	AV7 +0.21	64	13	0.14	7	AV2 -0.19	65	138	0.16	8	AV6 -0.18
62	13	0.09	5	AV1 -0.20			0.10	6	AV3 +0.26	65	144	0.18	9	AV3 +0.00
		0.23	10	AV2 -0.16			0.35	14	AV6 -0.03	65	148	0.38	14	AV3 +0.03
		0.44	16	AV3 -0.16			0.53	17	AV7 +0.00	65	150	0.12	6	AV1 -0.15
		0.21	10	AV7 +0.00			0.34	13	AV8 +0.00	65	152	0.24	10	AV6 -0.03
		0.22	10	AV8 +0.02	64	15	0.20	9	AV2 +0.02			0.24	10	AV7 -0.02
62	15	0.12	6	AV3 -0.19			0.21	9	AV3 +0.05	65	154	0.24	11	AV6 +0.02
		0.30	12	AV7 +0.02			0.45	16	AV6 +0.00	65	156	0.12	6	AV2 -0.14
		0.18	9	AV8 +0.02			0.21	9	AV7 +0.02			0.32	13	AV3 +0.25
62	17	0.20	9	AV3 -0.19	64	17	0.12	6	AV3 -0.17			0.19	9	AV7 -0.21
		0.41	15	AV6 -0.21	64	19	0.12	6	AV8 -0.09	65	158	0.13	7	AV1 -0.14
		0.21	9	AV7 -0.02	64	21	0.11	6	AV3 +0.00			0.29	12	AV8 +0.14
		0.10	5	AV8 +0.02	64	23	0.22	10	AV3 -0.19	66	13	0.13	7	AV1 +0.00
62	19	0.46	16	AV6 -0.03			0.17	8	AV8 +0.04			0.39	14	AV2 +0.05
		0.23	10	AV7 -0.02	64	27	0.13	7	AV3 -0.17			0.36	14	AV7 +0.02
62	21	0.42	15	AV6 +0.00			0.16	8	AV6 -0.05			0.16	8	AV8 +0.16
		0.39	14	AV7 +0.02			0.16	8	AV7 +0.00	66	15	0.09	5	AV1 +0.00
62	23	0.17	8	AV3 -0.17	64	31	0.14	7	AV3 -0.17			0.17	8	AV2 +0.02
62	29	0.11	6	AV3 +0.03	64	33	0.21	10	AV6 +0.00			0.26	11	AV3 -0.17
		0.18	8	AV6 -0.03	64	59	0.10	6	AV3 -0.19			0.33	13	AV6 -0.03
62	31	0.13	7	AV3 -0.20	64	67	0.14	7	AV3 +0.00			0.16	8	AV7 -0.16
62	37	0.15	8	AV6 -0.05	64	101	0.17	8	AV6 +0.26	66	17	0.14	7	AV2 +0.00
62	39	0.19	9	AV6 +0.02	64	107	0.12	6	AV3 +0.00			0.22	10	AV3 +0.25
		0.15	8	AV7 -0.02	64	129	0.17	8	AV6 -0.03			0.17	8	AV6 -0.03
62	43	0.12	6	AV3 -0.21	64	137	0.11	6	AV3 -0.18	66	19	0.60	19	AV7 +0.00
62	131	0.16	8	AV6 +0.00			0.15	7	AV7 -0.02			0.20	9	AV8 +0.02
62	139	0.16	8	AV6 +0.21	64	151	0.26	11	AV6 -0.03	66	23	0.28	11	AV3 -0.16
62	149	0.13	7	AV2 -0.14	64	153	0.41	15	AV6 +0.00	66	29	0.25	11	AV6 +0.02
62	155	0.18	9	AV8 +0.00			0.23	10	AV7 +0.05	66	31	0.08	5	AV2 -0.45
62	157	0.14	7	AV1 -0.19	64	157	0.12	6	AV1 -0.17			0.17	8	AV3 -0.21
		0.12	6	AV2 -0.17			0.49	17	AV2 -0.14			0.24	10	AV6 -0.02
		0.13	7	AV6 -0.03			0.24	10	AV3 +0.03	66	33	0.16	8	AV6 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
66	41	0.19	9	AV6 -0.05			0.44	16	AV7 +0.02			0.27	9	AV4 +0.90
66	49	0.10	5	AV6 +0.02	67	154	0.23	10	AV3 +0.03	69	20	0.15	8	AV2 +0.17
66	51	0.18	9	AV6 +0.02			0.29	12	AV6 +0.00			0.22	8	AV4 +0.75
66	57	0.11	6	AV6 +0.00			0.21	9	AV7 +0.02	69	24	0.20	9	AV2 +0.19
66	63	0.20	9	AV6 +0.02	67	156	0.16	8	AV1 -0.15			0.15	7	AV3 +0.29
66	65	0.09	5	AV3 -0.16			0.23	10	AV2 -0.14			0.21	8	AV4 +0.95
66	75	0.09	5	AV3 -0.14			0.53	17	AV3 +0.23	69	28	0.09	5	AV7 +0.00
66	89	0.14	7	AV2 -0.14			0.18	8	AV6 -0.15	69	34	0.12	6	AV2 +0.23
		0.11	6	AV3 -0.02			0.25	11	AV7 -0.16			0.15	7	AV3 +0.21
66	93	0.09	5	AV3 -0.21			0.25	11	AV8 +0.19	69	36	0.12	6	AV3 +0.12
66	95	0.09	5	AV2 +0.02	67	158	0.11	6	AV2 -0.21			0.27	11	AV6 -0.04
66	99	0.17	8	AV2 +0.05			0.26	11	AV3 +0.28			0.15	6	AV4 +0.97
		0.18	8	AV3 +0.03			0.14	7	AV6 +0.21	69	38	0.16	8	AV3 +0.17
		0.27	11	AV6 +0.02			0.43	15	AV7 +0.18	69	44	0.22	7	AV4 +0.73
66	103	0.14	7	AV6 +0.05			0.23	10	AV8 +0.21	69	46	0.10	5	AV3 +0.03
66	109	0.13	7	AV3 -0.05	68	13	0.17	8	AV1 -0.20			0.14	5	AV4 +0.98
		0.20	9	AV6 +0.00			0.21	9	AV2 +0.24	69	52	0.20	9	AV6 +0.07
66	143	0.22	10	AV3 +0.03			0.43	15	AV3 +0.24			0.22	10	AV7 +0.02
		0.47	16	AV6 -0.03			0.19	9	AV7 -0.19			0.12	5	AV4 +0.96
		0.20	9	AV7 +0.00			0.21	9	AV8 +0.20	69	56	0.21	8	AV4 +1.02
66	149	0.22	10	AV6 -0.03	68	15	0.11	6	AV2 +0.19	69	62	0.27	11	AV3 +0.00
66	151	0.22	10	AV3 +0.05			0.14	7	AV3 +0.29			0.49	17	AV6 +0.02
		0.30	12	AV6 +0.00			0.25	11	AV6 -0.07			0.16	8	AV7 +0.02
66	153	0.33	13	AV7 +0.00			0.34	13	AV7 -0.19			0.30	10	AV4 +1.07
		0.37	14	AV8 -0.14			0.15	7	AV8 +0.16	69	68	0.24	10	AV6 +0.02
66	155	0.17	8	AV1 +0.02	68	17	0.22	10	AV3 +0.22	69	74	0.14	7	AV3 +0.03
		0.10	6	AV2 +0.04			0.09	5	AV7 +0.05	69	76	0.22	10	AV7 +0.00
		0.16	8	AV7 -0.14	68	23	0.23	10	AV3 +0.00	69	78	0.32	11	AV4 +1.30
66	157	0.19	9	AV1 -0.19			0.20	9	AV6 +0.00	69	80	0.13	7	AV2 +0.02
		0.13	7	AV2 -0.19	68	27	0.21	9	AV6 -0.02	69	82	0.12	6	AV2 +0.05
		0.20	9	AV6 -0.03	68	39	0.17	8	AV6 +0.02	69	84	0.18	9	AV2 -0.14
		0.57	18	AV7 -0.14	68	41	0.21	9	AV6 -0.02			0.16	8	AV3 +0.03
67	12	0.18	9	AV1 -0.15	68	51	0.13	7	AV3 -0.12			0.17	6	AV4 +0.95
		0.53	18	AV3 -0.12	68	65	0.29	12	AV3 +0.00	69	92	0.23	8	AV4 +0.09
		0.20	9	AV6 +0.00	68	67	0.17	8	AV3 -0.02	69	98	0.22	8	AV4 +0.07
		0.15	8	AV7 +0.19	68	93	0.14	7	AV2 +0.02	69	100	0.11	6	AV3 +0.06
		0.19	9	AV8 +0.16	68	97	0.20	9	AV6 +0.02	69	102	0.14	7	AV6 +0.00
67	14	0.13	7	AV1 +0.05	68	101	0.41	15	AV6 +0.00	69	104	0.19	9	AV3 -0.02
		0.10	6	AV2 -0.18			0.16	8	AV7 +0.00			0.53	17	AV6 +0.00
		0.17	8	AV3 +0.05	68	109	0.34	13	AV3 +0.05	69	110	0.14	7	AV6 +0.05
		0.15	7	AV7 +0.21			0.53	17	AV6 +0.02	69	126	0.32	13	AV6 +0.00
		0.24	10	AV8 +0.02			0.22	10	AV7 -0.05	69	138	0.12	6	AV6 +0.00
67	16	0.25	11	AV3 +0.05	68	113	0.26	11	AV6 +0.02	69	142	0.10	6	AV6 +0.00
		0.55	18	AV6 -0.03	68	143	0.11	6	AV3 +0.02	69	148	0.10	6	AV2 +0.00
		0.17	8	AV8 -0.14			0.26	11	AV6 +0.02			0.34	13	AV3 +0.05
67	18	0.14	7	AV7 -0.14			0.21	9	AV8 +0.05	69	152	0.15	8	AV1 +0.23
67	22	0.20	9	AV3 +0.00	68	147	0.21	9	AV2 +0.00			0.16	8	AV3 +0.00
67	34	0.13	7	AV2 -0.02			0.39	14	AV3 +0.02			0.22	10	AV6 +0.00
67	36	0.13	7	AV3 +0.02			0.29	12	AV6 -0.02	69	154	0.13	7	AV3 +0.19
		0.20	9	AV6 -0.05	68	149	0.27	11	AV3 +0.02			0.19	9	AV7 +0.16
67	58	0.19	9	AV6 +0.02			0.18	8	AV7 -0.02	69	156	0.22	10	AV1 -0.17
67	68	0.27	11	AV6 +0.05	68	151	0.16	8	AV7 +0.07			0.55	18	AV3 +0.28
67	70	0.14	7	AV3 +0.00	68	153	0.11	6	AV2 +0.04			0.60	19	AV6 -0.02
67	96	0.16	8	AV3 +0.00			0.14	7	AV8 -0.14			0.26	11	AV7 -0.21
67	98	0.11	6	AV3 +0.00	68	155	0.17	8	AV1 +0.02			0.18	8	AV8 +0.21
67	100	0.18	9	AV7 +0.05			0.61	19	AV2 +0.02	70	13	0.19	9	AV2 +0.21
67	102	0.16	8	AV3 +0.03			0.17	8	AV3 +0.02			0.10	6	AV3 +0.05
67	108	0.17	8	AV2 +0.05	68	157	0.22	10	AV1 -0.19	70	15	0.12	6	AV1 -0.13
		0.11	6	AV3 +0.00			0.30	12	AV2 -0.19			0.10	6	AV2 +0.22
67	112	0.15	7	AV3 +0.00			0.28	12	AV3 +0.16			0.41	15	AV3 +0.15
67	114	0.18	8	AV2 +0.05			0.27	11	AV8 +0.02			0.61	19	AV6 -0.02
		0.26	11	AV6 +0.02			0.48	17	AV7 +0.20			0.31	12	AV7 -0.18
		0.18	9	AV7 +0.00			0.60	19	AV7 -0.23			0.19	9	AV8 +0.18
67	120	0.16	8	AV3 +0.05	69	14	0.12	6	AV2 +0.20	70	17	0.09	5	AV2 -0.12
		0.35	14	AV6 +0.05			0.30	12	AV7 -0.03			0.37	14	AV3 +0.19
67	134	0.31	12	AV6 -0.03			0.09	5	AV8 +0.18			0.14	7	AV6 -0.14
		0.18	8	AV7 -0.02	69	16	0.18	9	AV3 +0.02			0.09	5	AV7 -0.09
67	148	0.10	6	AV6 +0.05			0.21	10	AV6 +0.00	70	21	0.16	8	AV3 +0.15
67	150	0.19	9	AV3 +0.03			0.16	8	AV8 -0.09			0.12	6	AV6 +0.00
67	152	0.17	8	AV1 +0.02	69	18	0.36	14	AV6 +0.00	70	33	0.15	7	AV3 +0.12
		0.26	11	AV3 +0.03			0.17	8	AV7 +0.00	70	37	0.17	8	AV6 -0.04
		0.40	15	AV6 +0.00			0.23	10	AV8 +0.00			0.23	10	AV7 +0.05

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.18	8	AV8 +0.05			0.09	5	AV1 -0.02	73	82	0.19	9	AV3 -0.02
70	41	0.16	8	AV3 +0.04			0.14	7	AV2 +0.19	73	84	0.14	7	AV2 -0.07
70	47	0.16	8	AV3 +0.00			0.18	8	AV3 +0.20			0.25	11	AV3 +0.02
		0.20	9	AV6 +0.05			0.12	6	AV4 +0.08			0.11	6	AV4 +0.36
70	49	0.22	10	AV7 +0.05			0.31	12	AV6 -0.02			0.16	8	AV5 -0.03
70	65	0.24	10	AV6 +0.02			0.19	9	AV5 -0.11	73	86	0.15	7	AV2 -0.12
70	67	0.17	8	AV3 +0.02			0.14	7	AV7 -0.14	73	88	0.16	8	AV2 -0.16
		0.30	12	AV6 +0.00			0.23	10	AV8 +0.18	73	94	0.13	7	AV3 +0.04
		0.28	12	AV7 +0.02	72	17	0.09	5	AV1 +0.00	73	96	0.13	7	AV3 +0.00
70	69	0.16	8	AV2 +0.02			0.19	9	AV3 +0.20			0.13	7	AV5 +0.00
		0.13	7	AV3 +0.02			0.14	7	AV6 -0.19			0.22	10	AV6 +0.02
70	77	0.16	8	AV6 +0.07			0.11	6	AV8 +0.00	73	98	0.26	11	AV4 +0.07
70	81	0.13	7	AV2 +0.02	72	21	0.12	6	AV3 +0.13			0.17	8	AV5 +0.00
70	83	0.18	8	AV2 +0.00			0.17	8	AV7 +0.00			0.19	9	AV6 +0.05
		0.35	13	AV3 +0.02	72	23	0.09	5	AV1 +0.02	73	102	0.24	10	AV6 +0.00
70	85	0.15	8	AV2 +0.00			0.18	9	AV3 +0.02	73	104	0.13	7	AV6 +0.00
70	89	0.15	7	AV2 +0.00	72	27	0.07	4	AV1 +0.05	73	110	0.15	8	AV5 +0.02
70	99	0.29	12	AV3 +0.00			0.09	5	AV2 +0.02	73	116	0.43	15	AV6 +0.02
70	101	0.13	7	AV6 -0.02			0.24	10	AV3 +0.02			0.18	8	AV7 +0.05
70	107	0.14	7	AV6 +0.02	72	65	0.28	12	AV6 +0.00	73	144	0.14	7	AV3 -0.16
		0.20	9	AV7 +0.02			0.26	11	AV7 +0.00	73	150	0.11	6	AV1 -0.12
70	129	0.14	7	AV3 -0.04	72	67	0.15	7	AV6 +0.02			0.23	10	AV6 -0.02
70	153	0.14	7	AV6 -0.13	72	69	0.21	9	AV2 -0.02	73	152	0.23	10	AV7 +0.00
		0.11	6	AV7 +0.16			0.14	7	AV3 +0.00	73	154	0.14	7	AV1 -0.12
		0.24	10	AV8 -0.14			0.23	10	AV4 +0.00			0.14	7	AV3 +0.11
70	155	0.17	8	AV3 +0.18			0.10	5	AV6 -0.02			0.12	6	AV6 +0.00
		0.38	14	AV6 -0.02	72	75	0.17	8	AV3 +0.00			0.17	8	AV8 +0.26
70	157	0.33	13	AV3 -0.16			0.16	8	AV4 +0.00	74	15	0.12	6	AV1 +0.21
		0.21	9	AV7 +0.20			0.20	9	AV5 -0.37			0.28	12	AV2 +0.21
71	16	0.15	7	AV2 +0.02			0.20	9	AV6 +0.00			0.12	7	AV3 +0.21
		0.19	9	AV3 +0.16	72	77	0.21	9	AV6 +0.02			0.59	19	AV4 +0.03
		0.24	10	AV6 -0.04	72	79	0.16	8	AV3 +0.02			0.13	7	AV5 -0.27
		0.14	7	AV8 +0.18	72	85	0.14	7	AV2 -0.10			0.17	8	AV6 +0.00
71	18	0.29	12	AV3 +0.16	72	91	0.17	8	AV7 +0.07			0.23	10	AV7 -0.21
		0.25	11	AV4 -0.26	72	99	0.09	5	AV2 -0.38			0.27	11	AV8 +0.20
		0.09	5	AV8 +0.02			0.17	8	AV3 +0.00	74	17	0.15	8	AV3 -0.22
71	20	0.14	7	AV2 +0.17	72	101	0.25	11	AV2 +0.02	74	19	0.21	9	AV6 -0.04
		0.11	6	AV3 +0.02			0.14	7	AV3 -0.02	74	21	0.14	7	AV3 +0.22
71	24	0.15	7	AV3 +0.18	72	103	0.15	8	AV3 +0.00	74	25	0.14	7	AV3 +0.05
71	28	0.14	7	AV1 +0.21			0.20	9	AV6 +0.07	74	27	0.14	7	AV5 -0.30
		0.14	7	AV6 +0.02	72	105	0.16	8	AV5 -0.04	74	51	0.21	9	AV6 +0.02
71	62	0.63	19	AV6 +0.05	72	117	0.22	10	AV6 +0.02			0.15	7	AV7 +0.02
		0.21	9	AV7 +0.00	72	147	0.10	5	AV1 +0.02	74	53	0.10	6	AV4 -0.02
71	76	0.23	10	AV7 +0.05	72	151	0.46	16	AV6 +0.00			0.15	7	AV5 -0.12
71	78	0.22	10	AV3 +0.04	72	153	0.18	8	AV6 +0.00	74	63	0.23	10	AV6 +0.05
71	80	0.19	9	AV2 +0.00			0.23	10	AV8 -0.16			0.18	8	AV7 +0.02
		0.22	10	AV3 +0.04	72	155	0.08	5	AV1 -0.10	74	65	0.30	12	AV4 +0.06
		0.22	10	AV6 +0.05			0.13	7	AV8 +0.18			0.36	14	AV5 -0.18
71	88	0.14	7	AV2 -0.16	73	14	0.24	10	AV2 +0.19			0.14	7	AV1 -0.02
71	92	0.10	6	AV2 +0.00	73	16	0.23	10	AV6 -0.04			0.14	7	AV2 +0.00
71	96	0.12	6	AV3 +0.00	73	18	0.17	8	AV4 +0.10	74	67	0.15	7	AV2 +0.05
71	100	0.15	7	AV3 +0.04	73	20	0.12	6	AV4 +0.36			0.28	12	AV6 +0.02
		0.18	8	AV7 +0.00			0.10	6	AV8 -0.14			0.20	9	AV7 +0.00
71	102	0.15	8	AV7 +0.00	73	22	0.28	12	AV3 +0.02	74	69	0.27	11	AV4 +0.00
71	104	0.16	8	AV6 +0.02	73	26	0.12	6	AV1 -0.15	74	71	0.18	9	AV5 +0.00
		0.06	4	AV7 -0.14	73	36	0.09	5	AV5 +0.09			0.14	7	AV6 +0.00
71	106	0.44	16	AV6 +0.05	73	48	0.14	7	AV3 +0.20	74	75	0.14	7	AV2 +0.00
		0.56	18	AV7 +0.02	73	54	0.11	6	AV4 +0.32			0.20	9	AV3 +0.00
71	126	0.10	6	AV3 +0.02	73	56	0.14	7	AV2 +0.02			0.30	12	AV6 +0.02
71	128	0.15	7	AV3 +0.04			0.24	10	AV6 +0.02			0.17	8	AV7 +0.00
71	130	0.10	6	AV3 +0.14			0.27	11	AV7 +0.02			0.17	8	AV4 +0.00
		0.06	4	AV7 -0.43	73	58	0.33	13	AV4 +0.03			0.18	9	AV5 -0.25
71	132	0.18	8	AV6 -0.16			0.21	10	AV5 +0.00	74	77	0.16	8	AV3 +0.16
71	150	0.12	6	AV1 +0.07			0.19	9	AV6 +0.05			0.14	7	AV5 -0.19
71	152	0.12	6	AV4 +0.47	73	60	0.09	5	AV4 +0.20	74	79	0.15	8	AV5 -0.25
71	154	0.17	8	AV3 +0.14	73	62	0.17	8	AV6 +0.02			0.21	9	AV6 +0.02
		0.32	13	AV7 +0.02	73	70	0.16	8	AV5 -0.03			0.14	7	AV7 +0.02
		0.27	11	AV8 +0.02	73	76	0.54	18	AV3 +0.02	74	83	0.13	7	AV2 -0.02
71	156	0.24	10	AV3 +0.18			0.35	13	AV4 +0.03			0.16	8	AV4 +0.03
		0.14	7	AV8 +0.23			0.54	18	AV6 +0.05			0.17	8	AV5 -0.21
		0.19	9	AV6 -0.14			0.28	12	AV7 +0.00	74	85	0.12	6	AV2 -0.14
		0.15	7	AV7 -0.21	73	80	0.12	6	AV2 -0.19			0.41	15	AV3 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.18	9	AV4 +0.31			0.16	8	AV3 +0.00			0.21	9	AV4 +0.06
		0.13	7	AV6 +0.05			0.16	8	AV5 -0.03			0.60	19	AV5 +0.02
		0.34	13	AV7 +0.02	75	86	0.23	10	AV3 +0.00	76	69	0.19	9	AV1 +0.05
74	91	0.15	8	AV7 +0.02			0.21	9	AV4 +0.06			0.34	13	AV2 +0.02
74	93	0.13	7	AV6 +0.00			0.27	11	AV5 +0.00			0.40	15	AV3 +0.07
		0.12	6	AV7 +0.00			0.20	9	AV6 +0.02			0.62	19	AV5 -0.20
74	95	0.28	12	AV2 +0.00			0.14	7	AV7 +0.02			0.24	10	AV6 +0.02
		0.13	7	AV3 +0.02	75	88	0.18	9	AV2 +0.02	76	71	0.14	7	AV6 +0.05
		0.17	8	AV4 +0.00			0.37	14	AV4 +0.09	76	73	0.25	11	AV3 +0.00
74	97	0.13	7	AV2 +0.00			0.63	19	AV5 +0.02			0.30	12	AV4 +0.03
		0.22	10	AV3 +0.00			0.45	16	AV6 +0.00			0.26	11	AV5 +0.00
		0.25	11	AV4 +0.06			0.20	9	AV7 +0.05			0.30	12	AV6 +0.05
		0.17	8	AV5 -0.09	75	90	0.14	7	AV4 +0.06	76	75	0.18	8	AV1 +0.02
		0.14	7	AV7 +0.05	75	94	0.15	7	AV4 +0.15			0.42	15	AV2 +0.00
		0.24	10	AV8 +0.02			0.21	9	AV6 +0.05			0.43	15	AV3 +0.02
74	99	0.17	8	AV5 +0.00	75	98	0.18	9	AV6 +0.00			0.56	18	AV4 +0.03
		0.22	10	AV6 +0.02			0.26	11	AV4 +0.06			0.35	14	AV7 +0.07
		0.23	10	AV7 +0.00			0.13	7	AV5 +0.00			0.18	9	AV8 +0.02
74	101	0.17	8	AV2 +0.02	75	100	0.12	6	AV4 +0.03	76	77	0.18	9	AV4 +0.14
		0.20	9	AV3 +0.00			0.32	13	AV5 +0.00			0.45	16	AV5 -0.03
		0.24	11	AV4 +0.03			0.14	7	AV6 +0.05			0.34	13	AV6 +0.02
		0.26	11	AV5 -0.03			0.18	9	AV7 +0.05			0.21	9	AV7 +0.05
		0.23	10	AV6 +0.02	75	104	0.20	9	AV4 +0.06	76	79	0.29	12	AV6 +0.02
74	103	0.11	6	AV4 +0.31			0.29	12	AV5 +0.05			0.15	8	AV7 +0.00
		0.15	7	AV5 +0.00			0.33	13	AV6 +0.02	76	81	0.17	8	AV3 -0.02
74	105	0.18	8	AV6 +0.03			0.22	10	AV7 +0.00			0.17	8	AV5 -0.05
		0.21	9	AV7 +0.02	75	106	0.22	10	AV3 +0.05	76	83	0.15	8	AV1 -0.02
74	107	0.23	10	AV5 -0.03			0.22	10	AV6 +0.00			0.20	9	AV3 +0.02
		0.30	12	AV7 +0.00			0.26	11	AV7 +0.02	76	85	0.17	8	AV2 +0.00
74	137	0.25	11	AV2 +0.02			0.18	8	AV8 +0.02			0.22	10	AV3 +0.02
		0.33	13	AV3 +0.02	75	108	0.15	8	AV3 +0.02	76	87	0.15	8	AV2 +0.00
74	151	0.21	9	AV6 +0.02			0.14	7	AV4 +0.26			0.17	8	AV3 +0.02
74	153	0.22	10	AV4 +0.31			0.22	10	AV6 +0.00			0.14	7	AV4 +0.06
		0.14	7	AV5 -0.31			0.17	8	AV7 +0.02			0.35	13	AV5 +0.00
		0.12	6	AV8 +0.00			0.18	8	AV8 +0.02			0.16	8	AV6 +0.02
75	16	0.12	6	AV1 -0.16	75	126	0.11	6	AV5 +0.02	76	89	0.16	8	AV2 -0.02
		0.20	9	AV3 +0.15	75	138	0.12	6	AV4 +0.25	76	91	0.21	9	AV3 -0.02
		0.12	6	AV7 +0.02	75	144	0.17	8	AV3 +0.00			0.25	11	AV4 +0.06
		0.20	9	AV8 +0.16	75	150	0.13	7	AV3 +0.02			0.20	9	AV5 +0.02
75	18	0.19	9	AV2 +0.05	75	152	0.32	13	AV4 +0.26			0.20	9	AV6 +0.02
		0.14	7	AV3 +0.21			0.14	7	AV5 -0.23			0.22	10	AV7 +0.02
		0.13	7	AV4 +0.29			0.14	7	AV7 -0.17	76	93	0.15	7	AV3 -0.02
		0.12	6	AV5 -0.23			0.11	6	AV8 +0.14			0.17	8	AV4 +0.19
		0.17	8	AV8 +0.16	75	154	0.19	9	AV1 -0.12			0.18	8	AV5 +0.02
75	20	0.17	8	AV5 -0.20			0.15	7	AV4 +0.26	76	95	0.12	6	AV1 +0.02
75	26	0.14	7	AV1 -0.14			0.24	10	AV5 -0.20			0.19	9	AV2 -0.02
		0.20	9	AV2 +0.00			0.24	10	AV7 +0.16			0.11	6	AV4 +0.08
		0.18	9	AV8 +0.02	76	17	0.19	9	AV3 +0.21	76	97	0.13	7	AV5 +0.02
75	36	0.28	12	AV4 -0.12			0.14	7	AV6 -0.18			0.17	8	AV6 +0.02
		0.23	10	AV5 +0.02			0.22	10	AV8 +0.18			0.18	8	AV7 +0.02
75	54	0.12	6	AV4 +0.23	76	19	0.15	8	AV7 +0.02	76	99	0.12	6	AV2 +0.00
75	60	0.15	7	AV7 +0.02			0.21	9	AV8 +0.02			0.17	8	AV3 +0.02
75	62	0.18	9	AV4 +0.06	76	21	0.12	6	AV1 -0.02			0.22	10	AV4 +0.03
75	66	0.13	7	AV1 -0.02			0.16	8	AV2 +0.00			0.54	18	AV5 +0.00
		0.25	11	AV2 +0.02			0.31	12	AV5 +0.02			0.55	18	AV7 +0.02
		0.43	15	AV3 +0.02	76	23	0.21	9	AV3 +0.05			0.37	14	AV8 +0.02
		0.27	11	AV4 +0.00	76	33	0.15	7	AV4 +0.29	76	101	0.19	9	AV5 -0.03
		0.27	11	AV5 +0.00	76	35	0.13	7	AV5 -0.20			0.17	8	AV6 +0.02
75	74	0.17	8	AV3 +0.00	76	49	0.19	9	AV3 +0.02	76	103	0.14	7	AV2 -0.02
		0.18	9	AV4 +0.03	76	61	0.29	12	AV4 +0.03			0.17	8	AV3 +0.00
		0.21	10	AV5 +0.02			0.27	11	AV5 +0.02			0.15	7	AV4 +0.23
		0.21	10	AV6 +0.00			0.63	19	AV6 +0.02	76	107	0.16	8	AV2 +0.14
75	76	0.16	8	AV4 +0.03	76	63	0.18	8	AV2 +0.00	76	135	0.11	6	AV4 +0.22
		0.24	10	AV5 +0.02			0.57	18	AV4 +0.06	76	139	0.13	7	AV4 +0.22
		0.31	12	AV6 +0.02			0.50	17	AV5 +0.00	76	151	0.20	9	AV6 +0.00
		0.22	10	AV7 +0.02	76	65	0.17	8	AV1 +0.00			0.11	6	AV7 +0.02
75	78	0.15	8	AV4 +0.23			0.36	14	AV5 -0.22	76	153	0.19	9	AV3 +0.05
		0.21	9	AV3 -0.02			0.52	17	AV6 +0.02			0.21	10	AV4 +0.20
75	80	0.15	8	AV2 -0.02			0.43	15	AV7 +0.02			0.22	10	AV5 -0.20
75	82	0.17	8	AV3 +0.00			0.19	9	AV8 -0.02			0.16	8	AV7 +0.02
		0.22	10	AV5 +0.02	76	67	0.38	14	AV6 +0.05	77	16	0.31	12	AV8 +0.16
75	84	0.18	9	AV2 +0.02			0.14	7	AV7 +0.02	77	18	0.12	6	AV2 +0.02

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
77	20	0.15	8	AV1 +0.05			0.15	7	AV4 +0.00			0.11	6	AV6 +0.00
		0.46	16	AV2 +0.05	77	146	0.13	7	AV3 -0.02			0.17	8	AV7 +0.00
		0.13	7	AV3 +0.02	77	148	0.09	5	AV1 -0.17	78	109	0.30	12	AV5 +0.00
		0.30	12	AV5 -0.22	77	150	0.15	7	AV6 +0.00			0.11	6	AV6 +0.05
		0.62	19	AV6 -0.02	77	152	0.16	8	AV3 -0.09	78	113	0.14	7	AV6 +0.00
		0.40	15	AV7 -0.02			0.13	7	AV4 +0.11	78	115	0.19	9	AV8 +0.02
		0.41	15	AV8 -0.02			0.15	7	AV7 -0.19	78	149	0.22	10	AV5 +0.02
77	22	0.12	6	AV2 +0.02	78	17	0.33	13	AV3 +0.24	78	151	0.30	12	AV6 +0.02
77	24	0.48	16	AV3 +0.08			0.17	8	AV8 +0.18	78	153	0.13	7	AV1 -0.15
		0.28	12	AV4 +0.09	78	19	0.14	7	AV4 +0.27			0.14	7	AV5 -0.20
		0.34	13	AV5 +0.05	78	23	0.08	5	AV1 +0.14			0.15	7	AV6 +0.02
		0.44	16	AV6 +0.00			0.11	6	AV2 -0.05			0.13	7	AV8 +0.18
		0.16	8	AV7 +0.02			0.18	9	AV3 +0.02	79	18	0.13	7	AV1 +0.02
77	46	0.12	6	AV4 +0.22	78	25	0.17	8	AV5 -0.03			0.12	6	AV2 +0.19
77	48	0.22	10	AV6 +0.00	78	27	0.15	8	AV5 +0.00			0.20	9	AV6 +0.02
77	52	0.07	4	AV3 +0.17	78	31	0.09	5	AV4 +0.21			0.11	6	AV7 -0.21
77	62	0.14	7	AV3 +0.02	78	43	0.09	5	AV3 +0.17			0.12	6	AV8 +0.16
		0.54	18	AV5 +0.00	78	49	0.11	6	AV3 -0.14	79	20	0.22	10	AV1 +0.19
		0.36	14	AV6 +0.02	78	63	0.19	9	AV4 +0.03			0.35	13	AV5 +0.00
		0.12	6	AV7 +0.00			0.16	8	AV5 +0.00	79	22	0.17	8	AV3 +0.02
77	64	0.20	9	AV5 +0.02			0.18	8	AV6 +0.00			0.16	8	AV4 +0.19
		0.15	8	AV6 +0.00	78	65	0.13	7	AV4 -0.16	79	24	0.13	7	AV2 +0.09
		0.17	8	AV7 +0.05			0.37	14	AV6 +0.00			0.14	7	AV3 +0.20
77	68	0.10	6	AV7 -0.05			0.25	11	AV7 +0.00	79	26	0.15	7	AV1 -0.24
77	70	0.14	7	AV3 +0.02	78	69	0.14	7	AV3 +0.00	79	32	0.15	7	AV1 +0.00
		0.11	6	AV5 +0.00			0.19	9	AV4 -0.17			0.16	8	AV4 +0.05
77	72	0.09	5	AV6 +0.00			0.20	9	AV5 -0.17	79	52	0.18	8	AV6 +0.05
77	76	0.16	8	AV3 +0.02	78	73	0.13	7	AV5 +0.02			0.20	9	AV7 +0.02
		0.37	14	AV4 +0.06	78	75	0.27	11	AV2 +0.02	79	54	0.14	7	AV2 +0.00
		0.60	19	AV5 +0.02			0.33	13	AV3 +0.02	79	60	0.12	6	AV6 +0.00
		0.46	16	AV6 +0.05			0.30	12	AV4 +0.08			0.11	6	AV3 +0.07
		0.25	11	AV2 +0.02			0.29	12	AV6 +0.02	79	62	0.20	9	AV3 -0.02
77	78	0.20	9	AV5 +0.02	78	77	0.21	10	AV4 +0.03			0.19	9	AV4 +0.08
77	80	0.10	6	AV2 +0.00			0.29	12	AV5 +0.02			0.36	14	AV5 +0.07
		0.18	9	AV3 -0.14	78	81	0.16	8	AV2 +0.02	79	64	0.14	7	AV3 +0.02
		0.12	6	AV4 +0.03			0.17	8	AV3 +0.00			0.12	6	AV5 +0.16
		0.12	6	AV5 -0.03	78	83	0.20	9	AV3 +0.02	79	66	0.17	8	AV2 +0.02
		0.13	7	AV6 +0.02			0.22	10	AV4 +0.00			0.42	15	AV3 +0.02
77	82	0.17	8	AV3 +0.02			0.20	9	AV5 -0.03			0.52	17	AV6 +0.02
		0.16	8	AV4 +0.22			0.21	9	AV6 +0.02	79	70	0.17	8	AV3 +0.02
		0.48	17	AV5 +0.05			0.12	6	AV7 +0.00			0.22	10	AV4 +0.05
		0.21	9	AV6 +0.05	78	85	0.38	14	AV3 +0.02			0.39	14	AV5 +0.05
77	86	0.11	6	AV4 +0.19			0.20	9	AV4 +0.08			0.29	12	AV6 +0.05
		0.12	6	AV5 -0.08			0.15	8	AV5 +0.05	79	72	0.12	6	AV3 +0.05
77	90	0.20	9	AV6 +0.02			0.11	6	AV7 +0.02			0.19	9	AV5 +0.02
77	92	0.13	7	AV2 +0.00	78	89	0.13	7	AV2 -0.02	79	76	0.10	6	AV2 -0.14
		0.14	7	AV3 +0.02			0.12	6	AV3 -0.05			0.09	5	AV3 -0.05
		0.32	13	AV5 +0.05			0.17	8	AV6 +0.00			0.12	6	AV4 -0.12
		0.27	11	AV6 +0.05			0.11	6	AV7 +0.05			0.13	7	AV5 -0.16
		0.12	6	AV7 -0.05	78	93	0.15	8	AV3 -0.16			0.14	7	AV6 +0.00
77	94	0.09	5	AV2 -0.07			0.13	7	AV7 +0.02	79	80	0.13	7	AV3 +0.05
		0.11	6	AV3 +0.00	78	95	0.27	11	AV4 +0.03			0.20	9	AV4 +0.00
		0.11	6	AV4 +0.23			0.16	8	AV5 +0.03			0.27	11	AV5 +0.02
		0.11	6	AV5 -0.20	78	97	0.19	9	AV2 +0.00			0.16	8	AV6 +0.02
		0.19	9	AV6 +0.02			0.16	8	AV3 -0.02	79	82	0.15	8	AV3 +0.00
77	96	0.11	6	AV2 +0.05			0.13	7	AV4 -0.12			0.15	7	AV4 +0.05
		0.13	7	AV3 +0.00			0.32	13	AV5 -0.03			0.43	15	AV5 +0.02
		0.14	7	AV5 +0.00			0.10	6	AV8 +0.00			0.27	11	AV6 +0.00
		0.09	5	AV6 +0.07	78	99	0.16	8	AV2 +0.02			0.23	10	AV7 +0.02
		0.36	14	AV7 +0.00			0.14	7	AV3 +0.02	79	84	0.29	12	AV3 +0.00
77	98	0.15	7	AV4 +0.03			0.23	10	AV7 +0.02			0.16	8	AV4 +0.03
77	100	0.09	5	AV1 +0.02	78	101	0.19	9	AV1 +0.02	79	86	0.24	10	AV3 +0.00
		0.16	8	AV2 +0.00			0.36	14	AV2 +0.02			0.17	8	AV4 -0.02
		0.11	6	AV3 +0.02			0.12	6	AV3 +0.05			0.14	7	AV5 +0.19
77	104	0.12	6	AV4 -0.12			0.09	5	AV4 +0.03			0.20	9	AV6 +0.00
		0.23	10	AV5 -0.20			0.29	12	AV5 +0.05			0.17	8	AV7 +0.00
77	106	0.18	8	AV5 +0.00			0.32	13	AV6 +0.02	79	88	0.19	9	AV3 +0.00
		0.31	12	AV6 +0.02	78	103	0.16	8	AV5 +0.00			0.18	8	AV5 +0.02
77	110	0.14	7	AV4 +0.06			0.12	6	AV6 -0.02			0.14	7	AV2 +0.02
		0.40	15	AV5 +0.00	78	105	0.34	13	AV4 +0.25	79	92	0.13	7	AV7 +0.14
77	140	0.15	7	AV5 -0.17			0.22	10	AV5 +0.00	79	94	0.14	7	AV2 +0.05
77	142	0.08	5	AV2 -0.05	78	107	0.16	8	AV5 +0.00			0.13	7	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.15	7	AV4 +0.05			0.12	6	AV4 -0.14			0.17	8	AV1 -0.14
		0.10	6	AV6 +0.19			0.17	8	AV5 +0.00			0.16	8	AV3 +0.00
79	96	0.16	8	AV1 +0.00	80	71	0.13	7	AV3 +0.05			0.13	7	AV5 +0.17
		0.29	12	AV2 +0.00			0.23	10	AV4 +0.05			0.18	8	AV6 +0.07
		0.20	9	AV3 +0.05			0.45	16	AV5 +0.02	81	26	0.12	6	AV2 +0.02
		0.07	4	AV4 -0.14			0.50	17	AV6 +0.02			0.14	7	AV5 +0.19
		0.34	13	AV6 +0.05	80	73	0.12	6	AV4 +0.03	81	28	0.18	9	AV1 +0.02
		0.39	14	AV7 +0.05			0.11	6	AV7 +0.07			0.17	8	AV4 +0.00
79	98	0.36	14	AV4 +0.00	80	75	0.12	6	AV3 -0.02			0.10	6	AV5 +0.19
		0.30	12	AV5 +0.00			0.23	10	AV4 +0.03	81	30	0.13	7	AV4 +0.25
		0.18	9	AV7 +0.05			0.53	17	AV6 +0.02	81	36	0.17	8	AV4 +0.00
79	100	0.12	6	AV3 +0.00			0.18	8	AV7 +0.02			0.22	10	AV7 +0.02
		0.24	10	AV4 +0.03	80	77	0.34	13	AV7 +0.05	81	38	0.15	7	AV2 +0.00
		0.27	11	AV5 +0.00			0.18	9	AV3 +0.02			0.16	8	AV4 +0.08
79	104	0.10	5	AV2 +0.02			0.46	16	AV4 +0.03	81	44	0.27	11	AV6 +0.02
		0.24	10	AV3 +0.07	80	79	0.15	8	AV3 -0.02	81	52	0.11	6	AV3 +0.02
		0.53	17	AV4 +0.08	80	81	0.15	8	AV3 +0.00			0.12	6	AV4 +0.08
		0.43	15	AV5 +0.05			0.15	8	AV5 +0.07			0.26	11	AV5 +0.05
		0.12	6	AV6 +0.02	80	83	0.19	9	AV3 +0.02			0.16	8	AV6 +0.12
		0.16	8	AV7 +0.00			0.28	12	AV4 +0.03	81	54	0.23	10	AV4 +0.05
79	106	0.28	12	AV2 +0.00			0.18	8	AV5 +0.00			0.61	19	AV5 +0.00
		0.27	11	AV3 +0.02	80	85	0.23	10	AV3 +0.00			0.18	8	AV7 +0.02
		0.19	9	AV4 +0.05			0.18	8	AV4 +0.08	81	56	0.14	7	AV3 +0.05
79	108	0.14	7	AV4 +0.03			0.11	6	AV6 -0.02			0.23	10	AV5 +0.05
		0.18	8	AV5 +0.00			0.17	8	AV7 +0.00	81	62	0.18	8	AV6 +0.05
		0.28	12	AV6 +0.00	80	87	0.24	10	AV2 +0.05			0.15	8	AV7 +0.07
79	110	0.41	15	AV4 +0.03			0.25	11	AV3 -0.14	81	64	0.34	13	AV3 +0.05
		0.11	6	AV8 +0.02			0.19	9	AV4 +0.00			0.16	8	AV4 +0.05
79	128	0.10	6	AV4 -0.05			0.50	17	AV5 +0.00			0.41	15	AV5 +0.02
79	132	0.23	10	AV6 +0.00			0.28	12	AV6 +0.02			0.27	11	AV7 +0.05
		0.41	15	AV7 +0.02			0.13	7	AV7 +0.00	81	66	0.40	15	AV3 +0.02
79	136	0.12	6	AV4 +0.03	80	89	0.15	8	AV3 -0.02	81	68	0.18	8	AV1 +0.00
79	150	0.13	7	AV1 -0.17			0.11	6	AV7 +0.02			0.17	8	AV2 +0.02
		0.13	7	AV8 +0.19			0.14	7	AV2 -0.19			0.17	8	AV4 +0.00
79	152	0.10	6	AV1 +0.14	80	91	0.17	8	AV3 -0.02			0.57	18	AV5 +0.02
		0.14	7	AV2 +0.07			0.12	6	AV4 +0.03			0.47	16	AV6 +0.00
		0.13	7	AV4 +0.05	80	93	0.15	8	AV3 +0.00	81	70	0.19	9	AV4 +0.00
		0.25	11	AV7 +0.00			0.21	9	AV6 +0.00			0.53	18	AV5 +0.02
80	19	0.14	7	AV1 +0.00			0.21	10	AV7 +0.02			0.61	19	AV6 +0.02
		0.11	6	AV2 +0.02	80	95	0.10	6	AV2 -0.14			0.20	9	AV7 +0.00
		0.13	7	AV3 +0.02			0.10	5	AV4 +0.03	81	72	0.15	8	AV4 +0.00
		0.15	7	AV6 +0.02			0.19	9	AV5 +0.02			0.28	12	AV5 +0.02
		0.09	5	AV7 +0.09	80	97	0.14	7	AV3 +0.00	81	74	0.23	10	AV2 -0.02
		0.22	10	AV8 +0.02			0.11	6	AV4 +0.03			0.21	10	AV3 +0.00
80	21	0.21	9	AV1 -0.02			0.14	7	AV5 +0.02			0.27	11	AV4 +0.03
		0.37	14	AV2 +0.05			0.16	8	AV6 +0.00			0.15	8	AV5 +0.00
		0.12	6	AV3 +0.19			0.14	7	AV2 +0.02	81	76	0.32	13	AV4 +0.00
		0.21	10	AV4 +0.08	80	99	0.14	7	AV2 -0.02			0.30	12	AV5 +0.00
80	23	0.10	6	AV4 +0.22			0.23	10	AV4 +0.00			0.19	9	AV6 +0.05
		0.11	6	AV6 +0.02			0.27	11	AV5 +0.00			0.35	13	AV7 +0.02
80	25	0.13	7	AV4 +0.00			0.18	8	AV6 -0.02	81	78	0.26	11	AV4 +0.03
80	27	0.12	6	AV1 -0.17	80	101	0.18	8	AV4 +0.03			0.38	14	AV5 +0.00
80	29	0.10	5	AV4 +0.16			0.29	12	AV5 +0.02			0.45	16	AV6 +0.02
80	35	0.17	8	AV4 +0.22			0.24	10	AV6 +0.02			0.48	17	AV7 +0.02
		0.21	10	AV7 -0.02	80	103	0.10	6	AV6 -0.02	81	80	0.19	9	AV7 +0.00
80	37	0.20	9	AV5 -0.03	80	105	0.26	11	AV4 +0.22			0.17	8	AV2 +0.02
80	51	0.19	9	AV7 +0.05			0.07	4	AV5 +0.05			0.17	8	AV3 +0.02
80	59	0.19	9	AV1 +0.05			0.13	7	AV6 +0.03			0.58	18	AV4 +0.05
		0.30	12	AV4 -0.21	80	109	0.14	7	AV6 +0.00			0.47	16	AV5 +0.02
		0.15	8	AV7 +0.05			0.10	6	AV4 -0.19			0.33	13	AV6 +0.02
80	63	0.14	7	AV2 +0.00	80	115	0.15	7	AV5 -0.17	81	82	0.48	16	AV3 +0.02
		0.17	8	AV4 -0.12	80	125	0.14	7	AV5 -0.03			0.34	13	AV4 +0.05
		0.32	13	AV6 +0.05	80	135	0.14	7	AV3 -0.02			0.48	16	AV5 +0.05
		0.15	7	AV7 +0.02			0.14	7	AV5 -0.03			0.56	18	AV6 +0.00
80	65	0.42	15	AV2 +0.02	80	139	0.14	7	AV3 +0.02			0.22	10	AV7 +0.02
		0.28	12	AV3 +0.02	80	143	0.18	9	AV2 +0.00	81	84	0.29	12	AV3 +0.02
		0.42	15	AV4 +0.05			0.19	9	AV3 +0.00			0.27	11	AV4 +0.00
		0.57	18	AV5 +0.02	80	145	0.18	8	AV4 +0.00			0.19	9	AV5 +0.00
		0.59	19	AV6 +0.02	80	151	0.15	8	AV1 -0.12			0.13	7	AV6 +0.02
		0.20	9	AV7 +0.02			0.13	7	AV2 +0.02	81	86	0.22	10	AV3 -0.02
80	67	0.13	7	AV2 -0.02			0.27	11	AV6 -0.02			0.49	17	AV4 +0.05
80	69	0.24	10	AV2 +0.00	81	20	0.17	8	AV6 -0.02			0.37	14	AV5 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
81	88	0.19	9	AV6 +0.00	82	79	0.13	7	AV3 -0.12	83	56	0.26	11	AV6 +0.02
		0.19	9	AV2 +0.02	82	81	0.15	7	AV1 -0.05			0.25	11	AV7 +0.00
		0.23	10	AV3 +0.02			0.16	8	AV2 -0.02			0.14	7	AV5 +0.00
		0.18	9	AV5 +0.02			0.23	10	AV3 +0.02	83	58	0.09	5	AV2 +0.02
81	90	0.16	8	AV5 +0.00			0.27	11	AV5 +0.07			0.18	9	AV4 +0.05
		0.18	8	AV6 +0.02	82	83	0.25	11	AV3 -0.11	83	60	0.09	5	AV4 +0.03
		0.19	9	AV7 +0.02			0.28	11	AV5 -0.03	83	62	0.63	19	AV5 +0.02
81	92	0.23	10	AV2 +0.00			0.38	14	AV6 -0.02			0.44	16	AV6 +0.05
		0.16	8	AV3 +0.07	82	85	0.42	15	AV3 +0.05			0.43	15	AV7 +0.05
		0.33	13	AV4 +0.03			0.35	14	AV4 +0.05	83	64	0.24	10	AV3 +0.00
		0.32	13	AV5 +0.02			0.18	8	AV5 +0.00			0.55	18	AV6 +0.00
		0.17	8	AV6 -0.05			0.20	9	AV6 -0.02			0.34	13	AV7 +0.05
81	94	0.14	7	AV4 +0.03			0.18	8	AV7 +0.05	83	66	0.20	9	AV2 +0.02
		0.13	7	AV5 +0.07	82	87	0.17	8	AV2 +0.00			0.14	7	AV3 +0.02
81	96	0.18	8	AV4 +0.00			0.32	13	AV3 -0.16			0.46	16	AV4 +0.05
		0.16	8	AV5 +0.02			0.25	11	AV4 +0.00	83	70	0.15	7	AV4 +0.00
		0.28	12	AV6 +0.02			0.32	13	AV5 +0.02			0.39	14	AV5 +0.02
		0.47	16	AV7 +0.00			0.36	14	AV6 +0.02			0.62	19	AV6 +0.02
		0.17	8	AV8 +0.00			0.16	8	AV7 +0.02			0.15	7	AV7 +0.02
81	98	0.28	11	AV1 +0.00	82	89	0.15	7	AV2 +0.00	83	72	0.15	7	AV3 +0.02
		0.19	9	AV2 +0.00			0.17	8	AV3 +0.02	83	74	0.12	6	AV3 +0.02
		0.14	7	AV3 +0.02			0.14	7	AV4 +0.00			0.30	12	AV4 +0.03
		0.20	9	AV4 +0.08	82	91	0.15	7	AV3 -0.16			0.44	16	AV5 +0.05
		0.20	9	AV5 +0.05	82	93	0.13	7	AV2 +0.05			0.17	8	AV6 +0.02
81	100	0.20	9	AV5 +0.00			0.13	7	AV3 +0.00	83	76	0.11	6	AV4 +0.03
81	104	0.17	8	AV5 +0.00			0.18	8	AV4 +0.05			0.37	14	AV5 +0.05
81	106	0.23	10	AV2 +0.00			0.16	8	AV6 +0.07	83	78	0.48	17	AV4 +0.08
		0.32	13	AV3 +0.02			0.17	8	AV7 +0.02			0.34	13	AV3 +0.05
		0.31	13	AV4 +0.05	82	95	0.15	7	AV1 +0.05	83	80	0.25	11	AV3 +0.00
81	108	0.16	8	AV6 +0.05			0.25	11	AV2 +0.00			0.40	15	AV4 +0.05
81	124	0.18	8	AV6 +0.00			0.28	12	AV3 +0.02			0.24	11	AV7 +0.00
81	150	0.17	8	AV1 -0.14			0.18	8	AV4 +0.03	83	84	0.39	14	AV3 +0.02
82	19	0.09	5	AV3 -0.12			0.13	7	AV5 +0.02			0.16	8	AV4 +0.05
82	21	0.14	7	AV1 +0.00			0.21	9	AV6 +0.00			0.49	17	AV5 +0.02
		0.18	9	AV3 +0.02	82	97	0.30	12	AV2 +0.02			0.32	13	AV7 -0.02
		0.14	7	AV4 +0.05			0.33	13	AV3 +0.00	83	86	0.33	13	AV4 +0.00
		0.10	5	AV5 +0.02			0.38	14	AV4 +0.00			0.13	7	AV5 +0.05
82	23	0.20	9	AV1 +0.00			0.56	18	AV5 +0.02			0.14	7	AV6 -0.02
		0.18	8	AV3 +0.05			0.33	13	AV6 -0.02			0.13	7	AV7 +0.02
		0.14	7	AV4 +0.19			0.27	11	AV7 +0.02			0.16	8	AV3 +0.00
82	25	0.13	7	AV1 +0.02	82	99	0.18	9	AV2 +0.00	83	88	0.21	9	AV2 +0.02
		0.19	9	AV4 +0.03			0.31	12	AV3 +0.05			0.30	12	AV3 +0.05
82	27	0.15	7	AV4 +0.03			0.36	14	AV4 +0.05			0.11	6	AV4 -0.02
82	31	0.13	7	AV5 -0.03			0.43	15	AV7 +0.02			0.18	8	AV5 +0.02
82	33	0.19	9	AV4 +0.14			0.18	8	AV8 +0.05			0.15	7	AV6 -0.02
82	41	0.18	9	AV3 +0.02	82	103	0.17	8	AV4 +0.03	83	90	0.15	8	AV2 -0.02
82	43	0.13	7	AV4 +0.03			0.24	10	AV7 +0.05			0.13	7	AV3 +0.07
82	57	0.17	8	AV6 +0.07	82	105	0.15	8	AV4 +0.05			0.19	9	AV4 +0.00
82	59	0.22	10	AV3 +0.02			0.46	16	AV5 +0.00			0.19	9	AV5 +0.02
		0.13	7	AV7 +0.02	82	107	0.33	13	AV5 +0.02			0.17	8	AV6 +0.02
82	61	0.26	11	AV5 +0.02			0.22	10	AV6 +0.05	83	92	0.17	8	AV4 +0.00
		0.16	8	AV6 +0.02	82	109	0.13	7	AV3 +0.02			0.32	13	AV5 +0.00
82	65	0.16	8	AV1 +0.02			0.23	10	AV4 +0.00			0.24	10	AV6 -0.05
		0.16	8	AV2 +0.00	82	145	0.12	6	AV3 -0.11			0.18	8	AV7 +0.05
		0.25	11	AV5 +0.00			0.21	9	AV4 +0.05	83	94	0.12	6	AV8 +0.00
		0.40	15	AV6 +0.02	82	147	0.23	10	AV2 +0.02			0.23	10	AV6 +0.07
		0.29	12	AV7 +0.00	82	149	0.24	10	AV2 +0.00			0.28	12	AV7 +0.00
82	67	0.17	8	AV5 +0.02	83	20	0.19	9	AV3 +0.07			0.26	11	AV4 +0.08
		0.20	9	AV6 +0.02	83	22	0.19	9	AV2 +0.02			0.25	11	AV5 +0.05
82	69	0.12	6	AV4 +0.05	83	24	0.09	5	AV2 +0.22	83	96	0.11	6	AV2 +0.00
82	71	0.29	12	AV2 +0.02	83	26	0.16	8	AV4 +0.03			0.15	7	AV3 +0.00
		0.24	10	AV6 +0.02	83	28	0.15	7	AV5 +0.17			0.11	6	AV4 -0.05
82	73	0.23	10	AV2 -0.05	83	32	0.20	9	AV1 +0.05			0.28	12	AV5 +0.05
		0.21	9	AV6 +0.07			0.24	11	AV2 +0.05			0.23	10	AV6 +0.05
		0.19	9	AV7 +0.05	83	36	0.17	8	AV3 +0.00			0.54	18	AV7 +0.05
82	75	0.35	13	AV7 -0.02			0.26	11	AV5 +0.02			0.28	12	AV8 +0.00
		0.46	16	AV4 +0.03	83	38	0.12	6	AV5 +0.18	83	98	0.14	7	AV2 -0.02
		0.20	9	AV3 +0.05	83	46	0.11	6	AV4 -0.02			0.15	7	AV3 +0.02
82	77	0.37	14	AV4 +0.03	83	52	0.15	7	AV6 +0.02			0.31	12	AV4 +0.03
		0.37	14	AV5 +0.02	83	54	0.26	11	AV5 +0.07			0.46	16	AV6 +0.05
		0.60	19	AV6 +0.00			0.45	16	AV6 +0.05			0.14	7	AV7 +0.00
		0.30	12	AV7 +0.00			0.33	13	AV7 +0.02	83	100	0.31	12	AV3 +0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.23	10	AV4 +0.05	84	87	0.22	10	AV3 +0.02			0.49	17	AV5 +0.00
		0.41	15	AV5 +0.02			0.31	12	AV4 +0.03	85	56	0.17	8	AV2 +0.00
		0.26	11	AV6 +0.02			0.30	12	AV5 +0.02	85	60	0.18	8	AV7 +0.02
83	102	0.29	12	AV5 +0.02			0.52	17	AV6 +0.02	85	62	0.23	10	AV5 +0.02
		0.21	10	AV6 +0.03			0.21	9	AV7 +0.02	85	64	0.38	14	AV5 +0.02
		0.32	13	AV7 +0.02	84	89	0.16	8	AV3 -0.02			0.27	11	AV6 +0.02
83	104	0.26	11	AV5 +0.05			0.14	7	AV4 -0.05			0.19	9	AV7 +0.02
		0.31	12	AV6 +0.02			0.62	19	AV6 +0.00	85	66	0.16	8	AV4 +0.08
83	106	0.56	18	AV4 +0.05			0.18	9	AV7 +0.02			0.29	12	AV5 +0.02
		0.63	19	AV6 +0.00	84	91	0.17	8	AV5 +0.05			0.22	10	AV6 +0.05
		0.51	17	AV7 +0.00			0.26	11	AV6 +0.02			0.14	7	AV7 +0.05
83	110	0.27	11	AV5 +0.08			0.22	10	AV7 +0.02	85	68	0.17	8	AV5 +0.07
		0.26	11	AV6 +0.05	84	93	0.15	7	AV1 -0.02	85	70	0.14	7	AV3 +0.05
		0.27	11	AV8 +0.02			0.17	8	AV2 +0.00			0.07	5	AV4 -0.07
83	128	0.09	5	AV4 -0.12			0.19	9	AV3 +0.00			0.27	11	AV5 +0.16
83	130	0.09	5	AV2 +0.02			0.25	11	AV5 +0.02			0.17	8	AV6 +0.02
83	136	0.12	6	AV3 -0.18			0.27	11	AV6 +0.02	85	72	0.10	5	AV4 +0.03
83	140	0.13	7	AV5 -0.16			0.20	9	AV7 +0.05			0.27	11	AV7 +0.05
83	146	0.13	7	AV2 -0.17	84	95	0.20	9	AV1 +0.02	85	74	0.35	13	AV3 +0.02
84	21	0.24	10	AV3 +0.05			0.40	15	AV2 -0.02			0.12	6	AV4 +0.05
		0.14	7	AV6 +0.00			0.39	14	AV3 +0.00			0.12	6	AV5 +0.00
84	23	0.25	11	AV1 +0.02			0.13	7	AV4 +0.00			0.21	9	AV6 -0.14
		0.21	10	AV3 +0.05			0.25	11	AV5 +0.00	85	76	0.52	17	AV7 +0.00
		0.13	7	AV4 +0.06			0.13	7	AV6 -0.02			0.32	13	AV3 +0.00
		0.09	5	AV7 -0.12			0.31	12	AV7 +0.00			0.26	11	AV4 +0.00
84	25	0.13	7	AV1 +0.19	84	97	0.22	10	AV2 +0.02	85	78	0.16	8	AV3 +0.02
		0.14	7	AV4 +0.03			0.15	7	AV3 +0.00			0.22	10	AV4 +0.08
84	27	0.11	6	AV1 +0.19			0.18	8	AV4 +0.00			0.57	18	AV5 +0.02
		0.22	10	AV4 +0.00			0.15	7	AV6 -0.02			0.63	19	AV6 +0.05
84	29	0.13	7	AV4 +0.06			0.25	11	AV7 +0.05			0.58	18	AV7 +0.02
84	31	0.13	7	AV2 +0.14			0.08	5	AV8 +0.00	85	80	0.09	5	AV5 -0.03
84	33	0.12	6	AV4 +0.06	84	99	0.11	6	AV2 +0.00			0.14	7	AV7 +0.02
84	57	0.44	16	AV5 +0.05			0.28	12	AV3 +0.02	85	82	0.20	9	AV6 +0.00
		0.19	9	AV3 +0.02			0.31	12	AV4 +0.03	85	84	0.11	6	AV6 +0.02
		0.17	8	AV4 -0.02			0.56	18	AV5 +0.02	85	86	0.12	6	AV3 -0.02
		0.18	8	AV6 +0.00			0.53	18	AV6 +0.00			0.14	7	AV4 -0.02
84	63	0.12	6	AV3 +0.02			0.32	13	AV7 +0.00			0.21	9	AV5 +0.05
		0.16	8	AV4 +0.03	84	101	0.14	7	AV2 +0.00			0.19	9	AV6 -0.05
		0.44	16	AV6 +0.00			0.35	13	AV4 +0.03	85	88	0.14	7	AV3 +0.00
84	65	0.15	8	AV5 -0.22			0.30	12	AV5 +0.05	85	90	0.11	6	AV3 -0.12
		0.36	14	AV6 +0.05			0.25	11	AV6 +0.02			0.10	6	AV5 +0.21
		0.36	14	AV7 +0.02	84	103	0.17	8	AV2 -0.05	85	92	0.31	12	AV2 +0.05
84	67	0.10	6	AV1 +0.00			0.14	7	AV4 +0.03			0.21	9	AV3 +0.07
		0.10	6	AV2 +0.00	84	105	0.11	6	AV2 +0.07			0.28	12	AV4 +0.00
		0.24	10	AV4 +0.05			0.36	14	AV4 +0.08			0.15	7	AV5 +0.05
		0.11	6	AV7 -0.12			0.45	16	AV7 +0.00			0.25	11	AV6 +0.10
84	71	0.11	6	AV2 +0.00	84	107	0.13	7	AV4 +0.03			0.23	10	AV7 +0.02
		0.24	11	AV4 +0.03			0.36	14	AV5 +0.02	85	94	0.09	5	AV2 +0.00
84	73	0.12	6	AV1 -0.02	84	141	0.13	7	AV5 -0.03			0.09	5	AV4 -0.02
		0.36	14	AV2 +0.05	84	143	0.15	7	AV2 +0.00			0.14	7	AV5 +0.00
		0.52	17	AV3 +0.02	84	149	0.13	7	AV1 -0.13			0.11	6	AV6 +0.02
		0.44	16	AV6 +0.00			0.15	8	AV2 +0.00			0.08	5	AV7 -0.02
84	75	0.14	7	AV3 +0.00			0.17	8	AV3 +0.02	85	96	0.09	5	AV1 -0.02
		0.54	18	AV4 +0.05			0.21	9	AV7 +0.00			0.18	8	AV2 +0.02
		0.33	13	AV7 -0.02	85	22	0.10	6	AV8 +0.04			0.10	6	AV3 +0.00
84	77	0.25	11	AV3 +0.02			0.16	8	AV2 +0.00			0.15	8	AV4 +0.00
		0.61	19	AV4 +0.05			0.16	8	AV6 +0.02			0.18	9	AV5 +0.02
84	79	0.11	6	AV5 +0.00	85	24	0.11	6	AV1 +0.02			0.15	7	AV6 +0.00
		0.21	9	AV6 +0.05			0.09	5	AV4 +0.08	85	98	0.19	9	AV2 +0.02
84	81	0.23	10	AV3 -0.02			0.14	7	AV5 +0.05			0.16	8	AV3 -0.02
		0.16	8	AV4 +0.03	85	26	0.15	7	AV1 -0.17			0.37	14	AV4 +0.05
		0.47	16	AV5 +0.02			0.15	7	AV4 +0.00			0.28	12	AV7 +0.02
84	83	0.11	6	AV2 +0.00			0.09	5	AV5 +0.20	85	100	0.16	8	AV3 -0.02
		0.42	15	AV3 +0.05	85	28	0.14	7	AV4 +0.03			0.60	19	AV4 +0.03
		0.24	11	AV4 +0.08			0.19	9	AV5 +0.18			0.28	12	AV6 +0.02
		0.38	14	AV5 +0.02	85	30	0.08	5	AV1 +0.00	85	102	0.14	7	AV3 +0.00
		0.22	10	AV6 +0.05			0.13	7	AV2 +0.02			0.15	7	AV4 -0.14
84	85	0.12	6	AV2 -0.02			0.12	6	AV5 +0.00	85	104	0.51	17	AV3 +0.00
		0.34	13	AV3 +0.00	85	32	0.11	6	AV4 +0.08			0.57	18	AV4 +0.03
		0.28	12	AV4 +0.05	85	36	0.11	6	AV4 +0.05			0.33	13	AV5 +0.00
		0.33	13	AV5 +0.05			0.12	6	AV5 +0.14			0.14	7	AV6 +0.00
		0.17	8	AV7 +0.00	85	44	0.45	16	AV6 +0.02	85	106	0.20	9	AV2 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.24	10	AV3 +0.05	86	91	0.23	10	AV7 +0.02			0.52	17	AV4 +0.00
		0.25	11	AV4 +0.03			0.14	7	AV8 +0.02			0.20	9	AV7 -0.05
85	108	0.18	8	AV3 +0.02	86	93	0.23	10	AV2 +0.02	87	82	0.18	9	AV2 +0.02
85	110	0.13	7	AV4 +0.03			0.23	10	AV3 +0.00			0.30	12	AV3 +0.05
		0.18	8	AV5 +0.05			0.18	9	AV4 +0.00			0.49	17	AV4 +0.08
86	23	0.27	11	AV1 +0.02			0.45	16	AV6 +0.00	87	84	0.16	8	AV1 +0.02
		0.29	12	AV2 +0.00			0.28	12	AV7 +0.05			0.36	14	AV2 +0.02
		0.21	9	AV5 +0.00			0.10	5	AV8 +0.02			0.61	19	AV3 +0.05
		0.16	8	AV6 +0.00	86	95	0.28	12	AV3 +0.02			0.21	9	AV6 +0.05
		0.17	8	AV7 -0.14			0.25	11	AV4 +0.03	87	86	0.34	13	AV3 +0.02
86	25	0.09	5	AV1 +0.23			0.46	16	AV5 +0.02			0.25	11	AV4 +0.05
		0.11	6	AV2 -0.18			0.43	15	AV6 +0.00			0.36	14	AV5 +0.02
		0.15	7	AV4 +0.00			0.43	15	AV7 +0.02			0.22	10	AV6 +0.02
86	27	0.16	8	AV4 +0.03	86	97	0.12	6	AV1 -0.02			0.16	8	AV7 +0.02
		0.19	9	AV6 -0.05			0.31	12	AV2 +0.02	87	88	0.18	8	AV2 +0.00
86	43	0.09	5	AV6 +0.02			0.62	19	AV4 +0.05			0.28	12	AV3 +0.00
86	53	0.14	7	AV7 +0.02			0.45	16	AV6 +0.02			0.20	9	AV4 +0.03
86	57	0.17	8	AV5 +0.02			0.22	10	AV7 +0.02			0.40	15	AV5 +0.02
		0.22	10	AV8 +0.02	86	99	0.18	8	AV1 +0.02			0.16	8	AV6 +0.05
86	59	0.23	10	AV6 +0.02			0.20	9	AV2 +0.02	87	90	0.16	8	AV2 +0.00
		0.21	10	AV7 -0.02			0.36	14	AV3 +0.02			0.21	10	AV3 +0.05
86	61	0.23	10	AV3 +0.05			0.33	13	AV4 +0.03			0.45	16	AV4 +0.00
86	63	0.13	7	AV4 +0.00			0.49	17	AV6 +0.02			0.47	16	AV6 +0.00
		0.23	10	AV5 +0.05			0.16	8	AV7 +0.05			0.35	14	AV7 +0.02
86	65	0.14	7	AV2 +0.00	86	101	0.11	6	AV3 +0.00	87	92	0.20	9	AV3 +0.05
		0.14	7	AV3 +0.00			0.23	10	AV4 +0.00			0.30	12	AV4 +0.00
		0.10	6	AV4 -0.14			0.12	6	AV5 +0.02			0.46	16	AV5 +0.02
		0.25	11	AV5 +0.02	86	103	0.20	9	AV4 +0.00			0.17	8	AV7 -0.02
		0.14	7	AV6 +0.00			0.47	16	AV5 +0.02	87	94	0.19	9	AV2 +0.02
		0.20	9	AV7 +0.00			0.31	12	AV6 +0.05			0.17	8	AV3 +0.05
86	67	0.13	7	AV2 +0.00	86	105	0.16	8	AV4 +0.03			0.19	9	AV4 +0.05
		0.51	17	AV3 +0.05			0.21	10	AV6 +0.03			0.23	10	AV5 +0.05
		0.21	9	AV4 +0.05	86	107	0.12	6	AV4 +0.00			0.22	10	AV6 +0.00
86	71	0.20	9	AV3 +0.02	86	109	0.18	9	AV2 +0.00	87	96	0.20	9	AV1 +0.00
86	73	0.14	7	AV1 -0.02			0.16	8	AV7 -0.02			0.39	14	AV2 +0.05
		0.11	6	AV3 +0.02	86	133	0.14	7	AV4 -0.05			0.40	15	AV3 +0.05
		0.33	13	AV4 +0.05	87	24	0.12	6	AV7 -0.02			0.31	12	AV4 +0.05
		0.28	12	AV6 +0.02	87	34	0.12	6	AV2 +0.00			0.37	14	AV6 +0.05
		0.12	6	AV7 +0.12			0.16	8	AV4 +0.00			0.14	7	AV7 +0.05
		0.10	6	AV8 +0.05	87	36	0.12	6	AV4 +0.05	87	98	0.32	13	AV2 +0.00
86	75	0.38	14	AV4 +0.08	87	48	0.15	7	AV5 +0.05			0.25	11	AV4 +0.03
		0.59	19	AV7 +0.05	87	54	0.24	10	AV2 -0.02			0.58	18	AV5 +0.00
86	77	0.12	6	AV3 -0.02	87	58	0.11	6	AV6 +0.05	87	100	0.18	8	AV4 +0.03
		0.23	10	AV5 +0.07	87	62	0.16	8	AV2 +0.00			0.18	8	AV5 +0.02
		0.15	7	AV7 +0.02			0.22	10	AV6 +0.05			0.23	10	AV6 +0.02
86	79	0.23	10	AV3 +0.05	87	64	0.26	11	AV4 +0.00			0.15	7	AV7 +0.07
		0.15	7	AV6 +0.05			0.40	15	AV5 +0.02	87	102	0.46	16	AV2 +0.02
		0.12	6	AV7 +0.00	87	66	0.36	14	AV5 +0.00			0.45	16	AV3 +0.05
86	81	0.20	9	AV2 +0.02			0.37	14	AV6 +0.02	87	104	0.16	8	AV3 +0.07
		0.11	6	AV4 +0.08			0.57	18	AV7 +0.02	87	106	0.20	9	AV6 +0.03
		0.55	18	AV5 +0.02			0.17	8	AV4 +0.03			0.24	10	AV8 +0.00
86	83	0.19	9	AV3 +0.00	87	68	0.29	12	AV2 +0.02	87	110	0.22	10	AV4 +0.05
		0.35	14	AV4 +0.05	87	70	0.13	7	AV1 +0.00			0.50	17	AV5 +0.02
		0.46	16	AV5 +0.00			0.31	12	AV2 -0.02			0.30	12	AV6 +0.00
		0.35	13	AV6 +0.00			0.51	17	AV3 +0.02			0.33	13	AV7 +0.02
		0.40	15	AV7 +0.02	87	72	0.42	15	AV2 +0.02	87	120	0.13	7	AV5 +0.02
86	85	0.54	18	AV2 +0.00			0.14	7	AV3 +0.00	87	122	0.13	7	AV4 -0.02
		0.56	18	AV5 +0.07			0.37	14	AV4 +0.03	87	128	0.10	6	AV3 +0.07
		0.18	8	AV6 +0.02			0.19	9	AV5 +0.02	87	130	0.17	8	AV4 +0.05
		0.26	11	AV7 +0.02			0.17	8	AV7 +0.05	88	23	0.12	6	AV1 +0.02
86	87	0.33	13	AV4 +0.00	87	74	0.19	9	AV3 +0.00			0.16	8	AV4 +0.03
		0.42	15	AV5 +0.00			0.24	10	AV4 -0.02	88	27	0.13	7	AV1 +0.02
		0.57	18	AV6 +0.02			0.40	15	AV5 +0.00			0.16	8	AV4 +0.03
		0.48	16	AV7 +0.00			0.19	9	AV6 +0.02	88	29	0.21	9	AV1 +0.18
		0.14	7	AV8 +0.02	87	76	0.32	13	AV3 +0.02	88	37	0.11	6	AV5 +0.00
		0.11	6	AV2 +0.02	87	78	0.25	11	AV3 +0.02	88	39	0.16	8	AV3 -0.02
		0.44	16	AV3 +0.02			0.30	12	AV4 +0.00			0.19	9	AV4 +0.03
86	89	0.13	7	AV2 -0.02			0.38	14	AV5 +0.00	88	41	0.14	7	AV4 -0.02
		0.19	9	AV3 +0.00			0.40	15	AV6 +0.02	88	47	0.12	6	AV4 -0.17
		0.45	16	AV4 +0.03			0.21	10	AV7 +0.02	88	49	0.11	6	AV5 +0.16
		0.45	16	AV5 +0.02	87	80	0.16	8	AV2 +0.02	88	59	0.18	8	AV3 +0.00
		0.32	13	AV7 +0.05			0.31	12	AV3 +0.02			0.20	9	AV4 +0.08

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.22	10	AV5 +0.00			0.26	11	AV6 +0.02			0.22	10	AV8 +0.05
		0.58	18	AV6 +0.02			0.17	8	AV7 +0.02	89	90	0.21	9	AV2 +0.05
		0.24	10	AV7 +0.05	88	111	0.19	9	AV3 +0.00			0.42	15	AV3 +0.02
88	63	0.18	8	AV5 +0.00			0.19	9	AV6 +0.05			0.45	16	AV6 +0.02
88	65	0.22	10	AV2 +0.02	88	113	0.16	8	AV5 +0.05			0.17	8	AV7 +0.00
		0.26	11	AV5 +0.05	88	131	0.16	8	AV3 +0.05	89	92	0.12	6	AV2 +0.02
88	67	0.17	8	AV3 +0.02			0.09	5	AV5 +0.05			0.15	8	AV3 +0.02
88	69	0.15	7	AV4 +0.05	88	133	0.20	9	AV2 +0.00			0.57	18	AV5 +0.02
		0.14	7	AV5 -0.16	89	26	0.08	5	AV1 -0.13			0.18	8	AV6 +0.02
88	71	0.38	14	AV3 +0.05	89	36	0.13	7	AV4 +0.03			0.34	13	AV7 +0.02
		0.23	10	AV8 +0.00	89	38	0.08	5	AV4 -0.02	89	94	0.14	7	AV2 +0.02
88	73	0.57	18	AV4 +0.00	89	40	0.15	8	AV4 +0.05			0.28	12	AV3 +0.02
		0.45	16	AV5 +0.02	89	42	0.14	7	AV6 +0.02			0.15	8	AV4 +0.05
		0.52	17	AV6 +0.00	89	46	0.11	6	AV3 +0.00			0.24	10	AV6 +0.02
		0.17	8	AV3 +0.02	89	48	0.15	8	AV5 +0.05			0.27	11	AV7 +0.02
88	75	0.23	10	AV2 +0.05	89	52	0.09	5	AV2 +0.00	89	96	0.18	8	AV1 +0.02
		0.19	9	AV3 -0.02	89	58	0.14	7	AV2 +0.02			0.25	11	AV2 +0.02
		0.22	10	AV5 +0.00			0.11	6	AV3 -0.02			0.22	10	AV3 +0.02
		0.16	8	AV6 +0.05	89	60	0.19	9	AV3 +0.00			0.16	8	AV4 +0.00
88	77	0.18	8	AV5 +0.00			0.09	5	AV7 -0.02			0.18	8	AV5 +0.02
		0.24	10	AV6 +0.02	89	62	0.18	9	AV2 +0.00			0.17	8	AV7 +0.02
		0.29	12	AV7 -0.02			0.37	14	AV3 +0.00	89	98	0.15	7	AV7 +0.02
88	79	0.19	9	AV4 +0.05			0.17	8	AV4 +0.03			0.18	9	AV1 +0.00
		0.16	8	AV7 +0.02	89	64	0.15	7	AV5 +0.05			0.19	9	AV3 +0.05
88	81	0.17	8	AV2 +0.00	89	66	0.32	13	AV4 +0.05			0.50	17	AV4 +0.03
		0.16	8	AV3 +0.02			0.14	7	AV5 +0.05			0.17	8	AV5 +0.02
		0.20	9	AV4 +0.00			0.23	10	AV7 +0.07			0.10	6	AV6 +0.00
		0.29	12	AV6 +0.00	89	68	0.17	8	AV3 +0.00	89	100	0.12	6	AV3 -0.02
		0.39	15	AV7 +0.00			0.16	8	AV4 +0.00			0.19	9	AV4 +0.08
88	83	0.22	10	AV3 +0.02			0.29	12	AV5 +0.00			0.27	11	AV6 +0.02
		0.17	8	AV5 +0.00	89	70	0.35	13	AV5 +0.00			0.44	16	AV7 +0.05
		0.16	8	AV6 +0.02	89	72	0.11	6	AV1 +0.00			0.19	9	AV8 +0.05
88	85	0.52	17	AV2 +0.02			0.12	6	AV2 +0.00	89	104	0.30	12	AV3 +0.00
		0.56	18	AV3 +0.05			0.25	11	AV3 +0.05			0.12	6	AV4 +0.00
		0.63	19	AV4 +0.05			0.13	7	AV4 +0.03	89	116	0.15	7	AV5 +0.00
		0.31	13	AV6 +0.02			0.42	15	AV6 +0.05	89	128	0.12	6	AV3 +0.05
88	87	0.26	11	AV3 +0.02			0.22	10	AV8 +0.09			0.07	4	AV4 -0.16
		0.23	10	AV4 +0.08	89	74	0.22	10	AV2 +0.02	90	29	0.14	7	AV1 +0.18
		0.20	9	AV5 +0.05			0.37	14	AV3 +0.02	90	31	0.13	7	AV1 +0.02
		0.58	18	AV6 +0.02			0.44	16	AV4 +0.05	90	33	0.15	7	AV3 +0.00
		0.57	18	AV7 +0.02			0.51	17	AV5 +0.05	90	37	0.13	7	AV5 +0.00
		0.22	10	AV8 +0.02	89	76	0.10	6	AV3 +0.00	90	39	0.08	5	AV5 +0.02
88	89	0.26	11	AV3 +0.00			0.16	8	AV4 +0.00	90	43	0.10	6	AV3 -0.02
		0.21	9	AV4 +0.05			0.26	11	AV5 +0.00	90	51	0.20	9	AV3 -0.02
88	91	0.15	7	AV2 +0.02			0.17	8	AV6 +0.02	90	53	0.17	8	AV8 +0.02
		0.16	8	AV6 +0.02			0.21	10	AV7 +0.05			0.11	6	AV3 -0.05
88	93	0.18	9	AV2 +0.00	89	78	0.25	11	AV5 +0.00			0.28	12	AV5 -0.03
		0.17	8	AV3 +0.02			0.20	9	AV7 +0.02			0.18	8	AV6 +0.00
		0.18	9	AV4 +0.03	89	80	0.17	8	AV2 +0.02			0.35	13	AV7 +0.00
		0.26	11	AV6 +0.02			0.35	13	AV3 +0.00	90	59	0.14	7	AV3 +0.00
		0.28	12	AV7 +0.05			0.19	9	AV4 +0.00	90	61	0.17	8	AV3 +0.00
88	95	0.35	13	AV3 +0.00			0.33	13	AV5 +0.00			0.42	15	AV5 +0.07
		0.52	17	AV4 +0.03			0.20	9	AV6 +0.07	90	63	0.51	17	AV5 +0.09
		0.40	15	AV8 +0.00	89	82	0.15	8	AV2 +0.02			0.30	12	AV6 +0.05
		0.15	7	AV2 +0.02			0.53	18	AV4 +0.03			0.21	9	AV7 +0.07
88	97	0.62	19	AV4 +0.05			0.47	16	AV7 +0.05	90	65	0.28	12	AV2 +0.05
		0.41	15	AV7 +0.02	89	84	0.09	5	AV1 +0.00			0.31	12	AV3 +0.00
		0.40	15	AV2 +0.02			0.31	13	AV2 +0.02			0.30	12	AV5 +0.05
88	99	0.21	9	AV1 +0.02			0.25	11	AV3 +0.00			0.17	8	AV7 +0.02
		0.24	10	AV2 +0.00			0.20	9	AV7 +0.00	90	67	0.10	6	AV2 +0.05
		0.49	17	AV3 +0.05	89	86	0.24	10	AV2 +0.00			0.11	6	AV3 +0.05
		0.60	19	AV7 +0.02			0.50	17	AV3 -0.02			0.10	6	AV4 +0.05
88	101	0.17	8	AV3 +0.02			0.44	16	AV4 +0.00			0.12	6	AV5 +0.05
88	103	0.13	7	AV2 +0.00			0.60	19	AV5 +0.00			0.27	11	AV6 +0.05
		0.51	17	AV4 +0.00			0.28	11	AV6 -0.02			0.19	9	AV7 +0.02
		0.54	18	AV7 +0.02			0.22	10	AV7 +0.02	90	69	0.11	6	AV3 +0.05
88	105	0.35	14	AV2 +0.00	89	88	0.16	8	AV2 +0.00			0.19	9	AV4 +0.03
		0.24	10	AV3 +0.02			0.24	10	AV3 +0.00			0.17	8	AV5 -0.18
		0.27	11	AV6 +0.02			0.10	6	AV4 +0.03			0.22	10	AV6 +0.02
88	107	0.21	9	AV3 +0.02			0.29	12	AV5 +0.00	90	71	0.10	6	AV2 -0.02
		0.19	9	AV4 +0.03			0.37	14	AV6 +0.02			0.15	8	AV6 +0.05
		0.41	15	AV5 +0.00			0.44	16	AV7 +0.00			0.54	18	AV7 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
90	73	0.19	9	AV3 +0.02	91	50	0.17	8	AV6 +0.21			0.21	9	AV1 -0.02
		0.37	14	AV4 +0.03			0.12	6	AV5 -0.15	91	100	0.12	6	AV6 +0.02
90	75	0.12	6	AV2 -0.02	91	54	0.12	6	AV4 +0.15			0.34	13	AV5 +0.02
		0.16	8	AV3 -0.19	91	58	0.06	4	AV4 +0.34			0.56	18	AV4 +0.05
		0.10	6	AV4 +0.03	91	60	0.15	7	AV4 -0.24	91	102	0.06	4	AV8 +0.00
		0.15	7	AV5 -0.03			0.26	11	AV2 +0.00			0.15	7	AV7 -0.02
90	77	0.32	13	AV4 +0.05	91	62	0.08	5	AV3 +0.26			0.07	4	AV5 +0.02
90	79	0.30	12	AV4 +0.03	91	64	0.16	8	AV5 +0.00	91	104	0.20	9	AV3 +0.05
		0.42	15	AV6 +0.02	91	66	0.29	12	AV7 +0.05			0.09	5	AV6 -0.02
		0.26	11	AV7 -0.02			0.08	5	AV2 -0.23			0.07	4	AV5 -0.19
90	81	0.40	15	AV2 +0.00			0.12	6	AV1 +0.07	91	106	0.10	5	AV4 -0.19
		0.16	8	AV3 +0.00	91	68	0.08	5	AV3 -0.19	91	110	0.12	6	AV4 +0.03
		0.36	14	AV4 +0.03	91	70	0.31	12	AV5 +0.12			0.21	9	AV3 -0.02
90	83	0.17	8	AV2 +0.00			0.05	3	AV4 +0.13	91	120	0.12	6	AV5 +0.00
		0.26	11	AV3 +0.05	91	72	0.08	5	AV6 +0.20	91	124	0.08	5	AV4 -0.19
		0.42	15	AV6 +0.02			0.20	9	AV5 +0.16	91	128	0.11	6	AV4 -0.18
90	87	0.29	12	AV3 +0.00			0.14	7	AV4 +0.00	91	130	0.09	5	AV4 -0.16
		0.45	16	AV4 +0.00			0.10	6	AV2 +0.21	92	25	0.11	6	AV1 -0.05
		0.23	10	AV5 +0.00	91	74	0.51	17	AV7 +0.00	92	37	0.11	6	AV5 +0.00
		0.21	9	AV6 +0.05			0.53	18	AV6 -0.02	92	39	0.20	9	AV5 -0.03
		0.29	12	AV7 +0.02			0.29	12	AV5 -0.05	92	43	0.09	5	AV5 +0.09
90	89	0.20	9	AV2 +0.02			0.21	9	AV4 -0.02			0.09	5	AV4 +0.29
		0.26	11	AV3 +0.05			0.10	5	AV3 +0.00	92	45	0.06	4	AV5 -0.03
		0.17	8	AV4 +0.03	91	78	0.51	17	AV6 +0.02	92	49	0.14	7	AV4 -0.05
		0.52	17	AV5 +0.05			0.50	17	AV5 +0.00	92	53	0.06	4	AV5 -0.03
		0.61	19	AV6 +0.02			0.39	14	AV3 +0.02	92	57	0.08	5	AV3 -0.05
		0.29	12	AV7 +0.05			0.07	4	AV2 -0.20	92	61	0.15	7	AV3 -0.02
90	91	0.19	9	AV2 +0.00	91	80	0.29	12	AV7 -0.02	92	63	0.16	8	AV5 +0.05
		0.14	7	AV3 +0.00			0.44	16	AV5 +0.00	92	65	0.12	6	AV4 -0.07
		0.22	10	AV4 +0.08			0.11	6	AV4 -0.05	92	67	0.11	6	AV4 +0.00
		0.19	9	AV5 +0.02	91	82	0.13	7	AV4 -0.09	92	69	0.23	10	AV7 +0.00
90	93	0.22	10	AV2 +0.00			0.14	7	AV2 -0.02			0.36	14	AV6 -0.03
		0.16	8	AV3 -0.02	91	84	0.09	5	AV7 +0.00			0.16	8	AV4 -0.02
		0.19	9	AV4 +0.03			0.21	10	AV6 +0.05			0.17	8	AV3 +0.00
		0.26	11	AV5 +0.00			0.55	18	AV5 +0.00	92	71	0.16	8	AV8 +0.02
		0.23	10	AV6 +0.00			0.36	14	AV4 +0.05			0.10	6	AV6 +0.00
		0.40	15	AV7 +0.02			0.21	9	AV3 +0.00			0.12	6	AV3 -0.02
90	95	0.15	8	AV3 +0.00			0.07	4	AV2 -0.18			0.09	5	AV2 -0.23
		0.13	7	AV2 -0.14	91	86	0.22	10	AV7 +0.00	92	73	0.09	5	AV7 -0.10
		0.18	8	AV7 +0.02			0.28	12	AV6 +0.00			0.10	5	AV4 +0.16
		0.14	7	AV4 +0.00			0.47	16	AV5 +0.02	92	75	0.09	5	AV3 -0.19
		0.41	15	AV5 +0.02			0.47	16	AV4 +0.03			0.13	7	AV8 +0.00
		0.37	14	AV6 +0.02			0.38	14	AV2 +0.02			0.55	18	AV7 +0.00
90	97	0.38	14	AV2 +0.02	91	88	0.08	5	AV8 +0.44			0.20	9	AV6 +0.05
		0.46	16	AV3 +0.00			0.14	7	AV7 -0.02			0.17	8	AV4 +0.03
		0.28	11	AV4 +0.03			0.16	8	AV6 +0.00	92	77	0.09	5	AV8 +0.02
		0.46	16	AV5 +0.07			0.45	16	AV5 -0.03			0.08	5	AV3 -0.30
90	99	0.14	7	AV2 +0.02			0.37	14	AV4 +0.03			0.07	4	AV2 -0.18
		0.21	9	AV3 -0.02			0.27	11	AV3 +0.00	92	79	0.29	12	AV7 -0.02
		0.11	6	AV4 +0.00			0.09	5	AV2 +0.00	92	81	0.12	6	AV8 +0.00
		0.63	19	AV5 +0.02	91	90	0.45	16	AV7 +0.02			0.08	5	AV4 +0.36
		0.33	13	AV7 +0.05			0.13	7	AV6 +0.17			0.17	8	AV3 -0.16
90	101	0.16	8	AV3 +0.00			0.15	7	AV5 +0.02	92	83	0.16	8	AV7 -0.22
		0.21	10	AV4 +0.08			0.33	13	AV4 +0.03			0.22	10	AV6 -0.02
90	103	0.12	6	AV1 +0.02			0.19	9	AV3 +0.07			0.57	18	AV4 -0.02
		0.20	9	AV2 -0.02	91	92	0.62	19	AV8 -0.02			0.38	14	AV3 -0.02
		0.13	7	AV3 +0.05			0.51	17	AV4 +0.05			0.10	5	AV2 +0.00
		0.48	17	AV4 +0.03			0.16	8	AV3 +0.05	92	85	0.46	16	AV4 +0.03
		0.16	8	AV5 +0.05			0.17	8	AV2 +0.02			0.18	9	AV3 +0.00
		0.63	19	AV7 +0.05	91	94	0.26	11	AV7 -0.02			0.25	11	AV2 -0.02
		0.17	8	AV8 +0.00			0.19	9	AV6 +0.02			0.06	4	AV1 -0.23
90	105	0.15	7	AV5 +0.00			0.06	4	AV5 -0.08	92	87	0.16	8	AV8 +0.05
90	107	0.41	15	AV5 +0.05			0.13	7	AV4 -0.05			0.28	11	AV7 +0.02
90	127	0.09	5	AV5 +0.07			0.19	9	AV3 +0.00			0.28	12	AV6 +0.00
90	131	0.15	8	AV5 +0.02			0.13	7	AV2 -0.05			0.22	10	AV4 +0.00
91	24	0.11	6	AV1 -0.14	91	96	0.39	14	AV7 -0.03			0.51	17	AV3 +0.05
91	36	0.06	4	AV4 +0.13			0.16	8	AV3 +0.02			0.14	7	AV1 +0.00
91	38	0.09	5	AV5 +0.16			0.12	6	AV2 +0.05	92	89	0.09	5	AV6 -0.02
		0.08	5	AV3 +0.24			0.14	7	AV1 -0.02			0.16	8	AV4 +0.00
91	44	0.07	4	AV3 -0.19	91	98	0.24	11	AV4 +0.05			0.14	7	AV3 -0.14
91	46	0.09	5	AV5 +0.33			0.39	14	AV3 +0.05			0.07	4	AV2 -0.05
		0.11	6	AV4 -0.14			0.18	8	AV2 +0.00	92	91	0.21	9	AV7 -0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.16	8	AV6 -0.02			0.20	9	AV3 -0.02			0.07	4	AV2 +0.12
		0.16	8	AV3 +0.00			0.18	8	AV4 -0.02			0.09	5	AV1 +0.07
92	93	0.23	10	AV7 +0.00			0.13	7	AV3 +0.02	94	73	0.15	7	AV2 +0.05
		0.32	13	AV6 +0.02			0.14	7	AV2 -0.02			0.28	12	AV1 -0.05
		0.28	12	AV4 +0.05	93	84	0.17	8	AV8 +0.05			0.19	9	AV4 +0.16
		0.12	6	AV3 +0.02			0.47	16	AV7 -0.02	94	75	0.14	7	AV4 +0.05
		0.11	6	AV2 -0.02			0.36	14	AV3 -0.02			0.17	8	AV3 +0.02
92	95	0.07	4	AV7 +0.02			0.20	9	AV2 +0.00	94	77	0.59	19	AV7 -0.03
		0.35	14	AV3 +0.02	93	86	0.53	17	AV3 +0.00			0.27	11	AV4 +0.00
		0.16	8	AV2 -0.16			0.14	7	AV2 +0.00			0.15	7	AV2 -0.07
92	97	0.29	12	AV7 +0.00	93	88	0.26	11	AV7 +0.00	94	79	0.36	14	AV7 -0.03
		0.53	18	AV6 -0.02			0.60	19	AV6 -0.02			0.34	13	AV5 +0.02
		0.32	13	AV5 +0.00			0.53	17	AV5 +0.00			0.14	7	AV4 -0.02
		0.12	6	AV8 -0.02			0.35	13	AV3 +0.02			0.14	7	AV3 -0.05
		0.14	7	AV4 +0.03			0.25	11	AV2 +0.00			0.19	9	AV2 -0.02
		0.13	7	AV3 +0.02	93	90	0.12	6	AV7 +0.16			0.11	6	AV1 -0.02
		0.10	6	AV2 +0.00			0.31	13	AV5 +0.00	94	81	0.43	15	AV3 +0.00
92	99	0.36	14	AV8 +0.00			0.12	6	AV4 -0.02	94	83	0.22	10	AV8 +0.05
		0.61	19	AV7 +0.00			0.14	7	AV3 +0.02			0.57	18	AV7 -0.02
		0.25	11	AV4 +0.03			0.15	7	AV2 +0.00			0.23	10	AV2 +0.02
		0.56	18	AV3 +0.02	93	92	0.39	14	AV8 +0.00			0.11	6	AV1 -0.18
		0.53	17	AV2 +0.00			0.18	9	AV7 -0.24	94	85	0.19	9	AV1 +0.00
		0.36	14	AV1 -0.02			0.29	12	AV6 -0.02			0.33	13	AV7 +0.00
92	101	0.18	9	AV5 +0.02			0.12	6	AV4 -0.16			0.42	15	AV6 -0.02
		0.29	12	AV2 +0.00			0.11	6	AV3 -0.05	94	87	0.37	14	AV7 +0.00
		0.12	6	AV1 +0.12			0.27	11	AV2 +0.00			0.35	14	AV6 +0.02
92	103	0.15	8	AV3 +0.02	93	94	0.52	17	AV3 +0.05			0.17	8	AV2 +0.02
		0.09	5	AV2 -0.12			0.18	8	AV2 -0.02	94	89	0.11	6	AV8 -0.02
92	107	0.09	5	AV7 +0.02			0.10	6	AV1 -0.02			0.09	5	AV7 +0.51
		0.20	9	AV4 -0.05	93	96	0.14	7	AV4 -0.02			0.16	8	AV6 +0.02
		0.18	9	AV3 -0.05			0.13	7	AV3 +0.02			0.21	9	AV5 +0.03
92	109	0.12	6	AV5 +0.02	93	98	0.10	5	AV8 -0.02			0.38	14	AV4 +0.05
92	117	0.16	8	AV4 +0.03			0.36	14	AV3 -0.02			0.42	15	AV3 +0.02
92	121	0.14	7	AV5 +0.00			0.12	6	AV2 -0.05			0.24	10	AV2 +0.00
		0.11	6	AV3 +0.02	93	100	0.52	17	AV7 +0.00			0.07	4	AV1 +0.07
92	123	0.09	5	AV5 +0.16			0.21	9	AV6 +0.02	94	91	0.45	16	AV7 +0.02
		0.09	5	AV2 +0.00			0.22	10	AV5 +0.00	94	93	0.13	7	AV7 +0.16
93	24	0.17	8	AV1 -0.16			0.25	11	AV3 +0.00			0.50	17	AV6 -0.02
93	26	0.16	8	AV1 -0.14			0.14	7	AV2 -0.05			0.36	14	AV5 +0.00
93	30	0.16	8	AV1 +0.14	93	102	0.27	11	AV5 -0.03			0.46	16	AV4 +0.00
93	40	0.13	7	AV4 +0.13			0.18	9	AV4 -0.03			0.17	8	AV3 +0.02
		0.14	7	AV3 -0.02	93	104	0.22	10	AV6 +0.00			0.11	6	AV2 +0.00
93	44	0.14	7	AV4 -0.02			0.28	12	AV5 +0.00			0.10	6	AV1 -0.19
93	46	0.10	6	AV4 +0.18			0.36	14	AV4 +0.03	94	95	0.35	14	AV5 +0.02
93	54	0.07	4	AV6 +0.14			0.48	16	AV3 +0.05	94	97	0.08	5	AV8 +0.00
93	56	0.09	5	AV3 -0.21	93	106	0.09	5	AV4 -0.05			0.21	9	AV6 +0.00
93	60	0.14	7	AV4 -0.19	93	112	0.13	7	AV4 +0.03			0.15	8	AV5 -0.03
93	64	0.21	9	AV7 +0.00	93	116	0.07	4	AV2 -0.19			0.07	4	AV4 -0.05
		0.49	17	AV5 -0.03	93	128	0.16	8	AV5 +0.00			0.14	7	AV3 +0.00
		0.26	11	AV4 +0.00			0.12	6	AV4 +0.00			0.30	12	AV2 +0.00
93	66	0.14	7	AV6 -0.03	93	134	0.10	6	AV8 -0.09	94	99	0.11	6	AV8 +0.05
		0.18	8	AV5 -0.03			0.17	8	AV1 -0.16			0.07	4	AV7 -0.43
93	68	0.13	7	AV3 -0.05	94	39	0.08	5	AV5 +0.00			0.60	19	AV6 +0.02
		0.13	7	AV2 -0.02	94	45	0.18	9	AV4 +0.05			0.42	15	AV3 +0.02
93	70	0.13	7	AV5 +0.13	94	47	0.12	6	AV2 +0.14			0.09	5	AV2 -0.16
		0.12	6	AV4 +0.00	94	49	0.07	5	AV4 +0.03			0.08	5	AV1 +0.02
93	72	0.09	5	AV7 +0.14	94	53	0.11	6	AV6 -0.14	94	101	0.19	9	AV4 +0.08
		0.43	15	AV6 +0.00	94	55	0.08	5	AV5 -0.03			0.13	7	AV3 +0.02
		0.19	9	AV4 +0.03			0.10	6	AV4 -0.19	94	103	0.24	10	AV6 -0.02
		0.12	6	AV3 -0.02	94	59	0.13	7	AV7 +0.02			0.19	9	AV3 +0.02
93	74	0.60	19	AV5 +0.00			0.16	8	AV3 +0.00	94	105	0.24	10	AV3 +0.00
		0.29	12	AV4 +0.03	94	65	0.17	8	AV6 +0.00			0.23	10	AV2 -0.07
		0.24	10	AV3 +0.00			0.10	6	AV5 -0.03	94	115	0.08	5	AV4 +0.05
		0.12	6	AV2 -0.02			0.10	5	AV2 -0.02			0.13	7	AV3 -0.02
93	76	0.32	13	AV6 +0.02	94	67	0.38	14	AV7 +0.02	94	119	0.09	5	AV5 +0.00
93	78	0.15	7	AV7 +0.00			0.54	18	AV5 +0.00			0.18	9	AV4 +0.00
		0.40	15	AV6 -0.02			0.54	18	AV4 -0.02			0.14	7	AV3 +0.02
		0.61	19	AV5 +0.00	94	69	0.08	5	AV6 +0.02	94	123	0.13	7	AV4 -0.02
93	80	0.17	8	AV7 +0.00			0.58	19	AV3 +0.07	94	125	0.36	14	AV2 +0.02
		0.63	19	AV6 +0.02			0.10	6	AV1 -0.02	95	28	0.10	6	AV1 -0.18
		0.37	14	AV5 -0.03	94	71	0.51	17	AV5 +0.05	95	42	0.09	5	AV8 -0.30
		0.12	6	AV4 +0.00			0.08	5	AV3 +0.30	95	46	0.13	7	AV4 +0.21

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
95	48	0.11	6	AV5 +0.19			0.36	14	AV3 +0.02			0.29	12	AV2 +0.00
95	50	0.13	7	AV5 -0.13			0.12	6	AV2 -0.07			0.21	10	AV1 -0.02
		0.10	6	AV4 -0.12	95	98	0.19	9	AV7 +0.02	96	87	0.29	12	AV7 +0.00
95	54	0.14	7	AV3 +0.00			0.08	5	AV6 +0.21			0.44	16	AV5 -0.05
95	58	0.08	5	AV4 -0.21			0.08	5	AV5 +0.18			0.50	17	AV4 +0.00
		0.10	6	AV3 -0.02			0.12	6	AV4 -0.21			0.46	16	AV3 +0.00
95	60	0.12	6	AV4 -0.19			0.16	8	AV2 -0.02			0.26	11	AV2 +0.00
95	62	0.31	13	AV7 +0.02	95	100	0.17	8	AV7 +0.05			0.06	4	AV1 +0.05
		0.56	18	AV6 +0.00			0.20	9	AV6 +0.00	96	89	0.24	10	AV7 +0.00
		0.36	14	AV5 -0.03			0.39	14	AV5 +0.05			0.57	18	AV5 -0.03
		0.07	4	AV4 -0.02			0.55	18	AV4 +0.06			0.16	8	AV4 -0.19
95	64	0.41	15	AV6 +0.00			0.54	18	AV3 +0.00			0.12	6	AV3 -0.14
		0.05	4	AV4 +0.24			0.43	15	AV2 +0.00			0.06	4	AV8 -0.05
		0.07	4	AV3 +0.21			0.25	11	AV1 +0.00	96	91	0.19	9	AV7 -0.02
95	66	0.11	6	AV5 +0.05	95	102	0.19	9	AV4 +0.05			0.43	15	AV6 +0.00
		0.59	19	AV4 +0.03			0.27	11	AV3 +0.00			0.06	4	AV5 +0.26
		0.13	7	AV3 +0.00	95	104	0.45	16	AV8 +0.00			0.13	7	AV4 +0.00
		0.07	4	AV2 +0.21			0.11	6	AV4 -0.21			0.14	7	AV3 +0.00
		0.07	4	AV1 +0.27			0.19	9	AV3 +0.05			0.15	7	AV2 +0.05
95	68	0.10	6	AV5 -0.13	95	106	0.16	8	AV5 +0.00	96	93	0.06	4	AV8 +0.49
		0.07	4	AV3 -0.14	95	110	0.15	8	AV3 +0.00			0.14	7	AV4 +0.05
95	70	0.07	5	AV6 +0.02			0.12	6	AV2 +0.02			0.34	13	AV3 +0.02
		0.08	5	AV5 +0.16	95	112	0.07	4	AV4 -0.21			0.21	9	AV2 +0.00
		0.18	8	AV4 +0.00	95	118	0.13	7	AV5 +0.02	96	95	0.12	6	AV8 +0.00
		0.09	5	AV7 +0.07	95	120	0.10	5	AV4 +0.05			0.16	8	AV7 +0.02
95	72	0.19	9	AV6 +0.00			0.08	5	AV5 +0.16			0.22	10	AV6 +0.02
		0.50	17	AV5 +0.02	96	39	0.15	8	AV4 +0.00			0.20	9	AV5 +0.05
		0.35	13	AV4 +0.03	96	41	0.09	5	AV5 -0.18			0.09	5	AV4 +0.34
		0.46	16	AV3 +0.02	96	43	0.09	5	AV4 -0.02			0.09	5	AV3 -0.14
		0.12	6	AV1 +0.09	96	47	0.08	5	AV3 +0.17			0.14	7	AV2 -0.05
95	74	0.09	5	AV7 +0.17	96	49	0.09	5	AV6 +0.14	96	97	0.09	5	AV8 +0.00
		0.15	7	AV6 +0.02	96	53	0.08	5	AV6 +0.21			0.33	13	AV4 +0.00
		0.07	4	AV3 +0.16			0.12	6	AV4 -0.02			0.33	13	AV3 -0.02
95	76	0.43	15	AV7 +0.00			0.13	7	AV3 -0.07			0.18	8	AV2 +0.02
		0.55	18	AV6 +0.00	96	57	0.09	5	AV4 +0.16	96	99	0.10	5	AV5 +0.15
		0.14	7	AV4 +0.00	96	59	0.27	11	AV4 +0.05			0.27	11	AV4 -0.02
95	78	0.50	17	AV7 +0.00	96	61	0.07	4	AV4 +0.26			0.13	7	AV3 -0.02
		0.24	10	AV4 +0.03			0.16	8	AV1 -0.02	96	101	0.09	5	AV5 +0.00
95	80	0.21	9	AV3 -0.07	96	65	0.08	5	AV6 -0.19			0.16	8	AV4 +0.00
95	82	0.07	4	AV7 +0.00			0.10	5	AV5 -0.21			0.08	5	AV3 +0.00
		0.39	14	AV5 -0.05	96	67	0.14	7	AV4 +0.03	96	103	0.25	11	AV5 -0.05
		0.12	6	AV3 -0.02	96	69	0.15	7	AV5 -0.03			0.30	12	AV4 -0.03
		0.11	6	AV2 -0.11			0.08	5	AV4 -0.19	96	105	0.16	8	AV4 +0.03
95	84	0.41	15	AV2 +0.00			0.10	5	AV3 +0.00			0.33	13	AV2 -0.02
		0.06	4	AV1 -0.05	96	71	0.46	16	AV3 +0.05	96	107	0.27	11	AV5 -0.03
		0.23	10	AV8 +0.07			0.24	10	AV5 +0.03			0.13	7	AV3 -0.02
		0.60	19	AV7 -0.02			0.15	7	AV2 -0.02	96	109	0.10	6	AV7 -0.02
		0.18	9	AV6 +0.12	96	73	0.12	6	AV5 -0.21			0.17	8	AV5 +0.02
95	86	0.16	8	AV8 -0.02			0.28	11	AV4 -0.02	96	115	0.15	7	AV4 +0.00
		0.49	17	AV2 +0.02	96	75	0.06	4	AV7 -0.07	96	117	0.09	5	AV3 -0.05
95	88	0.16	8	AV8 +0.00			0.30	12	AV6 -0.02	97	34	0.16	8	AV3 +0.00
		0.38	14	AV5 +0.02			0.20	9	AV5 -0.03	97	36	0.15	7	AV5 +0.00
		0.22	10	AV3 +0.02			0.07	5	AV4 -0.19	97	42	0.11	6	AV6 +0.02
		0.31	12	AV2 +0.02			0.12	6	AV3 -0.21			0.08	5	AV5 +0.15
95	90	0.22	10	AV7 -0.02	96	77	0.24	10	AV8 +0.05	97	46	0.07	4	AV5 -0.20
		0.38	14	AV6 +0.00			0.10	6	AV7 +0.00	97	48	0.13	7	AV5 +0.05
		0.37	14	AV4 +0.03			0.62	19	AV6 +0.05	97	50	0.18	9	AV4 +0.00
		0.09	5	AV3 -0.16			0.16	8	AV4 +0.05	97	54	0.21	10	AV3 +0.02
		0.07	5	AV2 -0.20			0.43	15	AV2 -0.02	97	56	0.09	5	AV6 +0.05
95	92	0.15	8	AV4 -0.14	96	79	0.21	9	AV3 +0.05			0.12	6	AV3 -0.19
		0.23	10	AV7 +0.02	96	81	0.18	9	AV8 +0.12	97	58	0.11	6	AV6 +0.14
		0.13	7	AV6 +0.07			0.35	13	AV7 +0.00			0.28	12	AV5 +0.00
		0.13	7	AV3 -0.05			0.09	5	AV6 -0.14			0.15	7	AV4 +0.03
		0.14	7	AV2 +0.02			0.13	7	AV5 +0.23			0.10	6	AV3 +0.02
95	94	0.48	17	AV7 +0.00			0.11	6	AV4 +0.00	97	60	0.16	8	AV4 +0.00
		0.31	12	AV6 +0.00			0.16	8	AV3 +0.00	97	62	0.11	6	AV4 +0.05
		0.43	15	AV5 +0.00			0.07	5	AV2 -0.02			0.17	8	AV3 +0.00
		0.20	9	AV4 -0.05	96	83	0.23	10	AV8 +0.02	97	64	0.11	6	AV8 +0.00
		0.30	12	AV3 +0.02			0.36	14	AV7 -0.02			0.23	10	AV6 +0.00
		0.55	18	AV2 -0.02			0.39	14	AV6 -0.05	97	66	0.53	17	AV8 +0.02
		0.23	10	AV1 -0.02			0.58	19	AV5 -0.05	97	68	0.26	11	AV5 -0.03
95	96	0.54	18	AV7 +0.00			0.61	19	AV3 -0.02			0.18	8	AV4 -0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.11	6	AV3 -0.02										
97	70	0.18	8	AV5 +0.18	97	106	0.11	6	AV7 +0.02			0.48	17	AV5 +0.00
		0.14	7	AV4 -0.02			0.21	10	AV6 +0.00			0.27	11	AV3 -0.05
		0.26	11	AV3 +0.00			0.18	9	AV3 +0.00			0.08	5	AV2 +0.00
		0.31	12	AV2 +0.00	97	114	0.10	6	AV4 -0.14	98	93	0.08	5	AV6 -0.17
97	72	0.17	8	AV7 +0.16	97	118	0.10	6	AV5 +0.00			0.33	13	AV5 +0.05
		0.32	13	AV6 +0.02			0.11	6	AV4 -0.12			0.43	15	AV4 +0.03
		0.18	8	AV5 +0.21	98	27	0.17	8	AV1 -0.14			0.10	6	AV3 -0.02
		0.10	6	AV4 +0.03	98	29	0.10	6	AV8 +0.09			0.10	6	AV2 +0.00
		0.16	8	AV3 +0.00			0.07	4	AV2 +0.24			0.06	4	AV1 +0.00
		0.08	5	AV2 -0.05			0.11	6	AV1 +0.07	98	95	0.11	6	AV5 -0.03
97	78	0.47	16	AV5 -0.03	98	39	0.11	6	AV5 +0.18			0.08	5	AV3 -0.14
		0.19	9	AV4 -0.02	98	43	0.11	6	AV4 -0.05			0.14	7	AV2 -0.21
		0.31	12	AV3 -0.02	98	49	0.11	6	AV5 -0.16			0.05	4	AV1 -0.07
		0.38	14	AV7 -0.05	98	51	0.15	7	AV4 -0.02			0.45	16	AV8 -0.02
		0.27	11	AV6 -0.02	98	53	0.20	9	AV6 +0.21	98	97	0.17	8	AV8 -0.02
97	80	0.13	7	AV7 +0.00			0.10	6	AV3 -0.21			0.25	11	AV6 +0.00
		0.20	9	AV5 -0.03	98	57	0.15	8	AV4 -0.02			0.58	18	AV5 +0.02
		0.18	8	AV3 -0.05			0.08	5	AV2 -0.07			0.31	12	AV3 +0.02
97	82	0.17	8	AV7 +0.00	98	59	0.08	5	AV5 +0.05			0.52	17	AV2 +0.02
		0.41	15	AV6 +0.00	98	61	0.11	6	AV4 +0.21	98	99	0.08	5	AV8 +0.02
		0.41	15	AV5 -0.03	98	63	0.09	5	AV7 +0.02			0.23	10	AV4 +0.05
		0.20	9	AV4 +0.00			0.08	5	AV4 +0.03			0.12	6	AV3 +0.02
		0.19	9	AV3 -0.02	98	65	0.14	7	AV7 +0.02			0.11	6	AV2 -0.05
		0.18	9	AV2 -0.02			0.33	13	AV6 +0.02	98	101	0.07	5	AV7 +0.16
97	84	0.57	18	AV4 -0.02	98	67	0.13	7	AV4 +0.31			0.12	6	AV6 +0.02
		0.35	13	AV3 -0.02			0.15	8	AV2 +0.00			0.10	6	AV3 +0.00
		0.38	14	AV2 +0.00			0.10	6	AV1 +0.00			0.12	6	AV2 -0.02
		0.29	12	AV7 +0.00	98	69	0.12	6	AV7 -0.16	98	103	0.18	8	AV7 -0.05
97	86	0.22	10	AV8 +0.00			0.11	6	AV4 -0.26			0.58	19	AV5 +0.02
		0.62	19	AV6 -0.08			0.11	6	AV3 +0.17			0.62	19	AV4 +0.03
		0.34	13	AV2 -0.02			0.07	4	AV2 -0.02			0.27	11	AV2 +0.09
97	88	0.24	11	AV7 -0.05	98	71	0.10	6	AV4 +0.10	98	105	0.14	7	AV6 -0.05
		0.48	17	AV6 -0.03			0.08	5	AV3 +0.19			0.21	9	AV3 +0.00
		0.47	16	AV5 -0.03			0.06	4	AV6 +0.24	98	107	0.32	13	AV5 +0.00
		0.27	11	AV4 +0.00	98	73	0.11	6	AV5 +0.02	98	109	0.09	5	AV4 +0.03
		0.18	8	AV3 -0.02	98	75	0.57	18	AV8 +0.02			0.19	9	AV3 -0.02
		0.10	6	AV2 -0.02			0.62	19	AV6 +0.02	98	111	0.13	7	AV5 +0.19
97	90	0.53	17	AV7 +0.00			0.16	8	AV4 +0.00	98	121	0.09	5	AV4 +0.05
		0.49	17	AV6 +0.00			0.33	13	AV3 +0.00			0.09	5	AV3 -0.13
		0.22	10	AV5 +0.05			0.08	5	AV2 -0.05	98	129	0.08	5	AV3 -0.20
		0.12	6	AV4 +0.05	98	77	0.16	8	AV8 +0.02			0.09	5	AV2 -0.02
		0.48	17	AV3 -0.02			0.16	8	AV7 +0.00	98	141	0.05	3	AV3 +0.16
		0.14	7	AV2 +0.00			0.14	7	AV6 +0.03	99	30	0.12	6	AV1 +0.02
		0.06	4	AV1 +0.00			0.47	16	AV5 +0.05	99	32	0.09	5	AV1 +0.18
97	92	0.21	9	AV8 -0.02			0.17	8	AV4 +0.03	99	38	0.07	5	AV2 +0.19
		0.48	17	AV7 -0.02	98	79	0.12	6	AV3 +0.00	99	42	0.10	5	AV3 +0.19
		0.46	16	AV2 -0.02			0.36	14	AV6 +0.08	99	44	0.10	6	AV4 +0.08
97	94	0.20	9	AV2 -0.02			0.15	7	AV5 +0.05	99	46	0.11	6	AV6 -0.16
		0.08	5	AV1 +0.16			0.15	7	AV4 +0.03			0.06	4	AV5 +0.19
		0.24	10	AV7 -0.02	98	81	0.26	11	AV5 +0.02	99	48	0.06	4	AV3 +0.40
		0.43	15	AV6 +0.00			0.59	19	AV4 +0.00	99	50	0.11	6	AV4 +0.21
		0.09	5	AV5 +0.15			0.34	13	AV3 +0.00			0.07	5	AV2 +0.12
		0.16	8	AV4 +0.00	98	83	0.10	6	AV7 +0.02	99	52	0.10	6	AV4 +0.05
		0.27	11	AV3 +0.00			0.08	5	AV6 +0.02	99	54	0.08	5	AV6 +0.05
97	96	0.59	19	AV5 +0.00			0.52	17	AV5 -0.03			0.10	6	AV3 +0.02
		0.15	7	AV4 -0.18			0.52	17	AV4 -0.02	99	56	0.41	15	AV3 +0.02
		0.29	12	AV3 +0.00			0.44	16	AV3 -0.02			0.08	5	AV4 -0.14
		0.17	8	AV2 +0.05			0.19	9	AV2 -0.02	99	58	0.19	9	AV3 +0.00
		0.12	6	AV1 -0.05	98	85	0.10	6	AV8 -0.12	99	60	0.16	8	AV4 -0.21
97	98	0.58	18	AV7 +0.00			0.51	17	AV6 +0.00	99	62	0.11	6	AV4 +0.24
		0.53	18	AV4 +0.00			0.38	14	AV5 +0.03	99	64	0.20	9	AV8 +0.05
		0.27	11	AV3 -0.02			0.12	6	AV1 +0.02			0.08	5	AV4 -0.02
		0.11	6	AV2 -0.02	98	87	0.29	12	AV8 +0.00	99	66	0.08	5	AV7 +0.20
97	100	0.46	16	AV6 +0.00			0.62	19	AV5 -0.03			0.13	7	AV3 +0.02
		0.51	17	AV5 -0.03			0.36	14	AV4 +0.00			0.06	4	AV2 +0.00
		0.16	8	AV4 -0.19			0.18	9	AV3 +0.02	99	68	0.21	10	AV4 -0.02
97	102	0.09	5	AV4 -0.03	98	89	0.18	9	AV6 -0.03			0.22	10	AV3 -0.05
		0.08	5	AV1 -0.09			0.34	13	AV5 +0.00			0.19	9	AV2 -0.05
		0.14	7	AV5 +0.00			0.36	14	AV4 +0.00	99	70	0.09	5	AV5 +0.14
97	104	0.52	17	AV7 -0.02			0.16	8	AV3 -0.02			0.08	5	AV4 +0.24
		0.44	16	AV3 +0.05	98	91	0.16	8	AV6 +0.00	99	72	0.11	6	AV7 +0.12

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.27	11	AV6 +0.00			0.05	4	AV4 +0.16			0.33	13	AV2 +0.00
		0.30	12	AV5 +0.21	99	124	0.10	6	AV3 +0.23	100	99	0.13	7	AV6 -0.22
		0.07	4	AV3 -0.19			0.06	4	AV1 +0.16			0.55	18	AV4 +0.03
99	74	0.30	12	AV3 +0.02	99	128	0.08	5	AV6 +0.11			0.24	10	AV3 +0.00
		0.38	14	AV4 +0.08	99	132	0.18	8	AV5 +0.07			0.16	8	AV2 -0.05
99	76	0.22	10	AV7 -0.05	100	31	0.12	6	AV5 -0.03	100	101	0.17	8	AV3 +0.00
		0.45	16	AV5 -0.03			0.10	6	AV2 +0.21			0.12	6	AV7 +0.00
		0.38	14	AV4 +0.00	100	45	0.08	5	AV5 +0.23			0.31	12	AV6 +0.05
		0.41	15	AV3 +0.00	100	47	0.08	5	AV4 +0.18			0.18	9	AV5 +0.02
99	78	0.49	17	AV7 +0.00	100	49	0.11	6	AV5 +0.23	100	103	0.25	11	AV6 +0.05
		0.45	16	AV6 +0.02			0.16	8	AV4 +0.03			0.41	15	AV5 +0.00
		0.30	12	AV5 +0.21	100	55	0.09	5	AV3 +0.05			0.44	16	AV4 +0.00
		0.10	6	AV4 -0.09	100	57	0.10	6	AV2 -0.11			0.58	18	AV3 +0.03
		0.19	9	AV3 -0.02			0.08	5	AV5 +0.35			0.34	13	AV2 +0.05
99	80	0.15	8	AV7 +0.00			0.08	5	AV4 +0.21	100	105	0.14	7	AV6 -0.07
		0.10	6	AV6 +0.19	100	59	0.11	6	AV5 -0.05			0.18	9	AV2 +0.02
		0.40	15	AV4 +0.03	100	63	0.54	18	AV7 +0.02	100	135	0.14	7	AV4 -0.02
		0.61	19	AV3 +0.02			0.10	5	AV4 +0.18	101	30	0.22	10	AV2 +0.02
		0.09	5	AV2 +0.07	100	65	0.30	12	AV7 +0.07			0.27	11	AV1 -0.18
99	82	0.24	10	AV7 -0.05			0.26	11	AV6 +0.00	101	46	0.06	4	AV5 +0.00
		0.26	11	AV6 -0.05			0.10	6	AV5 -0.13			0.21	9	AV6 +0.19
		0.62	19	AV4 -0.02			0.09	5	AV4 +0.03	101	48	0.07	4	AV5 +0.16
		0.11	6	AV2 -0.18			0.31	12	AV3 -0.02			0.12	6	AV4 -0.02
99	84	0.09	5	AV8 +0.07	100	67	0.16	8	AV3 -0.02	101	50	0.11	6	AV4 +0.03
		0.15	7	AV7 -0.02	100	71	0.28	12	AV8 -0.02			0.20	9	AV3 +0.00
		0.40	15	AV3 +0.00			0.22	10	AV6 +0.03	101	52	0.18	8	AV4 +0.03
		0.44	16	AV2 -0.02			0.15	7	AV5 +0.00	101	54	0.14	7	AV4 -0.02
		0.13	7	AV1 -0.07			0.12	6	AV4 +0.03			0.09	5	AV3 -0.02
99	86	0.16	8	AV8 +0.05			0.27	11	AV3 +0.00	101	56	0.13	7	AV4 -0.16
		0.29	12	AV5 +0.02			0.20	9	AV2 -0.02	101	58	0.08	5	AV5 +0.16
		0.11	6	AV1 +0.02	100	73	0.09	5	AV1 +0.07	101	60	0.16	8	AV4 -0.07
99	88	0.16	8	AV7 -0.07	100	75	0.15	8	AV3 -0.11	101	62	0.14	7	AV4 +0.00
		0.34	13	AV6 +0.00	100	77	0.25	11	AV4 +0.05	101	64	0.26	11	AV8 +0.02
		0.41	15	AV5 -0.03	100	79	0.51	17	AV7 -0.02			0.19	9	AV5 +0.00
		0.20	9	AV4 +0.00			0.42	15	AV6 +0.02			0.14	7	AV4 +0.00
		0.18	8	AV3 -0.02			0.18	8	AV5 -0.05			0.08	5	AV3 +0.16
		0.12	6	AV2 -0.02	100	81	0.09	5	AV6 -0.02	101	66	0.08	5	AV7 +0.17
99	90	0.07	4	AV8 -0.05			0.59	19	AV5 +0.00			0.45	16	AV6 +0.00
		0.18	9	AV7 +0.00			0.26	11	AV4 +0.00			0.62	19	AV5 +0.00
		0.24	11	AV6 -0.02			0.26	11	AV3 -0.02			0.52	17	AV4 +0.00
		0.14	7	AV5 +0.00			0.10	6	AV2 -0.05	101	70	0.10	6	AV6 +0.02
		0.13	7	AV4 -0.21	100	85	0.15	8	AV5 +0.02			0.15	7	AV5 +0.18
		0.13	7	AV3 -0.07			0.50	17	AV3 -0.02	101	72	0.15	7	AV5 +0.17
99	92	0.12	6	AV1 -0.02			0.30	12	AV2 +0.00			0.10	6	AV3 -0.05
99	94	0.11	6	AV7 +0.00			0.06	4	AV1 +0.32	101	74	0.30	12	AV6 +0.00
		0.11	6	AV6 +0.19	100	87	0.43	15	AV4 -0.02			0.35	13	AV4 +0.03
		0.21	10	AV4 +0.05			0.09	5	AV3 -0.09			0.13	7	AV2 +0.00
		0.30	12	AV3 +0.05			0.50	17	AV7 +0.00			0.10	5	AV1 +0.00
		0.25	11	AV2 +0.00	100	89	0.07	4	AV7 -0.21	101	76	0.19	9	AV3 +0.00
		0.06	4	AV1 +0.02			0.18	9	AV6 +0.00	101	78	0.15	7	AV5 +0.14
99	96	0.08	5	AV7 +0.00			0.42	15	AV5 +0.02	101	80	0.11	6	AV5 -0.05
		0.36	14	AV3 +0.02			0.35	13	AV4 +0.05			0.20	9	AV4 -0.02
		0.09	5	AV1 -0.23			0.17	8	AV3 -0.02			0.10	6	AV2 -0.21
99	98	0.29	12	AV4 +0.03	100	91	0.57	18	AV5 -0.03	101	86	0.62	19	AV6 -0.05
		0.08	5	AV2 -0.02			0.16	8	AV4 -0.02			0.18	8	AV3 -0.02
		0.06	4	AV1 +0.00			0.46	16	AV7 +0.02			0.36	14	AV2 -0.07
99	100	0.19	9	AV5 -0.03			0.44	16	AV6 +0.00	101	88	0.16	8	AV7 -0.05
		0.11	6	AV3 +0.00	100	93	0.17	8	AV6 +0.02			0.27	11	AV6 +0.02
99	102	0.38	14	AV5 -0.03			0.28	11	AV4 -0.02			0.16	8	AV5 -0.03
		0.41	15	AV4 -0.03			0.07	4	AV3 -0.05			0.09	5	AV4 -0.19
		0.14	7	AV3 -0.05			0.09	5	AV2 -0.05			0.16	8	AV3 -0.02
		0.20	9	AV2 -0.02	100	95	0.31	13	AV7 +0.02			0.09	5	AV2 -0.14
		0.18	8	AV1 -0.02			0.06	4	AV6 -0.19	101	90	0.43	15	AV8 +0.02
99	104	0.10	5	AV5 -0.25			0.14	7	AV5 +0.07			0.39	14	AV6 +0.02
		0.12	6	AV3 -0.05			0.11	6	AV4 +0.03			0.32	13	AV5 +0.05
		0.24	10	AV2 +0.14			0.10	5	AV3 -0.07			0.10	6	AV4 +0.03
99	108	0.11	6	AV5 +0.02			0.18	8	AV2 -0.14			0.15	8	AV3 -0.14
		0.24	10	AV4 +0.00	100	97	0.05	4	AV7 +0.00			0.15	7	AV2 -0.02
		0.53	17	AV3 +0.00			0.06	4	AV6 +0.21	101	92	0.18	9	AV7 -0.21
99	110	0.35	13	AV4 +0.03			0.05	4	AV5 -0.16			0.19	9	AV6 +0.00
99	116	0.11	6	AV4 +0.03			0.25	11	AV3 +0.00			0.60	19	AV5 -0.06
99	120	0.09	5	AV5 +0.23			0.06	4	AV4 -0.19			0.13	7	AV4 -0.19

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.22	10	AV3 -0.07			0.12	6	AV7 +0.02			0.59	19	AV7 -0.02
		0.16	8	AV2 -0.07	102	93	0.16	8	AV5 +0.00			0.19	9	AV6 -0.02
101	94	0.14	7	AV7 -0.02			0.29	12	AV4 +0.03			0.13	7	AV5 -0.05
		0.19	9	AV6 -0.03			0.15	7	AV2 +0.00			0.17	8	AV3 -0.25
		0.28	12	AV4 -0.07			0.09	5	AV1 -0.05			0.13	7	AV2 -0.09
		0.17	8	AV3 +0.00	102	95	0.17	8	AV2 -0.02	103	92	0.44	16	AV8 +0.05
		0.14	7	AV2 -0.05			0.09	5	AV8 +0.00			0.50	17	AV7 +0.02
101	96	0.13	7	AV7 +0.02			0.11	6	AV7 +0.00			0.45	16	AV6 +0.00
		0.11	6	AV5 +0.19			0.42	15	AV6 +0.00			0.44	16	AV3 +0.00
		0.17	8	AV4 +0.00			0.11	6	AV5 -0.03			0.63	19	AV2 +0.00
		0.45	16	AV3 +0.00			0.14	7	AV4 -0.02			0.10	6	AV1 +0.00
		0.28	12	AV2 +0.02			0.11	6	AV3 -0.02	103	94	0.17	8	AV5 +0.00
101	98	0.19	9	AV8 -0.02	102	97	0.48	16	AV3 -0.02			0.46	16	AV4 +0.00
		0.26	11	AV6 +0.02			0.40	15	AV2 +0.00			0.44	16	AV3 +0.02
		0.33	13	AV5 +0.00			0.25	11	AV1 -0.02			0.10	5	AV2 -0.02
		0.59	19	AV2 +0.00			0.50	17	AV8 -0.02	103	96	0.14	7	AV7 +0.05
		0.23	10	AV1 +0.00	102	99	0.16	8	AV4 -0.02			0.06	4	AV6 +0.56
101	100	0.25	11	AV4 -0.02	102	109	0.14	7	AV5 +0.02			0.08	5	AV5 +0.16
		0.14	7	AV2 -0.05			0.42	15	AV3 +0.00			0.46	16	AV4 -0.02
101	104	0.21	10	AV6 +0.00			0.33	13	AV2 -0.02			0.28	12	AV3 +0.00
		0.21	9	AV3 +0.00	102	113	0.09	5	AV5 +0.15	103	98	0.22	10	AV7 +0.00
101	106	0.10	6	AV2 -0.05	102	115	0.14	7	AV4 +0.03			0.24	10	AV5 -0.05
101	110	0.14	7	AV5 +0.00	102	119	0.10	5	AV5 +0.00			0.11	6	AV4 +0.00
101	112	0.29	12	AV3 +0.00			0.12	6	AV4 -0.02			0.09	5	AV2 -0.18
		0.10	6	AV2 -0.21	103	44	0.11	6	AV5 +0.19	103	100	0.15	8	AV7 +0.02
101	118	0.12	6	AV4 -0.02	103	48	0.10	6	AV5 -0.10			0.18	9	AV6 -0.02
101	140	0.14	7	AV7 +0.02	103	52	0.08	5	AV3 +0.07			0.18	9	AV5 -0.03
		0.12	6	AV6 +0.03	103	54	0.05	4	AV3 +0.29	103	104	0.08	5	AV4 -0.17
		0.07	5	AV2 -0.18	103	56	0.11	6	AV6 -0.09			0.10	6	AV4 +0.00
102	31	0.10	6	AV6 -0.19			0.13	7	AV5 -0.13	103	110	0.11	6	AV5 -0.03
		0.08	5	AV3 +0.17			0.15	7	AV4 -0.14	103	120	0.15	7	AV4 +0.00
		0.10	6	AV2 +0.14			0.11	6	AV6 -0.12	103	124	0.16	8	AV5 +0.00
102	47	0.28	11	AV6 +0.00	103	58	0.11	6	AV6 -0.12	103	126	0.11	6	AV4 +0.00
		0.08	5	AV5 -0.03	103	60	0.12	6	AV4 -0.21	104	45	0.08	5	AV6 -0.12
		0.19	9	AV4 -0.02	103	64	0.08	5	AV4 +0.16	104	49	0.09	5	AV3 +0.00
102	51	0.10	6	AV4 -0.05	103	66	0.13	7	AV6 -0.09	104	55	0.06	4	AV5 -0.08
102	65	0.21	10	AV4 +0.05			0.11	6	AV4 +0.00			0.10	6	AV4 +0.00
		0.17	8	AV2 -0.02			0.07	4	AV2 +0.14	104	59	0.08	5	AV4 +0.08
102	71	0.29	12	AV6 +0.00	103	70	0.10	6	AV5 -0.16	104	61	0.07	4	AV4 +0.03
102	73	0.36	14	AV5 -0.03	103	72	0.13	7	AV6 +0.12			0.17	8	AV3 -0.16
102	75	0.41	15	AV8 +0.02			0.10	6	AV5 +0.21	104	63	0.12	6	AV6 -0.19
		0.25	11	AV3 -0.02			0.11	6	AV4 -0.05			0.12	6	AV5 -0.03
		0.13	7	AV2 +0.00	103	74	0.16	8	AV7 +0.02			0.09	5	AV4 -0.02
		0.07	5	AV1 -0.02			0.23	10	AV6 +0.02	104	71	0.07	4	AV7 +0.50
102	77	0.32	13	AV5 -0.03			0.18	8	AV5 -0.03			0.09	5	AV3 -0.05
		0.17	8	AV4 -0.07			0.09	5	AV4 +0.16	104	73	0.08	5	AV4 +0.18
		0.38	14	AV7 -0.03			0.13	7	AV3 +0.14			0.11	6	AV3 +0.00
		0.25	11	AV6 +0.00	103	76	0.41	15	AV6 +0.00			0.09	5	AV2 -0.21
102	79	0.12	6	AV6 +0.00			0.20	9	AV5 +0.00	104	77	0.31	12	AV7 -0.02
		0.24	10	AV4 +0.00			0.15	7	AV4 -0.02			0.19	9	AV6 +0.14
		0.12	6	AV3 -0.21			0.11	6	AV3 -0.05			0.10	6	AV5 -0.16
102	81	0.48	17	AV7 +0.00	103	78	0.13	7	AV5 +0.14			0.14	7	AV4 -0.05
		0.63	19	AV4 +0.03	103	80	0.10	6	AV5 +0.05			0.11	6	AV3 +0.00
		0.15	8	AV2 +0.00			0.11	6	AV1 +0.05	104	79	0.07	4	AV3 +0.23
102	83	0.10	6	AV8 -0.02	103	82	0.10	6	AV5 +0.26			0.08	5	AV2 +0.00
		0.23	10	AV3 -0.05			0.08	5	AV3 -0.14	104	81	0.17	8	AV7 -0.07
		0.10	6	AV2 -0.02	103	84	0.14	7	AV8 +0.05			0.24	10	AV6 +0.00
102	85	0.11	6	AV8 -0.02			0.60	19	AV6 +0.02			0.28	12	AV5 -0.03
		0.41	15	AV5 +0.02			0.55	18	AV4 +0.00			0.10	6	AV4 -0.16
		0.56	18	AV4 +0.03			0.42	15	AV2 -0.02			0.37	14	AV3 -0.02
		0.63	19	AV2 +0.00			0.06	4	AV1 +0.00	104	83	0.43	15	AV8 +0.00
		0.39	14	AV1 -0.02	103	86	0.27	11	AV7 -0.02			0.18	9	AV7 -0.21
102	87	0.08	5	AV8 +0.14			0.50	17	AV6 +0.02			0.11	6	AV3 -0.05
		0.48	16	AV4 +0.00			0.19	9	AV3 +0.00	104	87	0.10	6	AV7 +0.00
		0.21	9	AV3 -0.02			0.45	16	AV2 -0.05			0.24	10	AV6 +0.14
		0.58	19	AV2 -0.02	103	88	0.20	9	AV5 -0.05			0.37	14	AV4 +0.00
		0.16	8	AV1 -0.05			0.09	5	AV4 -0.16			0.15	7	AV3 -0.20
102	89	0.52	17	AV7 +0.00			0.23	10	AV3 -0.05			0.13	7	AV2 -0.07
		0.18	9	AV1 -0.05			0.40	15	AV8 +0.02			0.11	6	AV1 -0.21
102	91	0.20	9	AV4 -0.05			0.41	15	AV7 -0.05	104	89	0.18	9	AV7 +0.02
		0.39	14	AV3 -0.07			0.48	16	AV6 +0.00			0.09	5	AV6 +0.02
		0.32	13	AV2 +0.00	103	90	0.09	5	AV8 -0.02			0.15	7	AV5 +0.14

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.13	7	AV4 -0.21			0.15	7	AV4 -0.02			0.28	11	AV1 +0.00
		0.18	8	AV3 -0.18			0.13	7	AV3 -0.07	106	87	0.13	7	AV8 +0.02
104	91	0.10	6	AV8 +0.02			0.09	5	AV2 -0.05			0.10	6	AV7 -0.21
		0.28	12	AV6 +0.02	105	92	0.13	7	AV7 +0.00			0.50	17	AV6 +0.12
		0.35	14	AV2 +0.02			0.19	9	AV6 +0.02			0.21	9	AV5 -0.06
		0.10	6	AV1 +0.46			0.24	10	AV3 +0.00			0.13	7	AV4 +0.00
104	93	0.14	7	AV3 +0.00			0.11	6	AV2 +0.16			0.54	18	AV2 -0.02
104	95	0.10	6	AV7 +0.17			0.09	5	AV1 +0.00			0.20	9	AV1 -0.02
		0.07	4	AV6 -0.14	105	94	0.07	4	AV7 +0.02	106	89	0.13	7	AV2 -0.05
		0.26	11	AV5 +0.02			0.15	8	AV6 +0.00			0.26	11	AV7 -0.05
		0.10	5	AV4 -0.16			0.09	5	AV5 -0.03			0.15	8	AV6 -0.02
		0.17	8	AV3 +0.00			0.21	9	AV4 -0.02			0.15	7	AV5 +0.15
		0.33	13	AV2 -0.02			0.16	8	AV3 -0.02			0.14	7	AV4 -0.19
104	97	0.14	7	AV1 +0.00			0.11	6	AV2 -0.18			0.16	8	AV3 -0.05
		0.15	7	AV6 -0.02	105	96	0.14	7	AV6 +0.00	106	91	0.21	9	AV7 +0.02
		0.52	17	AV5 -0.03			0.14	7	AV4 +0.00			0.29	12	AV6 +0.00
		0.33	13	AV3 -0.05			0.28	11	AV3 +0.00			0.34	13	AV4 -0.05
104	99	0.18	8	AV2 -0.02			0.39	14	AV2 +0.00			0.12	6	AV3 -0.07
		0.09	5	AV1 -0.05			0.18	9	AV1 -0.02	106	93	0.24	10	AV6 +0.00
		0.11	6	AV7 -0.02	105	98	0.14	7	AV2 -0.02			0.35	13	AV5 +0.02
		0.10	6	AV6 +0.00			0.06	4	AV1 +0.11			0.37	14	AV4 +0.00
		0.09	5	AV5 +0.02			0.12	6	AV7 -0.02			0.20	9	AV3 +0.02
		0.06	4	AV4 +0.03			0.23	10	AV5 +0.00			0.38	14	AV2 +0.00
		0.50	17	AV3 +0.02			0.21	9	AV4 +0.03			0.12	6	AV1 -0.05
		0.18	8	AV2 +0.00			0.42	15	AV3 +0.05	106	95	0.17	8	AV6 -0.02
104	105	0.15	8	AV4 +0.00	105	100	0.15	7	AV7 +0.16			0.37	14	AV5 -0.03
104	107	0.19	9	AV4 +0.00			0.15	7	AV6 +0.00			0.46	16	AV4 -0.02
104	109	0.08	5	AV4 -0.14			0.21	10	AV4 +0.03			0.22	10	AV3 -0.02
104	121	0.12	7	AV4 -0.16	105	112	0.10	6	AV5 +0.02			0.22	10	AV2 -0.05
104	127	0.09	5	AV5 +0.05			0.28	12	AV3 -0.02			0.15	7	AV7 +0.00
104	133	0.13	7	AV7 +0.02	106	33	0.05	4	AV7 +0.26	106	97	0.12	6	AV7 +0.00
105	38	0.10	6	AV6 +0.00			0.23	10	AV6 +0.00			0.06	4	AV6 +0.19
105	54	0.25	11	AV5 +0.02	106	41	0.18	8	AV6 +0.02			0.31	12	AV5 +0.00
		0.13	7	AV4 +0.05	106	43	0.14	7	AV5 -0.03			0.51	17	AV4 +0.08
		0.17	8	AV3 +0.00	106	53	0.10	6	AV5 +0.21			0.27	11	AV1 -0.02
105	58	0.08	5	AV4 -0.14			0.10	6	AV4 +0.21	106	99	0.08	5	AV4 -0.05
		0.13	7	AV3 +0.00			0.08	5	AV3 +0.00			0.10	6	AV3 -0.02
105	64	0.12	6	AV5 +0.14			0.22	10	AV2 +0.02			0.10	6	AV2 +0.11
105	70	0.18	8	AV6 +0.00			0.08	5	AV1 +0.11	106	101	0.13	7	AV5 +0.17
105	72	0.52	17	AV2 +0.00	106	55	0.06	4	AV5 +0.21	106	103	0.10	6	AV6 +0.07
		0.11	6	AV1 -0.02			0.15	8	AV4 +0.00			0.10	5	AV5 +0.15
		0.18	8	AV6 +0.05	106	57	0.17	8	AV4 +0.00			0.14	7	AV4 -0.02
		0.26	11	AV5 +0.02	106	59	0.14	7	AV5 +0.05	106	111	0.13	7	AV5 +0.00
105	74	0.24	10	AV7 +0.02	106	61	0.12	6	AV5 -0.24	106	119	0.14	7	AV7 +0.02
		0.46	16	AV6 +0.02			0.08	5	AV4 +0.03			0.11	6	AV4 -0.02
		0.13	7	AV4 +0.00			0.08	5	AV3 +0.21	106	129	0.09	5	AV3 -0.02
		0.23	10	AV3 +0.02	106	63	0.06	4	AV5 +0.00	107	34	0.21	9	AV8 +0.00
105	76	0.09	5	AV4 +0.13			0.09	5	AV3 +0.05			0.06	4	AV7 -0.19
105	78	0.32	13	AV5 +0.02	106	65	0.12	6	AV6 -0.03			0.10	5	AV6 -0.19
		0.15	7	AV4 +0.03	106	67	0.10	6	AV4 +0.00			0.18	9	AV2 +0.14
		0.16	8	AV3 -0.05			0.08	5	AV3 +0.09			0.14	7	AV1 +0.07
		0.24	10	AV2 +0.00	106	71	0.09	5	AV5 -0.21	107	46	0.27	11	AV6 +0.02
105	80	0.17	8	AV6 +0.02			0.15	7	AV4 +0.00			0.09	5	AV3 +0.41
		0.09	5	AV5 +0.14			0.10	5	AV3 -0.18	107	50	0.08	5	AV7 -0.12
		0.09	5	AV2 +0.00	106	73	0.16	8	AV6 +0.00	107	56	0.12	6	AV5 -0.10
105	82	0.12	6	AV7 +0.02			0.12	6	AV5 -0.03			0.09	5	AV4 +0.03
		0.24	11	AV6 -0.03			0.14	7	AV4 -0.02			0.07	4	AV3 -0.30
		0.22	10	AV5 -0.03			0.13	7	AV3 -0.07	107	60	0.06	4	AV5 +0.30
		0.25	11	AV4 -0.02	106	75	0.09	5	AV4 +0.00			0.12	6	AV4 -0.19
		0.51	17	AV3 -0.02			0.28	12	AV3 +0.00			0.10	6	AV2 +0.12
105	86	0.25	11	AV3 -0.02			0.17	8	AV2 -0.02	107	62	0.07	4	AV3 +0.14
		0.42	15	AV2 -0.05	106	77	0.12	6	AV5 -0.03	107	64	0.09	5	AV6 -0.12
		0.29	12	AV8 +0.00			0.14	7	AV3 -0.05			0.09	5	AV2 +0.07
105	88	0.12	6	AV5 +0.00	106	81	0.44	16	AV7 -0.02			0.08	5	AV5 +0.21
		0.13	7	AV4 +0.03			0.33	13	AV6 -0.02	107	66	0.08	5	AV5 -0.11
		0.37	14	AV3 -0.05			0.33	13	AV5 -0.03	107	68	0.09	5	AV4 +0.13
		0.27	11	AV2 -0.02			0.49	17	AV4 +0.00			0.11	6	AV3 -0.21
		0.19	9	AV1 -0.02			0.17	8	AV3 -0.02			0.10	6	AV2 +0.14
105	90	0.12	6	AV8 -0.02	106	83	0.44	16	AV5 -0.03	107	70	0.11	6	AV8 -0.05
		0.63	19	AV7 -0.02			0.16	8	AV2 -0.02			0.19	9	AV6 +0.00
		0.17	8	AV6 +0.02			0.15	8	AV1 -0.02			0.14	7	AV5 +0.16
		0.44	16	AV5 -0.03	106	85	0.19	9	AV4 +0.03			0.10	6	AV4 +0.26

SL2-26 - 09/21  
Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
107	72	0.09	5	AV7 -0.27			0.12	6	AV6 +0.00	109	62	0.18	9	AV5 +0.00
		0.10	6	AV2 +0.05	108	67	0.09	5	AV7 -0.15			0.14	7	AV4 -0.02
107	74	0.10	6	AV3 +0.14			0.15	7	AV6 +0.00	109	64	0.14	7	AV7 +0.05
107	76	0.10	6	AV5 +0.14			0.11	6	AV3 +0.02			0.13	7	AV6 +0.00
		0.50	17	AV4 -0.02	108	71	0.22	10	AV5 +0.00			0.10	6	AV5 +0.12
		0.37	14	AV3 -0.02			0.08	5	AV4 +0.03	109	66	0.16	8	AV7 +0.05
		0.14	7	AV2 -0.02			0.24	10	AV6 +0.00			0.33	13	AV6 +0.02
107	78	0.62	19	AV7 +0.00	108	73	0.10	5	AV6 +0.28			0.21	9	AV5 +0.02
		0.24	10	AV5 +0.02			0.08	5	AV2 +0.07			0.29	12	AV4 +0.05
		0.08	5	AV4 +0.03			0.09	5	AV5 -0.22			0.10	6	AV3 +0.00
		0.12	6	AV3 -0.21	108	75	0.10	6	AV4 +0.10			0.28	12	AV2 +0.00
		0.05	4	AV1 -0.05			0.18	9	AV3 -0.23	109	68	0.27	11	AV7 +0.02
107	80	0.25	11	AV7 -0.02	108	77	0.10	5	AV6 +0.00			0.13	7	AV5 +0.12
		0.13	7	AV6 +0.02			0.09	5	AV5 -0.23			0.27	11	AV4 -0.02
		0.13	7	AV4 -0.19			0.10	6	AV3 -0.21			0.07	4	AV2 +0.39
107	82	0.14	7	AV7 +0.02			0.14	7	AV2 -0.16	109	70	0.09	5	AV7 +0.47
		0.15	7	AV6 +0.00	108	79	0.07	4	AV6 +0.23			0.12	6	AV4 -0.05
		0.49	17	AV5 -0.03			0.10	6	AV5 +0.00			0.12	6	AV3 -0.05
		0.50	17	AV4 -0.02			0.11	6	AV4 +0.13	109	72	0.33	13	AV4 -0.07
		0.37	14	AV3 -0.05	108	81	0.11	6	AV7 +0.05			0.11	6	AV3 -0.02
		0.12	6	AV2 -0.21			0.09	5	AV2 +0.25	109	74	0.09	5	AV7 +0.00
107	84	0.42	15	AV3 -0.02	108	83	0.29	12	AV8 +0.02			0.14	7	AV3 -0.02
		0.10	6	AV2 -0.02			0.61	19	AV4 -0.02	109	76	0.09	5	AV7 +0.12
107	88	0.17	8	AV7 -0.02			0.63	19	AV3 -0.02			0.05	4	AV6 +0.24
		0.16	8	AV6 +0.02			0.28	12	AV2 -0.02			0.14	7	AV4 -0.05
		0.44	16	AV5 +0.00			0.16	8	AV1 -0.02	109	78	0.15	7	AV5 +0.14
		0.46	16	AV4 +0.03	108	87	0.28	11	AV4 -0.02	109	80	0.15	8	AV3 -0.02
		0.26	11	AV3 -0.02			0.58	18	AV5 -0.03			0.10	6	AV2 -0.05
		0.11	6	AV2 -0.02			0.08	5	AV7 +0.05	109	82	0.11	6	AV7 +0.14
		0.08	5	AV1 -0.02			0.40	15	AV6 +0.12			0.46	16	AV5 +0.00
107	90	0.11	6	AV7 +0.09	108	89	0.12	6	AV7 +0.02			0.34	13	AV4 +0.16
		0.10	6	AV6 +0.05			0.30	12	AV6 -0.02			0.16	8	AV3 -0.21
		0.14	7	AV5 +0.05			0.31	13	AV5 -0.03	109	84	0.22	10	AV8 +0.07
		0.15	7	AV4 +0.05			0.10	6	AV4 -0.21			0.36	14	AV6 +0.03
		0.13	7	AV3 -0.07			0.11	6	AV3 -0.02			0.51	17	AV3 -0.05
		0.15	7	AV2 +0.02			0.10	5	AV2 -0.11			0.27	11	AV2 -0.02
107	92	0.46	16	AV7 +0.02	108	91	0.10	6	AV7 +0.14			0.33	13	AV1 +0.00
		0.11	6	AV6 +0.07			0.57	18	AV3 +0.02	109	86	0.20	9	AV8 +0.02
		0.11	6	AV1 -0.07			0.51	17	AV2 +0.00			0.35	13	AV3 -0.02
107	94	0.52	17	AV6 +0.00	108	93	0.18	8	AV1 -0.05			0.27	11	AV2 -0.05
		0.27	11	AV4 +0.00			0.47	16	AV2 +0.00	109	88	0.11	6	AV6 +0.00
		0.16	8	AV3 +0.05			0.40	15	AV3 +0.02			0.22	10	AV4 -0.07
		0.35	14	AV2 -0.02			0.08	5	AV7 +0.19			0.20	9	AV3 +0.00
		0.08	5	AV1 -0.02			0.34	13	AV4 +0.05			0.16	8	AV2 -0.02
107	96	0.47	16	AV4 +0.00	108	95	0.36	14	AV5 +0.02			0.07	4	AV1 -0.05
		0.60	19	AV3 -0.02			0.53	18	AV4 +0.05	109	90	0.10	6	AV8 +0.05
107	98	0.04	3	AV7 +0.21			0.62	19	AV2 +0.00			0.20	9	AV6 +0.00
		0.14	7	AV6 +0.05			0.12	6	AV1 +0.02			0.13	7	AV5 +0.17
		0.18	9	AV4 -0.05	108	97	0.06	4	AV8 -0.41			0.10	6	AV4 +0.00
		0.11	6	AV3 -0.18			0.20	9	AV7 +0.00			0.26	11	AV3 -0.07
		0.18	8	AV2 -0.02			0.24	10	AV6 -0.02	109	92	0.20	9	AV7 -0.19
		0.06	4	AV1 +0.32			0.24	10	AV5 -0.03			0.09	5	AV6 +0.19
107	100	0.18	8	AV7 +0.05			0.25	11	AV4 -0.05			0.13	7	AV5 -0.03
		0.07	5	AV6 +0.14	108	99	0.20	9	AV8 +0.02			0.36	14	AV4 +0.00
		0.21	10	AV5 -0.03			0.46	16	AV3 +0.00			0.22	10	AV3 +0.00
		0.30	12	AV4 -0.02	108	101	0.16	8	AV6 +0.02			0.13	7	AV2 -0.02
		0.11	6	AV2 -0.02			0.33	13	AV5 -0.03	109	94	0.11	6	AV6 -0.02
107	104	0.11	6	AV4 -0.02			0.25	11	AV3 -0.05			0.42	15	AV5 +0.02
107	108	0.09	5	AV5 -0.03	108	105	0.23	10	AV5 +0.00			0.30	12	AV4 -0.02
107	112	0.13	7	AV5 -0.03	108	107	0.14	7	AV5 +0.02			0.21	9	AV3 -0.02
107	128	0.09	5	AV5 +0.02	108	115	0.11	6	AV4 +0.00			0.27	11	AV2 +0.00
		0.10	6	AV4 +0.03			0.08	5	AV3 -0.18			0.08	5	AV1 -0.02
108	35	0.10	6	AV2 +0.14	108	117	0.12	6	AV5 +0.05	109	96	0.29	12	AV4 -0.02
108	45	0.09	5	AV3 +0.14			0.18	8	AV4 +0.00			0.13	7	AV3 -0.02
108	49	0.45	16	AV6 +0.05	108	123	0.09	5	AV8 +0.05	109	98	0.18	9	AV6 +0.21
		0.15	8	AV5 +0.05	108	125	0.22	10	AV5 +0.02			0.15	8	AV5 +0.05
		0.07	5	AV4 -0.12			0.27	11	AV4 +0.05			0.09	5	AV1 +0.00
108	61	0.09	5	AV5 -0.18			0.09	5	AV3 +0.00	109	100	0.15	7	AV7 +0.02
		0.09	5	AV3 -0.21	108	137	0.12	6	AV5 +0.15			0.25	11	AV5 +0.05
108	65	0.11	6	AV5 -0.13	109	48	0.08	5	AV6 -0.03			0.32	13	AV4 +0.05
		0.10	6	AV4 -0.16			0.13	7	AV5 -0.05			0.46	16	AV3 +0.05
		0.09	5	AV3 +0.07	109	54	0.09	5	AV5 +0.02			0.34	13	AV2 +0.02

SL2-26 - 09/21

Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.07	4	AV1 +0.12			0.40	15	AV5 +0.00			0.40	15	AV8 +0.00
109	102	0.11	6	AV4 -0.19			0.25	11	AV4 +0.00	111	102	0.53	17	AV4 -0.02
		0.10	6	AV3 -0.09			0.14	7	AV3 -0.04			0.58	18	AV2 -0.02
		0.10	6	AV2 -0.02			0.08	5	AV2 -0.32	111	128	0.10	6	AV5 -0.23
109	104	0.11	6	AV5 -0.03	110	101	0.35	13	AV4 -0.02			0.18	9	AV4 +0.00
109	106	0.06	4	AV5 +0.19			0.41	15	AV3 -0.02	112	63	0.18	9	AV8 +0.07
		0.10	6	AV2 -0.19			0.28	12	AV2 +0.00			0.42	15	AV7 +0.02
109	112	0.13	7	AV2 +0.02			0.13	7	AV1 -0.02			0.13	7	AV6 +0.00
109	114	0.19	9	AV7 +0.07			0.42	15	AV7 +0.00			0.16	8	AV5 -0.03
		0.17	8	AV6 +0.05	110	103	0.19	9	AV6 +0.07	112	69	0.17	8	AV4 -0.02
		0.13	7	AV5 +0.12			0.19	9	AV4 +0.00			0.22	10	AV3 -0.05
		0.23	10	AV3 +0.05			0.29	12	AV3 -0.02			0.34	13	AV2 -0.02
109	130	0.12	6	AV6 +0.02			0.14	7	AV2 -0.02			0.22	10	AV1 -0.05
109	136	0.09	5	AV7 -0.17	110	107	0.12	6	AV4 -0.02	112	71	0.12	6	AV6 +0.00
110	51	0.23	10	AV5 +0.34	110	127	0.13	7	AV7 -0.16			0.22	10	AV4 +0.00
110	53	0.18	8	AV5 +0.07			0.13	7	AV4 +0.00			0.19	9	AV3 -0.02
		0.12	6	AV4 +0.18	110	129	0.18	8	AV5 +0.00			0.14	7	AV2 -0.21
		0.08	5	AV3 +0.17	111	50	0.16	8	AV6 +0.36	112	73	0.46	16	AV6 -0.02
110	59	0.12	6	AV5 +0.05	111	72	0.10	6	AV6 -0.14			0.30	12	AV4 +0.00
		0.10	6	AV4 +0.05			0.09	5	AV4 -0.02			0.47	16	AV3 +0.00
		0.08	5	AV3 +0.00	111	74	0.08	5	AV6 +0.07			0.13	7	AV2 +0.00
110	67	0.12	6	AV3 +0.14			0.14	7	AV3 +0.00			0.30	12	AV1 -0.02
110	69	0.18	9	AV5 -0.05	111	76	0.14	7	AV3 -0.18			0.11	6	AV8 +0.02
		0.17	8	AV4 -0.02			0.18	8	AV2 -0.07			0.59	19	AV7 +0.02
110	71	0.07	5	AV6 +0.20			0.18	9	AV4 -0.02	112	81	0.08	5	AV4 -0.38
		0.10	6	AV4 +0.00	111	78	0.11	6	AV5 -0.05	112	87	0.11	6	AV7 +0.02
		0.10	5	AV3 +0.09			0.29	12	AV4 +0.00			0.16	8	AV6 +0.16
110	73	0.13	7	AV4 -0.14			0.09	5	AV3 +0.07			0.36	14	AV5 +0.00
		0.13	7	AV3 -0.21	111	80	0.09	5	AV7 +0.00			0.18	9	AV3 -0.02
110	75	0.20	9	AV5 +0.00	111	82	0.17	8	AV5 +0.00	112	89	0.20	9	AV6 +0.00
		0.18	9	AV3 -0.14			0.08	5	AV3 +0.21			0.11	6	AV5 +0.14
110	77	0.09	5	AV7 +0.00	111	84	0.47	16	AV7 +0.00			0.12	6	AV4 -0.19
		0.10	6	AV6 +0.18			0.41	15	AV6 +0.02			0.10	6	AV3 -0.02
		0.29	12	AV5 +0.00			0.07	4	AV2 +0.14			0.17	8	AV2 -0.11
		0.22	10	AV4 -0.05	111	86	0.55	18	AV8 +0.00			0.14	7	AV7 +0.02
		0.28	11	AV3 -0.02			0.16	8	AV5 -0.03	112	91	0.17	8	AV7 -0.12
		0.12	7	AV2 +0.00			0.25	11	AV3 -0.02			0.16	8	AV5 -0.03
110	79	0.20	9	AV4 -0.02			0.21	10	AV2 -0.07			0.51	17	AV4 -0.02
		0.11	6	AV3 -0.18	111	88	0.20	9	AV6 +0.02			0.27	11	AV3 -0.02
		0.10	6	AV2 -0.21			0.19	9	AV5 -0.03			0.11	6	AV2 -0.05
110	81	0.14	7	AV4 +0.00			0.31	12	AV4 +0.00			0.08	5	AV1 -0.02
110	83	0.41	15	AV6 -0.02			0.23	10	AV3 -0.07	112	93	0.09	5	AV5 +0.05
		0.10	5	AV3 -0.02			0.12	6	AV2 -0.25			0.07	4	AV4 +0.05
110	85	0.40	15	AV6 -0.03	111	90	0.15	7	AV6 +0.00			0.21	10	AV2 -0.02
		0.37	14	AV2 -0.02			0.36	14	AV5 -0.03			0.06	4	AV1 +0.07
110	87	0.28	12	AV8 +0.00			0.20	9	AV3 -0.07	112	95	0.08	5	AV7 +0.14
		0.48	17	AV7 -0.02	111	92	0.11	6	AV7 +0.19			0.08	5	AV6 -0.28
		0.16	8	AV5 -0.03			0.09	5	AV6 +0.31			0.09	5	AV5 +0.12
		0.41	15	AV4 -0.02			0.10	6	AV5 +0.14			0.13	7	AV4 -0.07
		0.08	5	AV2 +0.28			0.09	5	AV4 -0.16			0.50	17	AV3 -0.02
110	89	0.27	11	AV7 +0.00			0.17	8	AV3 -0.02			0.12	6	AV2 -0.21
		0.53	18	AV5 +0.02			0.27	11	AV2 +0.00	112	97	0.12	6	AV6 +0.02
		0.12	6	AV4 -0.16			0.07	5	AV1 -0.12			0.25	11	AV5 -0.03
		0.08	5	AV2 -0.02	111	94	0.11	6	AV6 +0.02			0.35	14	AV4 +0.00
110	91	0.13	7	AV8 +0.00			0.16	8	AV4 +0.00			0.41	15	AV3 +0.11
		0.32	13	AV7 +0.00			0.24	10	AV3 -0.02			0.07	4	AV2 +0.11
		0.25	11	AV6 +0.00			0.11	6	AV2 -0.02	112	99	0.15	7	AV6 -0.03
		0.44	16	AV5 +0.00	111	96	0.10	5	AV7 -0.17			0.21	10	AV5 +0.00
		0.17	8	AV4 +0.00			0.54	18	AV4 -0.02			0.41	15	AV4 -0.02
		0.14	7	AV3 -0.05			0.25	11	AV3 -0.05			0.49	17	AV3 -0.05
110	93	0.22	10	AV7 +0.02			0.20	9	AV2 -0.05			0.13	7	AV2 -0.05
		0.09	5	AV5 -0.03			0.20	9	AV1 -0.02	112	101	0.14	7	AV7 +0.00
		0.32	13	AV4 +0.00	111	98	0.33	13	AV8 +0.02			0.41	15	AV4 +0.00
		0.19	9	AV2 +0.00			0.37	14	AV7 +0.02			0.39	14	AV3 +0.00
110	95	0.21	10	AV2 -0.02			0.25	11	AV6 +0.02			0.13	7	AV2 -0.02
		0.08	5	AV6 -0.05			0.23	10	AV5 +0.00	112	103	0.46	16	AV7 -0.02
		0.19	9	AV5 -0.03			0.50	17	AV4 +0.00			0.25	11	AV6 +0.02
		0.28	11	AV3 -0.05			0.27	11	AV3 +0.02			0.10	6	AV5 +0.00
110	97	0.07	5	AV7 +0.14			0.21	9	AV2 +0.00			0.09	5	AV3 -0.02
		0.12	6	AV5 +0.00			0.04	3	AV1 -0.14	112	105	0.10	6	AV4 -0.10
		0.09	5	AV4 -0.21	111	100	0.12	6	AV3 +0.00	112	119	0.09	5	AV6 +0.00
		0.49	17	AV3 -0.02			0.10	6	AV2 -0.05			0.18	8	AV4 +0.03

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
112	121	0.19	9	AV4 +0.00	114	79	0.12	6	AV6 +0.02			0.52	17	AV5 -0.03
113	42	0.10	6	AV6 +0.03	114	81	0.08	5	AV7 +0.00			0.46	16	AV3 +0.02
		0.14	7	AV4 +0.55			0.07	4	AV6 +0.02			0.37	14	AV2 +0.00
		0.19	9	AV3 +0.07			0.14	7	AV4 -0.07			0.58	18	AV1 +0.00
113	48	0.13	7	AV6 +0.15	114	83	0.31	12	AV7 -0.03	115	88	0.17	8	AV8 +0.05
		0.18	9	AV5 -0.05			0.48	17	AV4 -0.02			0.38	14	AV7 +0.02
		0.15	7	AV4 +0.03			0.22	10	AV3 -0.05			0.32	13	AV6 +0.02
113	56	0.15	7	AV5 +0.00			0.09	5	AV2 -0.02			0.14	7	AV3 -0.05
113	66	0.10	5	AV6 +0.03	114	87	0.41	15	AV7 +0.02			0.09	5	AV2 +0.16
		0.27	11	AV5 +0.02			0.60	19	AV6 +0.00	115	90	0.16	8	AV7 +0.02
		0.16	8	AV4 +0.03			0.50	17	AV2 +0.00			0.46	16	AV6 +0.00
113	72	0.10	5	AV5 +0.12			0.24	10	AV1 -0.02			0.42	15	AV5 +0.00
113	74	0.17	8	AV6 +0.00	114	89	0.09	5	AV8 +0.05			0.19	9	AV3 -0.20
113	80	0.09	5	AV6 +0.09			0.16	8	AV4 -0.21			0.09	5	AV2 -0.16
		0.10	5	AV3 -0.23			0.42	15	AV3 -0.02	115	92	0.14	7	AV7 +0.19
113	82	0.12	6	AV3 -0.07			0.39	14	AV2 +0.00			0.10	6	AV6 +0.00
113	88	0.36	14	AV6 +0.03			0.18	8	AV1 -0.02			0.19	9	AV5 +0.02
		0.37	14	AV4 -0.02	114	91	0.19	9	AV7 +0.09			0.15	7	AV2 -0.02
		0.18	9	AV3 -0.02			0.25	11	AV6 +0.00	115	94	0.15	7	AV7 +0.05
		0.14	7	AV2 -0.14			0.17	8	AV5 +0.00			0.26	11	AV6 +0.00
113	90	0.14	7	AV8 +0.02			0.47	16	AV4 -0.05			0.17	8	AV3 -0.05
		0.48	17	AV7 -0.02			0.37	14	AV3 -0.05	115	96	0.56	18	AV7 +0.05
		0.36	14	AV6 -0.02			0.09	5	AV2 -0.18			0.36	14	AV2 +0.00
		0.37	14	AV5 -0.03	114	93	0.08	5	AV4 -0.02	115	100	0.21	9	AV5 +0.12
		0.08	5	AV4 -0.05			0.19	9	AV3 -0.07			0.12	6	AV2 -0.21
		0.16	8	AV3 -0.07			0.10	6	AV2 -0.05	115	102	0.27	11	AV5 -0.03
113	92	0.11	6	AV7 +0.16	114	95	0.37	14	AV5 +0.00			0.39	15	AV4 -0.02
		0.09	5	AV6 +0.00			0.33	13	AV4 -0.02			0.27	11	AV3 +0.00
		0.10	6	AV5 -0.03			0.33	13	AV3 -0.05			0.28	12	AV2 +0.00
		0.08	5	AV4 -0.16			0.11	6	AV2 -0.16	115	104	0.12	6	AV5 -0.03
		0.11	6	AV3 -0.18	114	97	0.05	4	AV5 +0.15	115	112	0.13	7	AV3 +0.00
		0.08	5	AV2 +0.48			0.18	8	AV3 -0.05	115	116	0.15	7	AV3 -0.02
113	94	0.06	4	AV7 -0.05	114	101	0.14	7	AV5 +0.00	115	122	0.10	6	AV3 +0.02
		0.08	5	AV6 +0.02			0.35	14	AV4 +0.00	115	130	0.27	11	AV6 +0.02
		0.33	13	AV5 +0.00			0.44	16	AV3 -0.02			0.08	5	AV5 +0.14
		0.34	13	AV4 -0.02			0.47	16	AV2 +0.00	116	55	0.09	5	AV6 +0.22
		0.34	13	AV3 -0.05			0.14	7	AV1 -0.02			0.18	8	AV5 +0.00
		0.08	5	AV2 -0.16	114	103	0.16	8	AV5 +0.00			0.21	9	AV4 +0.05
113	96	0.30	12	AV4 -0.02			0.12	6	AV2 +0.21	116	57	0.21	9	AV5 +0.02
		0.36	14	AV3 -0.05			0.16	8	AV4 +0.00			0.08	5	AV3 -0.48
		0.23	10	AV2 -0.02	114	123	0.06	4	AV5 +0.00	116	59	0.08	5	AV5 +0.21
		0.11	6	AV7 +0.02	115	40	0.18	8	AV8 +0.05			0.07	5	AV3 -0.05
		0.20	9	AV6 +0.00			0.08	5	AV4 +0.16	116	61	0.12	6	AV5 +0.00
		0.13	7	AV5 +0.00			0.05	4	AV3 +0.12	116	63	0.10	5	AV5 +0.05
113	98	0.07	4	AV5 -0.16	115	56	0.09	5	AV7 -0.29			0.12	6	AV3 +0.02
		0.06	4	AV4 -0.19			0.11	6	AV5 -0.21	116	69	0.15	8	AV5 +0.00
		0.19	9	AV3 -0.20			0.11	6	AV6 -0.09			0.14	7	AV4 +0.03
		0.10	6	AV2 -0.05			0.13	7	AV4 -0.16			0.08	5	AV3 +0.00
113	100	0.15	7	AV2 -0.05	115	58	0.10	6	AV5 -0.13			0.06	4	AV2 -0.18
		0.13	7	AV6 +0.00			0.07	4	AV4 -0.14	116	71	0.21	10	AV4 +0.00
113	102	0.09	5	AV4 -0.19			0.08	5	AV3 -0.23	116	73	0.10	5	AV4 +0.11
113	118	0.28	12	AV2 +0.00			0.06	4	AV2 -0.02	116	77	0.13	7	AV6 -0.12
		0.16	8	AV4 +0.03	115	60	0.14	7	AV5 +0.16	116	79	0.10	6	AV4 +0.03
114	41	0.26	11	AV6 +0.00			0.13	7	AV4 +0.03			0.11	6	AV3 +0.07
		0.19	9	AV4 -0.02			0.27	11	AV3 +0.05			0.11	6	AV2 +0.05
		0.23	10	AV3 +0.02	115	66	0.32	13	AV8 +0.07	116	81	0.06	4	AV6 -0.02
114	43	0.12	6	AV7 +0.21			0.36	14	AV6 +0.07			0.10	6	AV4 -0.02
		0.17	8	AV6 +0.00			0.09	5	AV5 +0.30	116	83	0.17	8	AV6 -0.02
		0.17	8	AV5 +0.02			0.16	8	AV4 +0.32			0.21	10	AV5 -0.05
		0.18	9	AV2 +0.02	115	70	0.10	6	AV7 +0.09			0.40	15	AV3 -0.02
114	57	0.17	8	AV5 +0.07			0.51	17	AV6 +0.05			0.29	12	AV2 -0.05
		0.11	6	AV4 +0.24			0.17	8	AV5 +0.23	116	87	0.42	15	AV8 +0.02
114	65	0.18	9	AV5 -0.03			0.10	6	AV4 +0.21			0.46	16	AV5 +0.00
114	73	0.14	7	AV4 -0.19	115	72	0.13	7	AV2 -0.18			0.42	15	AV4 -0.02
		0.13	7	AV2 +0.02			0.11	6	AV1 -0.18			0.21	9	AV3 -0.09
114	75	0.20	9	AV4 -0.02	115	74	0.14	7	AV4 +0.00			0.17	8	AV2 -0.02
		0.21	10	AV3 -0.05			0.10	6	AV3 +0.21			0.06	4	AV1 -0.09
		0.22	10	AV2 -0.05			0.15	7	AV2 +0.00	116	89	0.13	7	AV6 -0.02
		0.19	9	AV1 -0.05			0.06	4	AV1 +0.16			0.23	10	AV4 -0.02
114	77	0.11	6	AV6 +0.16	115	82	0.08	5	AV3 -0.05			0.08	5	AV2 -0.23
		0.14	7	AV4 -0.02	115	84	0.19	9	AV8 +0.07	116	91	0.10	6	AV7 +0.17
		0.14	7	AV3 +0.00			0.49	17	AV6 +0.00			0.15	7	AV6 +0.05

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.24	10	AV5 -0.03			0.35	13	AV7 +0.00			0.09	5	AV8 -0.29
		0.07	4	AV4 -0.02	118	93	0.31	12	AV6 +0.00			0.07	5	AV7 -0.16
		0.12	6	AV3 -0.05			0.22	10	AV4 -0.07	120	91	0.33	13	AV2 -0.05
116	93	0.25	11	AV5 -0.03			0.09	5	AV3 -0.05			0.13	7	AV8 -0.02
		0.26	11	AV4 -0.02			0.27	11	AV2 -0.02			0.40	15	AV7 +0.00
		0.09	5	AV3 -0.25			0.13	7	AV1 -0.05			0.48	16	AV5 -0.03
116	95	0.40	15	AV5 -0.05	118	95	0.08	5	AV1 +0.21	120	93	0.08	5	AV3 -0.16
		0.26	11	AV4 -0.02			0.08	5	AV5 +0.15			0.10	6	AV2 -0.05
		0.08	5	AV3 +0.12			0.33	13	AV4 -0.02	120	97	0.09	5	AV3 -0.05
		0.09	5	AV2 -0.14			0.11	6	AV3 -0.02			0.06	4	AV2 +0.23
116	97	0.08	5	AV5 +0.00			0.23	10	AV2 -0.02	120	105	0.12	6	AV5 +0.02
		0.11	6	AV2 -0.02	118	97	0.49	17	AV5 +0.00	120	117	0.14	7	AV4 +0.05
		0.07	4	AV1 +0.11			0.09	5	AV2 -0.18	120	119	0.13	7	AV7 +0.05
116	99	0.06	4	AV3 +0.00	118	99	0.16	8	AV8 +0.07	120	123	0.08	5	AV4 +0.00
117	78	0.14	7	AV3 -0.16			0.63	19	AV7 +0.05			0.15	7	AV2 +0.02
		0.12	6	AV2 -0.02			0.28	12	AV6 +0.02	121	58	0.10	6	AV6 -0.02
117	82	0.12	6	AV5 -0.03			0.19	9	AV5 +0.02			0.10	6	AV5 -0.03
117	84	0.50	17	AV7 +0.02			0.18	9	AV4 +0.03			0.10	6	AV4 +0.03
		0.17	8	AV4 +0.00			0.13	7	AV3 -0.20	121	62	0.19	9	AV6 +0.02
		0.15	7	AV3 -0.05			0.08	5	AV2 +0.09	121	68	0.20	9	AV4 -0.05
		0.45	16	AV2 -0.02	118	101	0.13	7	AV7 -0.05	121	74	0.17	8	AV4 -0.05
117	86	0.29	12	AV8 +0.00	118	103	0.10	6	AV7 -0.14			0.08	5	AV3 +0.14
		0.55	18	AV7 -0.02			0.13	7	AV5 -0.03			0.12	6	AV2 -0.02
		0.51	17	AV6 -0.05	118	127	0.18	8	AV7 +0.02	121	82	0.15	7	AV6 +0.00
		0.42	15	AV4 +0.00	119	78	0.09	5	AV7 +0.10			0.20	9	AV5 -0.03
		0.07	4	AV3 -0.18			0.09	5	AV6 -0.12	121	84	0.32	13	AV7 +0.02
		0.10	6	AV2 -0.18			0.11	6	AV4 +0.10			0.33	13	AV5 -0.05
117	88	0.16	8	AV2 -0.02	119	82	0.08	5	AV8 -0.29			0.55	18	AV4 +0.00
		0.19	9	AV6 -0.02			0.28	12	AV7 +0.00			0.13	7	AV3 -0.05
		0.16	8	AV5 +0.00			0.46	16	AV4 -0.05	121	88	0.61	19	AV7 +0.00
		0.08	5	AV4 -0.05			0.15	8	AV3 -0.05			0.63	19	AV6 +0.02
		0.16	8	AV3 -0.05	119	84	0.13	7	AV6 +0.07			0.45	16	AV5 -0.03
117	90	0.13	7	AV8 +0.05			0.28	12	AV4 -0.02			0.18	8	AV4 -0.05
		0.21	10	AV7 +0.00			0.30	12	AV3 -0.05			0.18	9	AV3 -0.02
		0.33	13	AV6 +0.00			0.17	8	AV1 +0.00			0.15	8	AV2 -0.02
		0.14	7	AV4 -0.05	119	88	0.14	7	AV7 +0.00	121	90	0.21	9	AV8 +0.02
117	92	0.09	5	AV7 +0.16			0.35	14	AV6 +0.00			0.36	14	AV7 +0.00
		0.07	4	AV6 +0.56			0.59	19	AV5 -0.03			0.28	12	AV6 -0.02
		0.13	7	AV5 -0.03			0.16	8	AV3 -0.02			0.42	15	AV5 +0.00
		0.15	7	AV3 -0.05			0.23	10	AV2 -0.05			0.36	14	AV3 -0.02
		0.20	9	AV2 -0.02			0.07	4	AV4 -0.02			0.09	5	AV2 +0.00
117	94	0.11	6	AV2 -0.05	119	90	0.26	11	AV7 -0.02	121	92	0.08	5	AV6 +0.07
117	98	0.16	8	AV7 +0.02			0.30	12	AV6 +0.00			0.17	8	AV3 -0.05
		0.06	4	AV6 +0.23			0.23	10	AV5 +0.00			0.13	7	AV2 -0.02
		0.11	6	AV5 +0.00			0.13	7	AV3 -0.20			0.08	5	AV1 +0.02
		0.12	6	AV3 -0.20			0.06	4	AV1 +0.14			0.26	11	AV7 +0.16
		0.08	5	AV2 -0.16	119	92	0.18	9	AV7 -0.16	121	94	0.14	7	AV4 -0.02
117	100	0.17	8	AV5 -0.06			0.08	5	AV6 +0.44			0.19	9	AV3 -0.07
		0.22	10	AV3 -0.05			0.12	6	AV5 -0.03			0.08	5	AV2 -0.18
		0.27	11	AV2 -0.05			0.08	5	AV3 +0.16	121	98	0.09	5	AV7 -0.05
118	79	0.08	5	AV2 -0.23	119	94	0.12	6	AV2 -0.21	121	100	0.30	12	AV7 +0.02
118	83	0.34	13	AV7 +0.00			0.08	5	AV1 +0.34			0.27	11	AV4 -0.05
		0.58	18	AV6 -0.02	119	96	0.11	6	AV1 -0.18			0.11	6	AV2 -0.18
		0.39	14	AV4 -0.05	119	124	0.10	6	AV5 +0.00	121	102	0.28	12	AV7 +0.02
		0.16	8	AV3 -0.07	120	61	0.12	7	AV7 +0.05			0.21	9	AV5 -0.08
		0.08	5	AV2 -0.02	120	81	0.07	4	AV4 +0.08			0.14	7	AV4 -0.09
118	87	0.12	6	AV8 +0.16	120	83	0.08	5	AV6 -0.14			0.13	7	AV3 -0.09
		0.10	6	AV7 -0.02			0.32	13	AV5 +0.00			0.10	5	AV1 -0.02
		0.33	13	AV6 -0.03			0.29	12	AV4 -0.21	122	73	0.18	9	AV4 -0.02
		0.45	16	AV3 -0.02			0.16	8	AV3 -0.05	122	79	0.24	10	AV7 +0.00
		0.40	15	AV2 -0.05	120	85	0.32	13	AV8 +0.02			0.48	17	AV6 +0.02
118	89	0.11	6	AV6 -0.02			0.10	6	AV6 +0.00	122	83	0.34	13	AV5 +0.02
		0.39	14	AV5 +0.02			0.10	6	AV2 -0.05			0.51	17	AV3 +0.00
		0.42	15	AV4 -0.05	120	87	0.24	10	AV7 +0.02			0.35	13	AV2 -0.02
		0.16	8	AV3 -0.05			0.46	16	AV6 +0.07			0.16	8	AV1 -0.02
		0.09	5	AV2 +0.00			0.41	15	AV5 +0.00	122	87	0.17	8	AV8 +0.05
118	91	0.38	14	AV7 +0.00			0.34	13	AV4 -0.02			0.12	6	AV7 +0.05
		0.38	14	AV6 +0.00	120	89	0.08	5	AV6 +0.18			0.61	19	AV3 -0.02
		0.30	12	AV5 +0.00			0.08	5	AV5 +0.18			0.28	12	AV2 -0.02
		0.10	6	AV4 -0.02			0.07	4	AV3 -0.18	122	89	0.14	7	AV6 -0.02
		0.10	6	AV3 -0.20			0.13	7	AV4 -0.21			0.26	11	AV5 +0.00
		0.11	6	AV2 -0.05			0.10	6	AV2 -0.23			0.51	17	AV4 -0.02

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.18	8	AV3 -0.02			0.45	16	AV4 +0.08			0.13	7	AV4 -0.02
		0.13	7	AV2 +0.00			0.26	11	AV2 +0.05			0.08	5	AV3 +0.16
122	91	0.08	5	AV8 +0.00	124	55	0.09	5	AV5 -0.08			0.12	6	AV2 -0.05
		0.18	8	AV7 -0.17			0.16	8	AV4 +0.00	125	96	0.47	16	AV4 +0.05
		0.10	6	AV6 -0.02			0.08	5	AV3 -0.14			0.21	9	AV1 +0.00
		0.45	16	AV5 -0.05			0.10	6	AV7 -0.12	125	98	0.54	18	AV4 +0.03
		0.10	5	AV3 -0.05			0.09	5	AV6 +0.00			0.11	6	AV3 -0.07
		0.15	8	AV2 -0.05	124	69	0.08	5	AV5 -0.21	125	100	0.23	10	AV8 +0.07
122	93	0.10	6	AV1 +0.00	124	71	0.17	8	AV4 +0.03			0.19	9	AV7 +0.05
		0.15	7	AV7 +0.18	124	83	0.30	12	AV6 +0.00			0.13	7	AV5 -0.05
		0.18	8	AV5 -0.03			0.44	16	AV5 -0.03			0.22	10	AV4 -0.02
		0.24	11	AV2 -0.02			0.38	14	AV4 -0.05	125	102	0.38	14	AV5 -0.05
122	95	0.10	5	AV5 -0.05			0.16	8	AV3 +0.00			0.30	12	AV3 -0.05
		0.11	6	AV4 -0.21	124	87	0.07	4	AV7 -0.05			0.14	7	AV2 -0.05
		0.25	11	AV3 -0.07			0.11	6	AV6 +0.09			0.09	5	AV1 -0.12
		0.21	9	AV2 -0.05			0.17	8	AV3 -0.07	126	55	0.10	6	AV7 -0.14
122	97	0.10	6	AV5 +0.03			0.35	13	AV2 +0.00			0.40	15	AV6 -0.05
		0.06	4	AV2 -0.02			0.18	9	AV1 -0.02			0.25	11	AV5 -0.08
		0.06	4	AV6 +0.07	124	89	0.23	10	AV6 +0.02			0.07	5	AV4 +0.18
122	99	0.23	10	AV7 +0.18			0.12	6	AV5 +0.14			0.07	4	AV3 -0.02
		0.10	5	AV5 +0.09			0.10	6	AV3 -0.23	126	69	0.21	9	AV4 +0.05
		0.15	7	AV4 +0.03	124	91	0.55	18	AV7 +0.02	126	75	0.08	5	AV3 -0.18
122	101	0.12	6	AV2 -0.16			0.33	13	AV6 +0.00	126	77	0.15	7	AV3 -0.02
		0.12	7	AV5 +0.05			0.29	12	AV5 -0.05	126	83	0.06	4	AV8 +0.12
		0.16	8	AV4 +0.03			0.07	4	AV2 -0.20			0.07	4	AV7 +0.02
122	103	0.11	6	AV3 -0.21	124	93	0.14	7	AV4 +0.18			0.11	6	AV6 +0.03
		0.18	8	AV6 +0.09			0.10	6	AV3 -0.23			0.35	13	AV5 -0.05
		0.34	13	AV4 +0.14			0.06	4	AV2 -0.16			0.27	11	AV4 -0.05
122	109	0.46	16	AV2 +0.07			0.06	4	AV1 +0.18			0.10	6	AV3 -0.02
		0.17	8	AV8 +0.07	124	95	0.07	4	AV3 -0.27	126	87	0.38	14	AV7 +0.02
		0.14	7	AV7 +0.05			0.11	6	AV2 -0.20			0.17	8	AV6 +0.12
		0.23	10	AV6 +0.09	124	97	0.08	5	AV5 +0.16			0.19	9	AV5 +0.00
		0.11	6	AV4 +0.10	124	99	0.14	7	AV7 +0.16			0.47	16	AV4 +0.03
123	70	0.10	6	AV7 +0.21			0.09	5	AV2 -0.20			0.17	8	AV3 +0.00
		0.11	6	AV5 -0.21	125	54	0.15	7	AV6 +0.02			0.19	9	AV2 -0.02
		0.15	8	AV4 -0.02			0.14	7	AV5 -0.03	126	89	0.34	13	AV6 +0.00
123	72	0.07	4	AV5 +0.28			0.18	8	AV4 +0.00			0.24	10	AV5 +0.00
		0.05	4	AV3 +0.23			0.17	8	AV3 +0.19	126	91	0.33	13	AV7 +0.02
		0.12	6	AV2 +0.02	125	56	0.08	5	AV3 +0.00			0.23	10	AV5 +0.00
123	74	0.14	7	AV7 -0.07			0.10	6	AV2 +0.00			0.13	7	AV3 -0.20
		0.20	9	AV6 -0.14	125	62	0.24	10	AV5 -0.03	126	93	0.10	5	AV6 +0.21
		0.09	5	AV3 +0.00			0.25	11	AV4 +0.05			0.09	5	AV3 +0.00
123	78	0.10	5	AV3 +0.05			0.08	5	AV2 +0.00			0.18	9	AV2 -0.02
123	82	0.16	8	AV6 +0.05	125	68	0.18	8	AV3 -0.05	126	97	0.12	6	AV7 -0.02
		0.10	6	AV4 +0.13			0.13	7	AV2 -0.02	126	99	0.07	5	AV4 -0.11
		0.10	5	AV2 +0.05			0.19	9	AV4 -0.05	126	101	0.15	7	AV4 +0.05
123	84	0.12	6	AV8 +0.07			0.15	7	AV5 -0.03			0.17	8	AV3 +0.00
		0.08	5	AV5 -0.05	125	72	0.39	14	AV4 +0.03	126	103	0.16	8	AV6 +0.00
		0.56	18	AV4 -0.05			0.28	12	AV3 +0.02			0.15	8	AV4 -0.05
123	86	0.10	6	AV3 -0.18			0.16	8	AV2 -0.02			0.12	6	AV1 +0.14
		0.23	10	AV6 -0.14			0.08	5	AV1 -0.02	126	105	0.19	9	AV4 -0.05
		0.23	10	AV4 -0.02	125	78	0.18	8	AV4 -0.02	126	119	0.15	8	AV4 +0.00
		0.44	16	AV3 -0.02	125	80	0.15	8	AV4 +0.03	127	66	0.07	4	AV6 +0.17
		0.13	7	AV2 -0.23	125	82	0.29	12	AV7 +0.05	127	68	0.06	4	AV3 -0.05
123	88	0.16	8	AV8 +0.02			0.10	6	AV6 +0.05			0.05	4	AV2 +0.14
		0.27	11	AV7 +0.00			0.18	9	AV4 +0.18			0.26	11	AV7 +0.02
		0.11	6	AV6 +0.00	125	84	0.10	6	AV6 +0.02			0.34	13	AV6 +0.00
		0.10	6	AV5 -0.24			0.50	17	AV5 -0.05			0.05	4	AV5 +0.18
		0.09	5	AV3 -0.23			0.28	12	AV3 -0.07			0.15	7	AV4 -0.02
		0.13	7	AV2 -0.23	125	88	0.08	5	AV8 +0.05	127	74	0.14	7	AV6 +0.09
123	90	0.14	7	AV7 +0.02			0.37	14	AV6 +0.00			0.11	6	AV4 -0.19
		0.07	4	AV6 +0.21			0.09	5	AV2 -0.05			0.09	5	AV3 +0.12
		0.18	9	AV3 -0.07	125	90	0.14	7	AV8 +0.02	127	82	0.07	4	AV6 +0.09
		0.09	5	AV2 +0.32			0.45	16	AV7 +0.00			0.12	6	AV4 +0.23
123	92	0.14	7	AV7 +0.24			0.39	14	AV6 -0.03			0.07	4	AV3 +0.12
		0.11	6	AV2 -0.02			0.23	10	AV5 +0.00	127	84	0.19	9	AV7 +0.05
123	94	0.18	8	AV5 +0.05			0.46	16	AV4 -0.07			0.43	15	AV6 +0.02
		0.46	16	AV4 +0.00			0.12	6	AV2 -0.02			0.33	13	AV5 +0.00
		0.20	9	AV3 -0.02			0.06	4	AV1 +0.07			0.48	16	AV4 +0.05
		0.14	7	AV2 -0.02	125	92	0.08	5	AV7 +0.23			0.27	11	AV3 -0.02
123	98	0.33	13	AV7 +0.05			0.09	5	AV3 -0.18			0.32	13	AV2 +0.00
		0.49	17	AV6 +0.07	125	94	0.20	9	AV5 +0.02	127	86	0.40	15	AV3 +0.00

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.13	7	AV2 -0.18			0.09	5	AV4 +0.00			0.11	6	AV4 +0.03
		0.25	11	AV6 +0.05			0.11	6	AV3 -0.09	130	67	0.38	14	AV7 +0.02
		0.38	14	AV4 +0.00			0.14	7	AV2 -0.02			0.37	14	AV3 +0.00
127	88	0.08	5	AV7 -0.05	128	99	0.14	7	AV7 +0.00			0.12	6	AV2 +0.00
		0.19	9	AV6 +0.05	128	101	0.16	8	AV8 +0.02	130	69	0.12	6	AV6 -0.02
		0.19	9	AV2 -0.21			0.46	16	AV7 +0.00			0.35	13	AV4 +0.00
127	90	0.11	6	AV8 +0.05			0.18	8	AV6 +0.00			0.14	7	AV3 +0.00
		0.19	9	AV7 +0.02			0.23	10	AV4 -0.05			0.32	13	AV2 -0.02
		0.21	9	AV5 -0.03	128	105	0.17	8	AV4 -0.02			0.10	6	AV1 -0.02
		0.32	13	AV4 -0.05			0.23	10	AV3 +0.02	130	73	0.12	6	AV4 +0.00
		0.12	6	AV3 -0.20	128	107	0.34	13	AV7 +0.02			0.22	10	AV3 +0.02
		0.17	8	AV1 -0.05	128	109	0.20	9	AV5 +0.09	130	83	0.15	7	AV5 +0.05
127	92	0.15	7	AV7 +0.05			0.16	8	AV4 +0.08			0.14	7	AV3 +0.05
		0.09	5	AV3 -0.16			0.13	7	AV3 -0.02			0.09	5	AV2 +0.05
127	94	0.09	5	AV2 -0.23	128	111	0.26	11	AV6 +0.00	130	87	0.12	6	AV7 +0.02
127	96	0.13	7	AV5 +0.05			0.34	13	AV5 -0.03			0.23	10	AV6 +0.00
127	98	0.19	9	AV5 +0.05			0.18	9	AV4 +0.03			0.31	12	AV5 -0.03
		0.15	7	AV4 +0.03			0.20	9	AV3 -0.02	130	89	0.31	12	AV6 +0.00
		0.22	10	AV3 -0.02	128	117	0.32	13	AV8 +0.07			0.44	16	AV5 -0.05
127	100	0.08	5	AV5 +0.22			0.44	16	AV7 +0.05			0.41	15	AV4 -0.05
		0.11	6	AV4 +0.00			0.19	9	AV6 +0.02			0.27	11	AV2 -0.05
127	102	0.27	11	AV7 +0.02			0.10	6	AV5 -0.21	130	91	0.14	7	AV7 +0.19
		0.17	8	AV5 +0.02			0.36	14	AV4 +0.00			0.24	10	AV6 +0.02
		0.40	15	AV4 -0.02	129	66	0.17	8	AV8 +0.07			0.52	17	AV5 -0.03
		0.13	7	AV3 +0.00			0.22	10	AV6 +0.00			0.11	6	AV4 -0.02
		0.22	10	AV2 -0.02			0.20	9	AV5 -0.05			0.18	8	AV2 -0.05
		0.14	7	AV1 +0.00	129	68	0.13	7	AV5 +0.00	130	93	0.15	7	AV7 +0.02
127	104	0.10	6	AV7 +0.07			0.54	18	AV3 -0.02			0.18	9	AV4 +0.03
		0.08	5	AV3 -0.05			0.26	11	AV2 -0.02			0.38	14	AV2 +0.00
127	106	0.31	12	AV4 +0.10	129	72	0.13	7	AV2 -0.21	130	95	0.49	17	AV8 +0.07
127	108	0.13	7	AV5 +0.00	129	74	0.18	9	AV6 -0.14			0.38	14	AV7 +0.02
		0.12	6	AV4 +0.00	129	76	0.14	7	AV4 -0.02			0.09	5	AV5 +0.17
127	118	0.09	5	AV6 -0.02			0.04	3	AV3 +0.02			0.21	10	AV4 -0.07
128	53	0.12	6	AV7 +0.19	129	78	0.30	12	AV6 -0.02			0.23	10	AV3 +0.00
		0.22	10	AV6 +0.00	129	80	0.14	7	AV4 -0.07	130	97	0.38	14	AV5 +0.08
		0.47	16	AV4 -0.05	129	82	0.12	6	AV4 +0.23			0.27	11	AV4 +0.03
128	67	0.12	6	AV6 +0.09	129	84	0.27	11	AV7 +0.02			0.16	8	AV3 +0.05
		0.08	5	AV5 -0.26			0.10	6	AV6 +0.54	130	99	0.24	10	AV4 +0.10
		0.06	4	AV3 +0.14			0.54	18	AV5 -0.08			0.10	5	AV3 -0.07
128	71	0.18	8	AV8 -0.14			0.39	14	AV4 -0.02			0.10	5	AV2 -0.16
		0.42	15	AV4 -0.02			0.49	17	AV3 -0.02	130	101	0.25	11	AV4 +0.05
		0.11	6	AV2 -0.23	129	86	0.58	18	AV7 +0.00			0.08	5	AV1 -0.18
128	73	0.09	5	AV8 +0.28			0.34	13	AV5 -0.03	130	103	0.18	9	AV8 +0.05
		0.10	6	AV6 +0.09	129	88	0.14	7	AV7 +0.00			0.48	16	AV7 +0.02
		0.09	5	AV4 +0.03			0.14	7	AV5 -0.03			0.11	6	AV5 -0.03
128	75	0.09	5	AV5 +0.21			0.15	7	AV4 -0.02			0.34	13	AV4 +0.00
		0.08	5	AV4 +0.18			0.13	7	AV2 -0.21			0.37	14	AV3 +0.00
128	77	0.08	5	AV3 +0.28	129	90	0.13	7	AV8 +0.07			0.35	13	AV2 +0.04
		0.08	5	AV4 +0.18			0.36	14	AV7 +0.02			0.16	8	AV1 +0.00
128	79	0.14	7	AV2 +0.09			0.21	10	AV6 -0.03	130	113	0.13	7	AV4 -0.02
128	81	0.06	4	AV6 -0.23			0.30	12	AV5 +0.03	131	66	0.07	4	AV3 +0.14
		0.13	7	AV4 +0.00			0.50	17	AV4 +0.00	131	68	0.28	11	AV6 +0.02
128	83	0.05	3	AV7 -0.26			0.30	12	AV3 -0.02			0.48	17	AV5 -0.03
		0.08	5	AV6 +0.00	129	92	0.22	10	AV7 +0.05			0.35	14	AV4 -0.05
		0.08	5	AV4 -0.35			0.08	5	AV6 +0.21	131	70	0.10	6	AV3 +0.23
		0.11	6	AV3 +0.05			0.14	7	AV5 +0.02			0.35	13	AV8 +0.07
128	85	0.23	10	AV2 +0.00			0.13	7	AV3 -0.09			0.14	7	AV7 +0.07
		0.17	8	AV6 +0.00			0.12	6	AV2 -0.02			0.43	15	AV6 +0.07
128	87	0.16	8	AV6 +0.16	129	94	0.17	8	AV7 +0.05	131	72	0.14	7	AV8 -0.07
		0.16	8	AV5 +0.00			0.18	8	AV4 +0.03			0.14	7	AV6 +0.16
128	89	0.10	6	AV7 +0.02			0.18	9	AV3 +0.00	131	74	0.13	7	AV5 +0.07
		0.05	4	AV6 -0.05			0.13	7	AV2 -0.21			0.13	7	AV4 +0.08
128	91	0.12	6	AV8 +0.05	129	96	0.11	6	AV7 -0.16			0.10	6	AV2 +0.21
		0.36	14	AV7 +0.00			0.15	8	AV6 +0.02	131	78	0.08	5	AV6 -0.32
		0.29	12	AV6 +0.00			0.15	7	AV5 +0.00	131	82	0.33	13	AV4 +0.36
		0.20	9	AV5 -0.03			0.11	6	AV4 +0.03			0.12	6	AV3 -0.05
		0.21	9	AV4 -0.05	129	98	0.17	8	AV6 +0.00	131	84	0.08	5	AV6 +0.09
		0.18	9	AV3 -0.07	129	102	0.41	15	AV5 -0.03	131	86	0.35	13	AV8 +0.07
		0.17	8	AV2 -0.21			0.25	11	AV3 -0.02			0.42	15	AV3 +0.02
128	95	0.07	4	AV3 -0.25			0.17	8	AV2 -0.02			0.17	8	AV2 +0.00
128	97	0.05	4	AV1 +0.11	129	112	0.13	7	AV7 +0.20			0.06	4	AV1 -0.05
		0.10	5	AV5 +0.21			0.20	9	AV6 +0.02	131	88	0.07	4	AV7 -0.37

SL2-26 - 09/21  
 Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.19	9	AV6 +0.02			0.11	6	AV6 -0.14			0.07	5	AV7 -0.43
		0.10	6	AV5 +0.09	132	99	0.16	8	AV4 +0.00	134	89	0.16	8	AV6 -0.02
		0.12	6	AV2 -0.21			0.20	9	AV3 +0.02			0.23	10	AV5 -0.05
131	90	0.14	7	AV7 +0.07			0.10	6	AV2 -0.05			0.27	11	AV4 -0.07
		0.25	11	AV6 +0.02	132	101	0.32	13	AV4 +0.03			0.14	7	AV3 -0.07
		0.17	8	AV3 -0.16			0.24	10	AV3 +0.00			0.16	8	AV2 +0.11
		0.10	6	AV2 -0.05			0.17	8	AV2 -0.02	134	91	0.16	8	AV6 +0.00
		0.37	14	AV1 +0.00	133	62	0.15	7	AV7 -0.14			0.13	7	AV3 -0.09
131	92	0.21	9	AV7 +0.28			0.11	6	AV6 +0.19	134	93	0.15	7	AV7 +0.00
		0.19	9	AV6 +0.07	133	70	0.18	8	AV8 +0.19			0.16	8	AV4 -0.05
		0.09	5	AV3 -0.25			0.36	14	AV7 +0.02			0.20	9	AV3 -0.05
131	94	0.13	7	AV2 -0.05			0.28	12	AV5 -0.05	134	95	0.22	10	AV5 -0.05
		0.11	6	AV1 -0.02			0.23	10	AV4 -0.14	134	97	0.18	9	AV7 +0.02
		0.22	10	AV5 +0.09	133	72	0.50	17	AV5 -0.08	135	70	0.19	9	AV8 +0.19
		0.10	6	AV4 +0.08	133	74	0.26	11	AV5 -0.05	135	72	0.13	7	AV8 -0.19
		0.29	12	AV3 +0.16			0.11	6	AV4 -0.02	135	74	0.20	9	AV6 +0.23
131	96	0.12	6	AV7 +0.27	133	76	0.13	7	AV2 -0.23	135	76	0.17	8	AV7 +0.07
		0.14	7	AV5 +0.05	133	78	0.17	8	AV6 -0.09			0.16	8	AV6 +0.27
131	98	0.22	10	AV5 +0.05	133	80	0.17	8	AV4 +0.00			0.14	7	AV5 -0.03
		0.17	8	AV4 +0.03	133	82	0.13	7	AV6 +0.05			0.11	6	AV4 -0.02
		0.30	12	AV3 +0.00	133	84	0.16	8	AV6 +0.00			0.13	7	AV3 -0.02
131	100	0.08	5	AV2 -0.16	133	86	0.07	4	AV6 +0.00	135	78	0.13	7	AV4 +0.05
131	102	0.52	17	AV8 +0.05	133	88	0.10	6	AV6 +0.05			0.07	4	AV2 +0.20
		0.25	11	AV2 +0.00			0.18	9	AV5 +0.02	135	80	0.10	6	AV8 -0.02
		0.15	8	AV1 -0.05			0.21	10	AV2 +0.02			0.23	10	AV7 +0.19
131	104	0.41	15	AV6 +0.05	133	90	0.41	15	AV7 +0.05			0.29	12	AV6 +0.07
		0.22	10	AV5 +0.02			0.57	18	AV6 -0.02			0.58	18	AV5 +0.05
		0.18	9	AV4 +0.21			0.57	18	AV5 +0.00			0.17	8	AV4 +0.08
		0.21	9	AV3 +0.07			0.24	10	AV3 -0.18			0.09	5	AV2 -0.23
132	69	0.09	5	AV7 +0.05			0.22	10	AV2 -0.02	135	82	0.32	13	AV2 +0.05
		0.20	9	AV5 +0.02	133	92	0.11	6	AV6 -0.02	135	84	0.06	4	AV8 +0.14
		0.12	6	AV4 +0.03			0.38	14	AV5 +0.00			0.14	7	AV7 +0.19
132	71	0.10	6	AV8 -0.17			0.16	8	AV4 -0.02			0.27	11	AV6 +0.05
		0.10	6	AV5 -0.11			0.11	6	AV2 +0.00			0.21	9	AV5 +0.00
		0.28	12	AV4 -0.02	133	94	0.10	6	AV5 -0.24	135	86	0.19	9	AV6 +0.02
132	73	0.11	6	AV7 +0.28			0.08	5	AV3 -0.05			0.10	6	AV5 +0.07
		0.13	7	AV4 +0.29	133	96	0.28	12	AV7 +0.05			0.32	13	AV4 +0.03
		0.11	6	AV2 -0.07			0.31	12	AV6 +0.00			0.20	9	AV3 +0.02
132	75	0.11	6	AV8 -0.28			0.09	5	AV5 +0.15			0.06	4	AV2 -0.09
		0.07	4	AV5 -0.21			0.09	5	AV4 -0.02	135	90	0.50	17	AV8 +0.07
		0.08	5	AV2 +0.02			0.18	9	AV3 -0.23			0.19	9	AV5 +0.02
132	77	0.42	15	AV6 +0.17			0.12	6	AV2 -0.18			0.15	7	AV3 -0.18
		0.08	5	AV4 +0.18			0.06	4	AV1 +0.25			0.12	6	AV2 -0.05
132	79	0.09	5	AV6 -0.12	133	102	0.16	8	AV3 +0.02			0.07	4	AV1 -0.07
		0.08	5	AV4 +0.00			0.17	8	AV1 -0.05	135	92	0.27	11	AV8 +0.10
132	81	0.40	15	AV6 -0.07	134	69	0.12	6	AV5 -0.05			0.49	17	AV6 +0.00
		0.29	12	AV5 -0.08			0.13	7	AV4 -0.16			0.22	10	AV4 +0.05
		0.17	8	AV4 -0.26			0.13	7	AV2 -0.02			0.14	7	AV3 +0.05
132	85	0.10	5	AV5 +0.00			0.16	8	AV7 +0.02	135	94	0.20	9	AV6 +0.07
		0.16	8	AV3 -0.02	134	71	0.22	10	AV5 -0.19			0.13	7	AV5 +0.23
132	89	0.09	5	AV7 +0.07			0.08	5	AV3 +0.30			0.20	9	AV4 +0.03
		0.20	9	AV6 +0.00			0.15	8	AV8 +0.07			0.27	11	AV3 +0.14
		0.16	8	AV5 +0.02			0.45	16	AV6 +0.18	135	96	0.11	6	AV7 +0.11
		0.35	13	AV4 +0.00	134	73	0.11	6	AV8 -0.15			0.25	11	AV6 +0.09
		0.10	6	AV3 -0.18			0.17	8	AV7 +0.02			0.17	8	AV5 +0.30
132	91	0.08	5	AV8 -0.28			0.14	7	AV6 -0.23			0.17	8	AV4 +0.08
		0.20	9	AV7 +0.02			0.23	10	AV5 -0.11			0.28	12	AV3 +0.00
		0.43	15	AV6 +0.00	134	75	0.17	8	AV8 -0.14			0.20	9	AV2 -0.02
		0.10	5	AV4 -0.19			0.12	6	AV7 +0.17	135	98	0.07	4	AV2 +0.14
		0.11	6	AV3 -0.20			0.15	7	AV4 +0.16	136	73	0.16	8	AV8 -0.28
		0.08	5	AV2 -0.23	134	77	0.26	11	AV4 -0.02	136	75	0.11	6	AV8 -0.12
132	93	0.13	7	AV5 -0.08	134	79	0.23	10	AV6 +0.00			0.12	6	AV1 -0.18
		0.14	7	AV4 -0.05			0.23	10	AV4 -0.05	136	77	0.09	5	AV4 -0.16
		0.18	9	AV7 +0.00	134	81	0.15	8	AV7 +0.02			0.07	4	AV2 +0.27
		0.10	6	AV6 +0.21			0.53	17	AV6 -0.02	136	79	0.16	8	AV6 +0.23
132	95	0.18	9	AV7 +0.02			0.31	12	AV5 -0.05	136	83	0.12	6	AV8 +0.30
		0.08	5	AV6 -0.09			0.20	9	AV4 -0.19			0.32	13	AV4 -0.28
		0.28	12	AV5 -0.13	134	83	0.09	5	AV8 +0.07			0.12	6	AV3 -0.23
		0.18	9	AV4 -0.12			0.12	6	AV6 +0.05	136	87	0.24	10	AV7 +0.05
		0.25	11	AV3 -0.09			0.25	11	AV4 -0.19			0.21	10	AV6 -0.05
132	97	0.08	5	AV7 +0.05			0.13	7	AV2 -0.05			0.50	17	AV5 -0.08
		0.10	6	AV5 +0.09	134	87	0.09	5	AV5 +0.17			0.12	6	AV3 -0.11

SL2-26 - 09/21

Bobbin AVB Wear 1-19%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
		0.11	6	AV2	-0.14									
		0.07	4	AV1	-0.18									
136	91	0.48	16	AV3	-0.05									
		0.29	12	AV2	-0.05									
		0.17	8	AV1	-0.05									
136	93	0.11	6	AV7	+0.05									
		0.16	8	AV6	+0.07									
		0.47	16	AV5	-0.03									
		0.23	10	AV4	-0.02									
136	95	0.13	7	AV7	+0.20									
		0.15	7	AV6	+0.07									
		0.10	6	AV4	+0.05									
		0.07	4	AV1	-0.05									
136	99	0.16	8	AV7	+0.05									
137	80	0.10	5	AV8	-0.17									
137	82	0.31	12	AV8	+0.09									
137	84	0.10	6	AV6	+0.07									
137	86	0.07	4	AV7	+0.07									
137	90	0.09	5	AV8	-0.28									
		0.52	17	AV7	+0.09									
		0.33	13	AV6	+0.05									
		0.17	8	AV5	+0.10									
		0.55	18	AV4	+0.11									
		0.10	5	AV3	-0.18									
		0.40	15	AV2	+0.00									
		0.12	6	AV1	+0.16									
137	92	0.28	12	AV7	+0.23									
		0.19	9	AV5	+0.05									
		0.17	8	AV2	+0.14									
138	85	0.27	11	AV8	-0.09									
		0.15	7	AV7	+0.02									
		0.29	12	AV5	-0.16									
		0.14	7	AV3	-0.05									
		0.11	6	AV2	+0.00									
		0.10	5	AV1	+0.16									
138	91	0.16	8	AV7	+0.21									
139	92	0.24	10	AV7	-0.14									

Total Tubes : 2103

Total Records: 5653

SL2-26 - 09/21  
 Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
54	9	0.66	20	AV6 -0.29										
		0.90	24	AV7 +0.20	84	75	1.11	20	AV5 +0.05	89	90	0.84	23	AV6 +0.00
56	17	0.74	21	AV6 -0.08			0.82	22	AV6 +0.00			0.77	22	AV4 +0.05
58	161	0.70	21	AV6 +0.21	84	77	0.67	20	AV5 +0.05	89	98	0.91	24	AV5 +0.02
60	159	0.68	20	AV2 +0.22			1.13	26	AV6 +0.02	90	65	0.68	20	AV2 +0.02
63	12	0.75	21	AV6 -0.03			0.80	22	AV7 +0.00	90	73	0.71	21	AV6 +0.02
63	158	1.06	26	AV2 +0.00	84	103	0.69	20	AV5 +0.02	90	77	0.74	21	AV5 +0.02
		0.99	25	AV6 +0.00			0.86	23	AV6 +0.00			0.65	20	AV6 +0.02
65	14	0.86	23	AV6 -0.05	84	105	0.91	24	AV5 +0.05	90	77	1.12	26	AV5 +0.07
65	16	0.77	22	AV6 -0.05			0.98	25	AV6 +0.02			2.85	38	AV6 +0.02
65	130	0.77	22	AV6 +0.00	85	76	0.67	20	AV5 +0.02			1.62	31	AV7 +0.02
65	148	1.07	26	AV6 +0.00			0.79	22	AV6 +0.05	90	83	0.68	20	AV4 +0.08
65	158	0.86	23	AV2 -0.14	85	98	0.74	21	AV5 +0.05			0.86	23	AV5 +0.02
		1.26	28	AV3 +0.30			0.82	22	AV6 +0.02	90	97	1.59	31	AV6 +0.02
		1.52	30	AV6 -0.03	85	100	0.77	22	AV5 +0.02			1.04	25	AV7 +0.02
		0.92	24	AV7 +0.20	86	57	0.64	20	AV6 +0.02			0.80	22	AV8 +0.02
66	13	0.65	20	AV3 +0.23			0.77	22	AV7 +0.00	90	99	0.75	21	AV6 +0.02
		2.17	35	AV6 -0.03	86	75	0.69	20	AV2 +0.05	90	103	1.15	27	AV6 +0.07
66	19	0.91	24	AV6 -0.03			1.24	27	AV5 +0.05	91	66	1.14	26	AV6 -0.02
66	153	1.15	27	AV6 -0.03			1.33	28	AV6 +0.02			1.32	28	AV5 -0.03
67	14	1.07	26	AV6 -0.05	86	77	0.68	20	AV6 +0.02			0.83	23	AV4 +0.00
68	13	0.68	20	AV6 -0.05	86	85	0.68	20	AV3 +0.02	91	78	1.12	26	AV7 -0.02
68	157	0.85	23	AV6 -0.02			1.05	25	AV4 +0.08	91	80	0.69	20	AV6 +0.00
69	14	0.81	22	AV3 +0.12	86	89	0.73	21	AV6 +0.02	91	82	0.69	20	AV5 -0.08
		0.80	22	AV6 -0.04	86	97	0.72	21	AV3 +0.02	91	86	0.65	20	AV3 +0.02
73	76	0.75	21	AV5 +0.00			0.81	22	AV5 +0.02	91	92	0.81	22	AV7 +0.02
74	65	0.99	25	AV6 +0.00	86	99	0.67	20	AV5 +0.02			0.92	24	AV6 +0.05
		0.92	24	AV7 +0.02	87	70	0.71	21	AV4 +0.00			1.75	32	AV5 +0.02
76	63	1.56	30	AV6 +0.02			1.67	31	AV5 +0.00	91	98	0.82	22	AV6 +0.00
		0.80	22	AV7 +0.05			1.33	28	AV6 +0.02			0.65	20	AV5 +0.02
76	69	1.38	29	AV4 +0.03	87	76	1.07	26	AV4 +0.05			0.77	22	AV7 +0.00
76	75	0.92	24	AV5 +0.02			2.40	36	AV5 +0.02	92	65	0.67	20	AV7 +0.02
		0.74	21	AV6 +0.02			0.67	20	AV6 +0.02			0.69	20	AV6 +0.00
76	99	0.66	20	AV6 +0.00	87	80	0.69	20	AV5 +0.00	92	77	1.61	31	AV7 +0.00
78	75	0.73	21	AV5 +0.02	87	82	0.70	21	AV5 +0.05			2.99	39	AV6 +0.05
78	99	0.73	21	AV4 +0.06			0.94	24	AV6 +0.02			1.43	29	AV5 +0.05
		1.66	31	AV5 +0.02			0.80	22	AV7 +0.02	92	79	0.79	22	AV4 +0.05
		1.12	26	AV6 +0.02	87	84	0.95	24	AV4 +0.05			1.16	27	AV6 +0.05
79	66	0.71	21	AV4 +0.05			0.94	24	AV5 +0.00			1.29	28	AV5 +0.05
		0.77	22	AV5 +0.02	87	90	0.64	20	AV5 +0.02			0.86	23	AV4 +0.05
79	96	0.71	21	AV5 +0.05	87	96	0.67	20	AV5 +0.02	92	81	0.89	23	AV7 -0.05
79	98	0.86	23	AV6 +0.05	87	98	1.19	27	AV6 +0.00			0.79	22	AV6 -0.02
79	110	0.83	23	AV5 +0.05			1.01	25	AV7 +0.02	92	83	1.77	32	AV5 -0.03
		0.97	24	AV6 +0.02			0.76	22	AV8 +0.00	92	85	1.38	29	AV7 -0.02
		0.72	21	AV7 +0.02	87	106	0.78	22	AV7 +0.02			1.82	32	AV6 +0.02
80	75	0.70	21	AV5 +0.00			1.18	27	AV5 +0.05			0.89	23	AV5 +0.02
80	77	0.71	21	AV5 +0.05	88	71	2.18	35	AV6 +0.02	92	93	0.64	20	AV5 +0.02
		0.98	25	AV6 +0.05			0.90	24	AV7 +0.02	92	95	0.64	20	AV6 +0.02
81	54	0.64	20	AV6 +0.02			0.86	23	AV5 +0.05			0.79	22	AV5 +0.02
81	66	0.76	22	AV4 +0.03	88	85	0.86	23	AV5 +0.05			0.90	24	AV4 +0.03
		1.37	29	AV5 +0.02			0.77	22	AV7 +0.00	92	99	1.51	30	AV6 +0.02
		1.73	32	AV6 +0.00	88	95	1.09	26	AV5 +0.02			2.15	35	AV5 +0.02
		0.77	22	AV7 +0.02			0.85	23	AV6 +0.02	92	103	0.65	20	AV5 +0.02
82	75	1.05	25	AV5 +0.02			1.13	26	AV7 +0.00			0.88	23	AV4 +0.03
		0.97	24	AV6 +0.02	88	97	1.30	28	AV5 +0.05	93	64	0.86	23	AV6 +0.00
82	99	1.41	29	AV5 +0.05			1.17	27	AV6 +0.02	93	72	0.77	22	AV5 -0.03
		1.19	27	AV6 +0.02			0.80	22	AV3 +0.00	93	82	0.65	20	AV6 -0.03
82	105	0.88	23	AV6 +0.00	88	99	0.94	24	AV4 +0.05			0.98	25	AV5 -0.05
		0.77	22	AV7 +0.00			2.15	34	AV5 +0.05	93	84	0.92	24	AV6 -0.02
		0.67	20	AV5 +0.02			1.22	27	AV6 +0.05			1.31	28	AV5 -0.05
83	64	0.67	20	AV5 +0.02	88	103	1.26	28	AV5 +0.00			1.29	28	AV4 +0.00
83	66	1.16	27	AV5 +0.02			1.53	30	AV6 +0.02	93	86	0.90	24	AV7 -0.05
		0.86	23	AV6 +0.00	89	70	0.84	23	AV6 +0.02			0.73	21	AV6 +0.00
83	76	0.76	22	AV6 +0.00			0.69	20	AV7 +0.02			0.78	22	AV5 +0.00
		0.65	20	AV7 +0.05	89	72	0.89	23	AV5 +0.02			0.74	21	AV4 +0.03
83	78	1.32	28	AV5 +0.05			0.68	20	AV7 +0.02	93	92	0.86	23	AV5 -0.03
		0.79	22	AV6 +0.02	89	74	0.77	22	AV6 +0.02			0.68	20	AV7 +0.00
		0.93	24	AV7 +0.02			1.13	26	AV7 +0.00	93	94	1.01	25	AV6 +0.02
83	80	0.64	20	AV5 +0.02	89	82	1.20	27	AV3 +0.02			0.98	25	AV5 +0.05
		0.85	23	AV6 +0.00			1.49	30	AV5 +0.00	93	98	2.43	36	AV7 +0.00
83	84	0.76	22	AV6 +0.05			1.02	25	AV6 +0.02			2.47	36	AV6 -0.02
83	106	0.81	22	AV5 +0.02	89	84	1.25	28	AV4 +0.00			1.64	31	AV5 -0.03
84	73	0.79	22	AV4 +0.05			1.52	30	AV5 +0.00			0.84	23	AV4 +0.00

SL2-26 - 09/21  
Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
93	100	0.89	23	AV4 +0.00	96	107	0.66	20	AV7 +0.02	100	77	2.09	34	AV7 +0.00
94	67	0.72	21	AV6 +0.00			0.84	23	AV6 +0.00			2.64	37	AV6 +0.02
94	69	0.78	22	AV4 +0.00	97	66	1.61	31	AV7 +0.02			1.18	27	AV5 +0.07
94	71	0.71	21	AV6 +0.05			1.55	30	AV6 -0.03			1.06	26	AV3 +0.05
94	77	1.42	29	AV6 +0.00			1.09	26	AV5 -0.03	100	85	0.96	24	AV7 -0.02
		0.90	24	AV5 -0.03	97	76	0.91	24	AV7 +0.00			0.68	20	AV6 +0.00
94	79	0.65	20	AV6 +0.03			1.95	33	AV6 +0.00			0.68	20	AV4 +0.00
94	81	0.83	23	AV6 +0.00			1.26	28	AV4 +0.03	100	87	1.02	25	AV6 +0.00
		0.64	20	AV5 -0.03			1.43	29	AV3 +0.00			1.36	29	AV5 +0.00
		0.68	20	AV4 -0.05	97	84	0.76	21	AV6 +0.02	100	93	0.74	21	AV5 +0.00
94	83	1.29	28	AV6 +0.02			0.99	25	AV5 +0.00	101	64	0.93	24	AV7 +0.05
		2.46	36	AV5 +0.05	97	86	1.50	30	AV7 -0.02			0.76	22	AV6 +0.02
		1.84	33	AV4 +0.13			0.78	22	AV5 +0.00	101	74	0.83	23	AV3 +0.02
		1.29	28	AV3 +0.05			0.97	24	AV4 +0.00	101	76	0.91	24	AV4 +0.03
94	85	0.67	20	AV5 -0.03			0.84	23	AV3 -0.02	101	86	0.75	21	AV7 -0.05
		1.42	29	AV4 -0.05	97	92	0.71	21	AV6 -0.05			1.38	29	AV5 -0.03
		0.85	23	AV3 -0.02			0.92	24	AV5 +0.00			0.79	22	AV4 -0.02
		0.75	21	AV2 +0.00			1.71	32	AV4 -0.02	101	90	0.89	23	AV7 +0.02
94	87	0.97	25	AV5 +0.02			0.91	24	AV3 +0.00	101	98	0.67	20	AV4 +0.06
		0.93	24	AV4 +0.08	97	96	0.75	21	AV7 -0.02			0.76	22	AV3 +0.02
		0.76	22	AV3 +0.02			1.25	28	AV6 +0.00	101	104	1.26	28	AV5 -0.03
94	91	0.93	24	AV6 +0.00	97	98	0.68	20	AV6 +0.02			1.38	29	AV4 +0.00
94	95	0.83	23	AV3 +0.00			0.94	24	AV5 -0.03	102	75	1.01	25	AV7 +0.00
		1.13	26	AV2 +0.00	97	104	0.71	21	AV6 +0.02	102	81	0.76	22	AV6 +0.00
		0.71	21	AV4 -0.02			0.73	21	AV5 -0.03			0.81	22	AV5 +0.02
94	99	1.13	26	AV5 +0.05			0.74	21	AV4 +0.00			0.64	20	AV3 +0.00
		0.74	21	AV4 +0.05	98	67	0.79	22	AV3 +0.05	102	83	1.41	29	AV5 -0.03
95	64	0.78	22	AV7 +0.03	98	75	1.78	32	AV7 -0.02			1.01	25	AV4 -0.05
95	76	0.73	21	AV5 -0.03	98	85	0.76	22	AV7 -0.02	102	85	2.33	36	AV7 -0.02
95	78	0.75	21	AV6 +0.05			1.77	32	AV4 +0.00			2.59	37	AV6 +0.00
		0.94	24	AV5 +0.02			1.79	32	AV3 +0.00			1.09	26	AV3 +0.02
		0.64	20	AV3 +0.02			1.25	28	AV2 +0.00	102	87	2.49	36	AV7 +0.00
95	80	0.81	22	AV7 +0.00	98	87	1.13	26	AV7 -0.02			2.89	38	AV6 -0.03
		1.14	26	AV6 +0.02			1.90	33	AV6 +0.00			1.62	31	AV5 -0.03
		1.35	29	AV5 +0.05	98	91	1.43	29	AV4 +0.00	102	89	1.32	28	AV6 -0.03
		0.81	22	AV4 +0.05	98	95	0.72	21	AV7 +0.00			1.46	30	AV5 -0.03
95	84	1.62	31	AV5 +0.05	98	97	0.71	21	AV4 +0.00			0.68	20	AV4 +0.00
		1.51	30	AV4 +0.08	98	103	0.70	21	AV3 +0.02			1.55	30	AV3 -0.02
		0.92	24	AV3 +0.05	98	107	0.73	21	AV7 +0.00			0.97	24	AV2 +0.00
95	86	1.00	25	AV7 -0.02			1.06	26	AV6 +0.00	102	91	2.16	35	AV7 +0.05
		0.76	22	AV6 +0.02	99	64	2.06	34	AV7 +0.02			1.30	28	AV6 -0.05
		1.67	31	AV5 +0.05			1.72	32	AV6 +0.02			1.39	29	AV5 -0.05
		1.24	28	AV4 +0.05			0.95	24	AV5 +0.00	102	97	0.78	22	AV7 +0.02
		0.72	21	AV3 +0.02	99	66	1.36	29	AV6 +0.00			1.00	25	AV6 -0.02
95	88	1.15	27	AV7 +0.00			2.49	36	AV5 +0.00			1.01	25	AV4 -0.02
		0.70	21	AV6 +0.02			1.36	29	AV4 +0.00			0.73	21	AV5 +0.00
95	90	0.64	20	AV5 +0.00	99	74	0.71	21	AV7 +0.00	103	84	0.68	20	AV7 -0.02
95	92	0.80	22	AV5 +0.02			1.66	31	AV6 +0.00			1.03	25	AV5 -0.03
95	96	1.33	28	AV6 +0.00			1.83	32	AV5 +0.00			1.16	27	AV3 +0.00
		1.50	30	AV5 +0.02	99	76	1.02	25	AV6 +0.00	103	86	1.24	28	AV5 +0.00
		0.81	22	AV4 +0.05	99	82	1.16	27	AV5 -0.08			1.27	28	AV4 +0.00
95	98	0.68	20	AV3 +0.02			0.95	24	AV3 -0.02	104	83	0.80	22	AV5 -0.05
95	104	2.56	37	AV7 +0.02	99	84	1.49	30	AV6 +0.00			1.06	26	AV4 -0.02
		1.28	28	AV6 +0.00			1.96	33	AV5 -0.03	104	87	0.81	22	AV5 -0.03
		0.85	23	AV5 +0.00			1.04	25	AV4 +0.03	104	91	0.87	23	AV5 +0.02
96	71	0.64	20	AV8 +0.02	99	86	2.22	35	AV7 -0.02			0.73	21	AV4 +0.03
		1.85	33	AV7 +0.00			0.81	22	AV6 -0.02			1.18	27	AV3 +0.00
		0.95	24	AV6 +0.00			0.87	23	AV4 +0.05	104	97	1.09	26	AV4 -0.05
96	77	0.87	23	AV3 +0.05			1.04	25	AV3 +0.02	105	72	0.64	20	AV4 +0.03
96	79	0.68	20	AV7 +0.00			0.72	21	AV2 -0.05			0.69	20	AV3 +0.02
		1.52	30	AV6 +0.05	99	92	1.82	32	AV6 +0.05	105	86	0.77	22	AV7 -0.05
		1.12	26	AV5 +0.05			2.24	35	AV5 +0.05			0.81	22	AV6 -0.02
		0.89	23	AV4 +0.05			1.78	32	AV4 +0.05			1.44	29	AV5 -0.06
96	83	0.77	22	AV4 +0.00			1.56	30	AV3 +0.05			1.42	29	AV4 -0.02
96	87	0.98	25	AV6 +0.00			0.76	22	AV2 +0.02	105	96	1.10	26	AV5 +0.00
96	89	0.80	22	AV6 +0.00			0.82	22	AV7 +0.05	106	83	0.83	23	AV4 +0.00
96	93	0.68	20	AV7 +0.02	99	96	1.01	25	AV6 +0.02			0.66	20	AV3 +0.00
		1.28	28	AV6 +0.00			1.77	32	AV5 +0.00	106	85	1.77	32	AV7 +0.00
		1.66	31	AV5 +0.00			1.31	28	AV4 +0.00			2.20	35	AV6 +0.00
96	97	0.97	24	AV6 +0.00	99	98	0.84	23	AV3 +0.05			0.94	24	AV5 -0.03
		0.86	23	AV5 -0.05	99	104	0.66	20	AV4 -0.05			1.70	31	AV3 +0.00
96	105	0.76	22	AV3 +0.00	100	71	0.78	22	AV7 +0.02			0.70	21	AV2 +0.00

SL2-26 - 09/21  
Bobbin AVB Wear 20-39%

ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION	ROW	COL	VOLTS	%TW	LOCATION
106	87	0.73	21	AV3 +0.00			0.65	20	AV4 -0.02	132	73	1.15	27	AV5 +0.00
106	91	0.76	21	AV5 -0.03	115	94	0.93	24	AV5 +0.02	132	91	0.96	24	AV5 +0.05
106	97	1.07	26	AV3 +0.00	115	96	0.70	21	AV6 +0.05	133	70	0.90	24	AV6 -0.02
		0.66	20	AV2 +0.00			1.10	26	AV4 +0.03	133	90	1.22	27	AV8 +0.05
107	78	1.12	26	AV6 +0.02			0.78	22	AV3 +0.00			0.65	20	AV4 -0.02
107	84	0.65	20	AV7 -0.02	116	83	0.89	23	AV4 +0.00	133	92	0.87	23	AV7 +0.00
		1.18	27	AV6 -0.05	116	87	1.26	28	AV7 -0.02	133	102	0.68	20	AV5 +0.09
		1.55	30	AV5 -0.08			0.80	22	AV6 +0.00			1.32	28	AV4 +0.10
107	92	0.97	24	AV4 +0.00	117	84	0.73	21	AV6 -0.02			0.69	20	AV2 +0.02
		1.27	28	AV4 +0.03			0.66	20	AV5 -0.03	134	71	0.71	21	AV7 +0.02
		1.57	30	AV3 +0.05	117	86	1.89	33	AV5 +0.00	134	91	3.13	39	AV8 +0.09
		0.68	20	AV2 +0.00	117	90	0.65	20	AV5 -0.03			0.67	20	AV7 +0.00
107	98	1.10	26	AV5 -0.03	118	83	1.70	32	AV5 -0.03			1.04	25	AV5 -0.05
107	100	0.65	20	AV3 -0.02	118	87	1.12	26	AV5 +0.00			0.73	21	AV4 -0.07
108	83	0.72	21	AV7 -0.02			1.05	25	AV4 -0.02	135	82	0.66	20	AV8 +0.09
		1.75	32	AV6 -0.02	119	82	0.68	20	AV6 +0.00			0.75	21	AV7 +0.07
		0.94	24	AV5 -0.03			1.10	26	AV5 -0.03			0.92	24	AV6 +0.07
108	91	1.37	29	AV5 +0.05	119	84	0.72	21	AV2 -0.02			0.82	22	AV5 +0.07
		1.89	33	AV4 +0.05	120	85	1.32	28	AV7 -0.02			2.51	37	AV4 +0.13
108	95	0.71	21	AV3 +0.05			1.34	28	AV5 -0.03			1.59	31	AV3 +0.05
108	99	0.66	20	AV7 +0.02			0.91	24	AV4 -0.02	135	84	0.96	24	AV4 +0.00
		2.24	35	AV6 +0.00			0.87	23	AV3 +0.00	135	90	1.23	27	AV7 +0.05
		0.71	21	AV4 +0.00	120	91	0.64	20	AV6 -0.05			2.69	37	AV6 -0.02
109	68	0.73	21	AV6 +0.03	121	84	1.01	25	AV6 +0.00			1.05	25	AV4 -0.02
109	72	0.88	23	AV5 -0.03	121	90	1.00	25	AV4 -0.02	135	92	1.76	32	AV7 +0.02
109	84	0.88	23	AV7 +0.00	121	100	1.03	25	AV6 +0.00			1.53	30	AV5 +0.05
		1.67	31	AV5 -0.05			2.68	37	AV5 -0.03	136	83	0.66	20	AV6 +0.00
		1.47	30	AV4 -0.02	122	83	0.96	24	AV4 +0.03	136	87	0.78	22	AV4 -0.07
109	86	0.79	22	AV7 +0.00	122	87	1.22	27	AV6 +0.00	136	91	0.70	21	AV8 +0.10
		1.21	27	AV6 -0.02			1.63	31	AV5 -0.03			2.94	39	AV7 +0.07
		1.36	29	AV5 -0.03			1.80	32	AV4 -0.02			0.65	20	AV6 +0.05
		1.99	34	AV4 -0.05	122	103	0.72	21	AV3 +0.07			0.75	21	AV5 +0.02
109	98	0.89	23	AV4 +0.06	123	84	0.69	20	AV7 +0.00			2.61	37	AV4 +0.03
		1.10	26	AV3 +0.05			0.83	23	AV6 -0.02	138	85	0.86	23	AV6 -0.05
		0.70	21	AV2 +0.00	123	86	0.78	22	AV5 +0.02			1.10	26	AV4 -0.12
109	100	0.92	24	AV6 +0.05	123	90	0.87	23	AV5 +0.00					
110	83	0.89	23	AV5 +0.00			1.57	30	AV4 -0.02					
		0.95	24	AV4 -0.02	123	98	0.86	23	AV3 +0.07					
110	85	1.70	31	AV7 +0.00	124	87	0.96	24	AV5 -0.03					
		1.83	32	AV5 -0.03			0.76	22	AV4 -0.05					
		0.90	24	AV4 -0.02	125	84	0.69	20	AV4 -0.02					
		0.78	22	AV3 -0.02	125	86	1.93	33	AV6 +0.00					
110	87	0.83	23	AV6 +0.02			0.93	24	AV5 -0.03					
		0.68	20	AV3 -0.02			1.41	29	AV4 -0.02					
110	95	1.03	25	AV4 -0.05			0.79	22	AV3 +0.00					
110	101	0.70	21	AV6 +0.02	125	96	0.67	20	AV3 +0.02					
		1.19	27	AV5 +0.00	125	98	1.29	28	AV6 +0.00					
111	84	0.89	23	AV5 -0.05			2.40	36	AV5 +0.02					
		0.90	24	AV4 +0.00	125	102	0.83	23	AV4 -0.05					
		0.88	23	AV3 -0.02	126	103	0.79	22	AV5 -0.03					
111	86	0.94	24	AV7 -0.02	127	86	2.40	36	AV5 +0.00					
		2.09	34	AV6 +0.02	128	53	1.57	30	AV5 -0.03					
		1.10	26	AV4 +0.00	128	85	1.45	29	AV5 +0.00					
111	94	1.06	26	AV5 +0.00			0.89	23	AV3 +0.00					
111	102	1.25	28	AV7 +0.00	129	68	1.12	26	AV4 -0.02					
		1.18	27	AV6 -0.02	129	86	0.79	22	AV6 -0.02					
		2.57	37	AV5 -0.05			0.86	23	AV4 -0.02					
		0.64	20	AV3 +0.00	129	102	0.94	24	AV4 -0.02					
113	88	0.92	24	AV5 +0.00	130	67	1.67	31	AV5 +0.02					
114	83	1.02	25	AV6 +0.00			1.14	26	AV4 +0.05					
		1.85	33	AV5 +0.00	130	69	0.65	20	AV5 -0.03					
114	87	0.96	24	AV5 +0.00	131	70	1.00	25	AV5 +0.07					
		0.86	23	AV4 +0.03	131	86	1.68	31	AV7 +0.05					
		0.98	25	AV3 +0.02			1.15	27	AV6 +0.07					
114	89	0.95	24	AV7 +0.00			0.72	21	AV5 +0.05					
		2.25	35	AV6 -0.02			1.13	26	AV4 +0.05					
		0.85	23	AV5 +0.00	131	90	0.69	20	AV4 +0.00					
115	66	0.73	21	AV7 +0.07	131	102	0.99	25	AV7 +0.05					
115	82	0.68	20	AV5 +0.02			1.33	28	AV6 +0.05					
115	84	1.55	30	AV7 +0.00			0.81	22	AV4 +0.03					
		1.02	25	AV4 +0.03	132	71	0.75	21	AV7 +0.02					
115	88	0.87	23	AV5 -0.03			1.99	34	AV6 +0.00					

Total Tubes : 301  
Total Records: 611