



Barbara E. Dotson
Manager, Regulatory Assurance
Palisades Nuclear Plant
269-764-2265

PNP 2022-002

March 24, 2022

10 CFR 50.46

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: Annual Report of Changes in Emergency Core Cooling System Models

Palisades Nuclear Plant
Docket 50-255
Renewed Facility Operating License No. DPR-20

Reference: 1) Letter FS1-0060893 1.0, dated February 7, 2022, from E. Hunter Marshall, Framatome, to Mr. Jimmy Willoughby, Entergy Services, Inc., "Palisades, Annual 10 CFR 50.46 Report - 2021"

Entergy Nuclear Operations, Inc. (ENO) is submitting the annual report of changes in the emergency core cooling system (ECCS) models for the Palisades Nuclear Plant (PNP). The report is submitted in accordance with 10 CFR 50.46(a)(3)(ii).

Attachment 1 contains the large break loss of coolant accident (LOCA) peak clad temperature (PCT) summary. Attachment 2 contains the small break LOCA PCT summary. This report covers the period from January 1, 2021, through December 31, 2021.

This letter contains no new commitments and no revisions to existing commitments.

Respectfully,

BED/mrp

Attachment 1: Large Break Loss of Coolant Accident Peak Cladding Temperature Summary
Attachment 2: Small Break Loss of Coolant Accident Peak Cladding Temperature Summary

CC Administrator, Region III, USNRC
Project Manager, Palisades, USNRC
Resident Inspector, Palisades, USNRC

**ATTACHMENT 1
LARGE BREAK LOSS OF COOLANT ACCIDENT
PEAK CLADDING TEMPERATURE SUMMARY**

	Δ PCT (°F)	PCT (°F)
PCT (Last Acceptable Model Results) New Cycle 21 Analysis		1740
PCT (2009 Annual Report)		
CR 2009-337 S-RELAP5 Radiation to Fluid Correlation Under Predicts the Radiative Heat Transfer	-27	1713
CR 2009-2309 S-RELAP5 Kinetics and Heat Conduction Model	-22	1691
CR 2009-2360 RODEX TCD (FAB09-306)	0	1691
PCT (2010 Annual Report)		
CR 2010-3095 RLBLOCA & S-RELAP5 – FIJ Multiplier & Underpredicting Liquid Entrained to SG Tubes (FAB10-387)	0	1691
PCT (2011 Annual Report)		
CR 2011-1688 RLBLOCA Upper Plenum Modeling (FAB11-219)	0	
CR 2011-7155 S-RELAP5 Sleicher-Rouse Correlation	+8	1699
PCT (2012 Annual Report)		
CR 2012-2301 Liquid fallback into surrounding 6 assemblies	0	
CR 2012-8277 Cathcart-Pawel Uncertainty Implementation in RLBLOCA Applications (FAB13-00134-001)	0	1699
PCT (2013 Annual Report)		
CR 2013-4230 S-RELAP5 routine associated with the RODEX3a fuel rod model in the code.	+6	1705
PCT (2014 Annual Report)		
CR 2012-8371 S-RELAP5 vapor absorptivity correlation	0	1705
CR 2014-3953 Non-Physical Axial Shapes Generated by Modal Decomposition Procedure	0	1705
PCT (2015 Annual Report)		1705
PCT (2016 Annual Report)		1705
PCT (2017 Annual Report)		1705
PCT (2018 Annual Report)		1705
PCT (2019 Annual Report)		
CR 2019-1130 Cathcart-Pawel Correlation Implementation (FS1-0046435-1.0)	0	1705
PCT (2020 Annual Report)		1705
PCT (2021 Annual Report)		1705
Total Delta	-35	
Total		1705

**ATTACHMENT 2
SMALL BREAK LOSS OF COOLANT ACCIDENT
PEAK CLADDING TEMPERATURE SUMMARY**

	ΔPCT (°F)	PCT (°F)
PCT (Last Acceptable Model Results) New Cycle 21 Analysis		1734
PCT (2009 Annual Report)		
CR 2009-337 S-RELAP5 Radiation to Fluid Correlation Under Predicts the Radiative Heat Transfer	-64	1670
CR 2009-2309 S-RELAP5 Kinetics Model	+4	1674
PCT (2010 Annual Report)		1674
PCT (2011 Annual Report)		1674
PCT (2012 Annual Report)		
CR 2011-7155 S-RELAP5 Sleicher-Rouse Correlation	-3	1671
PCT (2013 Annual Report)		1671
PCT (2014 Annual Report)		
CR 2012-8371 – S-RELAP5 Vapor Absorptivity Correlation	+73	1744
PCT (2015 Annual Report)		1744
PCT (2016 Annual Report)		1744
PCT (2017 Annual Report)		
CR 2017-3565 M5@ LOCA Swelling and Rupture Model (SRM) Update (FAB17-00369)	0	1744
CR 2017-5630 Error in S-RELAP5 Oxidation Calculations (FS1-0035262-1.0)	+17	1761
PCT (2018 Annual Report)		1761
PCT (2019 Annual Report)		1761
PCT (2020 Annual Report)		1761
PCT (2021 Annual Report)		1761
Total Delta	+27	
Total		1761