



Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, Pennsylvania, 16066
USA

U.S. Nuclear Regulatory Commission
Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

Direct tel: 412-374-5093
Direct fax: 724-940-8505
e-mail: harperzs@westinghouse.com

Your Ref: Docket No. 52-006
Our Ref: DCP_NRC_003346

March 18, 2022

Subject: 10 CFR 50.46 Annual Report for the AP1000® Plant Design

Pursuant to 10 CFR 50.46, “Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors”, Westinghouse Electric Company, LLC is submitting this report to document emergency core cooling system (ECCS) evaluation model changes or errors for the 2021 Model Year (i.e., 01/01/2021 – 12/31/2021) that affect the peak cladding temperature (PCT) calculations for the AP1000 plant design.

As described below, two AP1000 analyses of record (AORs) are reported:

AP1000 Design Certification AOR:

On December 30th, 2011, the U.S. Nuclear Regulatory Commission certified an amendment to the Design Certification Rule for the AP1000 plant. As such, AP1000 Design Control Document (DCD) Revision 19 documents the AOR for the AP1000 Design Certification. The limiting transient for the AP1000 Design Certification is the Best Estimate Large Break Loss-of-Coolant Accident (LBLOCA). Westinghouse last provided an annual reporting letter to the NRC in March 2021 (DCP_NRC_003344) which presented an estimated PCT of 2010°F for the LBLOCA evaluation. There are no new ECCS model changes that impact PCT for the 2021 model year. The estimated PCT for LBLOCA remains at 2010°F and does not exceed the 10 CFR 50.46 (b)(1) acceptance criterion of 2200°F.

The summary of the PCT margin allocations and their bases for the AP1000 Design Certification AOR are provided in the Attachment 1.

AP1000 Vogtle Units 3 & 4 AOR:

In addition to the AOR for the AP1000 Design Certification, the NRC has approved the AP1000 Core Reference Report (WCAP-17524-P-A), a generic topical which includes an ECCS “reanalysis” in the context of 10 CFR 50.46. The AOR contained in the Core Reference Report (CRR) has also been approved for incorporation into the Vogtle Units 3 & 4 licenses via NRC License Amendment 52. Westinghouse last provided an annual reporting letter to the NRC in March 2021 (DCP_NRC_003344) which presented an estimated PCT of 2046°F for the LBLOCA evaluation. There are no new ECCS model changes that impact the limiting LBLOCA PCT for

AP1000 is a trademark or registered trademark of Westinghouse Electric Company LLC, its affiliates and/or its subsidiaries in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners

the 2021 model year. As such, the estimated PCT for LBLOCA is 2046°F and does not exceed the 10 CFR 50.46 (b)(1) acceptance criterion of 2200°F.

Additionally, changes as part of the Automatic Depressurization System (ADS) and Core Makeup Tank (CMT) design parameters changes included in LAR-19-009 constitute a “reanalysis” in the context of 10 CFR 50.46 for the small break loss of coolant accident (SBLOCA) analysis and have been approved for incorporation into the Vogtle Units 3&4 licenses via NRC License Amendments 176 (Unit 3) and 175 (Unit 4). There are no new ECCS model changes that impact the limiting SBLOCA PCT for the 2021 model year. The estimated LBLOCA PCT continues to be the limiting estimated PCT following the SBLOCA reanalysis.

The summary of the PCT margin allocations and their bases for the AP1000 Vogtle Units 3 & 4 AOR are provided in the Attachment 2.

By copy of this letter, COL Holders and COL Applicants are hereby notified of any changes or errors in the AP1000 standard plant design PCT calculations as required by 10 CFR 50.46(a)(3)(iii). This letter contains site-specific evaluations for Vogtle Units 3 & 4.

Questions or requests for additional information related to content and preparation of this information should be directed to Westinghouse. Please send copies of such questions or requests to the respective COL Holders and COL Applicants referencing the amended AP1000 Design Certification Rule for the AP1000 nuclear power plant. A representative for each COL Holder and COL Applicant is included on the cc: list of this letter.

Very truly yours,



Zachary S. Harper
Manager, Licensing Engineering

/Attachments

1. 10 CFR 50.46 Annual Report for the AP1000 Design Certification AOR, 2021 Model Year
2. 10 CFR 50.46 Annual Report for the AP1000 Vogtle Units 3 & 4 AOR, 2021 Model Year

Cc:

M. Dudek	- U.S. NRC	A. Zaremba	- Duke/Progress	A. Schoedel	- Westinghouse
B. Smith	- U.S. NRC	S. Franzone	- FPL	M. Yuan	- Westinghouse
A. Chamberlain	- SNC	R. Orthen	- FPL	D. McDevitt	- Westinghouse
J. Baker	- SNC	D. Weaver	- Westinghouse	M. Sheaffer	- Westinghouse
E. Grant	- SNC	A. Konig	- Westinghouse	M. Barca	- Westinghouse
J. Douglass	- SNC	M. Corletti	- Westinghouse	M. Patterson	- Westinghouse

Attachment 1

10 CFR 50.46 Annual Report for the AP1000 Design Certification AOR, 2021 Model Year

GENERAL CODE MAINTENANCE

Background

Various changes have been made to enhance the usability of codes and to streamline future analyses. Examples of these changes include improving the input diagnostic checks; enhancing the code output; optimizing active coding; and eliminating inactive coding. These changes represent Discretionary Changes that will be implemented on a forward-fit basis in accordance with Section 4.1.1 of WCAP-13451.

Affected Evaluation Model(s)

1985 Westinghouse Advanced Plant Small Break LOCA Evaluation Model with NOTRUMP

2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

Estimated Effect

The nature of these changes leads to an estimated peak cladding temperature impact of 0°F.

LOCA Peak Cladding Temperature (PCT) Summary

Plant Name: AP1000
Utility Name: Westinghouse Nuclear Power Plants
EM: ASTRUM (2004)
AOR Description: Best Estimate Large Break
Summary Sheet Status: DCD

	PCT (°F)	Reference #	Note #
ANALYSIS-OF-RECORD	1837	1	

	Delta PCT (°ΔF)	Reference #	Note #	Reporting Year**
ASSESSMENTS*				
1. Evaluation of Pellet Thermal Conductivity Degradation and Peaking Factor Burndown	139	2		2012
2. Revised Heat Transfer Multiplier Distributions	11	3		2013
3. Error in Burst Strain Application	23	4		2013

AOR + ASSESSMENTS PCT = 2010.0 °F

* The licensee should determine the reportability of these assessments pursuant to 10 CFR 50.46.

** The "Reporting Year" refers to the annual reporting year in which this assessment was included.

REFERENCES

- 1 APP-GW-GL-700, Revision 19, "AP1000 Design Control Document," June 2011.
- 2 LTR-LIS-12-288, "Information Regarding the Evaluation of Fuel Pellet Thermal Conductivity Degradation and Peaking Factor Burndown Including Analysis Input Changes for AP1000 Large Break LOCA Analysis," June 2012.
- 3 LTR-LIS-13-357, "AP1000 Plant 10 CFR 50.46 Report for Revised Heat Transfer Multiplier Distributions," July 2013.
- 4 LTR-LIS-14-41, "AP1000 Plant 10 CFR 50.46 Report for the HOTSPOT Burst Strain Error Correction," January 2014.

NOTES:

- (a) None

LOCA Peak Cladding Temperature (PCT) Summary

Plant Name: AP1000
Utility Name: Westinghouse Nuclear Power Plants
EM: NOTRUMP-AP
AOR Description: Appendix K Small Break
Summary Sheet Status: DCD

	PCT (°F)	Reference #	Note #
ANALYSIS-OF-RECORD	1370	1	(a)

	Delta PCT (°ΔF)	Reference #	Note #	Reporting Year**
1. Adiabatic Heat-up Calculation	264	2	(a)	2010

AOR + ASSESSMENTS PCT = 1634.0 °F

* The licensee should determine the reportability of these assessments pursuant to 10 CFR 50.46.

** The "Reporting Year" refers to the annual reporting year in which this assessment was included.

REFERENCES

- 1 APP-GW-GL-700, Revision 19, "AP1000 Design Control Document," June 2011.
- 2 LTR-LIS-10-373, "10 CFR 50.46 Report for the Evaluation of AP1000 SBLOCA 10-inch Transient Adiabatic Heat-up Calculation," June 2010.

NOTES:

- (a) This is an adiabatic heat-up calculated PCT.

Attachment 2

10 CFR 50.46 Annual Report for the AP1000 Vogtle Units 3 & 4 AOR, 2021 Model Year

GENERAL CODE MAINTENANCE

Background

Various changes have been made to enhance the usability of codes and to streamline future analyses. Examples of these changes include improving the input diagnostic checks; enhancing the code output; optimizing active coding; and eliminating inactive coding. These changes represent Discretionary Changes that will be implemented on a forward-fit basis in accordance with Section 4.1.1 of WCAP-13451.

Affected Evaluation Model(s)

1985 Westinghouse Advanced Plant Small Break LOCA Evaluation Model with NOTRUMP

2004 Westinghouse Realistic Large Break LOCA Evaluation Model Using ASTRUM

Estimated Effect

The nature of these changes leads to an estimated peak cladding temperature impact of 0°F.

LOCA Peak Cladding Temperature (PCT) Summary

Plant Name: Vogtle Unit 3 and Unit 4
Utility Name: Southern Nuclear Operating Company
EM: ASTRUM (2004)
AOR Description: Best Estimate Large Break
Summary Sheet Status: Current

	PCT (°F)	Reference #	Note #
ANALYSIS-OF-RECORD	1936	1	(a)

	Delta PCT (°ΔF)	Reference #	Note #	Reporting Year**
ASSESSMENTS*				
1. Revised Heat Transfer Multiplier Distributions	11	2		2013
2. Error in Burst Strain Application	23	3		2013
3. Design Change Rebaseline Evaluation	54	4,5	(b)	2018
4. Evaluation of RCP Design Changes – LAR 189	22	6,7	(c)	2019

AOR + ASSESSMENTS PCT = 2046.0 °F

* The licensee should determine the reportability of these assessments pursuant to 10 CFR 50.46.

** The “Reporting Year” refers to the annual reporting year in which this assessment was included.

REFERENCES

- 1 WCAP-17524-P-A, Revision 1, “AP1000 Core Reference Report,” May 2015.
- 2 LTR-LIS-13-357, “AP1000 Plant 10 CFR 50.46 Report for Revised Heat Transfer Multiplier Distributions,” July 2013.
- 3 LTR-LIS-14-41, “AP1000 Plant 10 CFR 50.46 Report for the HOTSPOT Burst Strain Error Correction,” January 2014.
- 4 LTR-LIS-18-393, “Update to the Vogtle Units 3 & 4 LBLOCA and SBLOCA 10 CFR 50.46 PCT Summary Sheets for LAR-79,” November 2018.
- 5 ND-17-2074 (ML18029A243), “Containment Pressure Analysis (LAR-17-043),” December 2017. Approved by NRC November 7, 2018 as Amendments 147 (VEGP Unit 3) and 146 (VEGP Unit 4) (ML18289A742).
- 6 LTR-LIS-17-39, “AP1000 Plant Suggested 10 CFR 50.46 Reporting Text and Updated LBLOCA PCT Summary Sheet for Evaluation of Reactor Coolant Pump (RCP) Design Changes,” January 2017.
- 7 ND-18-1147 (ML18243A459), “Reactor Coolant System (RCS) Flow Coastdown (LAR-18-025),” August 2018. Approved by NRC February 25, 2019 as Amendments 155 (VEGP Unit 3) and 154 (VEGP Unit 4) (ML19038A450).

NOTES:

- (a) Value contains 2°F bias for PCT sensitivity to PRHR isolation, per Reference 1 response to CRR-008, Table 2 and Table 15.6.5-8.
- (b) The design change rebaseline evaluation used current code versions and accounts for design changes up to May 5, 2014 and plant model error corrections.
- (c) The RCP design changes evaluation assesses the impact of DCP 5338 (APP-GW-GEE-5338), which is tied to DCP 4880 (APP-GW-GEE-4880). The evaluated changes include updated homologous curves and small changes to the pump rated conditions and rotor inertia.

LOCA Peak Cladding Temperature (PCT) Summary

Plant Name: Vogtle Unit 3 and Unit 4
Utility Name: Southern Nuclear Operating Company
EM: NOTRUMP-AP
AOR Description: Appendix K Small Break
Summary Sheet Status: Current

	PCT (°F)	Reference #	Note #
ANALYSIS-OF-RECORD	1099	1	

AOR + ASSESSMENTS PCT = 1099.0 °F

REFERENCES

- 1 ND-19-1142 (ML19273A953), "Automatic Depressurization System (ADS) and Core Makeup Tank (CMT) Design Parameters (LAR-19-009)," September 2019. Approved by NRC March 11, 2020 as Amendments 176 (VEGP Unit 3) and 175 (VEGP Unit 4) (ML20049A721/ML20049A808).

NOTES:

- (a) None