

**From:** Miller, Ed  
**Sent:** Thursday, March 24, 2022 1:56 PM  
**To:** Erica.N.Combs@dominionenergy.com  
**Subject:** Draft RAI for N2-I4-LMT-003  
**Attachments:** Draft RAI for NA2 RR N2-14-LMT-003.docx

Erica,

Attached is the NRC staff's draft RAI for the subject request. The questions are being transmitted to you to determine 1) If the question clearly conveys the NRC information needs, 2) Whether the regulatory basis for the question is clear, and 3) If the information has already been provided in existing docketed correspondence. Additionally, review of the draft question will allow you to determine whether you are able to support a 30 day response time. After you've had a chance to review, please let me know if you would like to have a clarification call. Thank you.

Ed Miller  
(301) 415-2481

**Hearing Identifier:** NRR\_DRMA  
**Email Number:** 1569

**Mail Envelope Properties** (SA1PR09MB74876E4F025D8F4BD81F1147E9199)

**Subject:** Draft RAI for N2-I4-LMT-003  
**Sent Date:** 3/24/2022 1:55:52 PM  
**Received Date:** 3/24/2022 1:55:00 PM  
**From:** Miller, Ed

**Created By:** Ed.Miller@nrc.gov

**Recipients:**  
"Erica.N.Combs@dominionenergy.com" <Erica.N.Combs@dominionenergy.com>  
Tracking Status: None

**Post Office:** SA1PR09MB7487.namprd09.prod.outlook.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	630	3/24/2022 1:55:00 PM
Draft RAI for NA2 RR N2-14-LMT-003.docx		22855

**Options**  
**Priority:** Normal  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**

DRAFT REQUEST FOR ADDITIONAL INFORMATION  
BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELIEF REQUEST N2-14-LMT-003  
FOURTH TEN YEAR INSERVICE INSPECTION INTERVAL  
VIRGINIA ELECTRIC AND POWER COMPANY  
NORTH ANNA POWER STATION UNIT 2  
DOCKET NO. 50-339  
EPID: L-2021-LLR-0088

By letter dated December 13, 2021, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML21348A711), Virginia Electric and Power Company (the licensee), submitted Relief Request (RR) N2-14-LMT-003 to the U.S. Nuclear Regulatory Commission (NRC) for the fourth Inservice Inspection (ISI) interval at North Anna Power Station Unit 2. In RR N2-14-LMT-003, the licensee requested relief from the examination coverage requirements of Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code).

The NRC has determined that the following additional information is necessary to complete its review and make a regulatory decision.

1. What are the ASME code classes for welds 10, 19, and 8 in Section R2 "Elements Subject to Intergranular or Transgranular Stress Corrosion Cracking" of the RR N2-14-LMT-003?