



10 CFR 50.54(q)

LR-N22-0039
April 21, 2022

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Salem Nuclear Generating Station, Units 1 and 2
Renewed Facility Operating License Nos. DPR-70 and DPR-75
NRC Docket Nos. 50-272 and 50-311

Hope Creek Generating Station
Renewed Facility Operating License No. NPF-57
NRC Docket No. 50-354

Subject: Emergency Plan Document Revisions Implemented March 24, 2022.

Pursuant to 10 CFR 50.54(q) and 10 CFR 50.4(b)(5), PSEG Nuclear LLC (PSEG) is submitting 10 CFR 50.54(q) Summary Analysis Report numbered 2022-03 for the revision to procedures EP-SA-325-141, Salem Emergency Classification Guide Wall Chart, EP-SA-325-117, Salem Section S - S4 – RCS Activity, and EP-SA-325-217, Salem Section S EAL Technical Basis implemented on March 24, 2022 (Attachments 1, 2, 3 and 4).

There are no regulatory commitments contained in this letter.

Should you have any questions, or require further information regarding this submittal, please contact Ms. Megean M. Brown (856) 339-1773.

Respectfully,

Stephen T. Barr
Manager, Emergency Preparedness

LR-N22-0039

Attachment 1 – 10 CFR 50.54(q) Summary Analysis Report 2022-03

Attachment 2 – EP-SA-325-141 – Salem Emergency Classification Guide Wall Chart

Attachment 3 – EP-SA-325-117 – Salem Section S - S4 – RCS Activity

Attachment 4 – EP-SA-325-217 – Salem Section S EAL Technical Basis

cc (w/ Attachments): USNRC Administrator, Region I
 USNRC Project Manager
 USNRC Senior Resident Inspector, Salem
 USNRC Senior Resident Inspector, Hope Creek

(w/o Attachments): NJDEP Bureau of Nuclear Engineering
 PSEG Corporate Commitment Tracking Coordinator

ATTACHMENT 1

10 CFR 50.54(q) Summary Analysis Report 2022-03

ATTACHMENT 3
10CFR50.54(q) SUMMARY ANALYSIS REPORT

Page 1 of 3
Revision 0

50.54Q I.D. Number: 2022-03

50.54Q Title: **Revision to Emergency Action Level (EAL) SU4.2:
EP-SA-325-117, Rev. 1, RCS Activity (Flow Chart)
EP-SA-325-217, Rev. 1, RCS Activity (Technical Basis)
EP-SA-325-141, Rev. 2, EAL Wall Chart – Hot Conditions**

(Doc #, Rev. #, Name, If applicable)

Description of the change made to the Emergency Plan/Procedures:

EAL SU4.2, as defined in EP-SA-325-117, EP-SA-325-217 and EP-SA-325-141, is being revised IAW Technical Specification Amendment Nos. 337 and 318 (LAR S20-01). The amendment removed Figure 3.4-1 and associated references from the Technical Specifications for both Salem U1 (TS 3.4.8) and Salem U2 (TS 3.4.9), and inserts a limit of less than or equal to the site-specific Dose Equivalent Iodine (DEI) spiking limit of 60 microcuries per gram. A new specific activity for Dose Equivalent Xe-133 (DEX) is also implemented by this amendment. The Technical Specifications have been modified to provide an action for when DEX is not $\leq 600 \mu\text{Ci}/\text{gram}$, and to remove the limit associated with gross activity of the reactor coolant Ebar (\bar{E}). The site-specific limit of $600 \mu\text{Ci}/\text{gram}$ DEX is established based on the maximum accident analysis RCS activity corresponding to 1 percent fuel clad defects. IAW with the analysis provided in LAR S20-01, if iodine or noble gas spiking were to occur, the normal coolant concentration would be restored within the 48 hour time period provided. Also, there is a low probability of a Steam Line Break (SLB) or Steam Generator Tube Rupture (SGTR) occurring during this time period.

The EAL will be revised to remove the reference to Technical Specification Figure 3.4-1, and replace with the following EAL Threshold values:

SU4.2 Reactor coolant activity > ANY:

- $60 \mu\text{Ci}/\text{gram}$ Dose Equivalent I-131
- $1.0 \mu\text{Ci}/\text{gram}$ Dose Equivalent I-131 for > 48 hrs.
- $600 \mu\text{Ci}/\text{gram}$ Dose Equivalent XE-133 for > 48 hrs.

Description of why the change is editorial (if not editorial, N/A this block):

N/A

ATTACHMENT 3
10CFR50.54(q) SUMMARY ANALYSIS REPORT

Page 2 of 3
Revision 0

50.54Q I.D. Number: 2022-03

50.54Q Title: **Revision to Emergency Action Level (EAL) SU4.2:
EP-SA-325-117, Rev. 1, RCS Activity (Flow Chart)
EP-SA-325-217, Rev. 1, RCS Activity (Technical Basis)
EP-SA-325-141, Rev. 2, EAL Wall Chart – Hot Conditions**

(Doc #, Rev. #, Name, If applicable)

Description of the licensing basis affected by the change to the Emergency Plan/Procedure (if not affected, omit this element):

The following Emergency Plan Sections were reviewed:

- Emergency Plan Section 5.0 - Emergency Classification System
- Emergency Plan Section 6.0 - Notification Methods
- Emergency Plan Section 10.0 - Accident Assessment
- Emergency Plan Section 16.0 - Radiological Emergency Response Training

The emergency plan sections listed above describe methods and processes for accident assessment, classification and notifications, as well as training requirements. These sections do not specify emergency action thresholds or specific activity limits for reactor coolant and therefore are not impacted by the proposed change.

A description of how the change to the Emergency Plan/Procedures still complies with regulation:

The addition of the specific activity limits (e.g. DEX) is consistent with guidance provided in NEI 99-01, Revision 6 that states: *Developers may reword the EAL to include the reactor coolant activity parameter(s) specified in Technical Specifications and the associated allowable limit(s) (e.g., values for dose equivalent 1-131 and gross activity, time-dependent or transient values, etc.). If this approach is selected, all RCS activity allowable limits should be included.*

For 10 CFR 50.47(b)(4), Emergency Classification System, Reg. Guide 1.219 states that the following examples would generally not require prior NRC approval:

(1) A change to an EAL numeric threshold to reflect an approved change in a technical specification, provided that the basis of the approved EAL is unchanged (e.g., an EAL basis refers to a particular technical specification but not a limiting condition for operation value), and (2) A change to an EAL numeric threshold to reflect a change in a plant design parameter, instrument response characteristics, or design calculation, provided that the meaning or intent of the basis of the approved EAL is unchanged.

The proposed change complies with 10 CFR 50 Appendix E, Regulatory Guide 1.219, Revision 1, 10 CFR 50.47, and with industry guidance in NEI 99-01, Revision 6.

ATTACHMENT 3
10CFR50.54(q) SUMMARY ANALYSIS REPORT

Page 3 of 3

Revision 0

50.54Q I.D. Number: 2022-03

50.54Q Title: **Revision to Emergency Action Level (EAL) SU4.2:**
EP-SA-325-117, Rev. 1, RCS Activity (Flow Chart)
EP-SA-325-217, Rev. 1, RCS Activity (Technical Basis)
EP-SA-325-141, Rev. 2, EAL Wall Chart – Hot Conditions

(Doc #, Rev. #, Name, If applicable)

A description of why the proposed change was not a reduction in the effectiveness of the Emergency Plan/Procedure:

The proposed revision aligns with Technical Specification Amendment Nos. 337 and 318 (LAR S20-01) that affects Technical Specifications for both Salem U1 (TS 3.4.8) and Salem U2 (TS 3.4.9). The EAL change will require training be provided to Operations personnel through the Licensed Operator Training program. Training for the Emergency Coordinators in the TSC and EOF and their Direct Reports will be provided through Emergency Preparedness Focus Area Drills (FADs).

There is no reduction in effectiveness to the Emergency Plan resulting from the proposed change to EAL SU4.2, as defined in EP-SA-325-117, EP-SA-325-217, and EP-SA-325-141.

ATTACHMENT 2

**EP-SA-325-141
Salem Emergency Classification Guide Wall Chart**

		GENERAL EMERGENCY Implement Att. 4	SITE AREA EMERGENCY Implement Att. 3	ALERT Implement Att. 2	UNUSUAL EVENT Implement Att. 1 (Att. 24 for Common Site)																													
S System Malfunc.	1 Loss of AC Power	Prolonged loss of ALL offsite and ALL onsite AC power to vital buses SG1.1 [1 2 3 4] Loss of ALL offsite and ALL onsite AC power to 4 KV vital buses AND EITHER of the following: • Restoration of at least one vital bus in < 4 hrs is NOT likely (Note 1) • CFST Core Cooling RED path conditions met	Loss of ALL offsite power and ALL onsite AC power to vital buses for 15 minutes or longer SS1.1 [1 2 3 4] Loss of ALL offsite and ALL onsite AC power to 4 KV vital buses for ≥ 15 min. (Note 1)	Loss of ALL but one AC power source to vital buses for 15 minutes or longer SA1.1 [1 2 3 4] AC power capability to 4 KV vital buses reduced to a single power source for ≥ 15 min. (Note 1) AND ANY additional single power source failure will result in loss of ALL AC power to SAFETY SYSTEMS	Loss of ALL offsite AC power capability to vital buses for 15 minutes or longer SU1.1 [1 2 3 4] Loss of ALL offsite AC power to 4 KV vital buses for ≥ 15 min. (Note 1)																													
	2 Loss of DC Power	Loss of ALL vital AC and vital DC power sources for 15 minutes or longer SG2.1 [1 2 3 4] Loss of ALL offsite and ALL onsite AC power to 4 KV vital buses for ≥ 15 min. AND EITHER: • < 114 VDC bus voltage indications on ALL 125 VDC vital buses for ≥ 15 min. • < 25 VDC bus voltage indications on both 28 VDC vital buses for ≥ 15 min. (Note 1)	Loss of ALL vital DC power for 15 minutes or longer SS2.1 [1 2 3 4] < 114 VDC bus voltage indications on ALL 125 VDC vital buses for ≥ 15 min. OR < 25 VDC bus voltage indications on both 28 VDC vital buses for ≥ 15 min. (Note 1)	None	None																													
	3 Loss of CR Indications	None	Table S-2 Significant Transients • Automatic turbine runback > 25% thermal reactor power • Electrical load rejection > 25% full electrical load • Reactor Trip • Safety Injection Activation		UNPLANNED loss of Control Room indications for 15 minutes or longer with a significant transient in progress SA3.1 [1 2 3 4] An UNPLANNED event results in the inability to monitor one or more Table S-1 parameters from within the Control Room for ≥ 15 min. (Note 1) AND ANY significant transient is in progress, Table S-2	UNPLANNED loss of Control Room indications for 15 minutes or longer SU3.1 [1 2 3 4] An UNPLANNED event results in the inability to monitor one or more Table S-1 parameters from within the Control Room for ≥ 15 min. (Note 1)																												
	4 RCS Activity	None	None	Table S-1 Safety System Parameters • Reactor power • RCS level • RCS pressure • CET temperature • Level in at least one SG • Auxiliary or emergency feedwater flow to at least one SG		Reactor coolant activity greater than Technical Specification allowable limits SU4.1 [1 2 3 4] Letdown Line Monitor readings indicating fuel clad degradation based on receipt of EITHER of the following (Note 11): • 1R31A in warning • 2R31 in alarm SU4.2 [1 2 3 4] Reactor coolant activity > ANY: (Note 11) • 60 µCi/gram DOSE EQUIVALENT I-131 • 1.0 µCi/gram DOSE EQUIVALENT I-131 for > 48 hrs. • 600 µCi/gram DOSE EQUIVALENT XE-133 for > 48 hrs.																												
	5 RCS Leakage	None	None	None	RCS leakage for 15 minutes or longer SU5.1 [1 2 3 4] RCS UNIDENTIFIED or PRESSURE BOUNDARY LEAKAGE > 10 gpm for ≥ 15 min. OR RCS IDENTIFIED LEAKAGE > 25 gpm for ≥ 15 min. OR Leakage from the RCS to a location outside containment > 25 gpm for ≥ 15 min. (Notes 1, 11)																													
	6 RPS Failure	None	Inability to shutdown the reactor causing a challenge to RCS water level or RCS heat removal SS6.1 [1 2] An automatic or manual trip did NOT shut down the reactor as indicated by reactor power ≥ 5% AND ALL actions to shut down the reactor are NOT successful as indicated by reactor power ≥ 5% AND EITHER: • CFST Core Cooling RED path conditions met • CFST Heat Sink RED path exists due to actual loss of secondary heat sink and heat sink is required	Automatic or manual trip fails to shut down the reactor and subsequent manual actions taken at the reactor control consoles are NOT successful in shutting down the reactor SA6.1 [1 2] An automatic or manual trip did NOT shut down the reactor as indicated by reactor power ≥ 5% AND Manual trip actions taken at the reactor control console (reactor trip switches, trip bkr bezels, supply breakers 1/2E6D and 1/2G6D) are NOT successful in shutting down the reactor as indicated by reactor power ≥ 5% (Note 8)	Automatic or manual trip fails to shut down the reactor SU6.1 [1 2] An automatic or manual trip did NOT shut down the reactor after ANY RPS setpoint is exceeded or a manual trip action was initiated AND A subsequent automatic trip or manual trip action taken at the reactor control console (reactor trip switches, trip bkr bezels, supply breakers 1/2E6D and 1/2G6D) is successful in shutting down the reactor as indicated by reactor power < 5% (Note 8)																													
	7 Loss of Commun.	None	None	Table S-3 Communications Methods <table border="1" style="width: 100%;"><thead><tr><th>System</th><th>Onsite</th><th>Offsite</th><th>NRC</th></tr></thead><tbody><tr><td>Direct Inward Dial System (DID)</td><td>X</td><td>X</td><td>X</td></tr><tr><td>Station Page System (Galtronics)</td><td>X</td><td></td><td></td></tr><tr><td>Station Radio System</td><td>X</td><td></td><td></td></tr><tr><td>Nuclear Emergency Telephone System (NETS)</td><td></td><td>X</td><td>X</td></tr><tr><td>Centrex Phone System (ESSX)</td><td></td><td>X</td><td>X</td></tr><tr><td>NRC (ENS)</td><td></td><td></td><td>X</td></tr></tbody></table>		System	Onsite	Offsite	NRC	Direct Inward Dial System (DID)	X	X	X	Station Page System (Galtronics)	X			Station Radio System	X			Nuclear Emergency Telephone System (NETS)		X	X	Centrex Phone System (ESSX)		X	X	NRC (ENS)			X	Loss of ALL onsite or offsite communications capabilities SU7.1 [1 2 3 4] Loss of ALL Table S-3 onsite communication methods OR Loss of ALL Table S-3 offsite communication methods OR Loss of ALL Table S-3 NRC communication methods
	System	Onsite	Offsite	NRC																														
	Direct Inward Dial System (DID)	X	X	X																														
Station Page System (Galtronics)	X																																	
Station Radio System	X																																	
Nuclear Emergency Telephone System (NETS)		X	X																															
Centrex Phone System (ESSX)		X	X																															
NRC (ENS)			X																															
8 CMT Failure	NOTES Note 1: The Emergency Coordinator should declare the event promptly upon determining that time limit has been exceeded, or will likely be exceeded. Note 8: A manual trip action is ANY operator action, or set of actions, which causes the control rods to be rapidly inserted into the core, and does NOT include manually driving in control rods or implementation of boron injection strategies. Note 10: One full train of depressurization equipment consists of EITHER: • at least 5 CFCUs running in low speed with NO Containment Spray train in service • at least 3 CFCUs running in low speed with one Containment Spray train in service Note 11: Refer to the Fission Product Barrier Table for possible event escalation due to RCS leakage or high RCS activity. Note 12: If the affected SAFETY SYSTEM train was already inoperable or out of service before the hazardous event occurred, then emergency classification is NOT warranted. Note 13: If the hazardous event ONLY resulted in VISIBLE DAMAGE , with NO indications of degraded performance to at least one train of a SAFETY SYSTEM , then this emergency classification is NOT warranted.		Table S-4 Hazardous Events • Seismic event (earthquake) • Internal or external FLOODING event • High winds or tornado strike • FIRE • EXPLOSION • Other events with similar hazard characteristics as determined by the Shift Manager																															
9 Hazardous Event Affecting Safety Systems			Hazardous event affecting SAFETY SYSTEMS needed for the current operating mode SA9.1 [1 2 3 4] The occurrence of ANY Table S-4 hazardous event AND Event damage has caused indications of degraded performance on one train of a SAFETY SYSTEM needed for the current operating mode AND EITHER: • Event damage has caused indications of degraded performance on the second train of the SAFETY SYSTEM needed for the current operating mode • Event damage has resulted in VISIBLE DAMAGE to the second train of the SAFETY SYSTEM needed for the current operating mode (Notes 12, 13)																															

Use of Fission Product Barrier Table				Salem – Fission Product Barrier Table					
MODEs [1 2 3 4]				Fuel Clad Barrier		Reactor Coolant System Barrier		Containment Barrier	
				Potential Loss (4 pts)	Loss (5 pts)	Potential Loss (4 pts)	Loss (5 pts)	Potential Loss (2 pts)	Loss (3 pts)
RCS or SG Tube Leakage	None			None	None	RB1.P RCS leakage > 50 gpm due to EITHER: • UNISOLABLE RCS leakage • SG tube leakage	RB1.L An automatic or manual ECSS (SI) actuation required by EITHER: • UNISOLABLE RCS leakage • SG tube RUPTURE	None	CB1.L A leaking or RUPTURED SG is FAULTED outside of containment
	Inadequate Heat Removal	FB1.P CFST Core Cooling PURPLE path conditions met	FB1.L CFST Core Cooling RED path conditions met	RB2.P CFST Thermal Shock RED path conditions met	RB2.L CFST Heat Sink RED path exists due to actual loss of secondary heat sink and heat sink is required	None	CB1.P CFST Core Cooling RED path conditions met AND Restoration procedure 1(2)EOP-FRCC-1 NOT effective within 15 min.	None	None
CMT Radiation / RCS Activity		None	FB2.L Containment radiation monitor 1(2)R44A or 1(2)R44B reading > 300 R/hr	None	FB3.L Coolant activity > 300 µCi/gm dose equivalent I-131	None	CB2.L ANY of the following containment radiation monitor readings: • 1(2)R2 > 1000 mR/hr • 1(2)R44A > 10 R/hr • 1(2)R44B > 10 R/hr	CB2.P Containment radiation monitor 1(2)R44A or 1(2)R44B reading > 2000 R/hr	None
	CMT Integrity or Bypass	None	None	None	None	None	CB3.P CFST Containment RED path conditions met	CB4.P Containment hydrogen concentration > 4%	CB2.L Containment isolation is required AND EITHER: • Containment integrity has been lost based on Emergency Coordinator judgment • UNISOLABLE pathway from containment to the environment exists
EC Judgment		FB3.P ANY condition in the opinion of the Emergency Coordinator that indicates potential loss of the Fuel Clad barrier	FB4.L ANY condition in the opinion of the Emergency Coordinator that indicates loss of the Fuel Clad barrier	RB4.P ANY condition in the opinion of the Emergency Coordinator that indicates potential loss of the RCS barrier	RB3.L ANY condition in the opinion of the Emergency Coordinator that indicates loss of the RCS barrier	CB5.P Containment pressure > 15 psig with < one full train of containment depressurization equipment operating per design for ≥ 15 min. (Notes 1, 10)	CB6.P ANY condition in the opinion of the Emergency Coordinator that indicates potential loss of the Containment barrier	CB3.L Indications of RCS leakage outside of containment	CB4.L ANY condition in the opinion of the Emergency Coordinator that indicates loss of the Containment barrier

Modes:	1 Power Operations	2 Startup	3 Hot Standby	4 Hot Shutdown	EAL WALL CHART - HOT CONDITIONS (RCS > 200°F)	SALEM GENERATING STATION	EAL WALL CHART (HOT) EP-SA-325-141 Revision 02
---------------	------------------------------	---------------------	-------------------------	--------------------------	---	--------------------------	--

ATTACHMENT 3

**EP-SA-325-117, Salem Section S
S4 – RCS Activity**

Section S – System Malfunction

S4 – RCS Activity

Initiating Condition

Reactor coolant activity greater than Technical Specification allowable limits

MODE

1, 2, 3, 4

EAL #

SU4.1
IF

SU4.2
IF

EMERGENCY ACTION LEVELS

Letdown Line Monitor readings indicating fuel clad degradation based on receipt of **EITHER** of the following:

- 1R31A in warning
- 2R31 in alarm

(Note 11)

Reactor coolant activity > **ANY**:

- **60 µCi/gram DOSE EQUIVALENT I-131**
- **1.0 µCi/gram DOSE EQUIVALENT I-131 for > 48 hrs.**
- **600 µCi/gram DOSE EQUIVALENT XE-133 for > 48 hrs.**

(Note 11)

THEN

THEN

Action Required

Refer to Attachment 1
UNUSUAL EVENT

Refer to Attachment 1
UNUSUAL EVENT

Note 11: Refer to the Fission Product Barrier Table for possible event escalation due to RCS leakage or high RCS activity

ATTACHMENT 4

**EP-SA-325-217, Salem Section S
EAL Technical Basis**

EAL Category:	S – System Malfunction
EAL Subcategory:	4 – RCS Activity
Initiating Condition:	Reactor coolant activity greater than Technical Specification allowable limits
Mode Applicability:	1 - Power Operations, 2 - Startup, 3 - Hot Standby, 4 - Hot Shutdown
EAL# & Classification Level:	SU4.1 – UNUSUAL EVENT

EAL:

Letdown Line Monitor readings indicating fuel clad degradation based on receipt of **EITHER** of the following (Note 11):

- 1R31A in warning
- 2R31 in alarm

Note 11: Refer to the Fission Product Barrier Table for possible event escalation due to RCS leakage or high RCS activity.

Basis:

This EAL addresses a reactor coolant activity value that exceeds an allowable limit specified in Technical Specifications. This condition is a precursor to a more significant event and represents a potential degradation of the level of safety of the plant.

Escalation of the emergency classification level would be via category F or category R ICs.

Explanation/Discussion/Definitions:

Letdown Line Monitors serve as a failed fuel detector by monitoring gamma levels in the reactor coolant letdown line. Unit 1 Letdown Line Monitor (1R31A) and Unit 2 Letdown Line Monitor (2R31) measures letdown line activity. The Letdown Line Monitor “warning” setpoints are administratively set at 50% of the “alarm” setpoints.

- 1R31A “alarm” setpoint is based on 1% failed fuel. The “warning” setpoint represents about 0.5% failed fuel and has been selected because the setpoint would be readily identifiable on Control Room instrumentation.

- 2R31 “alarm” setpoint is based on 0.1% failed fuel. This setpoint is readily identifiable and also representative of typical values of coolant activity at Technical Specification limits.

Read-outs for these monitors can be obtained in the Control Room.

Other radiation monitors that may be used to confirm a **VALID** Letdown Line Monitor alarm include:

- 1(2)R4 Charging Pump Room
- 1(2)R26 Reactor Coolant Filter
- Containment Area Rad Monitors (1(2)R2, 1(2)7, 1(2)10A, 1(2)10B)

Definitions:

VALID: An indication, report, or condition, is considered to be valid when it is verified by (1) an instrument channel check, or (2) indications on related or redundant indicators, or (3) by direct observation by plant personnel, such that doubt related to the indicator’s operability, the condition’s existence, or the report’s accuracy is removed. Implicit in this definition is the need for timely assessment

EAL Bases Reference(s):

1. NEI 99-01, Rev. 06, SU3 Example EAL #1
2. PSBP 315733 Radiation Monitoring System Manual, Unit 1
3. PSBP 315734 Radiation Monitoring System Control Manual, Unit 2
4. UFSAR 9.3.5.3 Safety Evaluation (Failed fuel Detection System)
5. UFSAR 11.4 Radiological Monitoring
6. S1(S2).OP-AB.RC-0002 (Q) High Activity in the Reactor Coolant System

EAL Category: S – System Malfunction

EAL Subcategory: 4 – RCS Activity

Initiating Condition: Reactor coolant activity greater than Technical Specification allowable limits

Mode Applicability: 1 - Power Operations, 2 - Startup, 3 - Hot Standby, 4 - Hot Shutdown

EAL# & Classification Level: **SU4.2 – UNUSUAL EVENT**

EAL:

Reactor coolant activity > **ANY**:

- **60 µCi/gram DOSE EQUIVALENT I-131**
- **1.0 µCi/gram DOSE EQUIVALENT I-131 for > 48 hrs.**
- **600 µCi/gram DOSE EQUIVALENT XE-133 for > 48 hrs.**

(Note 11)

Note 11: Refer to the Fission Product Barrier Table for possible event escalation due to RCS leakage or high RCS activity.

Basis:

This EAL addresses a reactor coolant activity value that exceeds an allowable limit specified in Technical Specifications. This condition is a precursor to a more significant event and represents a potential degradation of the level of safety of the plant.

Escalation of the emergency classification level would be via category F or Category R ICs.

Explanation/Discussion/Definitions:

An **UNUSUAL EVENT** is only warranted when actual fuel clad damage is the cause of the elevated coolant sample (as determined by RCS sample analysis confirmation).

Escalation to an **ALERT** or higher emergency classification occurs if a sample analysis of reactor coolant activity exceeds 300 µCi/gm DEI-131 via fission product barrier monitoring.

EAL Bases Reference(s):

1. NEI 99-01, Rev. 06, SU3, Example EAL #2

2. SGS Technical Specification Section 3.4.8 - Unit 1 Specific Activity
3. SGS Technical Specification Section 3.4.9 - Unit 2 Specific Activity
4. S1(S2).OP-AB.RC-0002(Q) High Activity in Reactor Coolant System

This page intentionally blank