



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

May 17, 2022

Mr. Daniel G. Stoddard  
Senior Vice President and  
Chief Nuclear Officer  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: SUMMARY OF APRIL 13, 2022, PUBLIC MEETING WITH VIRGINIA ELECTRIC AND POWER COMPANY REGARDING ITS PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE THE AUXILIARY FEEDWATER SYSTEM ALLOWED OUTAGE TIME FOR SURRY POWER STATION, UNITS 1 AND 2 (EPID L-2022-LRM-0028)

Dear Mr. Stoddard:

On April 13, 2022, an observation public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Virginia Electric and Power Company (the licensee) via a webinar. The purpose of the meeting was for the licensee to discuss its plans to submit a proposed license amendment request (LAR) to change Technical Specification 3.6.1.2 to allow the auxiliary feedwater system allowed outage time for the Surry Power Station, Units 1 and 2, to be extended from 72 hours to 10 days.

The meeting notice and agenda, dated March 29, 2022, is available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML22088A117. The licensee's slide presentation associated with the meeting is available at ADAMS Accession No. ML22097A226.

The NRC staff questioned the licensee regarding the following points during its discussions with the licensee:

1. The licensee's risk assessment results and licensee's assertion that six Findings and Observations (F&Os) of the Probability Risk Assessment (PRA) model have no impact on this LAR. The licensee stated that each of these F&Os will be listed in the LAR and the basis for why each has no impact will be provided.
2. The licensee's proposed Technical Specification (TS) text change and the use of the word maintenance needs to be fully defined, documented and bounded to identify the actions and conditions which constitute maintenance for the proposed extension of the allowed outage time.
3. Any relevant PRA information already on the NRC docket should be referenced.
4. Fully describe the use, staging and water sources for the Flex pumps including hook-up locations and limits on fire events actions/support.
6. All compensatory measures.
7. Possible need for an audit to consider analysis and PRA results.

D. Stoddard

8. Confirmation of procedures and actions to verify the operational status of the opposite unit during the 10-day allowed outage time.
9. If the submittal will be risk-informed, the submittal should address Regulatory Guide (RG) 1.177, "Plant-Specific, Risk-Informed Decisionmaking Technical Specifications," Revision (Rev.) 2 and RG 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," Rev. 3 or justify alternatives.

No regulatory decisions were made as a result of the meeting. Members of the public were in attendance. Public meeting feedback forms were not received.

If you have any questions, please contact me at (301) 415-5136, or via email at [John.Klos@nrc.gov](mailto:John.Klos@nrc.gov).

Sincerely,

*/RA/*

John Klos, Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-280 and 50-281

Enclosure:  
List of Attendees

cc: Listserv

LIST OF ATTENDEES

APRIL 13, 2022 PRE-SUBMITTAL TELECONFERENCE

WITH VIRGINIA ELECTRIC AND POWER COMPANY

REGARDING PROPOSED LICENSE AMENDMENT TO

CHANGE THE AUXILIARY FEEDWATER SYSTEM ALLOWED OUTAGE TIME

FOR SURRY POWER STATION, UNITS 1 AND 2,

DOCKET NOS. 50-280 AND 50-281

**U.S. Nuclear Regulatory Commission**

John Klos  
Angelo Stubbs  
Bart Fu  
Charles Moulton  
Clinton Ashley  
Joshua Wilson  
Robert Vettori  
Brian Towne  
Steward Bailey  
Brian Wittick

**Virginia Electric and Power Company**

Gary Miller  
Robert Ewing  
John Harrell  
Fred Mladen  
John Henderson  
David Wilson  
Adina LaFrance  
Maria Groshner

**Members of the Public**

No members of the public participated

D. Stoddard

SUBJECT: SUMMARY OF APRIL 13, 2022, PUBLIC MEETING WITH VIRGINIA ELECTRIC AND POWER COMPANY REGARDING A FUTURE LICENSE AMENDMENT REQUEST TO CHANGE THE AUXILIARY FEEDWATER SYSTEM ALLOWED OUTAGE TIME FOR SURRY POWER STATION, UNITS 1 AND 2 (EPID L-2022-LRM-0028) DATED MAY 17, 2022

DISTRIBUTION:

PUBLIC  
LPL2-1 R/F  
RidsAcrs\_MailCTR Resource  
RidsNrrDorlLpl2-1 Resource  
RidsNrrLAKGoldstein Resource  
RidsNrrPMSurry Resource  
RidsRgn2MailCenter Resource  
ASubbs, NRR  
BFu, NRR  
CMoulton, NRR  
CAshley, NRR  
RVettori, NRR  
BTowne, NRR  
SBailey, NRR  
BWittick, NRR  
CNolan, OEDO

**ADAMS Accession No. ML22115A003**

OFFICE	NRR/DORL/LPL2-1/PM	NRR/ DORL/LPL2-1/LA	NRR/DSS/SCP/BC	NRR/DNRL/NPHP/BC
NAME	JKlos	KGoldstein	BWittick	MMitchell
DATE	04/22/2022	04/25/2022	4/26/2022	04/28/2022
OFFICE	NRR/DRA/APLB/ BC	NRR/DSS/STSB/BC	NRR/DORL/LPL2-1/BC	NRR/DORL/LPL2-1/PM
NAME	JWhitman	VCusumano	MMarkley	JKlos
DATE	05/02/2022	05/06/2022	05/16/2022	05/17/2022

**OFFICIAL RECORD COPY**