

Final ASP Analysis – Precursor

Accident Sequence Precursor Program – Office of Nuclear Regulatory Research		
Davis-Besse Nuclear Power Station	Reactor Trip due to Failed Uninterruptible Power Supply and Steam Feedwater Rupture Control System Actuations	
Event Date: 7/8/2021	LER: 346-2021-003 IR: 05000346/2021050	CCDP = 3×10^{-6}
Plant Type:	Babcock & Wilcox Raised-Loop Pressurized-Water Reactor (PWR) with Large, Dry Containment	
Plant Operating Mode (Reactor Power Level):	Mode 1 (100% Reactor Power)	
Analyst: Christopher Hunter	Reviewer: Mehdi Reisi Fard	Completion Date: 5/6/2022

1 EXECUTIVE SUMMARY

On July 8, 2021, an automatic reactor trip occurred due to de-energization of motor control center (MCC) 'E32A' caused by the failure of breaker 'BE306' during testing. The subsequent failure of an uninterruptible power supply (UPS) caused a loss of power to the main generator automatic voltage regulator (AVR) and resulted in a generator lockout and trip of the main turbine.

Following the reactor trip, overcooling was observed due to loss of power to a moisture separator reheater steam supply second state source valve 'MS199', which caused it to remain open. Operators manually initiated emergency core cooling systems (ECCS) as directed by plant procedures. The steam and feedwater rupture control system (SFRCS) actuated on low level on steam generator (SG) '1' due to the failure of a startup feedwater valve in "automatic" mode. Both turbine-driven auxiliary feedwater (AFW) pumps started, per design. Operators successfully closed 'MS199' approximately 8 minutes after the reactor trip occurred. Decay heat removal was provided by the main condenser and operators subsequently secured the ECCS pumps.

Approximately 2 hours after the reactor trip, low pressure on SG '2' was experienced while operators were transferring gland steam supply from main steam to auxiliary steam, which caused the SFRCS to isolate main feedwater (MFW) and close the main steam isolation valves (MSIVs). Operators took manual control of the atmospheric vent valves (AVVs) to control SG pressure when they failed to operate in automatic mode following the SFRCS actuation. Decay heat removal was maintained through manual control of the AVVs.

The mean conditional core damage probability (CCDP) for this event is calculated to be 3×10^{-6} . This accident sequence precursor (ASP) analysis reveals that the most likely core damage sequence is a loss of condenser heat sink initiating event with successful AFW, but operators fail to initiate high-pressure injection (HPI) prior to a safety features actuation system (SFAS) signal, which results in a loss of reactor coolant pump (RCP) seal cooling and injection and subsequent operator failure to trip the RCPs results in a loss-of-coolant accident (LOCA). HPI is successful, but recirculation fails resulting in core damage. This accident sequence accounts for approximately 48 percent of the total CCDP for this event.

2 EVENT DETAILS

2.1 Event Description

On July 8, 2021, an automatic reactor trip occurred due to de-energization of MCC 'E32A' caused by the failure of breaker 'BE306' during testing. The subsequent failure of an UPS caused a loss of power to the main generator AVR and resulted in a generator lockout and trip of the main turbine.

Following the reactor trip, overcooling was observed due to loss of power to a moisture separator reheater steam supply second state source valve 'MS199', which caused it to remain open. Operators manually initiated ECCS as directed by plant procedures. The SFRCS actuated on low level on SG '1' due to the failure of a startup feedwater valve in "automatic" mode. Both turbine-driven AFW pumps started, per design. Operators successfully closed 'MS199' approximately 8 minutes after the reactor trip occurred. Decay heat removal was provided by the main condenser and operators subsequently secured the ECCS pumps.

Approximately 2 hours after the reactor trip, low pressure on SG '2' was experienced while operators were transferring gland steam supply from main steam to auxiliary steam, which caused the SFRCS to isolate MFW and close the MSIVs. Operators took manual control of the AVVs to control SG pressure when they failed to operate in automatic mode following the SFRCS actuation. Decay heat removal was maintained through manual control of the AVVs.

Additional information is provided in licensee event report (LER) 346-2021-003, "Reactor Trip due to Failed Uninterruptible Power Supply and Steam Feedwater Rupture Control System Actuations," ([ML21250A131](#)) and inspection report (IR) 05000346/2021050, "Davis-Besse Nuclear Power Station – Special Inspection Reactive Report 05000346/2021050 and Apparent Violation," ([ML21321A365](#)).

2.2 Cause

The direct cause of the reactor trip was that with the AVR aligned to MCC 'E32A', a failure of breaker 'BE306' to close along with a failure of a battery within the digital electro-hydraulic control (DEHC) UPS caused a loss of control power to the automatic transfer switch (ATS), preventing the transfer to the alternate power source. The UPS battery failed due to normal aging. The primary cause of the ATS failure was inadequate licensee review of a change in the ATS control power for impact on the DEHC UPS.

3 MODELING

3.1 SDP Results/Basis for ASP Analysis

The [ASP Program](#) performs independent analyses for initiating events. ASP analyses of initiating events account for all failures/degraded conditions and unavailabilities (e.g., equipment out for maintenance) that occurred during the event, regardless of licensee performance.¹ For this analysis, no windowed events were identified.

¹ ASP analyses also account for any degraded condition(s) that were identified after the initiating event occurred if the failure/degradation exposure time(s) overlapped the initiating event date.

In response to this event, the NRC performed a special inspection per Management Directive 8.3, "NRC Incident Investigation Program" ([ML18073A200](#)). The special inspection, as documented in [IR 05000346/2021050](#), revealed three licensee performance deficiencies. These three inspection findings were associated with the licensee failure to:

- appropriately classify the DEHC UPS battery bank as "non-critical" as required by component classification procedures,
- establish procedural guidance for transferring the gland sealing steam supply from the main steam system to the auxiliary steam system following a reactor trip, and
- have an appropriate procedure for the replacement of main steam line '1' isolation valve limit switch 'ZS101B'.

All three findings were determined to be *Green* (i.e., very low safety significance). The LER remains open.

3.2 Analysis Type

An initiating event analysis was performed using version 8.58 of the standardized plant analysis risk (SPAR) model for Davis-Besse Nuclear Power Plant created in August 2021.

3.3 SPAR Model Modifications

The following SPAR model modifications were made to support this analysis:

- **Overcooling Event**. The failure of MS199 to automatically close after the reactor trip resulted in an overcooling event, which resulted in a quick reactor coolant system (RCS) pressure decrease. Operators manually initiated HPI, taking a suction off the residual heat removal (RHR) pumps (i.e., piggy-back mode), as directed by procedure. This mode of HPI operation has injection pressure of 1800 psig.² RCS pressure reached a low of approximately 1710 psig prior to HPI restoring RCS pressure. This action prevented the automatic actuation of the SFAS when RCS pressure reaches 1600 psig, which would have resulted in the automatic actuation HPI.³ In addition, an SFAS actuation would have resulted in the loss of seal cooling and injection to the RCPs. Operators would then need to trip the RCPs to prevent a failure of the RCP seals and a subsequent LOCA. To model this issue, the loss of condenser heat sink (LOCHS) event tree was modified by adding a new SFAS top event prior to querying the loss of seal cooling (LOSC) top event. The event tree branching was modified that if no SFAS actuation occurs (i.e., success branch) the LOSC fault tree is queried. If an SFAS actuation does occur (i.e., failure branch), then the LOSC-ISINJ is queried. This fault tree assumes the loss of RCP seal cooling and injection. This modified LOCHS event tree is shown in Figure A-1 of [Appendix A](#). The SFAS fault tree includes only a new basic event SFAS-XHE-XL-HPI (*operators fail to manually initiate HPI prior to SFAS signal*).

² Because HPI pump discharge pressure is limited to 1800 psig in "piggy-back" mode, there is no possibility of RCS pressure increase resulting in the pressurizer power-operated relief valves from opening.

³ Operators also successfully closed MS199 in approximately 8 minutes after the reactor trip. However, this action could not be performed in time to prevent an SFAS actuation.

- **Failure of Startup Feedwater Control Valve.** During the event, startup feedwater control valve 'SP7B' should have automatically opened when SG '1' experienced low level. However, a failure of the integrated control system (ICS) module resulted in the failure of 'SP7B'. Operators attempted to take manual control of 'SP7B'; however, they could not restore SG '1' level prior to actuation of SFRCS. Although operators could not restore SG '1' level prior to the SFRCS actuation, operators maintained the ability to manually control MFW and AFW flow via 'SP7B' throughout the event. The base SPAR model does not include this manual action. Therefore, the MFW-SG11-Feed fault tree was modified to account for the manual control of 'SP7B'. Specifically, a new 'AND' gate MFW-AOV-SP7B was added under existing OR gate MFW-AOV-SF7B. Existing basic event MFW-AOV-CC-SP7B (*startup control valve SP7B to SG 1-1 fails to open*) was moved under MFW-AOV-SP7B. In addition, a new basic event MFW-XHE-XM-SP7B (*operators fail to manually open/control SP7B*) was added under gate MFW-AOV-SP7B. The modified MFW-SG11-Feed fault tree is shown Figure B-1 in [Appendix B](#).
- **Failure of AVVs.** After the MSIVs closed, the AVVs should have automatically opened by the plant's ICS. However, failure of two limit switches that provide position indication of the MSIVs resulted in the failure of the AVVs to automatically open. Operators attempted to take control of the AVVs from the main control room (MCR). Subsequently, AVV '2' partially opened and could not be controlled from the MCR due to failure its controller's feedback arm. Operators subsequently isolated its instrument air supply to close AVV '2', and then stationed an operator locally to control the valve via its handwheel, as directed by procedures and training. To account for the failures and operator actions, the SG-HEAT-RELEASE fault tree was modified. Specifically, new AND gates SSC-5A and SSC-7A were inserted under existing gates SSC-5 and SSC-7, respectively. A new basic event MSS-ICS-LIMITSWITCHES (*ICS limit switches fail resulting is loss of automatic AVV control*) was inserted under both gates SSC-5A and SSC-7A. In addition, new basic events MSS-XHE-XM-AVV2 (*operators fail to manually control AVV2 locally*) and MSS-XHE-XM-AVV1 (*operators fail to manually control AVV1 from MCR*), were inserted under existing gates SSC-5a and SSC-7a, respectively. In addition, new house event HE-LOCHS (*loss of condenser heat sink initiating event has occurred*) was inserted under gates SSC-4 and SSC-6. House event HE-LOCHS was also added to the LOCHS flag set. The modified SG-HEAT-RELEASE fault tree is shown Figure B-2 in [Appendix B](#).
- **Fault Tree Correction.** House event HE-LOCHS was added under the top gate of the MFW fault tree to ensure that the MFW system was considered unavailable given a LOCHS during a postulated anticipated transient without scram (ATWS).

3.4 Analysis Assumptions

The following modeling assumptions were determined to be significant to the modeling of this initiating event assessment:

- The probability of IE-LOCHS (*loss of condenser heat sink*) was set to 1.0 due to automatic SI actuation. All other initiating event probabilities were set to zero.
- Basic event MFW-AOV-CC-SP7B was set to TRUE due to the failure 'SP7B' to automatically open when SG '1' experienced low level.

- Basic event MSS-ICS-LIMITSWITCHES was set to TRUE due the failure of two limit switches that provide position indication of the MSIVs, which resulted in the failure of the AVVs to automatically open.
- Basic events MFW-XHE-XM-SP7B and MSS-XHE-XM-AVV1 were set to a screening probability of 0.1. NUREG-1792, “Good Practices for Implementing Human Reliability Analysis,” ([ML051160213](#)) states that 0.1 is an appropriate screening (i.e., typically conservative) value for most post-initiator human failure events. Basic event MSS-XHE-XM-AVV2 was set to an elevated screening probability of 0.5 due to it being a local action. A review of the results show that further reduction of these human error probabilities would result in a negligible change in the CCDP for this event.
- The human error probability (HEP) for existing human failure event SFAS-XHE-XL-HPI was set to 0.23 based on an evaluation using IDHEAS-ECA. Details regarding this evaluation are provided in the following tables.

Table 1. IDHEAS-ECA Evaluation of SFAS-XHE-XL-HPI

Name	SFAS-XHE-XL-HPI
Definition	Given an overcooling event (i.e., a stuck-open steam valve), operators would need to initiate HPI in “piggy-back” mode (i.e., taking a suction off the RHR pumps) to prevent an automatic SFAS actuation on low RCS pressure that would result in a loss of RCP seal cooling/injection. The starting point for this task is when the reactor trip with stuck-open steam valve occurs (i.e., T = 0). The ending point for this task is when operators complete the initiation of the HPI in “piggy-back” mode of operation.
Description/ Event Context	An overcooling event occurred when MS199 failed to automatically close after the reactor trip. Given the rapidly decreasing RCS temperature, operators are procedurally directed to terminate the cause of the overcooling and to initiate HPI in “piggy-back” mode of operation. Completion of this task quickly will prevent an SFAS signal, which would increase the complexity of the event response by causing a loss of RCP seal cooling and injection. This event context was assumed for the evaluation of the cognitive failure modes (CFMs) and performance influencing factors (PIFs).
Success Criteria	Operators successfully initiate HPI in “piggy-back” mode prior to SFAS signal during the overcooling event.
Key Cue(s)	<ul style="list-style-type: none"> • Rapidly decreasing RCS temperature • SG pressure less than 960 psig
Procedural Guidance	<ul style="list-style-type: none"> • Emergency Procedure DB-OP-02000, <i>RPS, SFAS, SFRCS Trip, or SG Tube Rupture</i> • DBOP02000, Attachment 8, <i>Place HPI/LPI/MU In Service</i>
Critical Task(s)	Operators manually initiate HPI in “piggy-back” mode prior to SFAS signal.

<p>Task Analysis</p>	<p>Detection – This task requires the operators to detect the key alarms and annunciators given the reactor trip and stuck-open steam valve.</p> <p>Understanding – This task requires the operators to integrate the various cues to determine that an overcooling event has occurred, which requires operators to initiate HPI quickly to prevent an SFAS signal.</p> <p>Decisionmaking – Decisionmaking is not required for this task because with correct understanding of the event, operators would have an obvious decision to manually initiate HPI in “piggy-back” mode of operation per plant procedures. Therefore, this CFM is not applicable for this task.</p> <p>Action Execution – This task requires the operators to manually initiate HPI “piggy-back” mode of operation.</p> <p>Interteam Coordination – Interteam coordination is not required for this task because multiple teams would not be involved. Therefore, this CFM is not applicable for this task.</p> <p>The applicable CFMs are: <i>CFM1 – Failure of Detection</i> <i>CFM2 – Failure of Understanding</i> <i>CFM4 – Failure of Action Execution</i></p>
<p>Evaluation of PIFs for the Applicable CFMs</p>	<p>Detection ($P_{CFM1} = 3 \times 10^{-3}$)</p> <ul style="list-style-type: none"> • Scenario Familiarity – No impact because operators are routinely trained in response to reactor trip with secondary transients. • Task Complexity – <i>C1: Detection overload with multiple competing signals (1: Few < 7); Multiple annunciators associated with reactor and turbine trips.</i> • The other PIFs were evaluated to not have a significant impact on this task. <p>Understanding ($P_{CFM2} = 1 \times 10^{-3}$)</p> <ul style="list-style-type: none"> • Scenario Familiarity – No impact because a stuck-open steam valve is not an uncommon event and is covered in the reactor trip response procedure that is routinely trained. • Information Completeness and Reliability – No impact because the MCR indications are deemed sufficient that an overcooling event has occurred. • Task Complexity – No impact because an overcooling event is relatively basic plant operation concept that is specifically covered by plant procedures. • The other PIFs were evaluated to not have a significant impact on this task. <p>Action Execution $P_{CFM4} = 1 \times 10^{-3}$</p> <ul style="list-style-type: none"> • Scenario Familiarity – No impact because the execution steps are routinely trained. • Task Complexity – No impact because the execution steps are straight-forward and proceduralized. • Procedures and Guidance – <i>C31: Straightforward procedure with many steps.</i> • The other PIFs were evaluated to not have a significant impact on this task. <p>Using these assumptions, P_c was calculated as 5×10^{-3}.</p>
<p>Timing Evaluation</p>	<p>Based on RCS pressure plot from the event, operators had approximately 5 minutes to initiate HPI in “piggy-back” mode to prevent an SFAS signal, which occurs at an RCS pressure of 1600 psi. During the actual event, operators were able to complete this action in 4 minutes. Therefore, the $T_{reqd} = 4$ minutes (median) and the $T_{avail} = 5$ minutes (single value). The current IDHEAS-ECA guidance recommends using a lognormal distribution for the time values that use a distribution; however, the current IDHEAS-ECA software does not have this capability yet. So, P_t was calculated using an OpenBUGS script using lognormal distribution parameters recommended by PNNL-32384 for T_{reqd} ($\sigma = 0.28$ and $\mu = 1.4$). Using these assumptions, P_t was calculated as 0.23.</p>
<p>Recovery</p>	<p>Recovery credit is not provided for this task.</p>
<p>Calculated HEP</p>	<p>$HEP = 1 - (1 - P_c) (1 - P_t) = 1 - (1 - 5 \times 10^{-3}) (1 - 0.23) = 0.23$</p>

4 ANALYSIS RESULTS

4.1 Results

The mean CCDP for this analysis is calculated to be 2.6×10^{-6} . The ASP Program threshold for initiating events is a CCDP of 10^{-6} or the plant-specific CCDP of an uncomplicated reactor trip with a non-recoverable loss of feedwater or the condenser heat sink, whichever is greater. This CCDP equivalent for Davis-Besse Nuclear Power Plant is 1.2×10^{-6} . Therefore, this event is a precursor. The parameter uncertainty results for this analysis provided below:

Table 2. Parameter Uncertainty (Δ CCDP) Results

5%	Median	Point Estimate	Mean	95%
1.2×10^{-7}	1.1×10^{-6}	2.4×10^{-6}	2.6×10^{-6}	9.8×10^{-6}

4.2 Dominant Sequences⁴

The dominant accident sequence is a LOCHS sequence 4-9-2 (CCDP = 1.2×10^{-6}), which contributes approximately 48 percent of the total CCDP. The sequences that contribute at least 5.0 percent to the total CCDP are provided in the following table. The event tree with the dominant sequence is shown graphically in Figure A-1 of [Appendix A](#).

Table 3. Dominant Sequences

Sequence	Δ CCDP	%	Description
LOCHS 4-9-2	1.2×10^{-6}	48.2%	Loss of condenser heat sink initiating event; successful reactor trip; offsite power is available; AFW is successful; operators fail to initiate HPI prior to an SFAS signal, which results in a loss of RCP seal cooling and injection; operators fail to trip the RCPs resulting in a LOCA, HPI is successful, but recirculation fails resulting in core damage.
LOCHS 14	7.3×10^{-7}	30.2%	Loss of condenser heat sink initiating event; successful reactor trip; offsite power is available; AFW fails; and feed and bleed fails resulting in core damage.
LOCHS 4-8-2	1.5×10^{-7}	6.1%	Loss of condenser heat sink initiating event; successful reactor trip; offsite power is available; AFW is successful; operators fail to initiate HPI prior to an SFAS signal, which results in a loss of RCP seal cooling and injection; operators successfully trip the RCPs, but the RCP seals fail resulting in a LOCA, HPI is successful, but recirculation fails resulting in core damage.

4.3 Key Uncertainties

The analysis models this event as loss of condenser heat sink initiating event. However, the condenser heat sink was not lost until approximately 2 hours after the reactor trip. This difference could potentially affect the risk of the LOCHS sequence 14 in that there would be some additional time for operator actions. However, since the CCDP would still exceed the ASP

⁴ The CCDPs in this section are point estimates.

threshold regardless of the potential risk reduction of LOCHS sequence 14, further model refinements were not pursued.

Appendix A: Key Event Tree




Figure A-1. Modified Davis-Besse LOCHS Event Tree

Appendix B: Modified Fault Trees




Figure B-1. Modified MFW-SG11-Feed Fault Tree




Figure B-2. Modified SG-HEAT-RELEASE Fault Tree