



May 25, 2022
Serial: RA-22-0134

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: Brunswick Steam Electric Plant, Unit No. 1
Renewed Facility Operating License No. DPR-71
Docket No. 50-325
Unit 1 Cycle 23 MELLLA+ Eigenvalue Tracking Data

References:

1. Duke Energy Letter to NRC dated November 9, 2016, "Brunswick, Units 1 and 2 – Response to Request for Supplemental Information for License Amendment Request Regarding Core Flow Operating Range Expansion" (ADAMS Accession No. ML16330A504)
2. NRC Letter to Duke Energy, dated September 18, 2018, "Brunswick Steam Electric Plant, Units 1 and 2 – Issuance of Amendment Regarding Core Flow Operating Range Expansion (MELLLA+)" (ADAMS Accession Number ML18172A258)

Ladies and Gentlemen:

In Reference 1, Duke Energy Progress, LLC (Duke Energy), informed the NRC that it would evaluate and submit cycle-specific eigenvalue tracking data after the first full Maximum Extended Load Line Limit Analysis Plus (MELLLA+) operating cycle for each unit using AREVA methods. The enclosure provides this information for Brunswick Steam Electric Plant (BSEP), Unit 1, Cycle 23, which was completed in March 2022.

This document contains no regulatory commitments.

Please refer any questions regarding this submittal to Mr. Stephen Yodersmith, Brunswick Regulatory Affairs, at (910) 832-2568.

Sincerely,

Mark R. DeWire
Manager – Nuclear Support Services
Brunswick Steam Electric Plant

SBY/sby

Enclosure:

Brunswick Unit 1 MELLLA+ Eigenvalue Tracking Data

cc (with Enclosure):

Ms. Laura Dudes, NRC Regional Administrator, Region II
Mr. Luke Haeg, NRC Project Manager
Mr. Gale Smith, NRC Senior Resident Inspector
Chair - North Carolina Utilities Commission

**Brunswick Steam Electric Plant, Unit No. 1
Renewed Facility Operating License No. DPR-71
Docket No. 50-325**

Brunswick Unit 1 MELLLA+ Eigenvalue Tracking Data



Facility Code :	NGO	
Applicable Facilities :	NGO	
Document Number :	DPND-1553.63-1286	
Document Revision Number :	000	
Document EC Number :		
Change Reason :	Original Issue	
Document Title :	Brunswick Unit 1 MELLLA+ Eigenvalue Tracking	
Arasim, Lois	Preparer	4/27/2022
Wells, Ryan E.	Reviewer	4/27/2022
Lambert, Brad	Approver	4/27/2022
Notes :		

Brunswick Unit 1 MELLLA+ Eigenvalue Tracking

April 2022

Prepared by: _____
Signed Electronically
Lois Arasim (Brunswick Nuclear Design)

Reviewed by: _____
Signed Electronically
Ryan Wells (Brunswick Nuclear Design)

Approved by: _____
Signed Electronically
Brad Lambert (Manager – Brunswick/Oconee Nuclear Design)

1. Purpose and Scope

The purpose of this letter report is to document the fulfillment of Limitation and Condition (L/C) 23 of NEDC-33173P (Reference 1). This L/C states:

In the first plant-specific implementation of MELLLA+, the cycle-specific eigenvalue tracking data will be evaluated and submitted to NRC to establish the performance of nuclear methods under the operation in the new operating domain. The following data will be analyzed:

- *Hot critical eigenvalue,*
- *Cold critical eigenvalue,*
- *Nodal power distribution (measured and calculated TIP comparison),*
- *Bundle power distribution (measured and calculated TIP comparison),*
- *Thermal margin,*
- *Core flow and pressure drop uncertainties, and*
- *The MIP Criterion (e.g., determine if core and fuel design selected is expected to produce a plant response outside the prior experience base).*

Provision of evaluation of the core-tracking data will provide the NRC staff with bases to establish if operation at the expanded operating domain indicates: (1) changes in the performance of nuclear methods outside the EPU experience base; (2) changes in the available thermal margins; (3) need for changes in the uncertainties and NRC-approved criterion used in the SLMCPR methodology; or (4) any anomaly that may require corrective actions.

Based on Reference 2, the MIP Parameter will not be provided. Reference 2 states:

The NRC staff previously determined that submittal of the MIP was not necessary in letter to GEH dated November 20, 2015 (ADAMS Accession No. ML15292A421). That NRC staff's determination was generic and is applicable to AREVA methods as well.

2. Comparison Approach

Brunswick Nuclear Plant Unit 1 completed its first full cycle with MELLLA+, B1C23, in March 2022. For each metric being compared, data from the previous 3 cycles (including the B1C22 partial MELLLA+ cycle) will be provided for a basis of comparison.

The eigenvalues, at cold and hot reactor conditions, are presented in the attached plots as a function of exposure. The thermal margins (MAPRAT, MFDLRX, and MFLCPR) are presented also as a function of exposure. The definitions of the thermal margin parameters are as follows:

- MAPRAT: Maximum ratio of bundle measured Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) to the appropriate limit.
- MFDLRX: Maximum fraction of limiting Linear Heat Generation Rate (LHGR) to the Fuel Design Limit (FDL)

- MFLCPR: Maximum fraction of limiting Critical Power Ratio

The ratio of on-line core monitoring system (PPX) to offline-evaluation (MCB) or “bias” is presented. The power distributions assessment uses nodal and radial Traversing In-Core Probe (TIP) statistics, consistent with Reference 3, from plant measured/calculated data as a function of exposure, core average void fractions, and power-to-flow ratio (P/F in units of MWt/MIbm/hr). The plot of core flow and pressure drop uncertainties is presented also as a function of P/F ratio.

For convenience and better visualization, the MELLLA+ values plotted (relevant B1C22 and B1C23 data) are presented in red.



3. Conclusions

The results provided demonstrate the Methods performance in the MELLLA+ domain continues to meet expectations set by prior submittals and historical data at non-MELLLA+ conditions. Therefore, the intent of Limitation & Condition 23 has been satisfied. Similar data was provided for Unit 2 in Reference 4 and no further reporting is required.



4. References


1. NEDC-33171P-A, Revision 4, “Applicability of GE Methods to Expanded Operating Domains,” November 2012 (ADAMS Accession No. ML12313A107/ML12313A106 (Publicly Available/Non-publicly Available)).
2. Letter from the NRC, September 18, 2018, “Brunswick Steam Electric Plant, Units 1 and 2 – Issuance of Amendment Regarding Core Flow Operating Range Expansion (MELLLA+) (EPID L-2016-LA-0009)” (ADAMS Accession No. ML18172A258).
3. EMF-2158(P)(A), Revision 0, “Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2,” October 1999.
4. Letter to the NRC, June 7, 2021, “Brunswick Steam Electric Plant, Unit No. 2 Renewed Facility Operating License No. DPR-62 Docket No. 50-324 Unit 2 Cycle 24 MELLLA+ Eigenvalue Tracking Data,” (ADAMS Accession No. ML21158A056).

Hot and Cold Critical Eigenvalues







Thermal Margin







Nodal and Radial TIP Uncertainties







Core Flow and Pressure Drop Uncertainties

