

PUBLIC SUBMISSION

SUNI Review Complete
Template=ADM-013
E-RIDS=ADM-03

ADD: Michael Eudy, Kevin
Hsueh, Sean Meighan,
Mark Blumberg, Bridget
Curran, Mary Neely
Comment (16)
Publication Date:
4/21/2022
Citation: 87 FR 23891

As of: 6/23/22 7:41 AM
Received: June 21, 2022
Status: Pending_Post
Tracking No. 14p-13pv-6d3p
Comments Due: June 21, 2022
Submission Type: API

Docket: NRC-2021-0179

Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Plants

Comment On: NRC-2021-0179-0001

Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors

Document: NRC-2021-0179-DRAFT-0018

Comment on FR Doc # 2022-08519

Submitter Information

Name: Anonymous Anonymous

Email: JimM@gmail.com

General Comment

We agree that the containment sprays should not be credited in Regulatory Position A-4, especially when the steam line deposition models proposed in DG-1389 regulatory position A-5 are credited.