

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OUT OF SERVICE

JPM NUMBER: ADMIN-19 **REV.** 4

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): SS 341 ATI 00 00 026 / EVALUATE OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS

K/A NUMBERS: 2.1.25 (3.9/4.2)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 15 Minutes

Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☐ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins
	Developer Date
Validated by:	Justin Hasner
	Validator Date
	(See JPM Validation Checklist, Attachment 1)
Approved by:	Shawn Sarrasin
	Training Supervisor Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- Both units are at 100% power.
- The System Operator in the Transmission System Operation center has informed you that BOTH the Security Power System Analysis and the MISO RTCA programs are OOS.
- The plant is in its NORMAL at power 4.16 KV line-up.

INITIATING CUES:

- Evaluate the current system operating conditions for **BUS 25 ONLY** per C20.3 AOP 1.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

JPM PERFORMANCE INFORMATION**Required Materials:** Consumable copies of the following:

- C20.3
- C20.3 AOP1

General References: C20.3, ELECTRICAL POWER SYSTEM SECURITY ANALYSIS
 C20.3 AOP1, EVALUATING SYSTEM OPERATING CONDITIONS WHEN
 SECURITY ANALYSIS IS OUT OF SERVICE

Task Standards: Examinee determines that the Bus 25 grid source (2R) setpoint is 97.2% (335.3 kV), plots the line and operating points on Figure 5, and determines that Bus 25 grid source (2R) is operating in the acceptable region.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Qualification Program Examinations.

Performance Step:	C20.3 AOP1, step 2.4.1:
Critical <u>N</u>	Log the Security Analysis Program and the MISO RTCA Program OOS in the Operations Log.
Standard:	Examinee determines a log entry will be made concerning SAP and MISO RTCAP being OOS.
Evaluator Cue:	Inform the examinee that the Lead Reactor Operator will make the appropriate log entries.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

Performance Step:	C20.3 AOP1, step 2.4.2:
Critical <u>N</u>	If any 345 kV transmission line is OOS, then contact Electrical Engineering for assistance in evaluating grid operating conditions.
Standard:	Examinee determines by using ERCS ES-1 that no 345 kV lines are OOS.
Evaluator Cue:	If asked about current grid line up, then provide examinee with picture of ERCS ES-1 and EA25.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	C20.3 AOP1, step 2.4.3:
Critical <u>N</u>	Evaluate the 345 kV and 161 kV grid operating conditions using Section 3.0, Table 1, and Figure 1 through Figure 6. Document results on Appendix B.
Standard:	Examinee goes to appropriate sections for Bus 25 – Section 3.0, Table 1, and Figure 5.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

Performance Step:	C20.3 AOP1, step 3.2.2:	
Critical <u>Y</u>	Generate the correct 161 kV and 345 kV figure by evaluating plant 4.16KV bus line-up with Table 1.	
Standard:	Examinee evaluates grid operating conditions for Bus 25 source (2R) using Table 1 and Figure 5 as follows: <ul style="list-style-type: none"> • <i>(Critical)</i> Table 1 XFMR 2R – Case Study 2R-5 (21, 22, 23, 24, 25, 27) – 97.2%, 335.3 kV. • <i>(Critical)</i> Plot horizontal line from 335.3 kV and vertical line from 0 MVARs. • <i>(Non-Critical)</i> Plot a sloped line from plotted point using sloped grid lines as a reference. (Completion of this bullet is not necessary to successfully complete this step.) 	
Evaluator Cues:	<ul style="list-style-type: none"> • If not already done, provide examinee with picture of ERCS ES-1. 	
Performance:	SATISFACTORY _____	UNSATISFACTORY _____
Comments:	_____	

Performance Step:	C20.3 AOP1, step 3.2.3:	
Critical <u>N</u>	Using ERCS ES1 display read bus voltages and adjusted MVARs directly from display.	
Standard:	Examinee reads voltages and MVARs from ES1.	
Performance:	SATISFACTORY _____	UNSATISFACTORY _____
Comments:	_____	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

Performance Step:	C20.3 AOP1, step 3.2.4:	
Critical <u>Y</u>	Plot the points on the curve and evaluate for ACCEPTABLE or UNACCEPTABLE operating region.	
Standard:	Examinee determines that Bus 25 is operating in the ACCEPTABLE region.	
Evaluator Note:	Bus 26 is operating in the UNACCEPTABLE region. If the examinee incorrectly believes that 8H12 is closed and 8H10 is open, then the examinee will not arrive at the correct evaluation.	
Performance:	SATISFACTORY _____	UNSATISFACTORY _____
Comments:	_____	

Terminating Cues: When examinee has determined that the Bus 25 grid source (2R) setpoint is 97.2% (335.3 kV), plotted the line and operating points on Figure 5, and determined that Bus 25 grid source (2R) is operating in the acceptable region, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-19, EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OOS, REV 4

ATTACHMENT 2

JPM Number: ADMIN-19JPM Title: EVALUATE SYSTEM OPERATING CONDITIONS WHEN SECURITY ANALYSIS IS OUT OF SERVICE

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).**

EVALUATOR'S SIGNATURE: _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- Both units are at 100% power.
- The System Operator in the Transmission System Operation center has informed you that BOTH the Security Power System Analysis and the MISO RTCA programs are OOS.
- The plant is in its NORMAL at power 4.16 KV line-up.

INITIATING CUES:


- Evaluate the current system operating conditions for **BUS 25 ONLY** per C20.3 AOP 1.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4




Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4 cont.



Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: AUTHORIZATION OF WASTE GAS RELEASE

JPM NUMBER: ADMIN-22 **REV.** 3

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): SS 341.049.03.03 / APPROVE RADIOACTIVE GAS RELEASES

K/A NUMBERS: 2.3.6 (3.8/4.3)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 10 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☐ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-22, AUTHORIZATION OF WASTE GAS RELEASE, REV. 3**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- You are the Unit 1 Shift Supervisor.
- A Waste Gas Release is planned for your shift from 128 Low Level Gas Decay Tank.
- Unit 1 and Unit 2 are at 100% power.
- Cooling Towers are in service.
- There is no precipitation occurring.
- The Gas Decay Tank Gaseous Effluent Release Permit has been completed and approved.

INITIATING CUES:

- C21.3-10.8, Releasing Radioactive Gas from 128 Low Level Gas Decay Tank, has been completed through step 7.10.
- Determine if a gaseous release can be approved per C21.3-10.8, step 7.11.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-22, AUTHORIZATION OF WASTE GAS RELEASE, REV. 3

JPM PERFORMANCE INFORMATION

- Required Materials:**
- Consumable copy of C21.3-10.8, Releasing Radioactive Gas from 128 Low Level Gas Decay Tank
 - Attachment 4, Gas Decay Tank Gaseous Effluent Release Permit, with dates and times filled in.
 - Attachment 5, ERCS Server Group OPWIND
- General References:** Gas Decay Tank Gaseous Effluent Release Permit
C21.3-10.8, Releasing Radioactive Gas from 128 Low Level Gas Decay Tank
- Task Standards:** Determine release cannot be approved due to unfavorable wind conditions.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step:	C21.3-10.8, step 7.11.1:	
Critical <u>N</u>	Verify Chemistry Manager or designee has approved the release on the Gas Decay Tank Gaseous Effluent Release Permit.	
Standard:	Examinee verifies Chemistry Manager has approved the release on the GDTGER Permit.	
Evaluator Cue:	Give examinee Attachment 4, Gas Decay Tank Gaseous Effluent Release Permit.	
Performance:	SATISFACTORY _____ UNSATISFACTORY _____	
Comments:	_____	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-22, AUTHORIZATION OF WASTE GAS RELEASE, REV. 3

Performance Step: Critical <u>Y</u>	C21.3-10.8, step 7.11.2: Check wind conditions as specified in the Limitations section are satisfied (from ERCS server group "OPWIND"): <ul style="list-style-type: none"> • 10-meter average wind speed _____ mph • 10-meter average wind direction _____ °
Standard:	Examinee locates wind speed and direction from OPWIND ERCS Group Attachment 5.
Evaluator Cue:	Give examinee Attachment 5, ERCS Server Group OPWIND. 10-meter avg wind speed = 6 mph 10-meter avg wind direction = 22°
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step: Critical <u>Y</u>	C21.3-10.8, step 7.11.3: Release Approval: _____ Shift Supervisor Date: _____ Time: _____
Standard:	Examinee determines the release cannot be approved due to unfavorable wind conditions.
Evaluator Note:	This critical step is considered met if the examinee notes unfavorable wind conditions during review of step 7.11.3 or Precaution & Limitation 3.2.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When examinee has determined the release cannot be approved due to unfavorable wind conditions, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-22, AUTHORIZATION OF WASTE GAS RELEASE, REV. 3

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-22, AUTHORIZATION OF WASTE GAS RELEASE, REV. 3

ATTACHMENT 2

JPM Number: _____

JPM Title: _____

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- You are the Unit 1 Shift Supervisor.
- A Waste Gas Release is planned for your shift from 128 Low Level Gas Decay Tank.
- Unit 1 and Unit 2 are at 100% power.
- Cooling Towers are in service.
- There is no precipitation occurring.
- The Gas Decay Tank Gaseous Effluent Release Permit has been completed and approved.

INITIATING CUES:

- C21.3-10.8, Releasing Radioactive Gas from 128 Low Level Gas Decay Tank, has been completed through step 7.10.
- Determine if a gaseous release can be approved per C21.3-10.8, step 7.11.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4

Prairie Island Nuclear Generating Station

Permit Number: PIGB2018-136P

Gas Decay Tank Gaseous Effluent Release Permit**Pre-Release Conditions**

Release System: Gas Decay Tank
Release Point: 128 Low Level GDT
Release Point Comment: *** Checklist C21.3-10.8 ***
Waste Volume (cft): 0.00
Maximum Waste Flow (cfm): 1,000.00
Minimum Dilution Flow (cfm): 40,600.00
Release Fraction: 1.00

Radiation Monitor Data (Calculations include Background)

Monitor Description:	2R-30	2R-37
Calculated High Setpoint:	4.44E+04	3.30E+04
Current High Setpoint:	5.00E+02	6.00E+02
Background:	3.50E+01	3.50E+01
Expected Response:	4.40E+02	4.00E+02
Monitor Units:	cpm	cpm

Special Conditions:

test



Prepared By



Reviewed By



Approved By (Chem Mgr)

Prepared Date/Time

Review Date/Time

Approved Date/Time

Remarks:

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 5

R-TIME Data Viewer - [TABGRP1X.DS]
File Edit View Display Viewer Security ERCS QuickList Window Help

TABGRP1X top_menu tabgrp1x
100%

U 1 PSSA MODE: 1 AUT D1 ALM Server Group OPWIND U1 C21.3 WIND CONDS. FOR WG RELEASE TAB U1 =>U2 SAS MENU SAS SCH PZT 10:19:35 6/21/18
A:ACT B:N/A 1.POWER ON D2

POINT NAME	DESCRIPTION	VALUE	UNITS	QUALITY
1U4109A	MET WIND DIR 10M A 15MAV	22.87372	DEG	GOOD
1U4110A	MET WIND DIR 10M B 15MAV	21.63951	DEG	GOOD
1Y4105A	MET WIND SPEED 10M A	5.93481	MPH	GOOD
1Y4106A	MET WIND SPEED 10M B	6.28392	MPH	GOOD
1U4105A	MET WIND SPEED 10M A 15MAVG	5.98653	MPH	GOOD
1U4106A	MET WIND SPEED 10M B 15MAV	6.09514	MPH	GOOD
1U4101D	WASTE GAS RELEASE WIND CONDITION	0.00000	NORMAL	GOOD
1Y4115A	MET PRECIP A	0.35050	IN	GOOD
1Y4116A	MET PRECIP B	0.15914	IN	GOOD
2R0030A	U2 AUX BLD VENT GAS B	32.35644	CPM	GOOD
2R0037A	U2 AUX BLD VENT GAS R	34.10762	CPM	GOOD

PAGE 1 2 3 4 5
View PDF View Excel Export Excel Data Trend Fixed Trends Menu Custom Trends Menu Load Group

Retention: Life of Plant
Retain in: Training Record
Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS

JPM NUMBER: ADMIN-29 REV. 6

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): CRO 002 ATI 00 00 011, RESPONSE TO SG TUBE LEAK

K/A NUMBERS: 2.4.11 (4.0/4.2)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 15 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- Unit 1 is at 100% power.
- ERCS is unavailable.
- 1C4 AOP2 has been implemented in response to indications of SG Tube Leakage.
- Table 1 is being performed for periodic data entry.
- 1R-15 is currently reading 3600 CPM.
- Air Ejector flow is currently reading 3.1 CFM.

INITIATING CUES:

- Update Table 1 of 1C4 AOP2 for the 1045 entry based on current 1R-15 count rates.
- Determine the current Action Level per step 2.4.9 of 1C4 AOP2.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6

JPM PERFORMANCE INFORMATION

Required Materials: Copy of 1C4 AOP2 Table 1 filled out from 1000 to 1045 per Att. 2 KEY (blue ink only) or copy of Attachment 5 and Attachment 6, 1C4 AOP2 SG Tube Leak step 2.4.9.

General References: 1C4 AOP2, STEAM GENERATOR TUBE LEAK

Task Standards: Examinee determines Steam Generator Tube Leak Action Level 3 is met.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step:	1C4 AOP2, Table 1, step B.1:
Critical <u>N</u>	<p><u>IF</u> ERCS is out of service <u>OR</u> completing the table for periodic data entry, <u>THEN</u> perform the following:</p> <p>1. Enter the current date and time in the date/Time column, the current 1R-15 counts in column A, and the air ejector flow in Column H.</p>
Standard:	Examinee records 3600 in Column A for 1R-15 Counts and 3.1 in Column H for air ejector flow.
Evaluator Note:	Current date and time is already entered on Table 1.
Evaluator Cue:	<p>Provide examinee with Attachment 5, Table 1 of 1C4 AOP2 and Attachment 6, step 2.4.9 of 1C4 AOP2.</p> <p>If examinee requests Chemist to perform another leak rate determination based on sample, then inform examinee that sample results will take 1 hour to complete.</p>
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6

Performance Step:	1C4 AOP2 Table 1 Step B.2
Critical <u>Y</u>	Determine the current leak rate by dividing the 1R-15 counts (Column A) by the most recent conversion factor (Column C) and enter in Column F. (Column A ÷ Column C = Column F).
Standard:	Examinee records 116 in Column F for 1R-15 Leak rate.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	_____

Performance Step:	1C4 AOP2, Table 1, step B.3:
Critical <u>N</u>	Determine the rate of change (ROC) by dividing the change in leak rate (change in Column F) by the change in time (change in Date/Time column in hours) for the most recent entries and enter in Column G. (Δ Column F ÷ Δ Hours = Column G).
Standard:	Examinee records a number between 119 and 120 in column G for 1R-15 Leak rate ROC.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6

Performance Step:
Critical Y

1C4 AOP2 Step 2.4.9

Determine the appropriate procedure section:

Action Level	1U0016A CALC SG TUBE LEAK ROLLING AVG	1U0019A CALC SG TUBE LEAK RATE OF CHANGE	Go To Step
Increased Monitoring	≥ 5 GPD < 30 GPD	NA	2.5
1	≥ 30 GPD < 75 GPD	NA	2.6
2	≥ 75 GPD sustained for 1 hour	<u>AND</u> < 30 GPD/hr	2.7
3	≥ 75 GPD	<u>AND</u> ≥ 30 GPD/hr	2.8
3	≥ 150 GPD	<u>AND</u> < 30 GPD/hr	2.8

Standard:

Examinee determines Action Level 3 is met.

Evaluator Note:

Step 2.4.9 of 1C4 AOP2 is a continuous action step.

Performance:

SATISFACTORY ☐ UNSATISFACTORY ☐

Comments:

Terminating Cues: Examinee determines Steam Generator Tube Leak Action Level 3 is met.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

PRAIRIE ISLAND NUCLEAR GENERATING PLANT		ABNORMAL OPERATING PROCEDURE
C	STEAM GENERATOR TUBE LEAK	NUMBER: 1C4 AOP2
		REV: 24
		Page 16 of 19

B. IF ERCS is out of service OR completing the table for periodic data entry, THEN **perform** the following:

1. **Enter** the current date and time in the Date/Time column, the current 1R-15 counts in Column A, and the air ejector flow in Column H.
2. **Determine** the current leak rate by dividing the 1R-15 counts (Column A) by the most recent conversion factor (Column C) and **enter** in Column F.
(Column A ÷ Column C = Column F)
3. **Determine** the rate of change (ROC) by dividing the change in leak rate (change in Column F) by the change in time (change in Date/Time column in hours) for the two most recent entries and **enter** in Column G.
(Δ Column F ÷ Δ Hours = Column G)

[illegible]

Retention: Life of Plant
Retain in: Training Record
Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-29, DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS, REV. 6

ATTACHMENT 3

JPM Number: ADMIN-29JPM Title: DETERMINE SG LEAKAGE CORRELATION TO R-15 COUNTS

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4

TURNOVER SHEET

INITIAL CONDITIONS:

- Unit 1 is at 100% power.
- ERCS is unavailable.
- 1C4 AOP2 has been implemented in response to indications of SG Tube Leakage.
- Table 1 is being performed for periodic data entry.
- 1R-15 is currently reading 3600 CPM.
- Air Ejector flow is currently reading 3.1 CFM.

INITIATING CUES:

- Update Table 1 of 1C4 AOP2 for the 1045 entry based on current 1R-15 count rates.
- Determine the current Action Level per step 2.4.9 of 1C4 AOP2.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 5

PRAIRIE ISLAND NUCLEAR GENERATING PLANT		ABNORMAL OPERATING PROCEDURE	
C	STEAM GENERATOR TUBE LEAK	NUMBER:	1C4 AOP2
		REV:	24
		Page 16 of 19	

Table 1 SG Leakage Correlation to R-15 Counts (cont'd)

- B. IF ERCS is out of service OR completing the table for periodic data entry, THEN **perform** the following:
1. **Enter** the current date and time in the Date/Time column, the current 1R-15 counts in Column A, and the air ejector flow in Column H.
 2. **Determine** the current leak rate by dividing the 1R-15 counts (Column A) by the most recent conversion factor (Column C) and **enter** in Column F.
(Column A \div Column C = Column F)
 3. **Determine** the rate of change (ROC) by dividing the change in leak rate (change in Column F) by the change in time (change in Date/Time column in hours) for the two most recent entries and **enter** in Column G.
(Δ Column F \div Δ Hours = Column G)

[illegible]

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: RCS / STEAM GENERATOR TEMPERATURE VERIFICATION

JPM NUMBER: ADMIN-48 **REV.** 5

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): CRO 002 011 01 000 / HEATUP THE REACTOR COOLANT SYSTEM

K/A NUMBERS: 2.1.20 (4.6/4.6)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 8 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator	Date
	(See JPM Validation Checklist, Attachment 1)	
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- Unit 1 is in MODE 6.
- Preparations are being made to start the FIRST Reactor Coolant Pump.
- An Out Plant Operator reports SG Skin Temperatures are as follows:
 - 12413, 11 SG SKIN TI = 141°F
 - 12414, 12 SG SKIN TI = 147°F

INITIATING CUES:

- The SS directs you to complete step 5.6.3 of 1C1.2-M5, UNIT 1 STARTUP TO MODE 5, and determine whether or not an RCP can be started.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5

JPM PERFORMANCE INFORMATION

Required Materials: Consumable copy of 1C1.2-M5, step 5.6.3 (pages 31-32).

General References: 1C1.2-M5, UNIT 1 STARTUP TO MODE 5, REV 12

Task Standards: Examinee determines the SG to RCS ΔT is 22°F and the limiting SG to RCS ΔT of 15°F has been exceeded.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step: 1C1.2-M5, step 5.6.3:

Critical N

Verify the secondary water temperature of each SG is less than 15°F warmer than the RCS cold leg temperatures before starting an RCP as follows:

A. Record SG skin temperatures at the SG skin pyrometer locations:

- 12413, 11 SG SKIN TI
- 12414, 12 SG SKIN TI

Standard: Examinee records 11 and 12 SG Skin Temperatures.

Performance: SATISFACTORY _____ UNSATISFACTORY _____

Comments: _____

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5

Performance Step:	1C1.2-M5, step 5.6.3:
Critical <u>Y</u>	<p>Verify the secondary water temperature of each SG is less than 15°F warmer than the RCS cold leg temperatures before starting a RCP as follows:</p> <p>B. Record RCS cold leg temperatures:</p> <ul style="list-style-type: none"> • 1T0406A, RCS A TCOLD 450B • 1T0426A, RCS B TCOLD 451B
Standard:	Examinee obtains and records RCS A and B cold leg temperatures.
Evaluator Cue:	<p>When examinee has demonstrated the ability to locate RCS cold leg temps, then provide the examinee with the following:</p> <ul style="list-style-type: none"> • 1T0406A, RCS A TCOLD 450B = 125°F • 1T0426A, RCS B TCOLD 451B = 127°F
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	1C1.2-M5, step 5.6.3.C:
Critical <u>Y</u>	<p>Determine the limiting SG to RCS temperature difference by subtracting the lowest RCS cold leg temperature from the highest SG skin temperature:</p> $\frac{\text{Highest SG Skin T}}{\text{°F}} - \frac{\text{Lowest RCS cold leg T}}{\text{°F}} = \frac{\Delta T}{\text{°F}}$
Standard:	Examinee determines the SG to RCS temperature difference is 22°F.
Evaluator Note:	Calculation: 147°F – 125°F = 22°F
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5

Performance Step:	1C1.2-M5, step 5.6.3.D:
Critical <u>Y</u>	Verify the limiting SG to RCS temperature difference is less than 15°F.
Standard:	Examinee determines the limiting SG to RCS ΔT is GREATER than 15°F and step D is NOT met.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When examinee determines the SG to RCS ΔT is 22°F and the limiting ΔT of 15°F has been exceeded, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-48, RCS / STEAM GENERATOR TEMPERATURE VERIFICATION, REV 5

ATTACHMENT 2

JPM Number: ADMIN-48JPM Title: STEAM GENERATOR TEMPERATURE VERIFICATION

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- Unit 1 is in MODE 6.
- Preparations are being made to start the FIRST Reactor Coolant Pump.
- An Out Plant Operator reports SG Skin Temperatures are as follows:
 - 12413, 11 SG SKIN TI = 141°F
 - 12414, 12 SG SKIN TI = 147°F

INITIATING CUES:

- The SS directs you to complete step 5.6.3 of 1C1.2-M5, UNIT 1 STARTUP TO MODE 5, and determine whether or not an RCP can be started.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME

JPM NUMBER: ADMIN-78 **REV.** 2

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): CRO 048 012 01 04 000 / ADJUST TURBINE LOAD RATES

K/A NUMBERS: 2.1.25 (3.9/4.2)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 13 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- A plant startup is in progress.
- Preparations are in progress to roll the turbine off the turning gear IAW 1C1.2-M1, Unit 1 Startup to Mode 1.

INITIATING CUES:

- The Shift Supervisor directs you to determine the following IAW 1C1.2-M1, section 5.3.35, step A:
 - Turbine acceleration rate
 - Maximum recommended loading rate

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2

JPM PERFORMANCE INFORMATION

Required Materials: Calculator
Attachment 4, DEHC screen showing ERCS points 14019, 14020 and 14088.
Consumable copy of 1C1.2-M1 and Fig. C1-2A.

General References: 1C1.2-M1, Unit 1 Startup to Mode 1,
Figure C1-2A, Recommended Startup and Loading Times

Task Standards: Examinee determines the correct turbine acceleration times and maximum recommended loading rate calculated per 1C1.2-M1 Att. 1.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step: 1C1.2-M1, section 5.3.35:

Critical N

Determine the turbine acceleration rate as follows:

A. Using “Turbine Temperatures” screen, determine the following:

1. LP 1ST Stage metal temperatures:

14019 _____ °F for LP1

14020 _____ °F for LP2

2. HP impulse chamber metal temperature:

14088 _____ °F for Imp Chamber

Standard: Examinee determines 14019 is 55.4°F, 14020 is 56.5°F and 14088 is 190.4 °F.

Evaluator Cue Provide Attachment 4 when examinee asks for DEHC temperature points.

Performance: SATISFACTORY _____ UNSATISFACTORY _____

Comments: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2

Performance Step:	1C1.2-M1, section 5.3.35:
Critical <u>N</u>	
	B. Complete Attachment 1, Turbine Loading Calculation.
Standard:	Examinee transitions to 1C1.2-M1 Attachment 1.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	1C1.2-M1, Attachment 1, step 1:
Critical <u>N</u>	
	1. Record HP Turbine First Stage Metal Temperature from 1C1.2-M1 Step 5.3.35.A.2
	HP Turbine First Stage Metal Temperature _____ °F
Standard:	Examinee records temperature for 14088 Imp Chamber as 190.4°F.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	1C1.2-M1, Attachment 1, step 2:
Critical <u>Y</u>	
	2. Determine the time to accelerate to synch from Figure C1-2A:
	Time = _____ minutes
Standard:	Examinee determines the time to be 11.25-13.75 minutes (11 min 15 sec – 13 min 45 sec).
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2

Performance Step:	1C1.2-M1, Attachment 1, step 3:
Critical <u>Y</u>	
	3. Calculate the maximum recommended acceleration rate:
	1800 rpm/ _____ minutes = _____ rpm/min
Standard:	Examinee calculates an acceleration rate of 130-160 rpm/min.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	1C1.2-M1, Attachment 1, step 4:
Critical <u>Y</u>	
	4. Determine the recommended time to hold at approximately 15% reactor power from figure C1-2A:
	Hold for _____ minutes
Standard:	Examinee determines a time of 27-33 minutes.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step:	1C1.2-M1, Attachment 1, step 5:
Critical <u>Y</u>	
	5. Determine the time to raise load to 100% from Figure C1-2A:
	Load increase in _____ minutes
Standard:	Examinee determines a time of 85-95 minutes.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2

Performance Step:	1C1.2-M1, Attachment 1, step 6:
Critical <u>Y</u>	
	6. Determine the maximum recommended loading rate:
	85%/ _____ minutes = _____ %/min
Standard:	Examinee determines a load rate of 0.85 to 1.0 %/minute.
Evaluator Note:	Examinee may choose DEHC load rates of 0.25%, 0.5% or 1% as the max loading rate since those are the three options that don't exceed the calculated limit, depending on how the final calculation ends up.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When the examinee determines the correct turbine acceleration times and maximum recommended loading rate calculated per 1C1.2-M1 Att. 1, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2**ATTACHMENT 1****JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-78, DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME, REV. 2

ATTACHMENT 2

JPM Number: ADMIN-78JPM Title: DETERMINE RECOMMENDED TURBINE STARTUP AND LOAD TIME

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).**

EVALUATOR'S SIGNATURE: _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- A plant startup is in progress.
- Preparations are in progress to roll the turbine off the turning gear IAW 1C1.2-M1, Unit 1 Startup to Mode 1.

INITIATING CUES:


- The Shift Supervisor directs you to determine the following IAW 1C1.2-M1, section 5.3.35, step A:
 - Turbine acceleration rate
 - Maximum recommended loading rate

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4



Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	--------------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: ASSESS SHIFT STAFFING LEVELS

JPM NUMBER: ADMIN-88 **REV.** 1

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): SS 343 ATI 00 00 009 / ENSURE SHIFT MANNING FOR ALL EVOLUTIONS INCLUDING FFD

K/A NUMBERS: 2.1.5 (2.9*/3.9)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 9 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☐ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-88, ASSESS SHIFT STAFFING LEVELS, REV. 1**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- You are the Unit 2 Shift Supervisor.
- Unit 1 and 2 are both at 100% power.
- It is Saturday at 1730.
- Currently on site, there are
 - 2 Shift Supervisors.
 - 4 Licensed Reactor Operators
 - 7 Non-licensed Operators
 - 1 Shift Technical Advisor
 - 1 Shift Manager
 - 1 Shift Chemist
 - 4 Radiation Protection Specialists
- The Shift Technical Advisor (STA) receives a phone call from his relief calling in sick. A call out is made and a relief will not be available until 2100.
- The STA requests permission to leave at 1800 due to family dinner plans.

INITIATING CUES:

- Determine the following using SWI O-2, Shift Organization, Operation & Turnover:
 - Can the STA immediately leave the site?
 - If so, what actions must be taken?
- Report decisions to evaluator.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-88, ASSESS SHIFT STAFFING LEVELS, REV. 1

JPM PERFORMANCE INFORMATION

Required Materials: SWI O-2, SHIFT ORGANIZATION, OPERATION & TURNOVER

General References: SWI O-2, SHIFT ORGANIZATION, OPERATION & TURNOVER

Task Standards: Examinee determines that the STA cannot be released for convenience and must keep the duty until a qualified relief arrives.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step:	SWI O-2 – Table 1, Minimum Shift Staffing:
Critical <u>N</u>	
Standard:	Examinee determines minimum shift staffing is currently met.
Evaluator Note:	Steps may be performed in any sequence.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-88, ASSESS SHIFT STAFFING LEVELS, REV. 1

Performance Step: Critical <u>Y</u>	SWI O-2 – Table 1, Minimum Shift Staffing: Note 1. Shift crew composition may be one less than the minimum requirements for a period of time not to exceed two hours in order to accommodate an unexpected absence of one duty shift crew member provided immediate action is taken to restore the shift crew composition to within the minimum requirements specified. This SHALL NOT be used for convenience.
Standard:	Examinee determines the STA is requesting to leave for convenience.
Evaluator Note:	Steps may be performed in any sequence.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Performance Step: Critical <u>Y</u>	Table 1 Minimum Shift Staffing: If a person's relief calls in sick, they are to keep the duty until a qualified relief arrives.
Standard:	Examinee determines the STA is not allowed to leave until a qualified relief arrives.
Evaluator Note:	Steps may be performed in any sequence.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When examinee determines the STA cannot be released for convenience and must keep the duty until a qualified relief arrives, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-88, ASSESS SHIFT STAFFING LEVELS, REV. 1

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-88, ASSESS SHIFT STAFFING LEVELS, REV. 1

ATTACHMENT 2

JPM Number: ADMIN-88JPM Title: ASSESS SHIFT STAFFING LEVELS

Examinee & ID: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3**TURNOVER SHEET****INITIAL CONDITIONS:**

- You are the Unit 2 Shift Supervisor.
- Unit 1 and 2 are both at 100% power.

- It is Saturday at 1730.
- Currently on site, there are
 - 2 Shift Supervisors.
 - 4 Licensed Reactor Operators
 - 7 Non-licensed Operators
 - 1 Shift Technical Advisor
 - 1 Shift Manager
 - 1 Shift Chemist
 - 4 Radiation Protection Specialists

- The Shift Technical Advisor (STA) receives a phone call from his relief calling in sick. A call out is made and a relief will not be available until 2100.

- The STA requests permission to leave at 1800 due to family dinner plans.

INITIATING CUES:

- Determine the following using SWI O-2, Shift Organization, Operation & Turnover:
 - Can the STA immediately leave the site?
 - If so, what actions must be taken?

- Report decisions to evaluator.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS)

JPM NUMBER: ADMIN-96 **REV.** 2

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): SS 342 ATI 00 00 030 / PERFORM SHUTDOWN SAFETY ASSESSMENT

K/A NUMBERS: 2.2.18 (2.6/3.9)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐

Simulator: ☐ Other: ☒

Lab: ☐

Time for Completion: 10 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☐ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Justin Hasner
	Developer Date
Validated by:	Fredrick Collins
	Validator Date
	(See JPM Validation Checklist, Attachment 1)
Approved by:	Shawn Sarrasin
	Training Supervisor Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- Unit 1 is in a FORCED OUTAGE to repair Reactor Coolant pump seals.
- Due to a change in equipment status, PINGP 1102, UNIT 1 SHUTDOWN SAFETY ASSESSMENT, is being performed for Decay Heat Removal (RCS) only.
- PINGP 1102, pages 1-3 are provided.
- RCS Time to boil is 1 hour.
- RWST is available as a make up source to support pool boil-off
- Equipment status has been completed and verified accurate.

INITIATING CUES:

- Determine the Total points for Decay Heat Removal (RCS) ONLY.
- Determine the current Condition for Decay Heat Removal (RCS).

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2

JPM PERFORMANCE INFORMATION

Required Materials: Consumable copy of PINGP 1102 and 5AWI 15.6.1

General References: 5AWI 15.6.1, SHUTDOWN SAFETY ASSESSMENT
PINGP 1102, UNIT 1 SHUTDOWN SAFETY ASSESSMENT

Task Standards: Examinee determines Decay Heat Removal (RCS) is a YELLOW condition.

Start Time: _____

NOTE: When providing "Evaluator Cues" to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee's actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a "Y" below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step:	11 RHR Available	
Critical <u>Y</u>	Yes	No
	<input checked="" type="checkbox"/>	<input type="checkbox"/> Train A RHR is aligned for Shutdown Cooling
	<input type="checkbox"/>	<input checked="" type="checkbox"/> 11 RHR Pmp
	<input checked="" type="checkbox"/>	<input type="checkbox"/> 11 RHR HX
	<input checked="" type="checkbox"/>	<input type="checkbox"/> CC Available to 11 RHR HX
	<input checked="" type="checkbox"/>	<input type="checkbox"/> Clg Wtr Available to CC HX
	<input checked="" type="checkbox"/>	<input type="checkbox"/> Two (2) Clg Wtr Pmps Available (One SFGDS)
		11, 21, 121, 12, 22 (Circle Available CL Pmps) (0-1) _____
Standard:	Examinee allocates ZERO points for 11 RHR Available	
Performance:	SATISFACTORY _____ UNSATISFACTORY _____	
Comments:	_____	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2

Performance Step: Critical <u>Y</u>	<table border="0" style="width: 100%;"> <tr> <th align="left" colspan="2">12 RHR Available</th> <th></th> </tr> <tr> <td style="width: 10%; text-align: center;">Yes</td> <td style="width: 10%; text-align: center;">No</td> <td></td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>Train B RHR is aligned for Shutdown Cooling</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td>12 RHR Pmp</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>12 RHR HX</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>CC Available to 12 RHR HX</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>Clg Wtr Available to CC HX</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>Two (2) Clg Wtr Pmps Available (One SFGDS)</td> </tr> <tr> <td></td> <td></td> <td>11, 21, 121, 12, 22 (Circle Available CL Pmps) (0-1)</td> </tr> </table>	12 RHR Available			Yes	No		<input checked="" type="checkbox"/>	<input type="checkbox"/>	Train B RHR is aligned for Shutdown Cooling	<input type="checkbox"/>	<input checked="" type="checkbox"/>	12 RHR Pmp	<input checked="" type="checkbox"/>	<input type="checkbox"/>	12 RHR HX	<input checked="" type="checkbox"/>	<input type="checkbox"/>	CC Available to 12 RHR HX	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clg Wtr Available to CC HX	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Two (2) Clg Wtr Pmps Available (One SFGDS)			11, 21, 121, 12, 22 (Circle Available CL Pmps) (0-1)
12 RHR Available																												
Yes	No																											
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Train B RHR is aligned for Shutdown Cooling																										
<input type="checkbox"/>	<input checked="" type="checkbox"/>	12 RHR Pmp																										
<input checked="" type="checkbox"/>	<input type="checkbox"/>	12 RHR HX																										
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CC Available to 12 RHR HX																										
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clg Wtr Available to CC HX																										
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Two (2) Clg Wtr Pmps Available (One SFGDS)																										
		11, 21, 121, 12, 22 (Circle Available CL Pmps) (0-1)																										
Standard:	Examinee allocates ZERO points for 12 RHR Available																											
Performance:	SATISFACTORY _____ UNSATISFACTORY _____																											
Comments:	_____																											

Performance Step: Critical <u>Y</u>	<table border="0" style="width: 100%;"> <tr> <th align="left" colspan="2">Refueling Pool Core Cooling Available</th> <th></th> </tr> <tr> <td style="width: 10%; text-align: center;">Yes</td> <td style="width: 10%; text-align: center;">No</td> <td></td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td>At least 6 hours to boiling in the Refueling Pool (Ref. FIG C1-33)</td> </tr> <tr> <td></td> <td></td> <td>Time to boil: _____</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>A makeup source is available to support pool boil-off rate. (Ref. FIG C1-33A)</td> </tr> <tr> <td></td> <td></td> <td>Make-up source: _____</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> <td>At least one CFCU is available with Cooling Water flow capability of at least 900 gpm.</td> </tr> <tr> <td></td> <td></td> <td>(0-1) _____</td> </tr> </table>	Refueling Pool Core Cooling Available			Yes	No		<input type="checkbox"/>	<input checked="" type="checkbox"/>	At least 6 hours to boiling in the Refueling Pool (Ref. FIG C1-33)			Time to boil: _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	A makeup source is available to support pool boil-off rate. (Ref. FIG C1-33A)			Make-up source: _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one CFCU is available with Cooling Water flow capability of at least 900 gpm.			(0-1) _____
Refueling Pool Core Cooling Available																									
Yes	No																								
<input type="checkbox"/>	<input checked="" type="checkbox"/>	At least 6 hours to boiling in the Refueling Pool (Ref. FIG C1-33)																							
		Time to boil: _____																							
<input checked="" type="checkbox"/>	<input type="checkbox"/>	A makeup source is available to support pool boil-off rate. (Ref. FIG C1-33A)																							
		Make-up source: _____																							
<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one CFCU is available with Cooling Water flow capability of at least 900 gpm.																							
		(0-1) _____																							
Standard:	Examinee allocates ZERO points for Refueling Pool Core Cooling Available																								
Performance:	SATISFACTORY _____ UNSATISFACTORY _____																								
Comments:	_____																								

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2

Performance Step: Critical <u>Y</u>	<div style="display: flex; justify-content: space-between;"> <div> 11 S.G. Available <div style="display: flex; justify-content: space-between; font-size: small;"> Yes No </div> <div style="display: flex; justify-content: space-between;"> <div style="width: 30%;"> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> </div> <div style="width: 70%;"> RCS can be made intact by valve closure with primary and secondary manways installed. At least one PRESSURIZER PORV can be operated from the Control Room. At least one Charging Pump is available to pressurize the RCS. RCS filled and vented SG Wide Range Level > 60% AFW available Steam Release Path (Yes if any of the following are Yes) </div> </div> <div style="margin-top: 5px; font-size: x-small;"> <div style="display: flex; justify-content: space-between;"> Yes No </div> <div style="display: flex; justify-content: space-between;"> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> </div> <div style="display: flex; justify-content: space-between;"> S.G. PORV OPEN or available MSIV OPEN and STM DUMP valve available MSIV Bypass OPEN and STM Dump Valve available </div> </div> </div> <div style="text-align: right; margin-top: 5px;"> (0-1) _____ </div> </div>
Standard:	Examinee allocates ONE point for 11 S.G. Available
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	<hr style="border: 0; border-top: 1px solid black; height: 10px;"/>

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2

Performance Step: Critical <u>Y</u>	<table border="0" style="width: 100%;"> <tr> <th align="left" colspan="2">12 S.G. Available</th> <th></th> </tr> <tr> <th align="left">Yes</th> <th align="left">No</th> <th></th> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>RCS can be made intact by valve closure with primary and secondary manways installed.</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>At least one PRESSURIZER PORV can be operated from the Control Room.</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>At least one Charging Pump is available to pressurize the RCS.</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>RCS filled and vented</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>SG Wide Range Level > 60%</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>AFW Available</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>Steam Release Path (Yes if any of the following are Yes)</td> </tr> <tr> <td></td> <td>Yes</td> <td>No</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td>S.G. PORV OPEN or available</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td>MSIV OPEN and STM DUMP valve available</td> </tr> <tr> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td>MSIV Bypass OPEN and STM Dump Valve available</td> </tr> </table>	12 S.G. Available			Yes	No		<input checked="" type="checkbox"/>	<input type="checkbox"/>	RCS can be made intact by valve closure with primary and secondary manways installed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one PRESSURIZER PORV can be operated from the Control Room.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one Charging Pump is available to pressurize the RCS.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	RCS filled and vented	<input checked="" type="checkbox"/>	<input type="checkbox"/>	SG Wide Range Level > 60%	<input checked="" type="checkbox"/>	<input type="checkbox"/>	AFW Available	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Steam Release Path (Yes if any of the following are Yes)		Yes	No	<input checked="" type="checkbox"/>	<input type="checkbox"/>	S.G. PORV OPEN or available	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MSIV OPEN and STM DUMP valve available	<input type="checkbox"/>	<input checked="" type="checkbox"/>	MSIV Bypass OPEN and STM Dump Valve available
12 S.G. Available																																								
Yes	No																																							
<input checked="" type="checkbox"/>	<input type="checkbox"/>	RCS can be made intact by valve closure with primary and secondary manways installed.																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one PRESSURIZER PORV can be operated from the Control Room.																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	At least one Charging Pump is available to pressurize the RCS.																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	RCS filled and vented																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	SG Wide Range Level > 60%																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	AFW Available																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Steam Release Path (Yes if any of the following are Yes)																																						
	Yes	No																																						
<input checked="" type="checkbox"/>	<input type="checkbox"/>	S.G. PORV OPEN or available																																						
<input type="checkbox"/>	<input checked="" type="checkbox"/>	MSIV OPEN and STM DUMP valve available																																						
<input type="checkbox"/>	<input checked="" type="checkbox"/>	MSIV Bypass OPEN and STM Dump Valve available																																						
	(0-1) 																																							
	Total Points "DECAY HEAT REMOVAL" (RCS) Total (0-5) 																																							
Standard:	Examinee allocates ONE point for 12 S.G. Available																																							
Performance:	SATISFACTORY _____ UNSATISFACTORY _____																																							
Comments:	_____																																							

Performance Step: Critical <u>Y</u>	<table border="0" style="width: 100%;"> <tr> <td align="right">Total Points "DECAY HEAT REMOVAL" (RCS)</td> <td align="right">Total (0-5)</td> <td></td> </tr> </table>	Total Points "DECAY HEAT REMOVAL" (RCS)	Total (0-5)	
Total Points "DECAY HEAT REMOVAL" (RCS)	Total (0-5)			
Standard:	Examinee allocates TWO points for Decay Heat Removal RCS and determines DHR RCS is YELLOW			
Performance:	SATISFACTORY _____ UNSATISFACTORY _____			
Comments:	_____			

Terminating Cues: **When examinee has determined Decay Heat Removal RCS is a Yellow condition, then this JPM is complete.**

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written. The individual(s) performing the validation sign and date this form.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-96, PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS), REV 2**ATTACHMENT 2****JPM Number:** ADMIN – 96**JPM Title:** PERFORM SHUTDOWN SAFETY ASSESSMENT FOR DECAY HEAT REMOVAL (RCS)**Examinee & ID:** _____**Evaluator:** _____**Job Title:** _____**Date:** _____**Start Time** _____**Finish Time** _____**PERFORMANCE RESULTS:****SAT:** ☐**UNSAT:** ☐**COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- Unit 1 is in a FORCED OUTAGE to repair Reactor Coolant pump seals.
- Due to a change in equipment status, PINGP 1102, UNIT 1 SHUTDOWN SAFETY ASSESSMENT, is being performed for Decay Heat Removal (RCS) only.
- PINGP 1102, pages 1-3 are provided.
- RCS Time to boil is 1 hour.
- RWST is available as a make up source to support pool boil-off
- Equipment status has been completed and verified accurate.

INITIATING CUES:

- Determine the Total points for Decay Heat Removal (RCS) ONLY.
- Determine the current Condition for Decay Heat Removal (RCS).

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: PRAIRIE ISLAND

JPM TITLE: PERFORM RCS LEAKAGE INVESTIGATION (PRT)

JPM NUMBER: ADMIN-100 REV. 1

RELATED PRA INFORMATION: LOCA TOTAL – 14.3%

TASK NUMBERS / TASK TITLE(S): CRO 002 999 00 00 000 / OPERATE THE REACTOR COOLANT SYSTEM
CRO 002 ATI 00 00 017 / PERFORM RCS LEAKAGE INVESTIGATION

K/A NUMBERS: 2.2.12 (3.7/4.1)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐
Simulator: ☐ Other: ☒
Lab: ☐

Time for Completion: 7 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Justin Hasner	
	Developer	Date
Validated by:	Zach Elbert	
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-100, PERFORM RCS LEAKAGE INVESTIGATION (PRT), REV. 1**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- SP1001AA, Daily Reactor Coolant System Leakage Test has just been completed.
- Steps 7.2.1 through 7.2.3 of SP1001AAA are complete.
- Step 7.2.3 of SP1001AAA was completed at **1051**.
- PRT level, as read on 1L1-442, at the time step 7.2.3 was completed was **70%**.

INITIATING CUES:

- The Shift Supervisor directs you to complete step 7.2.4 of SP1001AAA, Reactor Coolant System Leakage Investigation.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-100, PERFORM RCS LEAKAGE INVESTIGATION (PRT), REV. 1**JPM PERFORMANCE INFORMATION**

- Required Materials:** Consumable copy of pages 7 and 8 of SP1001AAA, Reactor Coolant System Leakage Investigation, with the following data entered:
- Step 7.2.1 marked NA.
 - Step 7.2.2 marked with the following data:
 - PRT level is 68%.
 - PRT Gallons are 4300.
 - Time is 0831.
 - Step 7.2.3 marked complete with the bullet next to “2 hour period” circle/slashed.
- Calculator**
Unit 1 Tank Book – 11 & 21 PRT Level/Volume Graph
- General References:** SP1001AAA
Unit 1 Tank Book
- Task Standards:** Examinee determines that leakage into PRT is ~ 0.7 gpm.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step:	SP1001AAA, Step 7.2.4, Bullet 1:	
Critical <u>Y</u>	Final RCDT level using ERCS point 1L0485A, PRZR RELIEF TK L, or 1LI-442, PRT Level:	
Standard:	Examinee enters 70% for final PRT level, 4400 gallons for final PRT level, and 100 gallons for Gallons Changed.	
Performance:	SATISFACTORY _____	UNSATISFACTORY _____
Comments:	_____	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-100, PERFORM RCS LEAKAGE INVESTIGATION (PRT), REV. 1

Performance Step:	SP1001AAA, Step 7.2.4, Bullet 2:
Critical <u>Y</u>	
	Time final PRT level reading recorded:
Standard:	Examinee enters 1051 for time final PRT level was recorded, 140 min for duration of the test, and calculates the rate of change to be ~0.7 gpm.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When examinee has determined that leakage into the RCDT is ~0.7 gpm, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-100, PERFORM RCS LEAKAGE INVESTIGATION (PRT), REV. 1**ATTACHMENT 1****JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-100, PERFORM RCS LEAKAGE INVESTIGATION (PRT), REV. 1

ATTACHMENT 2

JPM Number: ADMIN-100JPM Title: PERFORM RCS LEAKAGE INVESTIGATION (PRT)

Examinee & ID: _____ Evaluator: _____

Job Title: _____ Date: _____

Start Time _____ Finish Time _____

PERFORMANCE RESULTS:

SAT: UNSAT: **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).**

EVALUATOR'S SIGNATURE: _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 3

TURNOVER SHEET

INITIAL CONDITIONS:

- SP1001AA, Daily Reactor Coolant System Leakage Test has just been completed.
- Steps 7.2.1 through 7.2.3 of SP1001AAA are complete.
- Step 7.2.3 of SP1001AAA was completed at **1051**.
- PRT level, as read on 1L1-442, at the time step 7.2.3 was completed was **70%**.

INITIATING CUES:

- The Shift Supervisor directs you to complete step 7.2.4 of SP1001AAA, Reactor Coolant System Leakage Investigation.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.



JOB PERFORMANCE MEASURE (JPM)

SITE: PRAIRIE ISLAND

JPM TITLE: DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION

JPM NUMBER: ADMIN-106 REV. 0

RELATED PRA INFORMATION: NONE

TASK NUMBERS / TASK TITLE(S): SS 344 023 03 03 000 / DIRECT EMERGENCY RESPONSE FOR THE EMERGENCY DIRECTOR

K/A NUMBERS: 2.4.40 (2.7/4.5)

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☐ Perform: ☒

EVALUATION LOCATION: In-Plant: ☐ Control Room: ☐
 Simulator: ☐ Other: ☒
 Lab: ☐

Time for Completion: 10 Minutes Time Critical: YES

Alternate Path: NO

TASK APPLICABILITY: SRO: ☒ RO: ☐ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:	Fredrick Collins	
	Developer	Date
Validated by:	Justin Hasner	
	Validator	Date
	(See JPM Validation Checklist, Attachment 1)	
Approved by:	Shawn Sarrasin	
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-106, DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION, REV. 0**JPM BRIEFING/TURNOVER**

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- You are the Unit 1 Shift Supervisor.
- Unit 1 has experienced a Large Break Loss of Coolant Accident.
- A SITE AREA EMERGENCY based on EAL FS1 has been declared due to Loss of RCS Barrier and Potential Loss of Containment Barrier.
- The Shift Manager completed filling out the PINGP 577 for initial notification for FS1 **5 minutes ago**.

INITIATING CUES:

- Wind Speed – 11.0 MPH
- Wind Direction – 255°
- Stability Class – A
- The Shift Manager has tasked you with performing the independent verification of his completed PINGP 577.
 - Review the completed PINGP 577.
 - Determine if is suitable for delivery to the SEC and return the form to the Shift Manager.

THIS JPM IS TIME CRITICAL

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-106, DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION, REV. 0**JPM PERFORMANCE INFORMATION**

Required Materials: Consumable copies of Attachments 5 & 6, PINGP 577 & 1576 – Student Consumable copies of PINGP 577 pages 2-12 PINGP 1576

General References: F3-2, Classification of Emergencies
PINGP 577, Rev. 60
PINGP 1576, Rev. 10

Task Standards: Determine errors exist in Blocks 4 (GE circled vice SAE), Block 5 (time/date/EAL# not filled in), and Block 8 (incorrect downwind sectors circled) of PINGP 577 and return the form to the Shift Manager for correction.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step shall result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step: Critical <u>Y</u>	Review completed PINGP 577.
Standard:	Examinee reviews PINGP 577 and determines the following errors exist: <ul style="list-style-type: none"> • Block 4: The incorrect declaration is circled. • Block 5: Time/Date/EAL# are not filled in • Block 8: The incorrect downwind sectors are circled.
Evaluator Note:	Errors are noted in RED on KEY with correct information with exception of time and date as the actual time/date are inconsequential.
Evaluator Cues:	Provide examinee with Attachments 5 & 6, PINGP 577 & PINGP 1576. If examinee asks for time/date, inform examinee that they can use the current time/date.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-106, DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION, REV. 0

Performance Step: Critical <u>Y</u>	Determine if PINGP 577 is suitable for delivery to SEC and return the form to the Shift Manager.
Standard:	Examinee determines that the PINGP 577 CANNOT be delivered to the SEC as is without fixing the errors.
Evaluator Note:	The examinee marking the errors on the form or informing the evaluator of the errors is sufficient to complete this step.
Performance:	SATISFACTORY _____ UNSATISFACTORY _____
Comments:	_____

Terminating Cues: When examinee has determined errors exist in Blocks 4 (GE circled vice SAE), Block 5 (time/date/EAL# not filled in), and Block 8 (incorrect downwind sectors circled) of PINGP 577 and returned the form to the Shift Manager for correction, then this JPM is complete.

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-106, DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION, REV. 0**ATTACHMENT 1****JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 2

KEY

EMERGENCY NOTIFICATION REPORT FORM	
1. REASON FOR CALL [A] Initial Report [B] Emergency Class Change [C] PAR Change [D] Release Status Change Only	
2. STATUS [A] ACTUAL EVENT [B] DRILL/EXERCISE	3. AFFECTED STATION [C] PRAIRIE ISLAND NUCLEAR GENERATING PLANT
4. ONSITE CLASSIFICATION [A] UNUSUAL EVENT [B] ALERT [C] SITE AREA EMERGENCY [D] GENERAL EMERGENCY [E] RECOVERY [F] TERMINATED	5. TIME & DATE OF CLASSIFICATION / PAR CHANGE / TERMINATION [A] CLASSIFICATION TIME XXXX DATE XXXX EAL # FS1 [B] PAR CHANGE TIME DATE [C] TERMINATION TIME DATE [D] RELEASE STATUS CHANGE ONLY
6. EVENT RELEASE STATUS [A] NONE [B] OCCURRING [C] TERMINATED	7. TYPE OF RELEASE [A] NOT APPLICABLE [B] AIRBORNE [C] LIQUID
8. WIND DIRECTION (Use current 15 minute average and Table 1 to choose currently affected downwind Sectors, if < 5 mph all sectors are affected.) FROM 255 DEGREES DOWNWIND SECTORS: A B C D E F G H J K L M N P Q R (Circle currently affected sectors.)	9. WIND SPEED & STABILITY CLASS (Use current 15 minute average.) MILES/HR.: 11.0 STABILITY CLASS: A B C D E F G (unstable <= => stable)
10. PRECAUTIONARY MEASURES and PROTECTIVE ACTION RECOMMENDATIONS (Use Table 1 to choose affected downwind Sectors and geopolitical Subareas.) [A] NONE [B] EVACUATE (or SHELTER) SECTORS OUT TO 2 MILES EVACUATE (or SHELTER) SECTORS FROM 2 MILES TO 5 MILES EVACUATE (or SHELTER) SECTORS FROM 5 MILES TO 10 MILES Affected SUBAREAS: (circle all that apply) 2 5N 5E 5S 5W 10NW 10N 10NE 10E 10SE 10SW 10W <u>AND</u> PUBLIC IN THOSE AFFECTED SUBAREAS TAKE KI IF AVAILABLE; <u>AND</u> REMAINDER OF PLUME EPZ TO MONITOR RADIO/TV BROADCASTS FOR FURTHER INFORMATION. (Clarifying notes, if needed) _____ [C] PRECAUTIONARY MEASURE FOR CASINO SHUTDOWN AND DISMISSAL OF STAFF AND PATRONS. [D] PRECAUTIONARY MEASURE TO ADVISE CASINO AND RESIDENTS WITHIN A 2 MILE RADIUS TO STAY INDOORS AND CONTINUE TO MONITOR RADIO/TV BROADCASTS FOR FURTHER INFORMATION. [E] OTHER: _____	
11. ADDITIONAL INFORMATION (Apply the EAL Gum Label or write the event descriptions based on the EAL. If PAR Change, write "None", "PAR Change" or other PAR information. If Release Status Change Only, specify time of change. If terminating, specify reason.) <div style="background-color: yellow; padding: 2px;">FS1 – Loss or Potential Loss of ANY two Barriers.</div> <div style="background-color: yellow; height: 15px; margin-top: 5px;"></div> <div style="background-color: yellow; height: 15px; margin-top: 5px;"></div> <div style="background-color: yellow; height: 15px; margin-top: 5px;"></div> <div style="background-color: yellow; height: 15px; margin-top: 5px;"></div> <div style="background-color: yellow; height: 15px; margin-top: 5px;"></div>	APPROVAL SIGNATURE <div style="background-color: yellow; padding: 2px; margin-bottom: 5px;">Jim Smith</div> EMERGENCY DIRECTOR/EMERGENCY MANAGER 12. EMERGENCY COMMUNICATOR (Print Name) _____ (Circle or indicate the appropriate callback number.) <ul style="list-style-type: none"> Control Room Callback (612) 330-6893 TSC Callback (651) 388-1121 Ext. 4369 Other Callback _____ Security Event SEC _____ EOF Callback (651) 388-1121 Ext. 5241 Backup EOF Callback (612) 330-5753

Retention: Life of Plant
Retain in: Training Record
Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ADMIN-106, DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION, REV. 0**ATTACHMENT 3****JPM Number:** ADMIN-106**JPM Title:** DETERMINE PINGP 577 ERRORS ON INITIAL CLASSIFICATION**Examinee & ID:** _____**Evaluator:** _____**Job Title:** _____**Date:** _____**Start Time** _____**Finish Time** _____**PERFORMANCE RESULTS:****SAT:** **UNSAT:** **COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 4**TURNOVER SHEET****INITIAL CONDITIONS:**

- You are the Unit 1 Shift Supervisor.
- Unit 1 has experienced a Large Break Loss of Coolant Accident.
- A SITE AREA EMERGENCY based on EAL FS1 has been declared due to Loss of RCS Barrier and Potential Loss of Containment Barrier.
- The Shift Manager completed filling out the PINGP 577 for initial notification for FS1 **5 minutes ago**.

INITIATING CUES:

- Wind Speed – 11.0 MPH
- Wind Direction – 255°
- Stability Class – A
- The Shift Manager has tasked you with performing the independent verification of his completed PINGP 577.
 - Review the completed PINGP 577.
 - Determine if is suitable for delivery to the SEC and return the form to the Shift Manager.

THIS JPM IS TIME CRITICAL

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 5

PINGP 577, Rev 60

Page 1 of 12

Doc Type/Sub Type: N/A

Retention: N/A

EMERGENCY NOTIFICATION REPORT FORM

1. REASON FOR CALL <input checked="" type="radio"/> [A] Initial Report <input type="radio"/> [B] Emergency Class Change <input type="radio"/> [C] PAR Change <input type="radio"/> [D] Release Status Change Only	
2. STATUS <input checked="" type="radio"/> [A] ACTUAL EVENT <input type="radio"/> [B] DRILL/EXERCISE	3. AFFECTED STATION <input checked="" type="radio"/> [C] PRAIRIE ISLAND NUCLEAR GENERATING PLANT
4. ONSITE CLASSIFICATION <input type="radio"/> [A] UNUSUAL EVENT <input type="radio"/> [B] ALERT <input checked="" type="radio"/> [C] SITE AREA EMERGENCY <input type="radio"/> [D] GENERAL EMERGENCY <input type="radio"/> [E] RECOVERY <input type="radio"/> [F] TERMINATED	5. TIME & DATE OF CLASSIFICATION / PAR CHANGE / TERMINATION <input checked="" type="radio"/> [A] CLASSIFICATION TIME _____ DATE _____ EAL # _____ <input type="radio"/> [B] PAR CHANGE TIME _____ DATE _____ <input type="radio"/> [C] TERMINATION TIME _____ DATE _____ <input type="radio"/> [D] RELEASE STATUS CHANGE ONLY
6. EVENT RELEASE STATUS <input checked="" type="radio"/> [A] NONE <input type="radio"/> [B] OCCURRING <input type="radio"/> [C] TERMINATED	7. TYPE OF RELEASE <input checked="" type="radio"/> [A] NOT APPLICABLE <input type="radio"/> [B] AIRBORNE <input type="radio"/> [C] LIQUID
8. WIND DIRECTION (Use current 15 minute average and Table 1 to choose currently affected downwind Sectors, if < 5 mph all sectors are affected.) FROM <u>255</u> DEGREES DOWNWIND SECTORS: <u>A B C D E F G H J K L M N P Q R</u> (Circle currently affected sectors.)	9. WIND SPEED & STABILITY CLASS (Use current 15 minute average.) MILES/HR.: <u>11.0</u> STABILITY CLASS <input checked="" type="radio"/> A <input type="radio"/> B <input type="radio"/> C <input type="radio"/> D <input type="radio"/> E <input type="radio"/> F <input type="radio"/> G unstable <= => stable
10. PRECAUTIONARY MEASURES and PROTECTIVE ACTION RECOMMENDATIONS (Use Table 1 to choose affected downwind Sectors and geopolitical Subareas.) <input checked="" type="radio"/> [A] NONE <input type="radio"/> [B] EVACUATE (or SHELTER) _____ SECTORS OUT TO <u>2</u> MILES EVACUATE (or SHELTER) _____ SECTORS FROM <u>2</u> MILES TO <u>5</u> MILES EVACUATE (or SHELTER) _____ SECTORS FROM <u>5</u> MILES TO <u>10</u> MILES Affected SUBAREAS: (circle all that apply) <u>2 5N 5E 5S 5W 10NW 10N 10NE 10E 10SE 10SW 10W</u> AND PUBLIC IN THOSE AFFECTED SUBAREAS TAKE KI IF AVAILABLE; AND REMAINDER OF PLUME EPZ TO MONITOR RADIO/TV BROADCASTS FOR FURTHER INFORMATION. (Clarifying notes, if needed) _____ <input type="radio"/> [C] PRECAUTIONARY MEASURE FOR CASINO SHUTDOWN AND DISMISSAL OF STAFF AND PATRONS. <input type="radio"/> [D] PRECAUTIONARY MEASURE TO ADVISE CASINO AND RESIDENTS WITHIN A 2 MILE RADIUS TO STAY INDOORS AND CONTINUE TO MONITOR RADIO/TV BROADCASTS FOR FURTHER INFORMATION. <input type="radio"/> [E] OTHER: _____	
11. ADDITIONAL INFORMATION (Apply the EAL Gum Label or write the event descriptions based on the EAL. If PAR Change, write "None", "PAR Change" or other PAR information. If Release Status Change Only, specify time of change. If terminating, specify reason.) <u>FS1 – Loss or Potential Loss of ANY two Barriers.</u> _____ _____ _____ _____	12. APPROVAL SIGNATURE <u>Jim Smith</u> EMERGENCY DIRECTOR/EMERGENCY MANAGER 12. EMERGENCY COMMUNICATOR (Print Name) (Circle or indicate the appropriate callback number.) • Control Room Callback (612) 330-6893 • TSC Callback (651) 388-1121 Ext. 4369 • Other Callback _____ • Security Event SEC _____ • EOF Callback (651) 388-1121 Ext. 5241 • Backup EOF Callback (612) 330-5753

*Italic words provide guidance for the person completing this form. See Directions for more guidance on completing form

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 6

Prairie Island Nuclear Generating Plant

EMERGENCY ACTION LEVEL MATRIX

GENERAL EMERGENCY		SITE AREA EMERGENCY		ALERT		UNUSUAL EVENT		HOT			
<input type="checkbox"/> FG1 1 2 3 4 Loss of ANY two Barriers AND Loss or Potential Loss of Third Barrier (Table F-1).		<input checked="" type="checkbox"/> FS1 1 2 3 4 Loss or Potential Loss of ANY two Barriers (Table F-1).		<input type="checkbox"/> FA1 1 2 3 4 ANY Loss or ANY Potential Loss of EITHER Fuel Clad OR RCS (Table F-1).		<input type="checkbox"/> FU1 1 2 3 4 ANY Loss or ANY Potential Loss of Containment (Table F-1).					
Table F-1 FISSION PRODUCT BARRIER REFERENCE TABLE											
NOTE Determine which combination of the three barriers are lost or have a potential loss and use the following key to classify the event. Also an event for multiple events could occur which result in the conclusion that exceeding the Loss or Potential Loss thresholds is imminent (i.e., within 1 to 2 hours). In this imminent loss situation use judgment and classify as if the thresholds are exceeded.											
Fuel Cladding Barrier <input type="checkbox"/> Loss <input type="checkbox"/> Potential Loss		RCS Barrier <input checked="" type="checkbox"/> Loss <input type="checkbox"/> Potential Loss		Containment Barrier <input type="checkbox"/> Loss <input checked="" type="checkbox"/> Potential Loss							
<input type="checkbox"/> 1. <u>Critical Safety Function Status</u> Core-Cooling-Red. <input type="checkbox"/> 2. <u>Primary Coolant Activity Level</u> Coolant Activity GREATER THAN 300 μ Q/gm l-131 equivalent. <input type="checkbox"/> 3. <u>Core Exit Thermocouple Readings</u> GREATER THAN 1200 degree F. <input type="checkbox"/> 4. <u>Reactor Vessel Water Level</u> Not Applicable. <input type="checkbox"/> 5. <u>Containment Radiation Monitoring</u> Containment rad monitor 1(2)R-48 or 49 reading GREATER THAN 200 R/hr. <input type="checkbox"/> 6. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 7. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Loss of the Fuel Clad Barrier.		<input type="checkbox"/> 1. <u>Critical Safety Function Status</u> Core-Cooling-Orange; OR Heat Sink-Red. <input type="checkbox"/> 2. <u>Primary Coolant Activity Level</u> Not Applicable. <input type="checkbox"/> 3. <u>Core Exit Thermocouple Readings</u> GREATER THAN 700 degree F. <input type="checkbox"/> 4. <u>Reactor Vessel Water Level</u> Level LESS THAN: - 40% RV/LIS Full Range (no RCP); - 30% RV/LIS Dynamic Head Range (1 RCP); - 60% RV/LIS Dynamic Head Range (2 RCPs). <input type="checkbox"/> 5. <u>Containment Radiation Monitoring</u> Not Applicable. <input type="checkbox"/> 6. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 7. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Potential Loss of the Fuel Clad Barrier.		<input checked="" type="checkbox"/> 1. <u>Critical Safety Function Status</u> Not Applicable. <input checked="" type="checkbox"/> 2. <u>RCS Leak Rate</u> GREATER THAN available makeup capacity as indicated by a loss of RCS subcooling LESS THAN 21 (40)* degree F. * Adverse containment conditions are defined as a containment pressure greater than 5 psig or containment radiation level greater than 164 R/hr. <input type="checkbox"/> 3. <u>SG Tube Rupture</u> SGTR that results in an ECCS (SI) Actuation. <input type="checkbox"/> 4. <u>Containment Radiation Monitoring</u> Containment rad monitor 1(2)R-48 or 49 reading GREATER THAN 7 R/hr. <input type="checkbox"/> 5. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 6. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Loss of the RCS Barrier.		<input type="checkbox"/> 1. <u>Critical Safety Function Status</u> RCS Integrity-Red; OR Heat Sink-Red. <input type="checkbox"/> 2. <u>RCS Leak Rate</u> Unisolable leak exceeding 60 gpm. <input type="checkbox"/> 3. <u>SG Tube Rupture</u> Not Applicable. <input type="checkbox"/> 4. <u>Containment Radiation Monitoring</u> Not Applicable. <input type="checkbox"/> 5. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 6. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Potential Loss of the RCS Barrier.		<input type="checkbox"/> 1. <u>Critical Safety Function Status</u> Not Applicable. <input type="checkbox"/> 2. <u>Containment Pressure</u> Rapid unexplained decrease following initial increase; OR Containment pressure or sump level response not consistent with LOCA conditions. <input type="checkbox"/> 3. <u>Core Exit Thermocouple Readings</u> Not Applicable. <input type="checkbox"/> 4. <u>SG Secondary Side Release with P-to-S Leakage</u> RUPTURED SG is also FAULTED outside of containment; OR Primary-to-Secondary leak rate GREATER THAN 10 gpm with nonisolable steam release from affected S/G to the environment. <input type="checkbox"/> 5. <u>CNMT Isolation Valves Status After CNMT Isolation</u> Containment isolation Valve(s) not closed; AND Direct pathway to the environment exists after Containment Isolation signal. <input type="checkbox"/> 6. <u>Significant Radioactive Inventory in Containment</u> Not Applicable. <input type="checkbox"/> 7. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 8. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Loss of the Containment Barrier.		<input type="checkbox"/> 1. <u>Critical Safety Function Status</u> Containment-Red. <input checked="" type="checkbox"/> 2. <u>Containment Pressure</u> 48 PSIG and increasing; OR Containment hydrogen concentration GREATER THAN OR EQUAL TO 6%; OR Containment pressure GREATER THAN 23 psig with LESS THAN one full train of depressurization equipment operating. <input type="checkbox"/> 3. <u>Core Exit Thermocouple Readings</u> Core exit thermocouples in excess of 1200 degrees F and restoration procedures not effective within 15 minutes; OR Core exit thermocouples in excess of 700 degrees F with reactor vessel level below 40% RV/LIS Full Range and restoration procedures not effective within 15 minutes. <input type="checkbox"/> 4. <u>SG Secondary Side Release with P-to-S Leakage</u> Not Applicable <input type="checkbox"/> 5. <u>CNMT Isolation Valves Status After CNMT Isolation</u> Not Applicable. <input type="checkbox"/> 6. <u>Significant Radioactive Inventory in Containment</u> Containment rad monitor 1(2)R-48 or 49 reading GREATER THAN 800 R/hr. <input type="checkbox"/> 7. <u>Other Indications</u> Not Applicable. <input type="checkbox"/> 8. <u>Emergency Director Judgment</u> Any condition in the opinion of the Emergency Director that indicates Potential Loss of the Containment Barrier.	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.