



June 27, 2022

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No.: 22-201
NRA/GDM: R0
Docket No.: 50-281
License No.: DPR-37

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION ENERGY VIRGINIA)
SURRY POWER STATION UNIT 2
CORE OPERATING LIMITS REPORT
SURRY 2 CYCLE 31 PATTERN MSK REVISION 1

Pursuant to Surry Power Station (Surry) Units 1 and 2 Technical Specification (TS) 6.2.C, attached is a copy of the Core Operating Limits Report (COLR) for Surry Power Station Unit 2, Cycle 31, Pattern MSK, Revision 1. The revision incorporates a change to the Control Bank Rod Insertion Limits (RILs) to accommodate operation with a Rod Cluster Control Assembly (RCCA) RIL of 225 steps for the C-Bank.

If you have any questions or require additional information, please contact Mr. Gary D. Miller at (804) 273-2771.

Respectfully,

A handwritten signature in black ink that reads "B E Standley".

B. E. Standley, Director
Nuclear Regulatory Affairs
Dominion Energy Services, Inc. for
Virginia Electric and Power Company

Attachment: Core Operating Limits Report, Surry Unit 2 Cycle 31 Pattern MSK, Revision 1

Commitment Summary: There are no new commitments contained in this letter.

cc: U.S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Avenue, NE
Suite 1200
Atlanta, Georgia 30303-1257

Mr. L. John Klos
NRC Project Manager – Surry
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 09 E-3
11555 Rockville Pike
Rockville, MD 20852-2738

Mr. G. Edward Miller
NRC Senior Project Manager – North Anna
U.S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 09 E-3
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Surry Power Station

Attachment

CORE OPERATING LIMITS REPORT

**Surry Unit 2 Cycle 31
Pattern MSK**

Revision 1

**Virginia Electric and Power Company
(Dominion Energy Virginia)
Surry Power Station Unit 2**

ATTACHMENT
CORE OPERATING LIMITS REPORT
SURRY UNIT 2 CYCLE 31, PATTERN MSK, REVISION 1

1.0 INTRODUCTION

This Core Operating Limits Report (COLR) for Surry Unit 2 Cycle 31 has been prepared in accordance with the requirements of Surry Technical Specification 6.2.C.

The Technical Specifications affected by this report are:

TS 2.1 – Safety Limit, Reactor Core
TS 2.3.A.2.d – Overtemperature ΔT
TS 2.3.A.2.e – Overpower ΔT
TS 3.1.E - Moderator Temperature Coefficient
TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limits
TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin
TS 3.12.B.1 and TS 3.12.B.2 - Power Distribution Limits (Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor)
TS 3.12.F – DNB Parameters
TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow

2.0 REFERENCES

1. VEP-FRD-42, Rev. 2.2-A, “Reload Nuclear Design Methodology,” October 2017.

Methodology for:

TS 2.1 – Safety Limit, Reactor Core
TS 3.1.E - Moderator Temperature Coefficient
TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3 and TS 3.12.C.3.b.1(b) - Control Bank Insertion Limit
TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G – Shutdown Margin
TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor and Nuclear Enthalpy Rise Hot Channel Factor
TS 3.12.F – DNB Parameters
TS Table 4.1-2A – Minimum Frequency for Equipment Tests: Item 22 – RCS Flow

2. WCAP-16009-P-A, “Realistic Large Break LOCA Evaluation Methodology Using the Automated Statistical Treatment of Uncertainty Method (ASTRUM),” (Westinghouse Proprietary), January 2005.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

3. EMF-2328(P)(A), "PWR Small Break LOCA Evaluation Model, S-RELAP5 Based," as supplemented by ANP-3676P, "Surry Fuel-Vendor Independent Small Break LOCA Analysis," as approved by NRC Safety Evaluation Report dated March 19, 2021.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

4. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Report," (Westinghouse Proprietary), April 1995.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

5. WCAP-12610-P-A and CENPD-404-P-A, Addendum 1-A, "Optimized ZIRLO," (Westinghouse Proprietary), July 2006.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Heat Flux Hot Channel Factor

6. VEP-NE-2-A, Rev. 0, "Statistical DNBR Evaluation Methodology," June 1987.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

7. DOM-NAF-2-P-A, Rev. 0.3, "Reactor Core Thermal-Hydraulics Using the VIPRE-D Computer Code," including Appendix B, "Qualification of the Westinghouse WRB-1 CHF Correlation in the Dominion VIPRE-D Computer Code," and Appendix D, "Qualification of the ABB-NV and WLOP CHF Correlations in the Dominion VIPRE-D Computer Code," September 2014.

Methodology for:

TS 3.12.B.1 and TS 3.12.B.2 - Nuclear Enthalpy Rise Hot Channel Factor

8. WCAP-8745-P-A, "Design Bases for Thermal Overpower Delta-T and Thermal Overttemperature Delta-T Trip Function," September 1986.

Methodology for:

TS 2.3.A.2.d – Overttemperature ΔT

TS 2.3.A.2.e – Overpower ΔT

3.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.2.C and repeated in Section 2.0.

3.1 Safety Limit, Reactor Core (TS 2.1)

The Reactor Core Safety Limits are presented in **Figure A-1**.

3.2 Overtemperature ΔT (TS 2.3.A.2.d)

$$\Delta T \leq \Delta T_0 [K_1 - K_2 \left(\frac{1+t_1 s}{1+t_2 s} \right) (T - T') + K_3 (P - P') - f(\Delta I)]$$

Where:

ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RATED POWER, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature (T_{avg}), °F.

T' is the nominal T_{avg} at RATED POWER, $\leq 573.0^\circ\text{F}$.

P is the measured pressurizer pressure, psig.

P' is the nominal RCS operating pressure ≥ 2235 psig.

$$K_1 \leq 1.1425$$

$$K_2 \geq 0.01059 / ^\circ\text{F}$$

$$K_3 \geq 0.000765 / \text{psig}$$

$$t_1 \geq 29.7 \text{ seconds}$$

$$t_2 \leq 4.4 \text{ seconds}$$

$$f(\Delta I) \geq 0.0268 \{-24 - (q_t - q_b)\}, \text{ when } (q_t - q_b) < -24.0\% \text{ RATED POWER}$$

$$0, \text{ when } -24.0\% \text{ RATED POWER} \leq (q_t - q_b) \leq +8.0\% \text{ RATED POWER}$$

$$0.0188 \{(q_t - q_b) - 8.0\}, \text{ when } (q_t - q_b) > +8.0\% \text{ RATED POWER}$$

Where q_t and q_b are percent RATED POWER in the upper and lower halves of the core, respectively, and $q_t + q_b$ is the total THERMAL POWER in percent RATED POWER.

3.3 Overpower ΔT (TS 2.3.A.2.e)

$$\Delta T \leq \Delta T_0 \left[K_4 - K_5 \left(\frac{t_3 s}{1 + t_3 s} \right) T - K_6 (T - T') - f(\Delta I) \right]$$

Where:

ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RATED POWER, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature (T_{avg}), °F.

T' is the nominal T_{avg} at RATED POWER, $\leq 573.0^\circ\text{F}$.

$$K_4 \leq 1.0965$$

$$K_5 \geq 0.0198 \text{ } ^\circ\text{F for increasing } T_{\text{avg}}$$

$$K_6 \geq 0.001074 \text{ } ^\circ\text{F for } T > T'$$

$$\geq 0 \text{ } ^\circ\text{F for decreasing } T_{\text{avg}}$$

$$\geq 0 \text{ for } T \leq T'$$

$$t_3 \geq 9.0 \text{ seconds}$$

$$f(\Delta I) = \text{as defined above for OT}\Delta T$$

3.4 Moderator Temperature Coefficient (TS 3.1.E)

The Moderator Temperature Coefficient (MTC) limits are:

+6.0 pcm/ $^\circ\text{F}$ at less than 50 percent of RATED POWER, and

+6.0 pcm/ $^\circ\text{F}$ at 50 percent of RATED POWER and linearly decreasing to 0 pcm/ $^\circ\text{F}$ at RATED POWER

3.5 Control Bank Insertion Limits (TS 3.12.A.1, TS 3.12.A.2, TS 3.12.A.3, and TS 3.12.C.3.b.1(b))

3.5.1 The control rod banks shall be limited in physical insertion as shown in **Figure A-2**.

3.5.2 The rod insertion limit for the A and B control banks is the fully withdrawn position as shown on **Figure A-2**.

3.5.3 The rod insertion limit for the A and B shutdown banks is the fully withdrawn position as shown on **Figure A-2**.

3.6 Shutdown Margin (TS 3.12.A.1.a, TS 3.12.A.2.a, TS 3.12.A.3.c and TS 3.12.G)

Shutdown margin (SDM) shall be $\geq 1.77 \text{ } \%\Delta k/k$.

3.7 Power Distribution Limits (TS 3.12.B.1 and TS 3.12.B.2)

3.7.1 Heat Flux Hot Channel Factor - FQ(z)

$$FQ(z) \leq \frac{CFQ}{P} K(z) \text{ for } P > 0.5$$

$$FQ(z) \leq \frac{CFQ}{0.5} K(z) \text{ for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFQ = 2.5$$

$$K(z) = 1.0 \text{ for all core heights, } z$$

3.7.2 Nuclear Enthalpy Rise Hot Channel Factor - FΔH(N)

$$F\Delta H(N) \leq CFDH * \{1 + PFDH(1 - P)\}$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED POWER}}$$

$$CFDH = 1.635$$

$$PFDH = 0.3$$

3.8 DNB Parameters (TS 3.12.F and TS Table 4.1-2A)

Departure from Nucleate Boiling (DNB) Parameters shall be maintained within their limits during POWER OPERATION:

- Reactor Coolant System T_{avg} ≤ **577.0 °F**
- Pressurizer Pressure ≥ **2205 psig**
- Reactor Coolant System Total Flow Rate ≥ 273,000 gpm (Tech Spec Limit)
and ≥ **274,000 gpm** (COLR Limit)

Figure A-1

**REACTOR CORE SAFETY LIMITS
THREE LOOP OPERATION, 100% FLOW**




Figure A-2
Surry 2 Cycle 31
Rod Group Insertion Limits
Max w/d position = 229 steps

The insertion limit for C-Bank is met for C-Bank positions greater than or equal to 225 steps.

