

SYSTEM DATA				
GPM	PSIG	°F	REMARKS	
1 4411	261	114		
2 200	7	106	1 PUMP	
3 1940	26	106	PRECOAT	
4 375	25	90	BACKWASH	
5 600	25	90	FILL	
6 25/50	100	90	TRANSFER	
6 25/50	50	90	DISCHARGE	

WI	19200	19222
DW	15500	15501
DW	5500	5641
WI	9200	9273
VALVE NUMBERING		
SYS. SUFFIX	FIRST NO.	LAST NO.

DESIGN DATA									
4	125	115	125	120					
3	125	95	125	100					
2	110	90	130	95	<1%	165	AM		
1	271	106	326	110	<1%	375	AM		
PSIG	CF	PSIG	CF	DURATION	HYDRO	BY	CHK'D	REMARKS	
NORMAL		UPSET							

