



Nuclear Division
18001 Sheldon Road
Middleburg Heights, OH 44130
T: 216.267.3200
www.curtisswright.com/NuclearDivision

Urgent Please Reply

Fax To:

Company: *NRC Operations Center*

Fax: *301-816-5151*

Number Pages: *2 (including cover)*

cc:

Date Sent: *6/24/2022*

From: *Chris Covan*

Company: *Curtiss-Wright*

Phone: *256-624-7301*



Nuclear Division
18001 Sheldon Road
Middleburg Heights, OH
44130
www.cwnuclear.com

File Number (H22-6438)

June 24, 2022

To whom it may concern:

In pursuance of compliance to Federal Regulation 10CFR21, this letter is issued to provide an interim notification of the potential defect in a configuration of the 1 1/2 Inch Quick Disconnect Connector (P/N: 913602-111) cable assemblies supplied to Duke under procurement documented 30129014. The potential deviation was discovered on April 24, 2022, where during the post installation testing, it was found that one of the cables wires were shorted to ground. After the initial discovery an inspection of the same configuration was performed on the cable assemblies in Duke's stock and found that 9 cable assemblies were found to have similar damage. This damage could cause the cable assembly to not perform its intended safety function. These items were returned to Curtiss-Wright on June 2, 2022 for further investigation and Curtiss-Wright has assumed the responsibility in reporting this potential issue.

Although we have completed some testing and verification activities, additional testing and more research into the background is in progress now and will provide necessary information to complete our evaluation. The current testing and research is projected to take 30 days and follow up letter with results and status will be provided by July 24, 2022.

This notification is being made to comply with the 60 day interim reporting requirements as defined in 10 CFR 21.21(a)(2).

For additional information, please contact Jim Tumlinson, Director of Operations (256-425-8037), Christopher Covan, Quality Assurance Manager (256-624-7301), or Tim Franchuk Director of Quality (513-201-2176).

Sincerely,

A large, stylized handwritten signature in black ink, appearing to be "Chris Covan". The signature is written over a large, faint, circular watermark or background graphic.

Chris Covan
Quality Assurance Manager
Curtiss-Wright Nuclear Division
18001 Sheldon Rd
Middleburg Height, OH 44130
ccovan@curtisswright.com