



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 22, 2022

LICENSEE: Florida Power and Light/NextEra

FACILITIES: Turkey Point Nuclear Generating Unit Nos. 3 and 4

SUBJECT: SUMMARY OF JULY 14, 2022, MEETING WITH FLORIDA POWER AND LIGHT/NEXTERA ON TURKEY POINT IMPROVED TECHNICAL SPECIFICATION CONVERSION LICENSE AMENDMENT REQUEST (EPID NO. L-2021-LLI-0002)

On July 14, 2022, a virtual observation public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Florida Power and Light/NextEra (FPL, the licensee). The purpose of the meeting was to discuss the license amendment request (LAR) for Turkey Point Nuclear Generating Unit Nos. 3 and 4 (Turkey Point) to convert to improved standard technical specifications in accordance with NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Revision 5 (improved standard technical specifications (ISTS)). The meeting notice and agenda, dated June 28, 2022, are available in the Agencywide Documents Access and Management System (ADAMS) Accession No. ML22179A285. A list of attendees is provided in the enclosure.

The following items were discussed during the meeting:

- Status of all open questions in Question and Answer (QA) Portal.
- Questions from the licensee on the following improved technical specification (ITS) sections:
 - Proposed Note in 3.8.1, Condition E – NRC asked a question in the QA Portal related to revision of the Note, and the licensee stated that revision of the Note would deviate from the standard and would change the intent of the subject Note.
 - The NRC staff asked a question in the QA Portal related to Section 3.1. The licensee stated that the current Surveillance Requirement 4.2.4.2 (in the current licensing basis) provides an option for the licensee to determine Quadrant Power Tilt Power Ratio when one excore detector is inoperable to use the incore thermocouple map, and the licensee seeks to continue to keep this current technical specification (CTS) in ITS.
- Questions/comments from the NRC staff:
 - The licensee's response from the QA Portal related to ITS Section 3.3.5. The NRC staff was seeking additional clarification to the licensee's proposed response. There was a discussion on Condition A, specifically the Note in Required Action A.1.
 - The NRC staff pointed out an apparent conflict with a justification of change and the proposed ITS in Section 3.1 where the licensee proposed to delete "at least," however the justification references "at least."

- The NRC staff is reviewing responses of QA Portal questions related to ITS Sections 3.7 and 3.8.

There were no members of the public in attendance.

Please direct any inquiries to me at 301-415-3867, or Michael.Mahoney@nrc.gov.

/RA/

Michael Mahoney, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES

JULY 14, 2022, PUBLIC MEETING WITH FLORIDA POWER AND LIGHT/NEXTERA

IMPROVED STANDARD TECHNICAL SPECIFICATION CONVERSION

Name	Organization
Michael Mahoney	U.S. Nuclear Regulatory Commission (NRC)
Caroline Tilton	NRC
Clinton Ashley	NRC
Craig Harbuck	NRC
Ravi Grover	NRC
Khadijah West	NRC
Edmund Kleeh	NRC
Robert Elliott	NRC
Matthew Hamm	NRC
Vic Cusumano	NRC
Gabe Lentchner	NRC
Josh Wilson	NRC
Andrea Russell	NRC
Jarrett Mack	Florida Power and Light Company (FPL)
Bruce Crabbs	FPL
Frederick Pollack	FPL
Bob Tomonto	FPL
Gregg Ellis	Excel Services Corporation (Excel)
Jerry Riste	Excel
Charles DeDeaux	Excel
Christina Long	Excel

SUBJECT: SUMMARY OF JULY 14, 2022, MEETING WITH FLORIDA POWER AND LIGHT/NEXTERA ON TURKEY POINT IMPROVED TECHNICAL SPECIFICATION CONVERSION LICENSE AMENDMENT REQUEST (EPID NO. L-2021-LLI-0002) DATED AUGUST 22, 2022

DISTRIBUTION:

PUBLIC
LPL2-2 R/F
RidsACRS_MailCTR Resource
RidsNrrDorlLpl2-2 Resource
RidsNrrDssStsb Resource
RidsNrrPMTurkeyPoint Resource

RidsNrrLARButler Resource
RidsRgn2MailCenter Resource
RidsNrrDorl Resource
RidsACRS_MailCTR Resource
CTilton, NRR

ADAMS Accession Nos.:

Package: ML22228A198

Meeting Notice: ML22179A285

Meeting Summary: ML22228A203

OFFICE	NRR/DORL/LPL2-2/PM	NRR/DORL/LPL2-2/LA	NRR/DORL/LPL2-2/BC
NAME	MMahoney	RButler	DWrona
DATE	08/22/2022	08/18/2022	08/22/2022

OFFICIAL RECORD COPY