

ATTACHMENT 1

MARKED-UP TS PAGES FOR TS 3.6.8

Containment Spray and Cooling Systems
3.6.8

3.6 CONTAINMENT SYSTEMS

3.6.8 Containment Sumps

LCO 3.6.8 Two containment sumps shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more containment sumps inoperable due to containment accident generated and transported debris exceeding the analyzed limits.	A.1 Initiate actions to reduce containment accident generated and transported debris.	Immediately
	<u>AND</u> A.2 Perform SR 3.4.13.1	Once per 24 hours
	<u>AND</u> A.3 Restore the containment sump(s) to OPERABLE status.	

(continued)

Containment Spray and Cooling Systems
 3.6.8

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. One or more containment sumps inoperable for reasons other than Condition A.</p>	<p>B.1</p> <p>-----NOTES-----</p> <p>1. Enter applicable Conditions and Required Actions of LCO 3.5.2, "ECCS – Operating," and LCO 3.5.3, "ECCS – Shutdown," for emergency core cooling trains made inoperable by the containment sump(s).</p> <p>2. Enter applicable Conditions and Required Actions of LCO 3.6.6 "Containment Spray and Cooling Systems," for containment spray trains made inoperable by the containment sump(s).</p> <p>-----</p> <p>Restore the containment sump(s) to OPERABLE status.</p>	<p>72 hours</p>
<p>C. Required Action and associated Completion Time not met.</p>	<p>C.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>C.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

Containment Spray and Cooling Systems
3.6.8

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.8.1	Verify, by visual inspection, the containment sumps do not show structural damage, abnormal corrosion, or debris blockage.	In accordance with the Surveillance Frequency Control Program