

**From:** [Gryglak, Magdalena](#)  
**To:** "[debbi@cammenga.com](mailto:debbi@cammenga.com)"; "[cj@cammenga.com](mailto:cj@cammenga.com)"  
**Subject:** Request to modify facility-NRC license no. 21-26460-01  
**Date:** Thursday, September 1, 2022 8:34:00 AM

---

Good morning,

I have reviewed your request dated July 21, 2022 to add additional square footage to your clean room.

In a signed and dated letter, please clarify the following:

1. The current clean room will still function as a clean room with the same layout with no changes inside (the room as illustrated with blue borders around will be intact with no walls removed/added, etc.).
2. The proposed clean room to be added (the area illustrated with the purple border) will be in addition to the current clean room or is it replacing the current clean room?
3. If both clean rooms will be utilized, are the rooms going to be divided by a wall and the areas inside the rooms will be exactly the same as shown on the diagram?
4. The diagram illustrates multiple tables/work stations in close proximity/adjoining each other in the proposed clean room with one vent for two work stations or two vents for three work stations. Please describe measures to reduce radiation hazard associated with having work stations in this configuration/close proximity and the number of vents per work station.
5. Please describe measures to secure the radioactive material in the proposed clean room when the material is in storage.

Please acknowledge receipt of this email.

Please respond by September 19, 2022.

Thank you

**Magdalena R. Gryglak**  
**Health Physicist**  
**U.S. NRC Region III**  
**630-829-9875**