

October 4, 2022

TP-LIC-LET-0042  
Project Number 99902100

U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001  
ATTN: Document Control Desk

**Subject:** Submittal of TerraPower, LLC Topical Report, *Regulatory Management of Natrium Nuclear Island and Energy Island Design Interfaces*

This letter transmits the TerraPower, LLC (TerraPower) Topical Report, NATD-LIC-RPRT-0001 Revision 0, *Regulatory Management of Natrium Nuclear Island and Energy Island Design Interfaces*, to the U.S. Nuclear Regulatory Commission (NRC) for review and approval. The report describes an evaluation of the NRC regulations pertaining to the design interface of the Nuclear Island and Energy Island systems for the Natrium™ design, a TerraPower and GE-Hitachi technology.

TerraPower requests the NRC's review and approval of the regulatory assessment presented in the report by October 4, 2023.

This letter and the enclosure make no new or revised regulatory commitments.

If you have any questions regarding this submittal, please contact Ryan Sprengel at [rsprengel@terrapower.com](mailto:rsprengel@terrapower.com) or (425) 324-2888.

Sincerely,

A handwritten signature in black ink that reads "Ryan Sprengel".

Ryan Sprengel  
Senior Manager Licensing



Date: October 4, 2022  
Page 2 of 2

TerraPower, LLC

Enclosure: TerraPower, LLC Topical Report, NATD-LIC-RPRT-0001, *Regulatory Management of Sodium Nuclear Island and Energy Island Design Interfaces*

cc: Mallecia Sutton, NRC

**ENCLOSURE**

**TerraPower, LLC**

**Topical Report, NATD-LIC-RPRT-0001**

***Regulatory Management of Sodium Nuclear Island and Energy Island Design Interfaces***



Controlled Document - Verify Current Revision

<b>TOPICAL REPORT</b>			
<b>Document Number:</b>	NATD-LIC-RPRT-0001	<b>Revision:</b>	0
<b>Document Title:</b>	Regulatory Management of Natrium Nuclear Island and Energy Island Design Interfaces		
<b>Functional Area:</b>	Licensing	<b>Engineering Discipline:</b>	Safety & Licensing
<b>Effective Date:</b>	10/3/2022	<b>Released Date:</b>	10/3/2022
			<b>Page:</b> 1 of 30
<b>Approval</b>			
Title	Name	Signature	Date
Originator, Licensing Engineer	Matthew Presson	Electronically Signed in Agile	10/2/2022
Reviewer, Principal Licensing Engineer	Nick Kellenberger	Electronically Signed in Agile	10/3/2022
Approver, Licensing Senior Manager	Ryan Sprengel	Electronically Signed in Agile	10/3/2022
<b>Export Controlled Content:</b>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
<b>QA Related:</b>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> (Note: If QA in Yes, a QA representative needs to be on review)		
<b>QA Criterion:</b>	N/A		

*Controlled Document - Verify Current Revision*

**REVISION HISTORY**

Revision No.	Effective Date	Affected Section(s)	Description of Change(s)
0	10/3/2022	All	Initial issuance.

**TABLE OF CONTENTS**

EXECUTIVE SUMMARY .....4

1 INTRODUCTION.....7

2 NATRIUM REACTOR DESCRIPTION .....7

3 BASIC PLANT DESIGN AND INTERFACES.....8

4 NATRIUM SAFETY FEATURES .....10

    4.1 Reactivity Control .....10

    4.2 Cooling - Residual Heat Removal.....11

    4.3 Contain - Low Reactor Pressure.....11

5 NATRIUM PLANT DESIGN.....12

    5.1 NI Systems.....13

    5.2 EI Systems .....17

6 PROCESS FOR SSC CLASSIFICATION.....19

7 BASIC PLANT TRANSIENT ANALYSES .....21

    7.1 Plant Transient Response .....21

8 REGULATORY ANALYSES.....22

    8.1 Regulatory analyses associated with 10 CFR 50.10, “License required; limited work authorization.” .....22

    8.2 Regulatory analyses associated with 10 CFR 55, “Operators’ Licenses”. .....24

    8.3 Regulatory analyses associated with 10 CFR 50.65, “Requirements for monitoring the effectiveness of maintenance at nuclear power plants”. .....26

    8.4 Regulatory analyses associated with 10 CFR 50 Appendix B, “Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plant”. .....28

9 CONCLUSION .....28

10 REFERENCES.....30

**LIST OF FIGURES**

Figure 1: Natrium Safety Features .....10

Figure 2: Natrium Nuclear Island.....12

Figure 3: Reactor Air Cooling and Intermediate Air Cooling .....15

Figure 4: Energy Island Photo.....17

Figure 5: Energy Island Diagram.....18

Figure 6: SSC Classification Process (Figure 4-1, SSC Function Safety Classification Process from NEI 18-04) .....20

*Controlled Document - Verify Current Revision***EXECUTIVE SUMMARY**

This Topical Report describes an evaluation of the Nuclear Regulatory Commission (NRC) regulations pertaining to the design interface of the Nuclear Island (NI) and Energy Island (EI) systems for the Natrium™ reactor design, a TerraPower, LLC (TerraPower) and GE-Hitachi technology. TerraPower is requesting NRC review and approval of this regulatory assessment for use by Natrium reactor applicants.

Controlled Document - Verify Current Revision

**Acronyms**

<b>Acronym</b>	<b>Definition</b>
ARDP	Advanced Reactor Demonstration Program
CFR	Code of Federal Regulations
CRD	Control Rod Drive Mechanism System
CSS	Core Support Structure
DID	Defense in Depth
DOE	Department of Energy
EBR	Experimental Breeder Reactor
EI	Energy Island
EOP	Emergency Operating Procedure
ESS	Energy Island Salt Transport System
FFTF	Fast Flux Test Facility
FSAR	Final Safety Analysis Report
GEH	GE-Hitachi Nuclear Energy Americas, LLC
GV	Guard Vessel
LMP	Licensing Modernization Project
IAC	Intermediate Air Cooling
IHT	Intermediate Heat Transfer System
IHX	Intermediate Heat Exchanger
IPE	Individual Plant Examination
ISP	Intermediate Sodium Pump
IVS	In-Vessel Storage
LBE	Licensing Basis Event
LWA	Limited Work Authorization
NEI	Nuclear Energy Institute
NI	Nuclear Island
NRC	Nuclear Regulatory Commission
NST	No Special Treatment
NSRST	Non-Safety-Related with Special Treatment
PHT	Primary Heat Transport System
PSP	Primary Sodium Pump
RAC	Reactor Air Cooling
RCC	Reactor Core Components
RES	Reactor Enclosure System
RG	Regulatory Guide
RI	Reactor Internals
RIS	Reactor Instrumentation System
RIPB	Risk-Informed and Performance-Based
RPS	Reactor Protection System
RXB	Reactor Building
RSA	Reactor Support Assembly
RV	Reactor Vessel
RVH	Reactor Vessel Head
SFR	Sodium Fast Reactor



*Controlled Document - Verify Current Revision*

SGS	Steam Generation System
SHX	Sodium-Salt Heat Exchanger
SR	Safety-Related
SSC	Structure, System, and Component
TSS	Thermal Salt Storage System

## 1 INTRODUCTION

In October 2020, the Department of Energy (DOE) selected the Sodium Sodium Fast Reactor (SFR) design for the Advanced Reactor Demonstration Program (ARDP).

TerraPower is utilizing the methodology described in Nuclear Energy Institute (NEI) 18-04 Revision 1, "Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development," as endorsed by Regulatory Guide (RG) 1.233, "Guidance for a Technology-Inclusive, Risk-Informed, and Performance Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors," for the selection of licensing basis events (LBEs); classification and special treatments of structures, systems, and components (SSCs); and assessment of defense-in-depth (DID).

The independence of operation between the systems contained within the NI and the plant systems composing the EI is a key aspect of the Sodium design philosophy. The NI boundary conditions have been intentionally designed so the interrelationship with the EI does not impact the NI safety case. Thermal energy storage and steam generation operations are independent from reactor power operations due to the Thermal Salt Storage System (TSS). This separation of plant areas allows the power production systems on the EI to be separate entities with respect to site design and quality standards while being integrated through the TSS. The isolation point for the thermal salt storage system (EI to NI isolation) is at the inlet valve (input from the cold salt storage tank) and outlet valve (output to the hot salt storage tank) of the sodium to salt heat exchangers.

TerraPower evaluated the regulatory impacts of the Sodium design interfaces with respect to the interaction of NI and EI systems and identified four regulations of interest. These regulations are described below in the Regulatory Analyses section of the report.

TerraPower requests NRC review and approval of this TR, which contains an evaluation of these four regulatory requirements as it pertains to the interfaces between the NI and EI systems and the design of the Sodium reactor. This Topical Report will serve as a means, via reference, for Sodium reactor licensees to utilize the regulatory evaluation.

## 2 NATRIUM REACTOR DESCRIPTION

The Sodium reactor is a metal fueled, pool-type Sodium Fast Reactor (SFR) that takes advantage of the simple and robust safety profile of SFRs to reduce the complexities associated with nuclear design and construction. Safety functions are made integral to the reactor vessel, and support equipment is moved to separate structures, resulting in a simplified reactor building. The superior heat transfer characteristics of sodium and low-pressure plant operations permit the use of compact and lightweight equipment, unlike in other reactor types cooled with pressurized water or gas.

The higher operating temperatures and constant thermal output provide an ideal match for thermal energy storage using molten salt, a mature and proven technology that is commercially deployed in the concentrated solar power industry. Hot sodium from the reactor transfers its heat to an intermediate sodium loop and eventually to a molten salt loop, which carries heat off the NI to the EI where it can be stored, converted into electricity,

*Controlled Document - Verify Current Revision*

or used for industrial process heating. This design architecture minimizes the size of the NI and allows the reactor to operate at constant conditions while the EI meets variable energy demands. The rating for the Natrium reactor is 840 MW thermal. The EI has the capability to produce up to 500 MW net electric.

### 3 BASIC PLANT DESIGN AND INTERFACES

The Natrium reactor was developed using insights from decades of research, design, and development leveraging the legacy of 40 reactor-years from the Experimental Breeder Reactor (EBR) -II and Fast Flux Test Facility (FFTF) operations. Insights were also gained from more recent designs such as GEH's PRISM technology and TerraPower's Traveling Wave Reactor technology. Previous SFR operating experience has demonstrated that the SFR technology can passively accommodate severe transients which challenge traditional Light Water Reactor technology. These inherent safety characteristics are leveraged in the Natrium design to reduce the envelope of safety-related (SR) SSCs.

The EI was designed specifically for energy storage to allow the Natrium plant to vary its supply of energy provided based on overall grid conditions. This feature allows the Natrium plant to provide a utility-scale carbon free solution that can make a meaningful impact on efforts to mitigate climate change and complement the increased use of intermittent renewable energy technology (e.g., solar, wind).

The reactor operates at near atmospheric pressure, circulating sodium through its core by pumps. Heat is transferred from the hot primary sodium pool to the intermediate sodium piping loop by means of two intermediate heat exchangers, which are located inside the reactor vessel. The Intermediate Heat Transfer System (IHT) uses two IHT pumps to move sodium through the two intermediate heat exchangers, via piping penetrations running through the reactor vessel head, to two sodium/salt heat exchangers per loop. The sodium/salt heat exchangers and IHT pumps are located in the reactor auxiliary building. Cold salt is pumped from the thermal salt storage cold tank through the four sodium/salt heat exchangers (two per loop) and is returned as hot salt back to the thermal salt storage hot tank. The thermal salt storage hot tank serves as thermal energy storage and is located within the EI systems.

The salt stored in the thermal salt storage hot tank is then used to generate steam for use in commercially available steam turbine generators or industrial process heating. This is accomplished by pumping the hot salt from the thermal salt storage hot tank through the steam generators and returning the salt to the thermal salt storage cold tank. The steam generator equipment converts water into steam by passing the hot molten salt through an economizer (water preheater), evaporator, superheater, and reheater and provides that steam to the Turbine/Generator. This technology is essentially the same as molten salt systems used in the concentrated solar power industry.

The operational flexibility to move the output of the NI separately to the energy storage and electric generation portions of the EI enables the steam turbine and reactor to operate at different power levels. The duty cycle of the reactor is low because it is isolated from grid demand changes. This enables the NI to operate at 100 percent, 24/7 at a capacity factor greater than 90 percent. Meanwhile, this operational flexibility allows the EI to adjust power

*Controlled Document - Verify Current Revision*

output to meet real-time grid demands and accommodate for the variability of renewable technologies.


As described below in the SSC classification and plant transient analyses sections, the NI is considered separate from the EI from a safety case perspective. Parameters such as salt pressure, temperature, and flow, are bounded in the safety analysis and are designed to be insignificant contributors to overall nuclear safety risk.

## 4 NATRIUM SAFETY FEATURES

Figure 1: Natrium Safety Features

# Natrium Safety Features

- Pool-type Metal Fuel SFR with Molten Salt Energy Island
  - Metallic fuel and sodium have high compatibility
  - No sodium-water reaction in steam generator
  - Large thermal inertia enables simplified response to abnormal events
- Simplified Response to Abnormal Events
  - Reliable reactor shutdown
  - Transition to coolant natural circulation
  - Indefinite passive emergency decay heat removal
  - Low pressure functional containment
  - No reliance on Energy Island for safety functions
- No Safety-Related Operator Actions or AC power
- Technology Based on U.S. SFR Experience
  - EBR-I, EBR-II, FFTF, TREAT
  - SFR inherent safety characteristics demonstrated through testing in EBR-II and FFTF



- Control**
  - Motor-driven control rod runback
  - Gravity-driven control rod scram
  - Inherently stable with increased power or temperature
- Cool**
  - In-vessel primary sodium heat transport (limited penetrations)
  - Intermediate air cooling natural draft flow
  - Reactor air cooling natural draft flow – always on
- Contain**
  - Low primary and secondary pressure
  - Sodium affinity for radionuclides
  - Multiple radionuclides retention boundaries

### 4.1 Reactivity Control

The Natrium reactor has been designed to accomplish the control of reactivity function with multiple layers of protection (i.e., DID); the first is active, the second is passive, and the third is inherent.

The reactor control system acts as a buffer to prevent the need for a scram. It detects abnormal operation and initiates a runback via motor driven insertion of neutron absorbing control rods to achieve a softer shutdown than a scram.

The reactor protection system (RPS) exists to initiate a scram should the reactor control system fail, or a properly initiated runback fails to prevent the reactor from reaching a scram setpoint. The scram function results in passive gravity insertion of control rods into the reactor core. All sensors monitoring Natrium reactor trip parameters, except for the seismic sensors, are located on the NI.

The core is designed such that the reactor can accommodate anticipated transients without scram for events such as loss of primary flow, loss of heat sink, and uncontrolled rod withdrawal. The natural feedbacks are self-regulating (inherent in the fuel design) and find a low power level at which heat production and heat removal are in balance.

## 4.2 Cooling - Residual Heat Removal

The Sodium reactor has been designed to accomplish the residual heat removal function with multiple layers of protection (i.e., DID); the first is active, the second is passive, and the third is inherent. The Sodium reactor utilizes two diverse residual heat removal methods in the Reactor Air Cooling (RAC) and Intermediate Air Cooling (IAC) systems. This design has been selected due to the passive, reliable, and sustainably safe nature of RAC with DID provided by IAC. RAC and IAC provide for passive, reliable, and safe air cooling of the reactor vessel.

Forced flow heat removal via IAC serves as the normal shutdown cooling system for outages. There are two trains, one for each IHT system loop. IAC leverages the existing intermediate heat exchanger heat transfer area rather than adding a shutdown cooling-only heat exchanger inside the reactor vessel. For the final heat sink, it rejects heat to a sodium-air heat exchanger leveraging the IHT system piping.

Natural circulation flow through both trains of IAC, actuated by passive damper opening, serves the heat removal function if power is not available to run the blowers feeding the sodium-air heat exchangers. The passive nature of this mode assures high reliability of the function.

RAC can remove all decay heat using natural circulation of air around the exterior of the guard vessel. Heat removal from the reactor vessel is dominated by radiative heat transfer with a small contribution by convection through argon in the gap between the reactor and guard vessels. The guard vessel, in turn, is cooled by the natural convection of air and by radiative heat transfer to the outside air duct wall, referred to as the collector cylinder. Hot air then rises, which establishes a natural circulation path using the atmosphere as a heat sink. In contrast with the IAC, RAC does not have any dampers to turn the system on or off. RAC is always operating and there are no actions required for the system to perform its function.

## 4.3 Contain - Low Reactor Pressure


The high boiling point of sodium allows reactor operation at near atmospheric pressure resulting in thinner reactor structures. The Sodium design is a low-pressure pool type reactor with no piping or fittings below the surface of the pool. A close-fitting guard vessel prevents a loss of coolant should a leak develop in the reactor vessel. The reactor cover gas system also operates at essentially atmospheric pressure. The intermediate coolant is, by static head alone, at a slightly higher pressure than the primary coolant.

Due to the absence of pressure driving forces in accidents and by utilizing a combination of different systems and components of the Sodium design a functional containment approach is utilized to meet the onsite and offsite radionuclide release limits for the event categories.

Controlled Document - Verify Current Revision

## 5 NATRIUM PLANT DESIGN

Figure 2: Natrium Nuclear Island



## 5.1 NI Systems

### Reactor Core Components System (RCC)

The Sodium reactor is a sodium fast reactor that provides 840 MW thermal of heat generation. The coolant flows upward through the core which is composed of fuel, control, reflector, and shield assemblies. The fuel assembly produces heat and provides the neutron flux environment. Sodium fuel features a U-10Zr fuel column with a sodium bond to HT9 cladding. The RCC contains control assemblies that function to position neutron absorber material to control and terminate the nuclear reaction. These are positioned by the control rod drive mechanism system discussed further below. The reflector assemblies surround the active fuel assemblies radially, improving neutron efficiency and limiting radiation damage to permanent reactor structures. A single row of shield assemblies makes up the outermost row of the reactor core, directly adjacent to the reflector assemblies. These function to absorb neutron leakage outside the reflector assemblies, limiting activation of the intermediate sodium system while also contributing to prevent radiation damage to permanent reactor structures.

### Reactor Enclosure System (RES)

The RES contains and supports the reactor core, the primary sodium coolant, and all supporting equipment and structures. The RES is divided into five subsystems: Reactor Vessel (RV), Reactor Internals (RI), Reactor Vessel Head (RVH), Guard Vessel (GV), and Reactor Support Assemblies (RSA). All subsystems are located in, and are either directly or indirectly supported by, the Reactor Building (RXB). The RV, along with the RVH, form the majority of the primary coolant and primary cover gas boundaries. Additionally, the RVH locates and supports additional systems and equipment that interfaces with the core and primary coolant. Finally, the RVH and RV provides support for the RI as well as the Core Support Structure (CSS).

The CSS is welded to and considered part of the RV. The RI is a collection of internal structures which perform various passive functions in reactor operation. The major components of the Reactor Internals include the Vessel Liner, Primary Sodium Pump (PSP) and Intermediate Heat Exchanger (IHX) supporting structures, primary coolant supply piping, and the Upper Internal Structure (UIS), which houses instrumentation conduits and locates the Control Rod Drivelines. The RVH supports and seals the RV. The RVH provides structural support and interfaces for a number of systems, including the IHX and PSP components of the Primary Heat Transport System (PHT), and elements of the Fuel Handling System (In-Vessel and Ex-Vessel), Reactor Instrumentation System (RIS), and Control Rod Drive Mechanism System. The RVH also houses and supports a number of other subsystems and components, such as the Rotating Plug, Head Thermal Shields, Fuel Transfer Ports and Access Ports, and Reactor Head Temperature Control. Of particular interest, the RVH supports and locates the rotating plug for refueling operation. This plug is essential for the initial fueling of the reactor and for all subsequent fuel transfer operations during refueling and decommissioning. The plug is configured such that the In-Vessel Transfer Machine can access all core components, the In-Vessel Storage (IVS) locations, and the fuel elevator. The plug rotates via a bearing and drive assembly and is equipped with sealing mechanisms to isolate the primary fluid and cover gas from atmosphere during normal, accident, and refueling operations. The GV is supported either by the RXB or the RVH, or a combination of both. The GV surrounds the RV and is



*Controlled Document - Verify Current Revision*

designed to contain any sodium leak in the unlikely event of a breach in the RV, ensuring sufficient coolant inventory is maintained in the RV for residual heat removal through level equalization and preventing a sodium reaction with the surrounding reactor building concrete. The GV is surrounded by a guided pathway for the RAC system, which is always in operation and functions to remove decay heat in the case of an emergency.

#### Primary Heat Transport System (PHT)


The PHT is entirely contained within the RV and consists of the reactor core, the Intermediate Heat Exchangers (IHX), the PSPs, the hot pool, and the cold pool. The PHT sodium flows up through the core where the fuel assemblies heat the sodium. The hot sodium enters the hot pool and flows downward through the shell side of the two IHXs. The sodium, cooled by the IHT sodium coolant, exits the bottom of the IHXs and enters the cold pool. Cold pool sodium flows downward to the PSP inlet plenums which are located very near the bottom of the vessel to maximize coolant inertia. PSP pumps drive the cold pool sodium downward from the inlet and discharge it into a series of core supply pipes, which return the sodium to the core inlet. The sodium then enters the core through the core support and distribution structure completing this flow circuit.

#### Intermediate Heat Transport System (IHT)

The IHT transfers heat from the PHT to the Thermal Salt Storage System (TSS). The IHT performs this function during normal power operation and transient conditions. There are two IHT piping loops for each reactor module. Each intermediate loop is thermally coupled to the reactor PHT by an IHX. IHT non-radioactive sodium is circulated via the Intermediate Sodium Pumps (ISPs) which transport heat from the IHXs to the Sodium-Salt Heat Exchangers (SHXs). The IHT pumps are located in the cold leg to reduce their operating temperature. The main components of the IHT loops are the ISPs, SHXs, intermediate sodium hot and cold leg piping, expansion tanks, and the sodium drain tank. The salt system pumps cold salt from the cold salt tank to NI above ground level as a single supply line. The salt stream splits into four parallel pipes within the NI to provide individual streams to each of the four SHXs. Cold salt enters each SHX unit where it is heated via the IHT sodium flow. Once heated in the SHX, the hot salt stream exits the SHX, joins into a single stream with the other SHX salt outlet streams, and flows out to the EI hot salt storage tank. Salt flow is controlled by the variable speed cold salt pumps and a temperature control system. A set of drain isolation valves on each stream ensures isolation of the salt systems and rapid drain of the SHXs during selected transient events.

#### Reactor Air Cooling System (RAC)

The RAC is the residual heat removal cooling system for the reactor and protects the fission product boundaries from the most severe spectrum of plant events. RAC supplies natural draft outside ambient air for reactor cooling. RAC relies on the natural circulation performance of the primary sodium and the conductive/convective heat transfer to the reactor vessel wall. Thermal radiative heat transfer then dominates heat transfer to the guard vessel. From there, natural draft air inlets provide ambient outside air to cool the guard vessel wall via a combination of radiative and convective heat transfer. RAC is an open passive design that is always in operation and does not require equipment alignment, power, operator action, or support systems to perform at peak performance.

**Figure 3: Reactor Air Cooling and Intermediate Air Cooling**

### Intermediate Air Cooling (IAC)

IAC serves as the normal shutdown cooling system for outages. It has two cooling modes: forced flow and passive flow. Each IHT loop is composed of two trains. For the final heat sink, it transfers heat to the atmosphere from the Sodium-Air Heat Exchangers (AHXs). Simple operation of a fail-open electromagnetic damper on the air side of the AHX initiates passive cooling. Active operations support normal controlled cooling operations (such as during a refueling outage) and in response to anticipated transient events. Forced flow is provided by air blowers on the air side of the AHXs and the ISPs on the sodium side. The IAC's natural draft arrangement, similar to RAC, permits passive operation of the system as a diverse alternative to the RAC cooling capabilities if power to support forced cooling is not available. These functions supplement the RAC system.

### Control Rod Drive Mechanism System (CRD)

The CRD controls reactor power by positioning the neutron absorber bundle within the core. This system also allows for rapid control rod insertion in response to manual or automatic signals (scram). When a scram is initiated, the CRD shuts down the reactor. Control rods are normally positioned by an electric motor. However, when a scram signal is received, the latch releases the absorber bundle from the driveline. The absorber bundle

then falls by gravity into the core which shuts down the reactor. As the alternate and preferred emergency shutdown method, each drive mechanism has a drive-in motor to rapidly drive the control rod into the core shutting down the reactor. In the unlikely event that the control rod does not fully insert, the drive-in motor pushes the control rod into the core.


#### Reactor Protection System (RPS)

The RPS is designed to ensure the safety of the reactor during plant operations. RPS monitors the plant conditions and initiates a sequence of appropriate functions as necessary to protect the public, plant workers, plant equipment, and the environment when an abnormal operating condition is detected. The RPS has multiple function-identical redundant divisions included in the configuration. Each division is located in a dedicated room physically separated from other divisions such that potential hazards within the design basis such as fire or flood would not damage multiple divisions simultaneously.


*Controlled Document - Verify Current Revision*

## 5.2 EI Systems

**Figure 4: Energy Island Photo**



Controlled Document - Verify Current Revision

**Figure 5: Energy Island Diagram**

### Thermal Energy Storage System (TSS)

Cold salt is transported from the cold salt tank, via the cold salt tank pump, to the NI intermediate sodium/salt heat exchanger, where it is heated, and returns to the hot salt tank. The sodium to salt heat exchangers are designed such that the thermal salt side pressure (shell side) is higher than the intermediate sodium pressure (tube side), to ensure that if a leak were to occur in the intermediate sodium system inside the sodium to salt heat exchanger the thermal salt system would flow into the IHT system. The system is composed of salt pumps and salt storage tanks, interfacing with salt heat transport loops to send and receive salt. The salt tanks are used for energy storage and the reactor is the charging system. Its architecture is essentially the same as the molten salt systems designed for concentrated solar power except the heat source is the Natrium reactor.

Salt from the hot salt tank is transported through the Steam Generation System (SGS) and returns to the cold tank. The energy storage capacity for the tank pair is equivalent to approximately 4 hours at 500-MWe net load. Energy storage maximizes the NI capacity factor while the EI can ramp power up and down based on grid conditions. An attenuation pump delivers cold salt to the SGS to control the hot salt temperature at the steam generator inlet during start-up.

### Steam Generation System (SGS)

The SGS generates high-pressure, superheated steam for conversion to electrical power by the Turbine/Generator. The SGS converts water into steam by passing the hot molten salt

*Controlled Document - Verify Current Revision*

through an economizer (water preheater), evaporator, superheater, and reheater and provides that steam to the Turbine/Generator. Use of hot molten salt in the steam generator re-heaters improves overall plant thermodynamic efficiency. The relatively colder salt returning from the SGS is stored in the cold salt tank prior to flowing back to the NI for re-heat, thus completing the heat transport circuit.

#### Condensate and Feedwater System

For power generation, the steam supplied to the turbine condenses and collects in a condenser. The condensate system pumps this sub-cooled water through several low-pressure feedwater heaters. Heat for these heaters is supplied by extraction steam from the turbine. After passing through the feedwater heaters, the water collects in the deaerator. The deaerator acts as the water supply for the feedwater system. The feedwater pumps supply high pressure water to the SGS system.

#### Steam Turbine and Generator Systems

The steam turbine generator is a commercially available modular platform General Electric STF-D453 or similar steam turbine. The system includes the main steam, reheat steam, and turbine bypass steam sub-systems. The main steam supplies the High-Pressure turbine and the reheat steam supplies the Intermediate- Pressure and Low-Pressure turbines. The bypass steam allows the steam to bypass the turbine in the event of a turbine trip which maintains the primary heat sink for the salt tanks. Operating in thermal equilibrium with the reactor, the main turbine generator can produce a net output of 336 MWe consistently. Using the additional stored energy capacity in the hot salt tank the main turbine generator can increase its electrical output to 500 MWe net without the NI adjusting its thermal output.

#### Heat Rejection Systems

The condenser/heat rejection system utilizes circulating water to condense and sub-cool the steam exiting the main turbine generator steam turbine. Circulating water pumps take water from the mechanical draft cooling tower basin passes it through the condenser and returns it to the cooling tower. The heat is removed from the tower by the water passing through a forced draft air flow.

## 6 PROCESS FOR SSC CLASSIFICATION

TerraPower developed a set of instructions for classifying SSCs of nuclear reactor facilities in accordance with their function, design & licensing basis, and safety significance. These classifications determine the codes and quality standards to which the SSCs shall be designed, fabricated, erected, maintained, and tested. The procedure is designed to be used under a licensing process that follows RG 1.233 "Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals For Non-Light-Water Reactors" which endorses, while providing clarification and points of emphasis, the methodology described in NEI 18-04, "Risk-Informed Performance-Based Guidance for Non-Light Water Reactor Licensing Basis Development". This process was used for the

selection of LBEs; safety classification of SSCs and associated risk-informed special treatments; and determination of DID adequacy for the Natrium reactor.

The SSC classification process flowchart shown below, as Figure 6, was used for the classifications of the SSCs in the Natrium reactor.

**Figure 6: SSC Classification Process (Figure 4-1, SSC Function Safety Classification Process from NEI 18-04)**




Figure 4-1. SSC Function Safety Classification Process

Using the above process, there are no SSCs on the EI necessary to meet the fundamental safety functions of the NI for controlling reactivity, cooling the core, or containing the release of radioactivity. There are no SSCs on the EI that provide a function classified as risk-significant. Additionally, no SSCs on the EI are used to provide a required DID function for

*Controlled Document - Verify Current Revision*

mitigation. Based on this, all SSCs located on the EI are classified as non-safety-related with no special treatment (NST). This analysis shows that none of the SSCs on the EI are utilized for any accident mitigation, safety system support, or DID, showing a separation from the NI for accident mitigation and the safety bases for the plant.

## 7 BASIC PLANT TRANSIENT ANALYSES

The Natrium reactor ensures that no EI SSCs are required to respond to mitigate any events impacting the NI, support SR SSCs, or ensure DID adequacy. This establishes a separation between the NI and EI from a safety perspective. The isolation point for the thermal salt storage system (EI to NI isolation) is at the inlet valve (input from the cold salt storage tank) and outlet valve (output to the hot salt storage tank) of the sodium to salt heat exchangers. The valves are located as close as possible to the exterior reactor auxiliary building wall (located on the NI) in the thermal salt system piping.

To fully appreciate the separation and interfaces between the NI and EI, it is important to understand the Natrium reactor response to the failure of any EI SSCs. From the NI perspective, all failures associated with the EI are grouped into loss of salt flow, high salt temperature, increased salt flow, low salt temperature and low salt pressure initiating events. The transient analyses from the EI groups these five events into two categories that are modeled either as a decrease in heat removal (loss of salt flow, high salt temp, low salt pressure) or an increase in heat removal (increase in salt flow, low salt temp).

For each of these event categories, the initial effects are seen in the IHT system and do not directly impact the conditions in the PHT system. A decrease in heat removal results in an increase in temperature in the IHT system while an increase in heat removal results in a decrease in IHT sodium temperature. The thermal inertia of the IHT and PHT systems are such that any changes in salt conditions can be adequately responded to using only signals monitored within the NI. Heat removal is ensured by the RAC and IAC systems of the NI.

Parameters in the salt system are continuously monitored such as salt flow, salt pressure, and salt tank levels. The architecture of the plant allows the use of different signals, including IHT temperature signals, to actuate an anticipatory power runback to provide asset protection, reduce thermal stresses on the NI systems, and improve plant availability without compromising plant safety.

### 7.1 Plant Transient Response

#### A. Reactor scram:

- RPS receives an input that exceeds a scram setpoint and initiates a scram signal.
- IAC Forced Circulation initiates coincident with the scram signal.
- Once reactor power has lowered to below the low neutron setpoint, ramp down of PSPs and ISPs commences.
- Once the ramp down sequence is complete, the ISPs and PSPs are controlled to establish PHT and IHT flow.
- After initiation of the scram signal and once reactor power has lowered to the low neutron setpoint, the cold salt flow ramps down, followed by isolation of the SHXs.



*Controlled Document - Verify Current Revision*

- As cold salt flow is reduced, cooling is transferred to IAC by adjusting the IAC damper position and fan speed to maintain cold leg IHT temperature to hot standby parameters.
- The plant is now in a stable hot standby condition.

**B. Anticipatory reactor runback:**

- Reactor power is decreased at a pre-determined rate by inserting control rods.
- PSP, ISP, and salt pump flows are decreased to the targeted low flow settings.
- The IAC/AHX system controls IHT temperature at a specified temperature.
- Once the IHT temperature is within the controlled setpoint the salt flows are reduced at a predetermined rate.
- The SHXs isolate and the cold salt pumps shut down.
- The reactor is now controlled at low power.

## **8 REGULATORY ANALYSES**

TerraPower evaluated the impact of the Sodium design interfaces between the NI and EI on the following regulations:

- 10 CFR 50.10 - License required; limited work authorization
- 10 CFR 55 – Operators’ Licenses
- 10 CFR 50.65 – Requirements for monitoring the effectiveness of maintenance at nuclear power plants
- 10 CFR 50 Appendix B - Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants

### **8.1 Regulatory analyses associated with 10 CFR 50.10, “License required; limited work authorization.”**

The purpose of 10 CFR 50.10 is to ensure that activities constituting construction of a production or utilization facility on a site on which the facility is to be operated do not begin until a license or authorization is issued by the NRC. This ensures there is a safety analysis report that demonstrates the activities conducted under the limited work authorization (LWA) are conducted in compliance with the technically-relevant NRC requirements in 10 CFR Chapter 1 that are applicable to the design of those portions of the facility within the scope of the LWA and that the NRC staff issues a final environmental impact statement for the LWA in accordance with subpart A of Part 51 of Chapter 1. These requirements ensure that an NRC authorization is obtained before undertaking activities that have a reasonable nexus to radiological health and safety and/or common defense and security.

Activities constituting construction are described in 10 CFR 50.10(a)(1):

50.10 License required; limited work authorization.

(a) Definitions. As used in this section, construction means the activities in paragraph (a)(1) of this section, and does not mean the activities in paragraph (a)(2) of this section.

*Controlled Document - Verify Current Revision*

(1) Activities constituting construction are the driving of piles, subsurface preparation, placement of backfill, concrete, or permanent retaining walls within an excavation, installation of foundations, or in-place assembly, erection, fabrication, or testing, which are for:

(i) Safety-related structures, systems, or components (SSCs) of a facility, as defined in 10 CFR 50.2;

(ii) SSCs relied upon to mitigate accidents or transients or used in plant emergency operating procedures;

(iii) SSCs whose failure could prevent safety-related SSCs from fulfilling their safety-related function;

(iv) SSCs whose failure could cause a reactor scram or actuation of a safety-related system;

(v) SSCs necessary to comply with 10 CFR part 73;

(vi) SSCs necessary to comply with 10 CFR 50.48 and criterion 3 of 10 CFR part 50, appendix A; and

(vii) Onsite emergency facilities, that is, technical support and operations support centers, necessary to comply with 10 CFR 50.47 and 10 CFR part 50, appendix E.

The Natrium reactor safety classification of SSCs is being performed utilizing the LMP as defined in NEI 18-04, Rev. 1. The output of the SSC classification process results in all SSCs located on the EI being classified as non-safety-related with no special treatment (NST). The Natrium design does not rely on any NST SSCs to provide mitigation for an accident or transient. The Natrium design does not have any NST SSCs whose failure could prevent SR SSCs from fulfilling their safety-related function. Based on this assessment, criteria i, ii, and iii of 10 CFR 50.10(a)(1) do not apply to SSCs on the EI.

The language in 10 CFR 50.10(a)(1)(iv) is consistent with the language currently in 10 CFR 50.65(b)(2)(iii). The language alignment of 10 CFR 50.10(a)(1)(ii, iii, iv) to that of 10 CFR 50.65(b)(2) (i, ii, iii) was further clarified in RG 1.206, Rev. 1, "Applications for Nuclear Power Plants." RG 1.206 states that, in the LWA rule, the scope of SSCs falling within the definition of construction was derived from the scope of SSCs that are included in the program for monitoring the effectiveness of maintenance at nuclear power plants, as defined in 10 CFR 50.65(b). As discussed in the supplementary information, the NRC selected the criteria used in the definition of construction to take advantage of work done during development and implementation of the maintenance rule (10 CFR 50.65, "Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants"). Like the LWA rule, the maintenance rule defines a scope of SSCs that have some nexus to radiological health and safety (i.e., safety significance). The NRC selected the maintenance rule criteria for use in the definition of construction, in part, because the criteria are well understood and there is good agreement on their implementation. In addition, the NRC prepared guidance that has been used extensively in the industry for implementing the maintenance rule in RG 1.160, "Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," issued in March 1997. RG 1.160 endorses industry guidance provided in

*Controlled Document - Verify Current Revision*

NUMARC 93-01, Rev. 2, "Industry Guideline for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," issued in April 1996. For these reasons, the NRC decided that the maintenance rule guidance can also be applied to determinations of SSCs that are within the scope of the definition of construction. The NRC also recognizes that determinations of which SSCs fall within the definition of construction depends on the design of the facility.

TerraPower plans to seek an exemption from 10 CFR 50.10(a)(1)(iv) and 10 CFR 50.65(b)(2)(iii) for the construction and operation of the EI of the Natrium reactor. The rationale for seeking an exemption from 10 CFR 50.10(a)(1)(iv) is discussed in Section 8.3 with the discussion on 10 CFR 50.65(b)(2)(iii).

Construction activities for SSCs necessary to comply with 10 CFR 73 include the preparation and building of physical barriers and structures and associated hardware and detection systems for the physical security program. None of these physical security program SSCs are located on the EI for the Natrium reactor. To meet the requirements of the cyber security programs included in 10 CFR 73.55, digital components and control systems identified as Critical Digital Assets (CDAs) are not installed or activated prior to receiving a construction permit. Based on this assessment, criterion v of 10 CFR 50.10(a)(1) does not apply to SSCs on the EI.

Construction activities for SSCs necessary to comply with 10 CFR 50.48 and Advanced Reactor Design Criterion 3 in Regulatory Guide 1.232, Rev. 0, "Guidance for Developing Principal Design Criteria for Non-Light-Water Reactors," include fire protection equipment and components to achieve and maintain safe shutdown. This includes all the fire protection equipment for protection of the equipment necessary to achieve and maintain safe shutdown, including the fire barriers in walls for penetrations to minimize spread and maintain separation. Potential fires on the EI would not prevent the ability to achieve and maintain safe shutdown of the reactor. Based on this assessment, criterion vi of 10 CFR 50.10(a)(1) does not apply to SSCs on the EI.

Onsite emergency facilities (i.e., technical support and operations support centers) necessary to comply with 10 CFR 50.47 and 10 CFR 50, appendix E are not located on the EI. The facility for providing onsite emergency first aid and decontamination are not located on the EI. Based on this assessment, criterion vii of 10 CFR 50.10(a)(1) does not apply to SSCs on the EI.

Based on these analyses and contingent on approval of the planned exemption request for criterion iv, construction of the EI would not constitute construction in accordance with 10 CFR 50.10. Therefore, an LWA would not be needed for EI construction activities.

## 8.2 Regulatory analyses associated with 10 CFR 55, "Operators' Licenses".

10 CFR 55 provides the requirements, scope and regulations associated with operators' licenses. In accordance with 10 CFR 55, operators' licenses are for activities constituting the operation of controls. Controls are manipulations which directly affect the reactivity or power level of the reactor of utilization facilities licensed under the Atomic Energy Act of 1954, as amended, or Section 202 of the Energy Reorganization Act of 1974, as amended, and part 50.

The following are excerpts from 10 CFR 55:

55.1 Purpose states that regulations in this part:

(a) Establish procedures and criteria for the issuance of licenses to operators and senior operators of utilization facilities licensed under the Atomic Energy Act of 1954, as amended, or Section 202 of the Energy Reorganization Act of 1974, as amended, and part 50, part 52, or part 54 of this chapter.

55.2 Scope states that the regulations in this part apply to:

(a) Any individual who manipulates the controls of any utilization facility licensed under parts 50, 52, or 54 of this chapter,

(b) Any individual designated by a facility licensee to be responsible for directing any licensed activity of a licensed operator.

(c) Any facility license.

55.3 License Requirements states that a person must be authorized by a license issued by the Commission to perform the function of an Operator, or a Senior Operator as defined in this part.

55.4 Definitions states the following definitions:

*Controls* when used with respect to a nuclear reactor means apparatus and mechanisms the manipulation of which directly affects the reactivity or power level of the reactor.

*Operator* means any individual licensed under this part to manipulate a control of a facility.

*Senior operator* means any individual licensed under this part to manipulate the controls of a facility and to direct the licensed activities of licensed operators.

The Natrium reactor removes direct interaction between the nuclear reactor and the main turbine generator. Due to the lack of direct interaction, operation of the main turbine generator is not an apparatus or mechanism whose manipulation directly affects the reactivity or power level of the reactor. Based on this design feature, operation of the main turbine generator is not considered a control by the definition in 10 CFR 55.4, which states, "with respect to a nuclear reactor means apparatus and mechanisms the manipulation of which directly affects the reactivity or power level of the reactor." The scope of 10 CFR 55.2 states that the regulations in this part apply to "any individual who manipulates the controls of any utilization facility licensed under part 50." Since main turbine generator operation for the Natrium design is not included in the definition of controls in 10 CFR 55.4, the regulations associated with 10 CFR 55 do not apply to operation of the main turbine generator of the Natrium plant. Because of this, the Natrium design allows for a non-licensed individual to fully operate and control the main turbine generator. Utilizing these principles allows the grid operator to control the main turbine generator as another asset for electrical grid management similar to conventional power sources.

*Controlled Document - Verify Current Revision*

### 8.3 Regulatory analyses associated with 10 CFR 50.65, "Requirements for monitoring the effectiveness of maintenance at nuclear power plants".

The purpose of 10 CFR 50.65, commonly referred to as the Maintenance Rule, is to monitor the effectiveness of maintenance at nuclear power plants. Holders of an operating license must monitor the overall performance or condition of SSCs and demonstrate that the SSCs are being effectively controlled through the performance of appropriate preventive maintenance, such that the SSC remains capable of performing its intended functions.

In accordance with 10 CFR 50.65, "Requirements for monitoring the effectiveness of maintenance at nuclear power plants", the scope of the program shall monitor the performance or condition of SSCs, against licensee-established goals, in a manner sufficient to provide reasonable assurance that these SSCs, as defined in paragraph (b) of this section, are capable of fulfilling their intended functions. These goals shall be established commensurate with safety and, where practical, take into account industrywide operating experience.

As stated in Table 4-1 of NEI 18-04 Revision 1, it is a basic requirement for all safety-significant SSCs that a Maintenance Program assures targets for SSC availability and effectiveness of maintenance to meet SSC reliability targets. This is essentially the same as 10 CFR 50.65 Maintenance Rule and is consistent with 10 CFR 50.69 for RISC-1 (SR) and RISC-2 (NSRST) SSCs. In addition, RG 1.233 states that "the framework incorporates an integrated review approach by using the satisfaction of selected requirements to provide reasonable assurance of some aspects of SSC performance (for example, performance-based acceptance criteria related to SSC capability, reliability, and availability). Examples of requirements that could be applied for this purpose include 10 CFR Part 50, Appendix A (general design criteria, overall requirements, criteria 1 through 5), 10 CFR Part 50, Appendix B (quality assurance program), 10 CFR 50.49 (electric equipment environmental qualification program), 10 CFR 50.55a (code design, Inservice testing and Inservice inspection programs), 10 CFR 50.65 (maintenance rule)[...]." Based on this statement, the process can be used to inform the SSCs included in the maintenance rule.

The following are excerpts from 10 CFR 50.65:

50.65, "Requirements For Monitoring The Effectiveness Of Maintenance At Nuclear Power Plants":

(b) The scope of the monitoring program specified in paragraph (a)(1) of this section shall include safety related and nonsafety related structures, systems, and components, as follows:

(2) Nonsafety related structures, systems, or components:

(i) That are relied upon to mitigate accidents or transients or are used in plant emergency operating procedures (EOPs); or

(ii) Whose failure could prevent safety-related structures, systems, and components from fulfilling their safety-related function; or

*Controlled Document - Verify Current Revision*

(iii) Whose failure could cause a reactor scram or actuation of a safety-related system.

The Natrium reactor safety classification of SSCs is being performed utilizing the LMP. The output of the process results in all SSCs located on the EI being classified as NST. The Natrium reactor does not rely on any NST SSC to provide any mitigation for any accident or transient or that are used in EOPs. The Natrium reactor does not have any NST SSCs whose failure could prevent any SR SSC from fulfilling their safety-related function. Based on this assessment, criteria i and ii of 10 CFR 50.65(b)(2) do not apply to SSCs located on the EI.

RG 1.160, "Monitoring the Effectiveness Of Maintenance At Nuclear Power Plants," Revision 4, and NUMARC 93-01, "Industry Guideline For Monitoring The Effectiveness Of Maintenance At Nuclear Power Plants," Revision 4 were evaluated for potential additional clarification for criterion iii, especially on the implementation of the maintenance rule program.

NUMARC 93-01 provides additional clarification by stating licensees should consider the following SSCs to be within the scope of the rule for criterion (iii):

1. SSCs whose failure has caused a reactor scram or actuation of a safety-related system at their site.
2. SSCs whose failure has caused a reactor scram or actuation of a safety-related system at a site with a similar configuration.
3. SSCs identified in the licensee's analysis (e.g., FSAR, IPE) whose failure would cause a reactor scram or actuation of a safety-related system.

A licensee may exclude SSCs that meet criteria 2 or 3 if they have demonstrated by analysis (e.g., FSAR, IPE) and by operational experience that the design or configuration of an SSC is fault-tolerant through redundancy or installed standby spares such that a reactor scram or actuation of a SR system is implausible.

The additional clarifications provided in 1 and 2 are not applicable to the Natrium design, since there is no previous operating experience and the configuration for the Natrium design is unique based on the thermal salt storage system. The clarification provided in 3 is applicable, since analysis shows that failures in the thermal storage salt system would lead to a runback, which is not an SR actuation. If the non-safety runback did not happen, the plant would eventually reach a scram set point. Since clarification 3 applies, 10CFR50.65(b)(2)(iii) also applies to the thermal salt storage system.

The NRC proposed Part 53 rulemaking language for a risk-informed, technology-inclusive regulatory framework for advanced reactors, specifically the NRC's proposed language in Section 53.715, "Maintenance, repair, and inspection programs" (ADAMS Accession No. ML22165A265, dated June 2022), states:

- a) A program to control maintenance activities and monitor the performance or condition of SR and NSRSS SSCs must be developed, implemented, and

*Controlled Document - Verify Current Revision*

maintained to provide reasonable assurance that the safety criteria defined in Sections 53.210 and 53.220 of this part will be met.

Section 53.715 proposed language is consistent with the safety classification of SSCs described in NEI 18-04. Please note that TerraPower is using the SSC classifications as defined in NEI 18-04 for safety-related (SR), non-safety-related with special treatment (NSRST), and non-safety-related with no special treatment (NST). These categories correspond to those in Part 53: safety related (SR), non-safety related but safety significant (NSRSS), and non-safety related (NSR). In utilizing the new NRC proposed draft process to address the current language associated with 50.65(b)(2)(iii), no SSCs on the EI would be part of the 53.715 rule as they would not be classified as SR or NSRSS.

Based on this, TerraPower plans to seek an exemption from 10 CFR 50.65(b)(2)(iii) by utilizing the NRC's proposed draft 10 CFR 53.715 language. This exemption would allow a Natrium plant's licensing basis to be consistent with the safety classification of SSCs described in NEI 18-04, in that only SR and NSRST SSCs are part of the maintenance rule scope. The output of the SSC classification process results in all SSCs located on the EI being classified as NST.

Based on these analyses and contingent on approval of the planned exemption request for criterion iii, EI SSCs would not be in the scope of the maintenance rule in accordance with 10 CFR 50.65(b)(2).

#### 8.4 Regulatory analyses associated with 10 CFR 50 Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plant".

10 CFR 50, Appendix B, establishes quality assurance requirements for the design, manufacture, construction, and operation of structures, systems, and components and states, "[t]he pertinent requirements of this appendix apply to all activities affecting the safety-related functions of those structures, systems, and components; these activities include designing, purchasing, fabricating, handling, shipping, storing, cleaning, erecting, installing, inspecting, testing, operating, maintaining, repairing, refueling, and modifying."

The Natrium reactor safety classification of SSCs is being performed utilizing the LMP as defined in NEI 18-04. The output of the SSC classification process results in all SSCs located on the EI being classified as NST. The Natrium reactor does not rely on any NST SSCs to provide any mitigation for any accident or transient. The Natrium design does not have any NST SSCs whose failure could prevent any SR SSCs from fulfilling their safety-related function. Since the SSCs located on the EI are NST and do not affect the SR functions of the SSCs used for mitigation, the requirements associated with 10 CFR 50 Appendix B do not apply to SSCs which are located on the EI.

## 9 CONCLUSION

The NI boundary conditions have been intentionally designed so the interface with the EI does not impact the Natrium reactor's safety case. Similarly, steam generation and thermal energy storage operations (e.g., ramp rates) are independent from reactor power operations due to the presence of the molten salt energy storage tanks. Several regulations were analyzed with these design principles in mind including: 10 CFR 50.10 - License Required;

*Controlled Document - Verify Current Revision*

Limited Work Authorization; 10 CFR 55 – Operators’ Licenses; 10 CFR 50.65 – Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants; and 10 CFR 50 Appendix B - Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants.

TerraPower requests NRC review and approval of the evaluations provided in this TR, as they pertain to the four regulatory requirements discussed above.

Exemption requests from portions of the requirements of 10 CFR 50.10(a)(1) and 10 CFR 50.65(b) for SSC’s not classified as SR or NSRST in accordance with NEI 18-04 are planned to be submitted for the NRC’s review. If the exemptions are granted for these two criteria, discussed in Sections 8.1 and 8.3, the four regulations discussed in Section 8 of this Topical Report would not apply to any SSCs located on the EI.



*Controlled Document - Verify Current Revision***10 REFERENCES**

- 1) 10 CFR 50
- 2) 10 CFR 73
- 3) NEI 18-04, Revision 1, "Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development"
- 4) NRC proposed Part 53 rulemaking
- 5) NUMARC 93-01, "Industry Guidelines for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants"
- 6) Regulatory Guide 1.160, Revision 4, "Monitoring the Effectiveness of Maintenance at Nuclear Power Plants"
- 7) Regulatory Guide 1.206, Revision 1, "Applications for Nuclear Power Plants"
- 8) Regulatory Guide 1.232, Revision 0, "Guidance for Developing Principal Design Criteria for Non-Light-Water Reactor"
- 9) Regulatory Guide 1.233, Revision 0, "Guidance for A Technology-Inclusive, Risk-Informed, And Performance-Based Methodology To Inform The Licensing Basis And Content Of Applications For Licenses, Certifications, And Approvals For Non-Light-Water Reactors"

END OF DOCUMENT