

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Open Session

Docket Number: (n/a)

Location: teleconference

Date: Thursday, September 8, 2022

Work Order No.: NRC-2076

Pages 1-106

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

698TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY

SEPTEMBER 8, 2022

+ + + + +

The Advisory Committee met via teleconference at 1:30 p.m., Joy L. Rempe, Chairman, presiding.

COMMITTEE MEMBERS:

JOY L. REMPE, Chairman

WALTER L. KIRCHNER, Vice Chairman

DAVID A. PETTI, Member-at-Large

RONALD G. BALLINGER, Member

VICKI M. BIER, Member

CHARLES H. BROWN, JR., Member

VESNA B. DIMITRIJEVIC, Member

GREGORY H. HALNON, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

JOSE A. MARCH-LEUBA, Member

MATTHEW W. SUNSERI, Member

ACRS CONSULTANTS:

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

QUYNH NGUYEN

5) NuScale Topical Report on Emergency Planning
Zone Plume.....4

5.1) Remarks from the Subcommittee Chairman.....5

5.2) Presentations and discussion with
representatives from the NuScale and
NRC staff.....7

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

(1:31 p.m.)

CHAIRMAN REMPE: So good afternoon. The meeting will now come order. This is the second day of the 698th meeting of the Advisory Committee on Reactive Safeguards.

I'm Joy Rempe, Chairman of the ACRS. Other members in attendance are Ron Ballinger, Vicki Bier, Charles Brown, Vesna Dimitrijevic, Greg Halnon, Walt Kirchner, Jose March-Leuba, Dave Petti, and Matt Sunseri.

I note we do have a quorum and similar to yesterday, the Committee is meeting in person and virtually. Communications channel has been open to allow members of the public to monitor the Committee discussion.

Mr. Kent Howard is the designated Federal Officer for today's meeting. During today's meeting, the Committee will consider the following topic: The NuScale Topical Report and Emergency Planning Zone Plume.

And if we finish early, we'll continue with our report preparations. A transcript of the open portions of the meeting is being kept and it is requested that speakers identify themselves and speak with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sufficient clarity and volume so that they can be
2 readily heard.

3 Additionally, participants should mute
4 themselves when they're not speaking. And at this
5 time, I'd like to ask Walt Kirchner to lead us through
6 our first topic for the day's meeting. Walt?

7 MEMBER KIRCHNER: Thank you, Joy. Good
8 afternoon, all. Welcome. My name is Walt Kirchner.

9 I am Chair of the NuScale Subcommittee for the NuScale
10 review.

11 For the purpose of this meeting is to review
12 the NuScale Topical Report, TR-0915-17772, Methodology
13 for Establishing the Technical Basis for Plume Exposure
14 Emergency Planning Zones and the associated Staff that
15 did the evaluation.

16 Just a few comments from me right now about
17 structure of the meeting. We're going to do this in
18 two parts. The first part will be open. We will allow
19 for public comments after the NuScale and Staff
20 presentations.

21 And then we'll take a break and we'll go
22 into a closed session with NuScale and the Staff. So
23 with that, let me see, we have Mike Dudek on the line.

24 Mike, would you like to make some opening comments?

25 MR. DUDEK: Thank you, Member Kirchner and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Chairman Rempe. So this is very exciting today for
2 the Staff to present our safety evaluation reports
3 associated with NuScale's Rev. 3 of the Topical Report
4 that you mentioned, the Methodology for Establishing
5 a Technical Basis for the Plume Exposure Emergency
6 Planning Zones for NuScale Small and Modular Reactor.

7 This is several years in the making. And
8 several revisions in the making and a lot of Staff hours
9 so this Topical Report today was very thought out by
10 all of the Staff Members that had it, bought into it
11 and via edits.

12 Several audits associated with it and came
13 to this resolution for this SER and I, as I read through,
14 I was very impressed by the level of detail and
15 transformation that was captured into it.

16 So I'm looking forward to the discussion
17 today. We're going to discuss how and why this Topical
18 Report is just applicable to NuScale. Some limiting
19 conditions that we had on it and some of the intricacies
20 behind the two RAIs, 9830 and 9828.

21 So a lot of good discussion and planned
22 for today. And with that said, I'll give my DRA
23 brethren a chance to give any opening remarks that they
24 would like to have as well. I think we have Shilp and
25 either Meena or Mr. Franovich on the line.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. VASAVADA: Thanks. This is Shilp
2 Vasavada on behalf of the NRC Staff. I don't have any
3 additional remarks compared to what Mike said. Enjoy
4 it all. Thank you.

5 MEMBER KIRCHNER: Okay and with that, let
6 me thank you both Staff and for those who are not
7 watching this, we have the NuScale team here. So thank
8 you for your trip to the East Coast, it's nice to see
9 you again in person.

10 And with that, I'm going to turn to Liz
11 English, and you can introduce your report and your
12 team.

13 MS. ENGLISH: Thanks. My name is Liz
14 English. I am a supervisor --

15 MEMBER KIRCHNER: You need to get your mic
16 lined up.

17 MS. ENGLISH: My name is Liz English. I'm
18 a supervisor in licensing for NuScale. Pleased to be
19 here today to present the outline of our Topical Report
20 to you.

21 With me are Thomas Griffith, also
22 supervisor on SDA, and Jeremiah Doyle who is the EPZ
23 technical lead for NuScale. He's the brains of the
24 bunch. Glad to have him here.

25 And I'll go to the next slide. We are very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 grateful to the DOE for the grant that we have to do
2 this work. Next slide. I'll turn it over to you,
3 Jeremiah. Ready to roll?

4 MR. DOYLE: Thanks, Liz. I'm Jeremiah
5 Doyle, the EPZ Technical Lead as Liz mentioned. So
6 this slide here is the agenda for the meeting. We'll
7 go over the purpose, introduce the Topical Report and
8 then provide an overview of the methodology and the
9 technical basis for the methodology for sizing
10 emergency planning zones. Next slide please.

11 The purpose of this meeting is to introduce
12 the methodology and the technical basis for the
13 methodology for determining the size of the plume
14 exposure emergency planning zone around NuScale plant
15 sites. Next slide please.

16 This Topical Report is applicable just to
17 NuScale small modular reactor designs. It's
18 consistent with the technical basis in the original
19 EPZ basis in NUREG-0396 and the supporting ERA technical
20 information in WASH-1400.

21 We identify a spectrum of accident
22 sequences, evaluate the source terms of those
23 sequences, compare the dose consequences of those
24 sequences to similar dose criteria as NUREG-0396 and
25 balance this quantitative evaluation with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 qualitative evaluation and engineering judgment.

2 And this implements the PRA methodology
3 and supporting codes that have been established in the
4 40 years since the original EPZ basis. And we designed
5 this so that any applicant could pick up this Topical
6 Report with the same information and produce the same
7 EPZ distance. Next slide please.

8 To use the Topical Report, we have two
9 conditions of applicability in the LTR. The first is
10 that this Topical Report is only applicable to NuScale
11 SMR designs and there are five overarching criteria
12 that define what it means to be a NuScale design.

13 And this is designed to capture the high
14 level safety attributes of the design while allowing
15 for some room for design improvements in the future.

16 And then the next condition of use is on the underlying
17 technical information that's input to the methodology.

18 The first condition is that the PRA that's
19 used as input needs to be full scope and capture all
20 hazards and all operating modes. And the second
21 condition is that the PRA needs to be technically
22 acceptable for this purpose.

23 MEMBER DIMITRIJEVIC: I have a question
24 there. This is Vesna Dimitrijevic. You mean that
25 technically acceptable period or just technically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 acceptable for this purpose?

2 MR. DOYLE: Technically acceptable
3 overall as in it's consistent with the existing PRA
4 standards and has been peer reviewed and has
5 demonstrated as technically acceptable and that it's
6 identified as acceptable for use in the underlying
7 application.

8 MEMBER DIMITRIJEVIC: All right because
9 you know that for some applications you don't need to
10 satisfy all higher level requirements so I just wanted
11 to make sure that you mean is just generally acceptable
12 for all that, you know, required so.

13 Okay, thanks. I understood that you said
14 that it's just review and acceptable generally not just
15 for this purpose.

16 MEMBER HALNON: Yes, this is Greg Halnon.
17 And how, the peer review befuddled me a little bit.
18 How are you going to get a peer review of a design
19 that nobody else can look at?

20 MR. DOYLE: The peer reviews of the PRA
21 itself and the, their existing PRA standards for
22 technical acceptability that outline the content and
23 scope and underlying information that's part of the
24 PRA and there's different capability categories
25 supporting that and there is peer review guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I forget the NEI document.

2 MEMBER HALNON: Yes, I understand.

3 MR. DOYLE: Yes.

4 MEMBER HALNON: Doesn't that require
5 knowledge, people knowledgeable of the plant itself
6 and some operating experience and other things? I
7 guess, have you looked at that to make sure you can
8 say that it's going to be peer reviewed in accordance
9 with that standard?

10 MR. DOYLE: We are in the process of
11 developing the peer review, of getting that information
12 in preparation for applying this report, but it is
13 understood that not everything could be met in the
14 standards or paper plan.

15 MEMBER HALNON: I think that caveat's
16 important. But just don't say it's peer reviewed
17 because it's traditionally commonly understood as
18 certain peer review has very diverse and also very
19 focused, experienced people on it.

20 And I'm not sure you're going to be able
21 to get all of that with this. So just be, as you go
22 through, keep that in mind.

23 MR. DOYLE: Thank you. Next slide please.

24 MEMBER DIMITRIJEVIC: Greg, Matt told me
25 that they don't have people with experience in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design or experience with the multi-units. But they
2 also will not carry information because, you know, all
3 of the PRA work requires procedures, lockdowns and
4 things like that so they will have also limited
5 information available and experience.

6 MEMBER HALNON: Yes, thanks, Vesna.
7 That's kind of what I was thinking. That there was
8 going to be kind of a small subset of peer review
9 actually is considered at this point.

10 MR. DOYLE: Next slide please. So the
11 NuScale methodology over all is a combination of a
12 quantitative evaluation and qualitative evaluation.
13 For the quantitative portion there's a balance of
14 deterministic evaluation of the design basis source
15 term.

16 And then the probabilistic best estimate
17 with uncertainty evaluation using a PRA and its
18 quantified sequences. And then there's an evaluation
19 of any other type of releases that may lie outside the
20 design basis or Sherman PRA and we'll talk about that
21 in more detail in the spectrum of accidents slide.

22 Once the spectrum of accidents is
23 identified, then the accidents vary as identified to
24 ensure that the appropriate dose criteria are applied.

25 And once the spectrum of accidents is identified, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 source term, time-dependent source term of the
2 environment for each sequence is calculated.

3 And then the dose for that sequence is
4 compare it for each sequence is compared against the
5 three dose criteria from the NUREG-0396.
6 Complementing that is a qualitative evaluation of
7 defense in depth to highlight design features and
8 operational strategies to preserve layers of defense
9 in depth in the design as well as a review and
10 disposition of key assumptions and other uncertainties
11 in the underlying PRA so that they are dispositioned
12 for the purpose of EPZ sizing. Next slide please.

13 This flowchart is just a graphical
14 representation of the quantitative portion of the
15 NuScale method. It reads from top to -- all right.
16 Hello? It's, okay. Oh, okay.

17 So the flowchart reads from top down, left
18 to right and identifies the PRA spectrum of accident
19 sequence selection process over to the incorporation
20 of the design basis input as well as the uncertainty
21 analysis of the source term and dose consequences.

22 That dash line is a conditional step in
23 the process where if certain criteria of the uncertainty
24 analysis are not satisfied, the source term and dose
25 consequence evaluations are repeated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then finally, the justified source term
2 and dose consequences are applied to the three dose
3 criteria and the plume exposure emergency planning zone
4 is the largest distance from the plant at which all
5 three criteria are met simultaneously.

6 MEMBER KIRCHNER: Let me ask a question
7 about the dotted line that you just highlighted. What
8 would change when you went back and iterated, are you
9 going to get to that? I mean, you do this analysis
10 and if it's not acceptable, then you go back and do
11 the source term evaluation again?

12 That's a misinterpretation by my, on my
13 part, but --

14 MR. DOYLE: That is correct. So the idea
15 is to perform an uncertainty analysis of the most
16 probable less severe and more severe PRA sequences that
17 are evaluated using a parametric evaluation of the
18 severe accident inputs and the dose consequence inputs.

19 And any inputs that are identified as
20 important to the final dose consequence, which is 5
21 percent of the, at least 5 percent of the uncertainty
22 regression metric used than those important perimeters
23 need to be justified as best as submitted.

24 And if they cannot be justified, a
25 conservative value must be justified and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conservative value would be used and the evaluation
2 would be repeated with that value.

3 MR. KIRCHNER: Thank you.

4 CHAIRMAN REMPE: So along those lines,
5 again I don't -- so just tell me to shut up if I'm getting
6 into something that's proprietary. But there was some
7 information regarding how the vessel failure assumption
8 would be invoked that to me (audio interference) more
9 thorough validation for evaluation or assessments, the
10 code that you assume for when you implement this?

11 MR. DOYLE: Part of the methodology is
12 providing some basis for consequence, for confidence
13 in the MELCOR results that MELCOR's used. And we
14 describe how to do a code to code comparison up to core
15 damage.

16 But specifically for any type of
17 containment phenomena that would be evaluated as part
18 of the underlying PRA. The EPZ methodology is not
19 modifying the underlying PRA, it's just using that
20 information and so.

21 CHAIRMAN REMPE: Yes, you're using it for
22 a different application than what was done for the
23 original. In this case, the CD, but of course, this
24 will be all for a SDA or something I suppose. But go
25 ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DOYLE: Right. So the acceptability
2 of the MELCOR evaluations would be, would fall under
3 the peer review aspect of the underlying PRA. And if,
4 there's, again this is where the other risk section
5 also comes into play as a capture.

6 We specifically talking the methodology
7 about severe accident phenomena like a containment
8 failure and that it's expected to be evaluated in the
9 underlying PRA.

10 But if it's not and there or there's not
11 confidence, that these releases would be demonstrated
12 to either meet the dose criteria or would be bounded
13 by other sequences that are captured in the spectrum
14 of accidents from the screening process.

15 So in some form, the doses will be evaluated
16 from an intact containment or a containment bypass
17 event. And if there's uncertainty as to which, as to
18 the status of containment, the methodology requires
19 the user to evaluate both the intact containment and
20 the containment bypass version of the accident.

21 CHAIRMAN REMPE: I'm concerned about the
22 assumption about the size of the hole for containment
23 value. And it's stated that the size is conservative
24 and I, if I were viewing it either as a peer review
25 or the Staff, I'd be wanting to see the justification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for that.

2 MR. DOYLE: Okay. I'm not sure I
3 understand the --

4 CHAIRMAN REMPE: Can you --

5 MR. DOYLE: -- full --

6 CHAIRMAN REMPE: -- talk more specifically
7 --

8 MR. DOYLE: -- or hole, okay.

9 CHAIRMAN REMPE: -- or can we get into --
10 although I don't think it's in your slides, but I can
11 bring up the report --

12 MR. DOYLE: Okay.

13 CHAIRMAN REMPE: -- assumption and all
14 that, but I just am curious if there was some additional
15 validation of some of the -- in the PRA, they got down
16 below frequency and I know the Staff did not go all
17 the way with their MELCOR validation to containment
18 failure because there's, you get into a lot more
19 uncertainties.

20 And they did it for a what, up to vessel
21 failure I think or a certain point and they didn't go
22 all the way and they said, okay, it's good enough and
23 we let it go.

24 But now you're taking those results in a
25 more severe accidents and you're using them to come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 up with your EPZ. And I just am wondering if somebody's
2 going to do some more assessment on the validity of
3 the code for that application.

4 MR. DOYLE: Okay, understood. Next slide
5 please. So the first step is the identification of
6 the spectrum of accident sequences. Consistent with
7 NUREG-0396, the design basis source term and the PRA
8 accident sequences are evaluated for inclusion in the
9 spectrum of accidents.

10 The design basis source term in the NuScale
11 design is at the core damage design basis source term
12 for offsite builds consequences is a combination of
13 intact containment beyond design basis accidents.

14 It's a surrogate accident with
15 characteristics from multiple beyond design basis
16 accidents. This viewed accident from the PRA are
17 identified for inclusion based on sequence frequency
18 so non-seismic, single module, multimodule sequences
19 are retained in the EPZ basis if they have a core damage
20 frequency greater than ten to the minus seven per year.

21 And this frequency captures the complete
22 spectrum of accidents in the underlying basis in
23 NUREG-0396. And the use of CDF as the metric rather
24 than release frequency also adds some conservatism to
25 the screening process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And additionally, following the initial
2 best-estimate screening, an uncertainty analysis of
3 the screening is performed using the 95th percentile
4 values for screened-out sequences.

5 The consistent with NUREG-1855, if a
6 sequence that initially screens out is within an order
7 of magnitude of the screening criteria, then if the
8 mean-best estimate CDF value is within an order of
9 magnitude, then the 95th percentile CDF is compared
10 to the ten to minus seven threshold.

11 And if that sequence 95th percentile value
12 is above the screening threshold, it's retained for
13 analysis in the spectrum of accident sequences. And
14 this ensures that we're not missing any cliff edge
15 sequences beyond that screening limit.

16 Following the identification of the design
17 basis, source term and PRA accidents, other releases
18 are identified. One specific example that lies outside
19 the design basis source term in PRA is an accident
20 involving failure of the single failure-proof crane
21 where the upper half of the module is dropped onto the
22 open bottom half of the module and the refueling tool.

23 In this instance, the release wouldn't meet
24 the core damage definition of the PRA because the fuel
25 is not over heating, but there is mechanical damage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and there is the potential for gap release from the
2 fuel.

3 And so that release would be identified
4 and evaluated as part of the EPZ method. And then
5 finally, once all the accident sequences have been
6 identified, their severity is determined consistent
7 with NUREG-0396.

8 There's two categories less severe and more
9 severe that are differentiated based on the level of
10 atmospheric release and less severe actions are
11 considered to be those with the containment intact.

12 And containment failure bypass accidents
13 are more severe. And if the containment status is
14 uncertain, you evaluate both intact containment and
15 bypass versions of the accident. Next slide please.

16 MEMBER KIRCHNER: One question on that
17 last set of bullets. So if you have a breach of
18 containment, whatever reason, do you take any credit
19 for scrubbing or do you assume that containment breach
20 is above the water level on all the gaseous fission
21 products that are released?

22 MR. DOYLE: So for the module drop accident
23 which is horizontal under the surface and we have
24 confidence that it would be under the surface, it is
25 scrubbed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But for other accidents, postulated
2 accidents from an upright module, that's assumed to
3 be above the pool surface.

4 MEMBER KIRCHNER: Thank you.

5 MR. DOYLE: So following the
6 identification of the spectrum of accident sequences,
7 the time dependent source terms are calculated using
8 a severe accident code like MELCOR, for example.

9 And it's expected that these severe
10 accident calculations will have already been performed
11 as part of the PRA. And these source term evaluations
12 will then feed into the off-site dose consequences.

13 So for the design basis source term, it
14 would be evaluated just as the release from containment
15 to the environment with no other credit for any other
16 type of retention or hold up.

17 But for the less severe, more severe beyond
18 design basis accidents, credit for additional scrubbing
19 or retention outside of the containment like in the
20 reactor building could be credited in, through separate
21 effects models from MELCOR.

22 And then these environmental source terms
23 will be fed into MACCS for comparison against the three
24 dose criteria. Criteria A for design basis source
25 terms is that the total effective dose equivalent is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 less than one REM or mean, meteorology conditions and
2 five REM for 95th percentile conditions for 96-hour
3 exposure.

4 The Criterion B is for less severe
5 accidents. The TEDE dose would be less than one REM
6 mean in the 95th percentile over 96-hour exposure.
7 And the Criterion C is that the more severe accidents
8 would demonstrate a reduction in early health effects
9 by comparison to a 200 REM threshold using acute
10 whole-body dose.

11 Consistent with NUREG-0396, the
12 recommended defaults for performing this modeling in
13 the methodology is that the individuals, the
14 individual, the dose receptor is located outdoors and
15 they're stationary.

16 They are in the direction of maximum
17 exposure. These receptors are located at least 50
18 meters from the reactor building and as far out as ten
19 miles to get the full spectrum of distances there.

20 And these receptors do not undergo any
21 sheltering, relocation or evacuation, no protective
22 actions and all the major short-term dose pathways are
23 evaluated.

24 And there's no shielding from these
25 different pathways with the exception of groundshine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which is recommended to have a 70, sorry, a 30 percent
2 shielding due to just natural variations of being
3 located on a planar surface and ground variations.

4 And that's all consistent with the
5 valuation in NUREG-0396. And then following this
6 evaluation of the source term and dose, that's when
7 we get to the evaluation of uncertainty that we
8 discussed on the flow chart slide.

9 CHAIRMAN REMPE: A good place to bring up
10 this question. Your report states that it expands on
11 the NEI methodology. Right?

12 MR. DOYLE: Correct.

13 CHAIRMAN REMPE: And one of the things I
14 like about the NEI methodology that you actually cited
15 in your report is that it mentions that the required
16 site emergency plans will provide a base for expanding
17 response efforts, if necessary, in accordance with
18 regulatory guidance so as to provide an additional layer
19 of defense and data.

20 And that away, it can, we all know that
21 PRAs do, nobody knows completely what kind of accidents
22 might occur with a first of a kind reactor. I kind
23 of felt more comfortable seeing that.

24 So how will this methodology be used to
25 or what's your vision on how you'll accommodate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 part of the NEI methodology? And I'm also curious on
2 how the Staff will ensure that that's done in the review
3 process.

4 MR. DOYLE: Well part of this methodology
5 is that we are just establishing the distance for the
6 emergency planning zone and outside of this plume
7 exposure distance, you know, traditionally there are
8 avenues for expanding this protection.

9 And because we're not evaluating the every
10 sequence individually, that could potentially happen.

11 But establishing a distance where it is, you know,
12 likely imprudent to have preplanned actions and having
13 the base for expansion for those.

14 So that's not something that's very
15 detailed in the methodology, but would come out of
16 implementing whatever site, whatever EPZ distance would
17 come out of the method.

18 CHAIRMAN REMPE: Some design developers
19 which may not be your organization, want to put very
20 small cladding zone site boundary. And so again I'm
21 thinking about one of the managers at SEPCO saying that
22 it's not a good time to come up with an emergency plan
23 during the middle of an accident.

24 So I really like that part of the NEI
25 methodology and I'm just kind of thinking about in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 future. I realize this is just a topical report, but
2 I'm just kind of thinking that some more acknowledgement
3 -- I'm glad it was in your Topical Report, but I'd like
4 to really make sure that somebody thinks about that
5 in the future and make sure that it gets implemented.

6 Because if you reduce the emergency
7 planning zone because you don't want to have drills,
8 I'd sure like to see that you've thought about how,
9 you know, what would need to be done. Does that make
10 sense where I'm coming from?

11 MR. DOYLE: Yes, understood. Thank you
12 for that feedback. Next slide please. So following
13 the quantitative evaluation and the establishment of
14 a specific plume exposure EPZ distance around the plant,
15 that there's a qualitative evaluation of defense and
16 depth and a review of the PRA uncertainties to provide
17 further confidence in the PRA risk numbers and the
18 qualitative or quantitative evaluation itself.

19 So the defense and depth evaluation will
20 be performed to confirm that the design meets the
21 guidance and INSAG-10 and Reg Guide of 1.174 to
22 demonstrate the five attributes in INSAG-10 and the
23 seven in Reg 1.174 of defense and depth.

24 I highlight these design features and SSCs
25 that are available and capable to prevent accidents

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and mitigate consequences should they occur. And then
2 it confirms that these, that these attributes exist
3 and that they're functional and that they confirm the
4 low risk in sites from the PRA.

5 The review of PRA uncertainties is
6 performed consistent with, you know, really any
7 risk-informed application of the PRA to address that
8 the underlying assumptions and model uncertainty and
9 completeness uncertainty in the PRA that were evaluated
10 for the specific purpose of that application do not
11 have any impacts or those impacts are evaluated and
12 are evaluated in the context of EPZ sizing. Next slide
13 please.

14 So in summary, the NuScale Topical Report
15 presents a method for sizing emergency, new emergency
16 planning zones that's consistent with the underlying
17 basis in NUREG-0396 and WASH-1400s and it provides the
18 same level of protection to the public that the existing
19 EPZs provide around operating plants and its limited
20 applicability to a NuScale SMR designs only. And I
21 believe that's the last slide.

22 MEMBER HALNON: I just had, this is Greg
23 Halnon. I don't know if this question is valid, but
24 you know, we just went through the 50.160 Emergency
25 Planning Rule aspect. If you overlaid this on top of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that, could this maneuvering be used under that rule?

2 MR. DOYLE: Yes, this is designed to be
3 a stand-alone methodology outside the existing guidance
4 and, or the existing regulations and the proposed
5 regulations.

6 But overlaying our method with the guidance
7 in Appendix A for the new rulemaking, we do meet those
8 major points of that methodology, that high level --

9 MEMBER HALNON: Kind of a plug and play
10 type of thing?

11 MR. DOYLE: Right.

12 MEMBER HALNON: Thanks.

13 MEMBER BIER: One other question. Very
14 early on, I think you said that any sequence will load
15 into minus seven would not be used in the calculation
16 of the then, some of these exceptional cases. Is that
17 correct?

18 MR. DOYLE: That's correct for a
19 non-seismic sequences.

20 MEMBER BIER: Okay. Have you thought
21 about just what if you have so many zillion sequences
22 at ten to the minus nine that they add up to be worth
23 including overall?

24 MR. DOYLE: That point is not specifically
25 addressed in the Topical.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BIER: Okay. I mean it may be that,
2 you know, if your design is simple enough, maybe you
3 just don't have that many zillion sequences in the PRA.

4 I haven't looked at it but for LWR PRAs, that concerned
5 me.

6 MEMBER KIRCHNER: Jeremiah, I am just
7 looking ahead to the closed session. Give you some
8 to think about what I'm going to ask. But I think it's
9 important to share for the public.

10 We would be particularly interested in how
11 you're dealing with, as your report identifies, seismic
12 as being one of the bigger concerns and drivers in this
13 analysis.

14 And how you handle seismic event that could
15 impact all the modules up to 12 and, you know, simple
16 thinking would suggest that if a seismic event damages
17 one module, it's got a high probability of damaging
18 identical modules even that maybe ones down for
19 refueling at the time.

20 You could have a common cause failure in
21 the systems. Can you linearly sum up the source terms
22 or --? I would like to hear a little bit more about
23 how you address the multimode, multimodule source term
24 and how you deal with the uncertainty in the seismic
25 probabilities and how that impacts your results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DOYLE: Okay. I can discuss the
2 multimodule portion, but I'll hold the seismic for the
3 closed portion of the meeting. But broadly, we have
4 a methodology for identifying multimodule sequences
5 from any hazard not just seismic.

6 And it involves looking at the initiating
7 event for a given sequence and then identifying does
8 that initiating event impact multiple modules, for
9 example, loss of off-site power.

10 And then would that initiating event either
11 compromise the safe shut down functions of multiple
12 modules like ECCS and DHRS or could it physically
13 propagate to other modules like a hypothetical module
14 drop that tips over and strikes another module.

15 And so in those cases where you end up with
16 a sequence where there's say six modules that are
17 experiencing the same accident sequence, in the dose
18 calculations we would evaluate six cores with the same
19 timing and release fractions.

20 In the case where one module is, for
21 example, horizontal under the pool and there may be
22 two vertical modules that are intact containment or
23 bypass, the, we require the use of the MACCS code in
24 the method.

25 And that allows for multiple difference

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 source terms to be evaluated simultaneously. And the
2 method would call for the scrubbed horizontal module
3 source term to be added to the containment bypass or
4 intact containment source terms.

5 And if there was one horizontal module and
6 two intact containments, you would evaluate three
7 cores. One core to the, or one core for the horizontal
8 and two for the intact containment. But yes, it would
9 be explicitly addressed --

10 DR. BLEY: Yes, this is Dennis.

11 MR. DOYLE: -- in this calculation.

12 DR. BLEY: Yes, this is Dennis.

13 MEMBER KIRCHNER: By the way, let me, I
14 think I hear Dennis. For the record, we have our
15 consultants, Dennis Bley and Stephen Schultz with us
16 for our meeting today. Go ahead, Dennis.

17 DR. BLEY: Yes, thanks. It sounds like
18 you've done more thinking and more work on the
19 multimodule problem than you had done at the time of
20 the design cert. Is that true and when are we going
21 to see actually some details we can read about that?

22 MR. DOYLE: So the insights I was
23 discussing are from an audit example calculation that
24 we performed for the NRC Staff in support of the review
25 of the Topical Report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It's based on the multimodule PRA that we
2 submitted with the design certification. So that's
3 the extent of how we've evaluated multi-modules so far
4 and nothing new since the design certification.

5 DR. BLEY: Okay.

6 MEMBER DIMITRIJEVIC: Well that true yes.
7 Dennis, you go.

8 DR. BLEY: Well I just wanted to ask that
9 response from the audit, is that in one of the RAIs
10 that I haven't read? Is there a place we can go read
11 about that in more detail?

12 MR. DOYLE: The multimodule analysis
13 wasn't specifically part of an RAI question. And I
14 don't believe that's, that information's in an RAI.
15 It was discussed in the audit.

16 DR. BLEY: Oh, it was, just in the audit.
17 Okay. Thank you. I'm sorry, Vesna, go ahead.

18 MEMBER DIMITRIJEVIC: Well my comment was
19 that in the design certification the, you know, that
20 the accident with the unit was, you know, in the
21 horizontal were not counted for that and the latitude
22 too for larger reasons.

23 So obviously this is something different,
24 you know, since you're counting them for this smaller
25 releases I assume so. Therefore, that's a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 part of the difference with design period. I mean with
2 the design certification period. I mean, at least the
3 design certification PRA Level 2.

4 MR. DOYLE: In the design certification,
5 yes, we did evaluate the dose consequences of the module
6 drop and demonstrated that did not meet our larger lease
7 criteria.

8 But in that accident, the containment was
9 assumed to fail. And in the example calculation we
10 preformed, we applied that same source term but to the
11 EPZ dose criteria and not to the larger lease criteria
12 from the DCA.

13 MEMBER DIMITRIJEVIC: Well, therefore,
14 those sequences are not in the design certification
15 period. Right?

16 MR. DOYLE: Those sequences were evaluated
17 in the environmental report of the design
18 certification.

19 MEMBER DIMITRIJEVIC: I see.

20 MR. DOYLE: And the module drop did
21 contribute to the core damage frequency, but it was
22 not a contributor to the larger lease frequency.

23 MEMBER DIMITRIJEVIC: Right. And
24 therefore it was not counted in the core damage
25 frequency because it was not the contributor. So okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so this settle that and this analyzes from your
2 environmental report. Okay.

3 DR. SCHULTZ: Jeremiah, this is Steve
4 Shultz. Question. You mentioned as you made your
5 presentation that the methodology that you've used is
6 MELCOR methodology, but that other methods could be
7 used.

8 That an Applicant, in doing their PRA,
9 their overall evaluation, could use other methods.
10 Is that what you're implying?

11 MR. DOYLE: Yes, we did not limit the
12 methodology to one specific code. Like for example,
13 if an applicant wanted to use the MACCS code, they could
14 use that for their severe accident evaluations.

15 But since NuScale used MELCOR, we used that
16 as the example in the Topical, but it's not required.

17 DR. SCHULTZ: But then that would have to
18 be re-evaluated by the Staff of the application.

19 MR. DOYLE: Correct.

20 DR. SCHULTZ: The MACCS code though is
21 specified at least as provided by the Staff as a tool
22 that must be used in the application in the safety
23 evaluation that they performed. Is that correct?

24 MR. DOYLE: That's correct. The
25 methodology requires MACCS to be used as the dose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequence code.

2 DR. SCHULTZ: Thank you.

3 MEMBER KIRCHNER: Other members?
4 Questions?

5 CHAIRMAN REMPE: Just a comment. We are
6 actually in the full committee meeting, not
7 subcommittee meeting. I just noticed that your slides
8 and the Staff slides say subcommittee meeting and it's
9 not a big deal, but I wanted everyone to be aware of
10 it. I know it's confusing.

11 We had originally you guys scheduled for
12 a subcommittee meeting and this is a full committee
13 meeting so.

14 MEMBER KIRCHNER: One comment I was going
15 to make on that subject is that since you have the full
16 committee, and the full committee is here, this is a
17 good time to ask especially during the closed session,
18 any of the harder questions you have because we are
19 going to look to writing a letter report on this and
20 the Staff's review in our October full committee
21 meeting.

22 If we can answer all of your questions,
23 we can have a very brief summary presentation --

24 CHAIRMAN REMPE: Or even have it. It's
25 up to you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: -- or possibly none for
2 the October meeting so like please fire away now while
3 we have the NuScale people here as well as the Staff.
4 So any further questions or you want to hold some
5 questions for the closed session?

6 Okay, thank you, Liz. Thank you,
7 Jeremiah. I tell you what, I think we're ready for
8 the Staff --

9 MR. VASAVADA: Yes.

10 MEMBER KIRCHNER: -- presentations.

11 MR. VASAVADA: Thank you. So I have a
12 clarification question. So this is not a subcommittee
13 meeting?

14 CHAIR REMPE: We are in a full committee.
15 Again, we had scheduled, I'm sorry --

16 MEMBER KIRCHNER: You might want to turn
17 your microphone on.

18 CHAIR REMPE: We are in full committee.
19 We had scheduled something earlier in September as an
20 extra session to accommodate your schedule and then
21 we are hoping we can accomplish all of this during full
22 committee week.

23 And so that's why we're all saying you may
24 not have to present again.

25 MR. VASAVADA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN REMPE: But it's up to you all.

2 MR. VASAVADA: There is --

3 MEMBER KIRCHNER: So we are going to ask
4 you to pick up speed so we can move the Staff into your
5 chairs. And thank you for your presentation.

6 MR. DOYLE: Sure.

7 (Off record comments.)

8 MEMBER KIRCHNER: I don't know if you can
9 see this, but we have a placard there for you and it
10 says you're remote.

11 MS. SCHILLER: Good afternoon. My name
12 is Alina Schiller. I am a project manager in the NRC
13 Office of Nuclear Reactor Regulation, Division of New
14 and Renewed Licenses, New Reactor Licensing Branch.

15 Thank you. Thank you, Shilp, for sharing
16 your screen. I would like to thank the ACRS
17 Subcommittee and Full Committee for NuScale Power, LLC
18 and the general public for entertaining the NRC for
19 the presentation of the Staff safety evaluation of
20 NuScale's Licensing Topical Report titled Methodology
21 for Establishing the Technical Basis for Plume Exposure
22 Emergency Planning Zones at NuScale's small modular
23 reactor plant sites Revision 3. Next slide please.

24 In August 2020, NuScale submitted Revision
25 2 of this Topical Report to the NRC. The NRC showed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 two requests for additional information, RAIs, to
2 NuScale in April 2021.

3 Originally the Topical Report Revision 2
4 was applicable to light water small modular reactors
5 and non-light water reactors. In May 2021, in response
6 to one of the two RAIs, NuScale removed applicability
7 to non-light water reactors.

8 From November 2021 to April 2022, NRC
9 performed the regulatory audit as part of its review
10 of the methodology in Revision 2. In June 2022, NuScale
11 provided response to the 2nd RAI and submitted Revision
12 3 of the Topical Report which is applicable only to
13 the NRC design and its derivatives and which
14 incorporated the responses to the two RAIs.

15 We are here today to discuss the Staff's
16 advanced safety evaluation of the Topical Report. Next
17 slide please. The NRC Staff reviewers are Marie
18 Pohida, the lead technical reviewer with the PRA
19 Licensing Branch C in the Division of Risk Assessment
20 in NRR, Shilp Vasavada, the acting branch chief of the
21 PRA Licensing Branch C, Elijah Dickson from the
22 Radiation Protection and Consequence Branch, Raymond
23 Hoffman with the Reactor Licensing Branch in the Office
24 of Nuclear Security and Incident Response Division of
25 Preparedness and Response and Todd Smith with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Division of Preparedness and Response and Answer.

2 The presenters today are Marie Pohida,
3 Shilp Vasavada and Elijah Dickson. I'm the project
4 manager for this Topical Report supported by Senior
5 Project Manager Getachew Tesfaye.

6 Now I'm turning over to Marie Pohida, the
7 NRC first presenter.

8 MS. POHIDA: Thank you, Alina. First I'd
9 like to discuss the outline of our presentation.
10 First, we're going to discuss the regulatory and
11 technical basis for the Staff's evaluation.

12 Then we're going to go through an overview
13 of the Topical Report methodology. We will then
14 discuss the dose-distance criteria and figures of
15 merit.

16 We will then discuss the source term and
17 consequence assessment and then the screening of PRA
18 sequences. We will highlight the treatment of
19 uncertainty and the conditions of use for this Topical
20 Report. Next slide please, Shilp.

21 First, I'd like to discuss this, the
22 regulatory and technical basis for our valuation. Our
23 basis is 10 CFR 50.47 on emergency plans, 10 CFR Part
24 50, Appendix E, emergency planning and preparedness
25 and 10 CFR Part 20, standards for protection against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 radiation.

2 The documents that I'm going to discuss
3 below, all the ADAMS information where the documents
4 can be found in the reference slide at the back of the
5 public presentation.

6 So our next document that we relied in is
7 NUREG-0396. It is the planning basis of emergency
8 response plans for light water reactors. And it is
9 the technical basis for the ten-mile EPZ and it is also
10 the technical basis for the draft final EP rule for
11 small modular reactors and other nuclear technologies.

12 This review was informed by the Commission
13 PRA policy statement of 1995. It was also informed
14 by the SRM SECY 98-144 and it's a white paper on risk
15 informed and performance-based regulations.

16 This review was informed by Reg Guide 1.174
17 which is an approach for using PRA in risk-informed
18 decisions on changes to the licensing basis and finally,
19 it was informed by Reg Guide 1.20 which is the, outlines
20 the technical acceptability of PRA results for
21 risk-informed activities. Next slide please.

22 I would like to discuss NUREG 0396 from
23 1978. It identifies the purpose of the emergency
24 planning zone. And it's the area within which plume
25 protected actions may be necessary to provide dose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 savings in the event of radiological release.

2 It is the technical basis for our, the
3 current prescribed plume exposure pathway EPZ radius
4 of ten miles. And if you look at NUREG 0396, it states
5 that the taskforce reviewed the dose distance curves
6 1 NUREG 0396 and they can be found in Figure I-11.

7 And they concluded that plume accidents
8 can be severe, but the probability of large doses drops
9 off substantially about ten miles from the reactor.

10 You know, based on the review of licensing
11 basis events and, I mean, this report was based on a
12 review of licensing basis events and a spectrum of
13 accident sequences from WASH-1400.

14 And these included BWR and PWR accident
15 release categories from WASH-1400. And Elijah will
16 present details of this later in the presentation.
17 I'd like to briefly discuss the Staff's method of
18 review.

19 It's consistent with a technical basis of
20 NUREG 0396 and it's also consistent with risk-informed
21 decision making and use of PRA in current risk-informed
22 applications.

23 And our review was supported by a
24 regulatory audit where NuScale provided an example
25 calculation using their design certification PRA and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 their SAMDA analysis which has source terms and release
2 frequencies to produce an example dose distance curve
3 demonstrating the entire methodology.

4 I would also just like to briefly discuss
5 our review of the applicability of the NuScale EPZ TR
6 methodology. It's only applicable to the NuScale
7 design and its derivatives which includes the standard
8 design approval.

9 And if you look in Section 2.5.1 of the
10 Topical Report, it provides high level design
11 characteristics that determine the applicability. You
12 know, as an example, for it, you'll see that it's
13 applicable for a small modular integral pressurized
14 light water reactor.

15 And the reactor modules are consisted,
16 composed of a reactor core, a primary coolant loop,
17 depressurizer and steam generators within a reactor
18 vessel which are housed within a containment vessel
19 that is normally operated in sub-atmospheric
20 conditions.

21 Additional characteristics like these can
22 be found in the SER. We find that these limitations
23 are acceptable because we believe these high level
24 design characteristics are capable of identifying the
25 NuScale design with features and the risk profile that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we considered in our review.

2 And at this, I'd like to turn over to Elijah
3 to discuss the dose distance criteria in more detail.

4 And I'll break here if there's any questions. All
5 right, thank you. Turn it over to Elijah.

6 MR. DICKSON: Thank you, Marie. So on
7 Slide 9 here, this slide discusses the Staff's approach
8 in reviewing the source term consequence portions of
9 the Topical Report which include performing review of
10 historical documents to familiarize ourselves on the
11 topic, current research analysis and results from other
12 organizations such as the NRC, NEI, EPRI as well as
13 the NuScale environmental report and other
14 organizations responsible for radiation protection
15 recommendations.

16 Specially, we paid careful attention to
17 the vintages of systems of dosimetry that were utilized
18 between NUREG 0396 and the Topical Report, the
19 radiological criteria as well as the radiological
20 consequence analysis methods and assumptions.

21 We did perform limited analyses using the
22 MACCS code, using assumptions drawn from WASH-1400 to
23 better understand the presented dose-based criteria
24 presented in NUREG 0396 and presented in the Topical
25 Report as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now before moving on to the next slide,
2 I'd like to provide some context in how the Staff
3 reviewed and compared the proposed methodologies and
4 criteria to the technical basis of the ten mile EPZ
5 described in NUREG 0396.

6 In doing so, you'll see that the Topical
7 Report is consistent with the robust analyses and
8 methods and intent of the current ten mile EPZ. NUREG
9 0396 captures the task force review analysis and
10 decision making insights in developing the planning
11 basis for a radiologically emergency response plans.

12 This includes members at all levels of
13 government, local, state and federal members. And here
14 they introduce the concept of generic emergency
15 planning zones as a basis for the planning for response
16 actions which will result in dose savings in the
17 vicinities of new purpose facilities in the event of
18 a serious accident.

19 A selection of the current ten mile EPZ
20 was chosen based on professional judgment considering
21 a variety of lines of evidence rather than being based
22 on a specific prescribed radiological consequence
23 assessment methodology.

24 The task force recommended considering
25 information from a spectrum of accidents which does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 include design basis accidents and a range of beyond
2 design basis accidents typically referred to as Class
3 9 accidents.

4 As defined in NUREG 0396, Class 9 accidents
5 are considered to be so low in probability as to not
6 require specific additional provisions in the design
7 of the reactor facility.

8 Such accidents would include sequences of
9 successive failures of more severe than those
10 postulated for the purposes of establishing the design
11 basis for protective systems and engineered safety
12 features.

13 With that, I would like you, to point your
14 attention to in your review of the Topical Report as
15 well as reviewing NUREG 0396, is specifically to
16 Appendix I of NUREG 0396.

17 It does contain a wealth of information
18 and insights from the task force and I'll be referring
19 back to it throughout my portion of the presentation.

20 Specifically, Appendix I of NUREG 0396 describes the
21 various rationales for establishing the planning basis
22 which includes risk, probability, cost effectiveness
23 and consequence spectrum.

24 The study based the rationale for the
25 planning basis on a special with consequences tempered

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by probability and NUREG 0396 also states that the
2 accident probability is important and does have a place
3 in the terms of evaluating the range of consequences
4 from accident sequences and setting some reasonable
5 bounds on a planning basis.

6 As such conditional probabilities of
7 various consequences were used to provide perspective
8 for critical doses of concern for emergency response
9 planners as were their probabilities.

10 Of most importance, the Staff reviewed,
11 in depth, NUREG 0396 dose distance curves that were
12 generated for design basis accidents and those are the
13 probability exceedance curves for the beyond design
14 basis accidents.

15 They also analyzed a number of other
16 important factors important for emergency planning
17 purposes such as accident progression, timing, source
18 terms and estimated arrival times.

19 With that, I'd go on to Slide 10 please.

20 Okay. This slide summarizes and presents the Topical
21 Reports of dose distance criteria and figures of merit.

22 For the most part, Topical Report follows
23 the recommendations of the Task Force for the assessed
24 design basis accidents and beyond design basis
25 accidents derived from their PRAs, the assessed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accident progression and timeliness.

2 They derive source terms and then perform
3 the applicable radiological consequence analyses.
4 Probably one of the primary differences between what
5 was done in NUREG 0396 back in the late '70s and with
6 being presented in the Topical Report, is that they
7 do utilize different systems of dosimetry.

8 And they do utilize updated tools and
9 analyses and updated codes and programs. So with that,
10 let me describe this table. It presents three
11 criteria.

12 Listed in each row in, it presents three
13 criteria and then listed in each row in the middle column
14 are the analyses used to derive the source term and
15 then lastly the figures of merit within each column.

16 The first row is Criterion A, specific to
17 design basis accidents, Criterion B and Criterion C,
18 rows 2 and 3 are for beyond basis accidents. As you
19 move from Criterion A to Criterion C, the analyses
20 become increasingly more mechanistic and rely on
21 additional realism.

22 So for Criterion A, I'll first discuss
23 insights from NUREG 0396. During that time when
24 they're developing the planning basis, the task force
25 had assessed already cited nuclear facilities safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis reports.

2 Specifically, the accident analyses that
3 were performed to demonstrate compliance with the Part
4 100 citing criteria, that is the 25 REM over a two-hour
5 period, they re-analyzed a handful of those analyses
6 and they determined at what distance you would compute
7 consequences less than one REM.

8 You can review these results, these are
9 the dose distance curves or dose distance analyses in
10 Tables I-2 and Figures I-1. The title of this figure
11 would be the upper bound plume exposure pathway
12 projected doses based off of 10cc per part of Part
13 100.11.

14 And what they found was that around ten
15 miles the doses would drop down below one REM with an
16 estimated time of arrival of that plume around five
17 hours.

18 So this was important information in regard
19 to emergency response planning. Not only, of course,
20 knowing what the projected computed doses are at
21 different RADI from the facility, but also what the
22 estimated time of arrival of that source term or plume
23 would be at that location.

24 Now we'll talk about the Topical Report.

25 The Topical Report methodology is generally consistent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with NUREG 0396 in that the EPZ should encompass those
2 areas in which projected doses from design basis access
3 could exceed early phase PAGs.

4 The source term that would be derived are
5 those that you would typically see from NUREG 0800 which
6 is a standard review plan, Chapter 15 accident analyses.

7 These are very stylized analyses and
8 deterministic in nature in which you're only applying,
9 for the most part, safety related structure systems
10 and components that meet single failure criteria and
11 do not rely on offsite power to mitigate the source
12 term and they do not consider accident frequency.

13 They are deterministic in nature. The
14 criteria used, the figures of merit criteria is one
15 to five REM total effective dose over 96 hours which
16 is consistent with the EPA PAG manuals early phase PAGs.

17 Now on to Criterion B and Criterion C.
18 These are the beyond design basis accident sequences
19 derived from the PRA. First let's talk about some
20 insights from NUREG 0396.

21 The task force was very focused on the more
22 severe accident sequence that involved large releases.

23 Primary consideration was given to prevention of early
24 health effects.

25 Early health effects that they had looked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at were one to five REM which corresponded to the lower
2 range of paths. Fifty REM corresponded to doses at
3 early, which early illnesses could occur.

4 And then 20 REM whole-body acute dose is
5 a dose at which significant early injuries would occur.

6 They generated a series of probability exceedance
7 curves for critical dose values at which emergency
8 planners would be concerned with.

9 Specifically, these exceedance curves were
10 generated for the source term frequency weighted and
11 in some yield the resulting curves. The primary curves
12 that were focused very heavily on by the task force
13 in NUREG 0396 were Figures I-11, I-12 and I-13.

14 And Marie had discussed this as well. As
15 quoted in NUREG 0396, it can be seen from Figure I-11.

16 Core melt accidents can be severe, but the probability
17 of large doses drops off substantially at about ten
18 miles from the reactor.

19 Such conclusions can be reached by
20 evaluating the other critical organ and lung dose
21 values. And these are in respective figures of I-12
22 and I-13.

23 As such, the shape of the curve itself that
24 you see in these exceedance frequency curves is very
25 important in the decision-making process for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 current ten-mile emergency planning zone.

2 I'll now go on to Criterion B and Criterion
3 C as they presented in the Topical Report. The EPZ
4 for Criterion B, the EPZ should encompass those areas
5 in which consequences of less severe accidents that
6 is contained and intact, sequences could exceed the
7 early phase PAG.

8 In this, for this criteria, the source term
9 that would be derived would be derived from PRA specific
10 accident sequences or BINs utilizing, for instance,
11 the MELCOR code to derive source terms which would then
12 utilize additional mitigating the design features and
13 operator actions.

14 The figures of merit that they would be
15 compared to would be the one to five REM total effective
16 dose equivalent evaluated over a four-day timeframe
17 which is consistent with the EPA PAG manual.

18 On to Criterion C. The EPZ should be a
19 sufficient size to provide for substantial reduction
20 early health effects in the event of more severe
21 accident sequences.

22 The source terms that would be derived for
23 these analyses would also be PRA specific accident
24 sequences or BINs of accident sequences. In this case
25 utilizing the MELCOR code and also perhaps maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 separate effects models to derive source terms which
2 would utilize additional mitigating design features
3 or phenomena and it would include operator actions.

4 The figure of merit that these would be
5 compared to would be the 200 REM acute dose metric based
6 on substantial reductions of early health effects.

7 And this too is consistent with NUREG 0396.

8 NuScale also has an acceptance criteria considered
9 proprietary and the Staff have, are still reviewing
10 this at this time for the 200 REM figure of merit.

11 It is based on analysis and discussions
12 presented in NUREG 0396. However, the Staff already
13 have reviewed this acceptance criteria and find that
14 it is within the residual risk discussed in NUREG 0396
15 Appendix I.

16 As such, I think that I'd also like to point
17 you to the bottom of this slide. We have a, we did
18 a little extra research with the Office of Research
19 in regard to providing a little more guidance in
20 producing the actual figures of merit utilizing the
21 MACCS code.

22 The MACCS code has many vintages of dose
23 conversion factors for many different ICRP
24 recommendations and so we provided a little extra
25 guidance on how one would compute the total effect of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dose equivalent versus the EPA's total effective dose
2 or how would you go when you compute the acute dose?

3 And that would be utilizing specific dose
4 conversion factors for lead bone marrow. So we did
5 provide the Staff report that you can see it at the
6 bottom of this screen. On to Slide 11.

7 MEMBER KIRCHNER: Elijah, before you go
8 on, --

9 MR. DICKSON: Yes.

10 MEMBER KIRCHNER: -- just to characterize
11 things, I would submit that the uncertainty between
12 the dose conversion that were used then and we use now
13 using MACCS is, they're comparable.

14 There's not a big difference there. These
15 uncertainties come in questions like Joy ask earlier.
16 So how does the system perform?

17 MR. DICKSON: Right.

18 MEMBER KIRCHNER: And you know, the
19 probability of a melt through and a containment breach,
20 how big are those breaches, et cetera, et cetera.

21 I mean, there's so much, compared to dose
22 conversion, there's so much uncertainty in the in
23 deriving that source term, --

24 MR. DICKSON: Right.

25 MEMBER KIRCHNER: -- that the dose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conversion is, it's an important thing too and I'm glad
2 you pointed that out, but it's not, it's not a big factor
3 in --

4 MR. DICKSON: You're --

5 MEMBER KIRCHNER: -- coming up with a
6 distance.

7 MR. DICKSON: You're right. There is more
8 of a regulatory purpose behind it.

9 MEMBER KIRCHNER: Yes.

10 MR. DICKSON: The whole system of Part 20
11 radiation protection is based off of, you know, the
12 ICRP 2630 system and those tissue weighting factors
13 from that system of dosimetry are directly codified
14 in Part 20.

15 And so if you were to compute TEDE, the
16 total effective dose equivalent which is also codified
17 by definition in Part 20, you need to use the right
18 dose conversion factors.

19 We find at times that applicants or
20 licensees may utilize the wrong dose conversion factors
21 and might compute the TED, the total effective dose,
22 so we're just trying to make that important distinction
23 here.

24 That if you're computing TEDE, you got to
25 use these dose conversion factors that way you are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistent with the regulation.

2 MEMBER KIRCHNER: Thank you.

3 MR. DICKSON: Thank you. Then lastly, on
4 Slide 11 for my section of the slides, the source term
5 and radiological consequence analyses, the top of the
6 report recommends the use of MELCOR and RELAP to perform
7 design specific source terms and then requires the MACCS
8 code to perform the radiologic consequence analyses.

9 And the Staff finds that these computer
10 codes are appropriate to perform these analyses. And
11 with that, I'll go on to the next slide which Marie
12 has if there's no other questions.

13 DR. BLEY: Yes, before you go on, I have
14 one. I almost didn't ask you. I've been waiting for
15 a while. This is Dennis Bley.

16 MR. DICKSON: Hi.

17 DR. BLEY: 0396 was done 50 years ago.
18 It was done when there was one PRA in existence. In
19 the last 10, 20 years, the Staff has made a very big
20 deal about how much more they've learned and how much
21 better they can calculate than they could way back then.

22 Why, what's the justification for still
23 hanging on to 0396? Just that it's perhaps
24 conservative with respect to these issues? What's your
25 thinking on that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DICKSON: It's, I think it's more the
2 process in which those individuals and organizations
3 came up with the planning basis. Not so much that very
4 specific WASH-1400 PRA, but that they went through a
5 process of considering risk information, they went from
6 a process of considering design basis type information
7 and then made that final selection.

8 That process is being echoed more or less
9 in this Topical Report.

10 DR. BLEY: Okay, well what I was really
11 getting at and I agree with what you just said. But
12 since we have learned how to calculate things better
13 and we have a lot of PDRAs since that time, not so many
14 Level 3s, but there are some, if we take that same
15 process and lay it up against what we know now, might
16 we come up with different results? It seems like we
17 ought to.

18 MR. DICKSON: Yes, that would be outside
19 I think the Topical Report review. That's more of a
20 policy type of question.

21 DR. BLEY: Yes, it is.

22 MR. DICKSON: It is.

23 DR. BLEY: You willing to talk about it?

24 MR. DICKSON: No, I'm not. I'll take that
25 one back with me. How about that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. BLEY: Okay.

2 MR. DICKSON: Yes.

3 MEMBER KIRCHNER: I think what you're
4 suggesting, Dennis this is Walt, is that based on the
5 SOARCA analyses, you could pull back on the ten mile
6 radius of the large plants. Maybe you might be thinking
7 that.

8 DR. BLEY: You can guess.

9 MEMBER KIRCHNER: I certainly was thinking
10 that. No comment necessary.

11 MR. DICKSON: Marie, are you next?

12 MS. POHIDA: Yes, thank you. I'd like to
13 discuss now event selection for EPZ sizing and how it
14 needs to be consistent with NUREG 0396. The first point
15 that I'd like to bring up is the spectrum of accidents
16 is it's not equal.

17 It's not similar to licensing and designing
18 new nuclear power plants against the QHOs. The
19 screening of accident sequences must ensure that
20 there's an adequate spectrum of events included in the
21 EPZ technical basis.

22 And so this task is completely different
23 and distinct from the licensing and review of a new
24 reactor's design against the Commission goals for new
25 reactors. And as you know, these goals are, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a CDF of ten of minus four, any large release frequency
2 of 20 minus six.

3 And that's stipulated in the S-REM
4 D-SECY-90-016. So the spectrum of accidents for EPZ
5 sizing has to include the characteristics of
6 radiological consequences from design basis access and
7 from a design basis, beyond design basis access.

8 So it has to include some the key
9 characteristics of more severe accidents and more
10 severe is the containment not intact with large releases
11 and it has to ensure that there's a capability to reduce
12 early severe health effects, injuries or death in the
13 event of the most severe beyond design basis events.

14 So the selection of the spectrum of
15 accidents for EPZ sizing does not, you know, alter the
16 design or operation of the plant. You know, new
17 reactors, you know, transition from large release
18 frequency to large early release frequency at or before
19 initial fuel load.

20 But emergency planning, you know, follows
21 the design and operation of the plant. Next slide
22 please. I'd like to continue this discussion of this
23 event selection on for EPZ sizing on Slide 13.

24 You know, the purpose of EPZ is dose
25 savings, not dose avoidance. And I'd like to present

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a quote from NUREG 0396. It's while the EPZ should
2 not be solely dependent on the most severe and most
3 improbable beyond design basis event, the determination
4 of the EPZ size needs to include some of the key
5 characteristics of very large releases.

6 Now, we expected that seismic risks would
7 be a dominant contributor to the NuScale risk profile,
8 you know, and factor into EPZ sizing. Okay. If you
9 look at the results of the NuScale design certification
10 PRA in their FSAR, and it's in Table 19.1-80, NuScale
11 reduced the risk from internal events, you know, logos,
12 losses of DC power and external events such as high
13 winds, internal fires and internal floods.

14 We also realize that the timing of these
15 seismically initiated sequences would be different to
16 non-seismic events. If you look at the seismic margin
17 results from the design certification PRA, it's
18 dominated by structural failures such as seismically
19 induced failure of the reactor building crane supports
20 and seismically induced failure of the reactor building
21 exterior walls.

22 And they are, if they occur or are soon
23 to result in core damage. So the inclusion of seismic
24 events in the spectrum of accident sequences is
25 important to maintain consistency with NUREG 0396.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And we can go to Slide 13 please.

2 And what I would like to do is discuss these
3 two donut charts. On the left you'll see the results
4 of the NuScale design certification PRA as it's
5 documented in the FSAR in Table 19.1-80.

6 And that's without any contributions from
7 seismic core damage frequency. If you look on the
8 right, you see an example risk profile of an existing,
9 you know, operating nuclear power plant site which
10 includes seismic core damage frequency assuming that
11 a NuScale design certification plant is built there.

12 So I'm going to note again that the EPZ
13 methodology was to ensure that there's an adequate
14 spectrum of seismic events to be consistent with NUREG
15 0396.

16 Now if you look at the donut chart on the
17 right, you'll note that this site lies within the
18 NuScale certified design response spectrum. And these
19 seismic core damage frequencies were derived using the
20 seismic hazard information from NTTF 2.1.

21 And the seismic hazard was convolved with
22 the fragilities of structural components that are
23 listed in Table 19.1-35 in the NuScale design
24 certification FSAR. And they were convolved to obtain
25 core damage frequencies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If you look in Table 19.1-34, you know,
2 seismically induced failure structural components were
3 assumed to lead to core damage. I will break here,
4 see if there's any question on this slide.

5 MEMBER PETTI: Just a lot of the NuScale,
6 philosophically, doesn't surprise me that a designer
7 would try to design away the internal --

8 MS. POHIDA: Yes.

9 MEMBER PETTI: -- threat. And so you're
10 left with the external so I think you're going to see
11 this over and over again with the advanced reactors
12 that are coming in where they've got inherent and past
13 features that are going to create the same dichotomy,
14 if you will, of the core damage frequencies.

15 Some may not even be able to describe a
16 core damage frequency, but upset frequencies are going
17 to be significantly different and you might want to
18 think about longer term, about as some guidance.

19 You know, in this regard that's generic,
20 you know, sort of a cross, but you know, independent
21 of a reactor technology because I think we're going
22 to, you're going to see this over and over again.

23 MS. POHIDA: We agree. And Shilp will
24 touch on this issue when he discusses seismic risks
25 and how we treat it in the methodology and how we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reviewed it. Is there any more questions?

2 We can go to next slide please. All right,
3 I'd like to discuss the Staff review of the non-seismic
4 single modules sequence screening. The Topical Report
5 uses a sequence screening of 20 minus 7 per reactor
6 year.

7 And that threshold would have screened in
8 all of the WASH-1400 release sequences. None of these
9 release sequences had a frequency less than 20 minus
10 7 per year. So we found this to be an acceptable
11 screening threshold.

12 May I go to the next slide. Thank you.
13 Second, I would like to discuss the Staff review of
14 the multimodule impacts for non-seismic hazards.
15 Okay. WASH-1400 did not explicitly model common mode
16 mechanisms such as fire, floods, tornadoes, which have
17 the potential to impact multiple modules in the event
18 trees and the fault trees.

19 I went and reviewed Appendix 4 of WASH-1400
20 and they, it states that these common mode mechanisms
21 were assessed as impacts when the system fault trees.

22 So the core damage sequence screening was
23 of 10, 20 minus 7 was also applied in the Topical Report
24 to multimodule core damage sequences. And once again
25 is I'll note that none of the WASH-1400 release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sequences had a frequency less than 20 minus 7 per
2 reactor year.

3 So the Staff found this screening threshold
4 for multimodule non-seismic hazards to be acceptable.

5 And then I'd like now to turn the discussion over to
6 Shilp so he can discuss seismic. Thank you.

7 MR. VASAVADA: All right. Thanks, Marie.

8 First of all before I start, I just wanted to make
9 sure I can be heard clearly at least on the phone.
10 I have a mask on so please let me know.

11 PARTICIPANT: Still has it.

12 MR. VASAVADA: Okay, how about now? Good?

13 PARTICIPANT: That's better.

14 MR. VASAVADA: Okay. All right, so I'll
15 start with the seismic screening threshold and then
16 go towards the end of the presentation. We have two
17 of the Topical Report proposed a seismic screening
18 threshold of 20 minus 5 per year based on the initially
19 frequency.

20 This was a long-standing open item in the
21 review. And not because the Staff decided to pay
22 excessive attention to seismic or treat it differently
23 from all the other hazards, but because 20 minus 5 per
24 year screening threshold resulted in an incomplete
25 spectrum effects.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is because there's negligible, if any,
2 beyond design it is seismic risk at that particular
3 frequency. The reason is that if the, what's called
4 a ground motion response spectrum which is used too
5 for the design purposes, is determined per the guidance
6 in Reg Guide 1.208 which it usually is than the approach
7 or their results in a target failure frequency for the
8 SSCs of 20 minus 5.

9 What that basically means and this is
10 explicitly mentioned in the Reg Guide that you have
11 negligible, if any, failure property of the SSCs at
12 that particular frequency.

13 So therefore you have negligible zone
14 design with assessment risk and the spectrum of
15 accidents is incomplete as was pointed out. 0396 does
16 call for a complete spectrum of accidents for EPZ
17 sizing.

18 So you do not have risk insights from the
19 dominant risk contributor. In addition, in WASH-1400,
20 seismic risk was considered although it was considered
21 qualitative.

22 The 20 minus 5 does not even cover the
23 extent of expirations that were considered
24 qualitatively in 1400s. From that perspective, it also
25 would be inconsistent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it would be inconsistent with my view
2 from the principles of risk informed decision making
3 because you do not have risk insights from a dominant
4 risk contributor or a risk informed decision.

5 That was primary reason why the 20 minus
6 5 in Version 2 was the concern, open item, and Staff
7 found that there was gap in the spectrum of accidents
8 that was being considered and therefore the risk in
9 size are EPZ size.

10 I'll fast forward to the Topical Report
11 which provides, proposes a proprietary value for the
12 screening curve. So the value at this and the
13 acceptability of this were and is consistency with 0396
14 as well as WASH-1400.

15 What the Staff did was it doubled up an
16 upload which we call the risk gap approach. The purpose
17 of the risk gap approach is to determine whether the
18 proposed screening threshold captures insufficient
19 spectrum effects against spectrum of seismic sequences
20 for consideration EPZ sizing.

21 As I talked about it in the previous slides,
22 zero percent at 20 minus 5 per year is inconsistent,
23 but so is 100 percent, the entirety of the seismic risk.

24 As Marie pointed out, 0396 clearly states
25 you do not have to use the worst case scenario for EPZ

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sizing. You need to have a good spectrum of facts.
2 And that's what the objective of this risk gap approach
3 was.

4 And the appropriate amount on the spectrum
5 of beyond design is -- please stop me if there are any
6 questions. I'll keep going. I'm on Slide 19 which
7 provides like an overview of the risk gap approach.

8 There are details provided in the Staff
9 safety evaluation and at this score, the approach is
10 simple to implement. It has four steps. I won't go
11 into the details, but overall, collect an ensemble of
12 hazard curves representing different sites within a
13 design and discuss most scales certifies seismic design
14 response spectrum.

15 You identify of land load fertility in the
16 mean scales marked for fertility and provides
17 additional details about sector ratios. You can wonder
18 too to get an estimate of the seismic core damage
19 frequency.

20 And you can let how much risk is being
21 essentially left off the table. And you can do sizing
22 determinations below the threshold. Either a
23 prescribed threshold or you can use this to identify
24 the property threshold.

25 And we will talk about the exact value.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So how often implemented this risk gap approach
2 determine if NuScale is proprietary in threshold
3 admitted and was acceptable.

4 We did this using nine of risk gap to size.

5 Let's go to the next Slide 21 to show the totally where
6 the sites are with respect to the NuScale certified
7 seismic design response spectrum of CSDRS.

8 As can be seen in the slides cover a range
9 of seismicity. They cover western and the central
10 eastern United States and they have different like
11 characteristics of the rock while back filled.

12 MEMBER HALNON: Shilp, this is Greg. How
13 did you assure yourselves that was representative of
14 any place a NuScale plant could be built?

15 MR. VASAVADA: Right, so the primary
16 reason was by selecting the site, removal of sites that
17 covered the regions, western United States, eastern
18 United States, different types of soil characteristics
19 and/or IP of seismicity from low seismicity as you see
20 the mustard line on the way to the yellow line.

21 MEMBER HALNON: Okay. But so your sample
22 was broad enough and the results close enough to have
23 you, give you confidence that was characteristic of
24 pretty much any soil types in the United States.

25 MR. VASAVADA: Right. So that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER HALNON: Did that include Alaska
2 as well?

3 MR. VASAVADA: So anything within the
4 NuScale's CSDRS, we did not go to Alaska.

5 MEMBER HALNON: Okay.

6 MR. VASAVADA: We did consider California.
7 Other than that, out of the NuScale CSDRS as NuScale
8 presented --

9 MEMBER HALNON: Okay.

10 MR. VASAVADA: -- and we talk about in the
11 conditions of use. This is --

12 MEMBER HALNON: A continuous --

13 MR. VASAVADA: -- only on the NuScale
14 design so it's been NuScale design.

15 MEMBER HALNON: Okay. They stayed within
16 their design.

17 MEMBER BALLINGER: Where does New Madrid
18 fit on this?

19 MR. VASAVADA: I'd have to go back and
20 check, but it would be somewhere --

21 MEMBER BALLINGER: But it's there.

22 MR. VASAVADA: Yes, it would be somewhere
23 --

24 MEMBER BALLINGER: Okay.

25 MR. VASAVADA: -- close to the CDCRS in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the top. What is at the bottom is some of the cited
2 updates like for example Texas where it has low
3 seismicity. Any further question?

4 MEMBER KIRCHNER: Yes, Shilp.

5 MR. VASAVADA: Yes.

6 MEMBER KIRCHNER: Explain to the public
7 the last sub-bullet on Slide 20.

8 MR. VASAVADA: Yes, I was getting to that.

9 MEMBER KIRCHNER: Why don't you capture
10 20 to 50 percent of the seismic risks.

11 MR. VASAVADA: So --

12 MEMBER KIRCHNER: Which is not captured
13 so in lay person terms explain this convolution that
14 you've gone through --

15 MR. VASAVADA: Okay.

16 MEMBER KIRCHNER: -- to address this risk
17 gap.

18 MR. VASAVADA: All right, so basically
19 going through that particular approach often watering
20 it and getting the seismic CDF looking below how much
21 risk is left off the table with all the proposed
22 proprietary screening threshold, we determined that
23 it was around between 50 to 80 percent of the seismic
24 risks would be not included, but EPZ sizing for the
25 majority of the plants.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For more than half of the plants, we did
2 not include 50 to 60 percent. Does that help?

3 MEMBER KIRCHNER: It will not include what
4 50 to 60 percent?

5 MR. VASAVADA: The seismic risk and the
6 sequences that guide.

7 MEMBER KIRCHNER: Okay.

8 MR. VASAVADA: And we also looked at the
9 absolute value of the risk gap in addition to the
10 relative contribution. And all of that information
11 and the details, including the numbers are in the Staff
12 safety evaluation.

13 I'm going to Slide 22 because I talked about
14 21 in conjunction with 20. We also looked at the
15 multimodule risks impacts and I'll talk about that in
16 detail in a subsequent slide and --

17 MEMBER PETTI: Can I just take you back
18 because I'm a little confused on that. The threshold,
19 the list that it's not capturing seismic events that
20 are extremely low frequency.

21 MR. VASAVADA: I'm sorry, yes.

22 MEMBER PETTI: Okay. I mean, that's what
23 I assumed. So you had taken the more frequent seismic
24 events?

25 MR. VASAVADA: Correct. I mean that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a part of the consideration in determining where the
2 property is, yes, how much is lost absolute terms,
3 relative terms. And what's the acceleration levels
4 at which we are talking about.

5 So I go to the Slide 18. At 100 percent
6 if you consider the entirety of seismic risk, you are
7 talking about like extremely unlikely accelerations
8 of 2Gs, et cetera.

9 And that was also, it would be found as
10 inconsistent with the fundamental digits in 0396. You
11 need a spectrum of accidents not designed in digital
12 in the worst case.

13 MEMBER PETTI: Fine, thanks.

14 DR. SCHULTZ: How is it that you used in
15 the, just go back to that slide, how is it -- this is
16 Steve Schultz. How is it that you used before the --

17 MR. VASAVADA: Before it?

18 DR. SCHULTZ: Yes. During the Slide 20.

19 MR. VASAVADA: Oh, got it.

20 DR. SCHULTZ: That you used the HCLPF, that
21 the NuScale high confidence low probability of failure?

22 MR. VASAVADA: So --

23 DR. SCHULTZ: It's at 95 percent values
24 so just to follow onto Dave's question.

25 MR. VASAVADA: All right, so the HCLPF high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confidence of low probability of failure is 95 percent
2 confidence with 5 percent failure or less. On the 95th
3 percent or what is also on the mean curve, 1 percent
4 or less failure probability.

5 And we use the values from their NuScale
6 SRA for the DCA design for this purpose, for the
7 convolution purpose.

8 DR. SCHULTZ: And when you say then the
9 threshold captures the 20 to 50 percent seismic risk
10 across the majority of nine sites, can you, can I get
11 something from the next slide that tells me what that
12 is in going to explain this to the public?

13 MR. VASAVADA: I'm sorry, if you can please
14 clarify like --

15 DR. SCHULTZ: How was HCLPF used, how was
16 that value of HCLPF used?

17 MR. VASAVADA: Okay. I can get in, so go
18 to Slide 19 for the steps. Step 2 is you determine
19 the plant level HCLPF are identified in the case of
20 NuScale.

21 You use that to provide the conditional
22 failure for the public of the plant considered as a
23 whole. And then you can roll that with the seismic
24 hazard.

25 And that convolution will give you the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equal, or an estimate of the seismic core down issues.

2 So that's how it was used for the purposes of this
3 evaluation.

4 DR. BLEY: Can, this is Dennis Bley. Can
5 I jump in with a kind of a question. This is an, it's
6 an interesting approach and it seems reasonable, but
7 what it's kind of telling me is that for the purposes
8 of looking at this report, nothing jumps out that's
9 truly unreasonable.

10 But eventually there will be a complete
11 plant design and a complete plant being built at a
12 particular site. And then they're going to have to
13 come and actually look at this for their site with the
14 actual seismicity at that site so that this is just
15 kind of a screen to say nothing crazy is sitting here
16 that would be bad.

17 But you get it right before you have a real
18 plant with a real, entering real operations. Is that
19 a reasonable statement?

20 MR. VASAVADA: Yes, I believe if I
21 understand you correctly, that is reasonable. And when
22 we get to the conditions of use, you will see that a
23 couple of conditions, actually three of them which I
24 believe speak to what you just provided as a comment.

25 DR. BLEY: Okay. I'd like to see. Thank

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you.

2 MR. VASAVADA: Okay. All right, so as on
3 Slide 22, we've talked about how we looked at the
4 multimodule risk aspect on a couple of other slides.

5 But what we found based on our evaluation again, found
6 that in the risk gap approach, was that the proposed
7 proprietary seismic hazard screening threshold
8 achieves consistency with NUREG 0396 and with WASH-1400
9 in that it results in a complete spectrum of accidents,
10 includes seismic sequences in that spectrum of
11 accidents and again, seismic is the dominant or we
12 expect it to be the dominant distributor.

13 While at the same time it does not penalize
14 NuScale for its mis-profile. Yes, they have reduced
15 the other risks and that is a benefit. And it does
16 not, you can say, provide extra focus to anything more
17 than what was done in 0396 in terms of determining an
18 adequate spectrum of accidents.

19 Nor does it include that extremely unlikely
20 seismic explorations of 2Gs and beyond. The one
21 difference I would point out compared to 0396 or in
22 terms of consistency is that the methodology.

23 And we believe it's appropriate to use as
24 quantified seismic sequences compared to the
25 qualitative approach that was used in WASH-1400. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 believe that's, that is necessary because it is a
2 dominant interest contributor.

3 And since Revision 2, the Topical Report
4 has called for a technically acceptable seismic PI,
5 but that's never been a point of contention. And
6 remember at this point to spend a minute or so hopefully
7 on this particular slide that we think this risk gap
8 approach has broader applicability.

9 Technology clean and close of applicant
10 routines or designers and other technologies to
11 identify what will be the appropriate spectrum and
12 maintain consistency with 0396 in determining if being
13 threshold for the seismic hazard.

14 Because a single one-size-fits-all value
15 may not work, given the technologies that are expected
16 to be out there. It may be too much for cert. Some
17 cases it may be too little for others.

18 The approach as well as pointed out, uses
19 design specific information. One doesn't have to go
20 about developing anything new and it can be used with
21 the metrics of the density LERF reused or risk gap.

22 One can go all the way to consequences and
23 use a consequence gap. And finally, the authority
24 itself can provide regulatory stability. You can get
25 different numbers that are as is usually done for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance, the approach can provide a consistent highly
2 reproducible way of achieving a decision on the seismic
3 screen.

4 I'm moving on to the treatment of
5 uncertainties for the seismic hazard. We will get into
6 the details in the proprietary section, how we have
7 already reviewed which was aided by the regulatory audit
8 in term and the approach and the lower bound threshold
9 for this uncertainty evaluation are sufficient to
10 identify any new risk insights.

11 And address any potential side effects
12 because the window that is adopted by this uncertainty
13 evaluation is large enough on that potential cliff as
14 you have scantily adorned it.

15 Plus the methodology, it brings in these
16 new sequences if they are identified in the evaluations
17 if they are not lost. They're actually comparatively
18 pleasing sizes.

19 For multimodule impacts from the seismic
20 hazard, we'll start with the bottom line of one that
21 we believe the methodology appropriately identifies
22 and includes multimodule impacts on seismic events.

23 We performed the primarily qualitative
24 evaluation and some of the considerations are listed
25 on the slide so. Slide, including the fact that based

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on our risk gap evaluation, the accelerations that were
2 being acquired or reached for at the screening special
3 included those where multimodule impacts are expected.

4 And I think NuScale talked about how
5 multimodule sequences will also be reflected in the
6 source term by amplifying the source term based on the
7 modules and pattern.

8 There's one difference in the seismic
9 multimodule consideration compared to non-seismic
10 which is that there's a screening at 20 minus seven
11 for your, or non-seismic multimodule sequences which
12 is not applied to the same sequences.

13 This is primarily because of the way
14 seismic events are screened and the value compared to
15 non-seismic sequences which can result in double
16 screening if there are, if the 20 minus 7 were to be
17 applied for the seismic hazard.

18 I'm on Slide 26. It's a pictorial of the
19 type of information one can get at different stages,
20 licensing and our FSAR Part 52. And the purpose of
21 this slide is to state that the PR calls for the use
22 of technically acceptable PRA including a seismic PRA.

23 And it's that combined license stage and
24 beyond that one would get that so this Topical Report
25 would essentially be used at the COL stage or beyond

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and we have a condition of use to provide equal and
2 you can say treatment for an operating license under
3 operating.

4 In terms of treatment of the modeling
5 uncertainty, I think NuScale talked about it that
6 there's a section, section 3.8 in the Topical Report
7 which includes a Board discussion of more uncertainty
8 of the need to be considered and disposition.

9 And we appreciate the discussion because
10 if it doesn't overlook any important piece of the items
11 in the, and based on our review, we determined the need
12 for consistency with established guidance for
13 identification and disposition of key assumptions and
14 sources of uncertainty which is Reg Guide 1, 200 and
15 1855.

16 So the Staff has included a corresponding
17 condition of use to achieve that. Next slide. I'm
18 on Slide 28. In terms of the consideration of defense
19 and depth, we find that methodology appropriately
20 identifies the key features that are necessary for doing
21 this defense and depth including SAMGs and then those
22 reaction I went got strategies and flex guidelines.

23 It is consistent with the PRA policy
24 statement and the certain considerations in 1.174 and
25 it also looks at the five levels of defense and insight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and which adds a level of confidence to the defense
2 and depth evaluation.

3 The qualitative defense and depth
4 evaluation as part of this method was.

5 CHAIRMAN REMPE: What flex strategies
6 would be required for, remind me, for NuScale? I mean,
7 are you going to bring in extra water sources or, and
8 if so, to be considered if the connectors are consistent
9 with what's needed for flex strategies?

10 MR. VASAVADA: Marie, you have any idea?
11 Marie?

12 MS. POHIDA: We may have to take that back.
13 I can't remember the specific --

14 MEMBER MARCH-LEUBA: Put your microphone
15 on.

16 MS. POHIDA: -- strategies used for design
17 certification.

18 MEMBER MARCH-LEUBA: Can --

19 CHAIRMAN REMPE: I can't remember either.
20 But it's something I've been thinking about for
21 non-LWRs and what you'd do for flex and that's why when
22 I saw this, it kind of made me wonder. I don't recall
23 us --

24 MEMBER MARCH-LEUBA: Does NuScale know?

25 MR. VASADA: I mean, we have, --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: -- you need to find
2 the microphone.

3 CHAIRMAN REMPE: I'm just curious about
4 flex strategy. Sorry to just talk to the mic, but I'm
5 curious about flex strategies and I can't remember if
6 we talked about flex strategies when we were dealing
7 with the EC review. Did we?

8 And which ones would you use? The other
9 recommenders?

10 MS. ENGLISH: We have --

11 MEMBER MARCH-LEUBA: No, you need to come
12 to microphone here and borrow this.

13 CHAIRMAN REMPE: So maybe you can come up
14 here.

15 PARTICIPANT: There on the floor which
16 side I see, indeed. See this mic is all ready.

17 PARTICIPANT: Just say who you are.

18 MS. ENGLISH: Hi, this is Liz English from
19 NuScale. The DCA did cover, addressed flex although
20 it's not a requirement of the design certification.
21 But in our Chapter 20 of the DCA, bottom line, is you
22 don't need to implement other than just keeping the
23 pool water adequate.

24 CHAIRMAN REMPE: So you dump it in a pool?
25 You don't need any connectors in the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. ENGLISH: It's already in the pool.

2 CHAIRMAN REMPE: Okay. That helps, thank
3 you.

4 MS. ENGLISH: You're welcome.

5 DR. BLEY: In that -- this is Dennis. In
6 that whole area, I remember we asked if they would be
7 participating in flex and I don't think we ever got
8 an answer on that from NuScale.

9 MS. ENGLISH: Right. And I believe that's
10 because it is not the design certification function
11 to look at, I'm not going to say this the right way.
12 Flex is a requirement of the licensee or the license
13 holder and not the design center.

14 CHAIRMAN REMPE: So when you have this on
15 your slide, you thought about what was going to be dumped
16 into the stint fuel pool is what gave you confidence
17 to say that you considered consideration or are you
18 just are repeating something that was in their Topical
19 Report?

20 MR. VASAVADA: So yes, we are including
21 something that is in Topical Report, but what we're
22 trying to say is that its own features and operational
23 characteristics considered for a defense and depth
24 evaluation include MGs and flex.

25 It's not like excluded. It's the entire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plan defense and depth that is considered. That is
2 what we are trying to say.

3 CHAIRMAN REMPE: Okay.

4 MR. VASAVADA: Thank you, Liz. I'm going
5 to Slide 29. So I'll talk about the Staff's conditions
6 of use. Based on our review and to ensure that the
7 key importance to the methodology and our findings are
8 addressed by the user of the Topical Report, we included
9 eight conditions of use.

10 The Slide 29 summarizes them. The exact
11 language is in the safety evaluation. At this point,
12 quickly go through them. So alpha is there to ensure
13 consistency between an operating license under Part
14 50 and a COL under Part 52.

15 Currently there's a need to ensure the
16 sense of consistency. Bravo talks about consistency
17 with an NRC guidance for technical acceptability.
18 Charlie is to demonstrate the treatment of key
19 assumption sources of uncertainties consistent with
20 NRC guidance.

21 Delta and Echo are about making sure that
22 the site, actually the GMRS is bounded by the NuScale's
23 CSDRS. And that the plant level fragility is in fact
24 attuned to the value that was in the DCN that was used
25 for the Staff's evaluation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And foxtrot talks about the demonstration
2 of both of those items, GMRS and HCLPF plant level for
3 duty at both application and prior dose load so I think
4 that I go and foxtrot together speak to the comment
5 that Member Bley had earlier about having a plant
6 specific demonstration that the assumptions and inputs
7 are actually valid.

8 Golf talks about the 120 degrees of the
9 200 REM dose exceedance curve as you remember Elijah
10 talked about and Marie did too, how 0396 states that
11 the consequences of severe accidents degrees
12 substantially.

13 And she informed the curve is important
14 so golf, make sure that the shape of the curve is not
15 overlooked by either the Applicant or Staff. And hotel
16 is speaking to the principle of the performance
17 monitoring in risk informed decision making so it calls
18 for a periodic evaluation to make sure that like there
19 with HCLPF.

20 It is indeed what it was at the beginning
21 of the plant's life and that the conclusions from the
22 EPZ sizing methodology conclusion remain valid as the
23 plant changes or changes are made to the plant over
24 the lifetime of the plant.

25 MEMBER KIRCHNER: Let me explore number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 G, golf.

2 MR. VASAVADA: Okay.

3 MEMBER KIRCHNER: How do you measure,
4 obviously in 0396 their Appendix I, that curve or that
5 ten miles has a sharp drop off. But as we pull or
6 potentially as the EPZ shrinks, will we see such a steep
7 drop off?

8 I don't know, have you kind of calculated
9 that out or has the NuScale curves convinced you that
10 we'll see the same thing if the calculations suggest
11 that the 200 REM threshold, I'm just thinking, how do
12 you measure that?

13 I know what you mean by that versus Appendix
14 I 0396, that curve has a steep fall off. But I think
15 what we're going to see is people are going to use a
16 methodology like this and be pulling in the -- I project
17 that the EPZs will come in.

18 We saw this with the early site permit work
19 for Clint River, you know, within a mile or so, but
20 what I don't know and maybe you've looked at this with
21 MACCS, do you see that same kind of steep fall off?

22 Because the general take away from 0396
23 is and I'll quote, that the EPZ should be a sufficient
24 size to provide substantial reduction in the early other
25 if that's in the event of a more severe Class 9 accident.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now I think that's what you're getting at,
2 but gee, I'm just curious how you measure that. So
3 you're looking at the shape of a curve or are you looking
4 again at some uncertainty in the shape of a curve or
5 how do you achieve that substantial reduction?

6 In other words, it's just like the existing
7 dose ends and can see afar 50 and 52. I mean, the idea
8 is not to run up to 25 REM in two hours.

9 It's to be substantially below so how in
10 your mind do you think there's enough conservatism in
11 the methodology such that the public will be
12 substantially protected by this guidance?

13 MR. VASAVADA: I think Elijah has his hand
14 up. I'll let him go first and then I can --

15 MR. DICKSON: Yes, I, this is something
16 of considerable discussion with the Staff. The way
17 it's addressed in 0396 is rather qualitative. Right?

18 That they look at the curve and they see that it drops
19 off quite quickly.

20 Our, I think our concern was we don't want
21 to see curves that have like sawtooth-type shapes or
22 ones that kind of just asymptotically decrease. We
23 don't want to see curves that may increase.

24 You know, it's hard to say what the, I use
25 the word measure and I, it's a bit more qualitative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 than that. You know? It's hard to perceive what types
2 of curve we would be seeing.

3 And it, if we don't, it would be a
4 collective Staff decision in regard to whether or not
5 that proposed EPZ would be acceptable if they have
6 something that differs drastically from what you're
7 seeing in 0396.

8 MEMBER PETTI: So Elijah, the decrease,
9 Appendix I, is that tied to just fall out from a plume?

10 MR. DICKSON: Yes, it's --

11 MEMBER PETTI: Yes?

12 MR. DICKSON: -- for the most parts, it,
13 for the most part, it's the meteorology and the
14 transport calculations that have a fall off that way.

15 MEMBER BIER: Yes, I have a follow up
16 question on that condition G which is can you talk about
17 which features would potentially lead to an increase
18 or saw-tooth nonmonotonic shape? How would that come
19 about?

20 MR. DICKSON: I do not know. I do not have
21 an answer for that question.

22 MEMBER BIER: So for now it's just stated
23 kind of --

24 MEMBER KIRCHNER: I can give an example
25 I think.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BIER: Okay, great.

2 MEMBER KIRCHNER: In answer to your
3 question. A near, if it really theoretically when you
4 calculate it came in very close, then building wake
5 effects and such will give you a different shaped curve
6 than a traditional plume description.

7 And so you may have a drop off and then
8 an increase. And then a fall off. Depending how close
9 you are so then using ARCON or something --

10 MEMBER BIER: Okay.

11 MEMBER KIRCHNER: -- near end might be an
12 important consideration. I don't know, does MACCS use
13 ARCON for close in distance or I'm trying to remember.

14 Are you just, it's just a classic plume dispersion?

15 MR. DICKSON: I do believe it's been
16 included now. I think we have one of our MACCS experts,
17 Keith Compton, on the phone on standby. He's here.
18 Keith?

19 MR. COMPTON: Yes, I, can you hear me?

20 MR. DICKSON: Yes.

21 MR. COMPTON: Yes. So yes, just so a few
22 comments. Yes, we have --

23 MEMBER KIRCHNER: Keith, just identify
24 yourself first please.

25 MR. COMPTON: I'm sorry. This is Keith

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Compton from the Office of Research.

2 MEMBER KIRCHNER: Okay.

3 MR. COMPTON: Yes, we have recently
4 upgraded MACCS to improve its near field capabilities
5 and you can include models that are comparable to the
6 ARCON model or to the full reg at 1.145 model at shorter
7 distances.

8 And that would help you as I believe one
9 of the members mentioned. Yes, if you had, if you had
10 a close-in distance and you had an elevated release
11 or plume rise or something like that, you could actually
12 have low, you know, kind of a low dose close in.

13 It would rise when you got plume impaction
14 and then it would start dropping so yes, certainly you
15 can have any number of different shapes on that curve.

16 MEMBER BIER: Yes, the high elevation
17 release is another one that occurred to me. It starts
18 out high with a low dose and it drops eventually, but
19 --

20 MR. COMPTON: That's right.

21 MEMBER BIER: Thank you.

22 MEMBER KIRCHNER: Thank you, Keith.

23 MR. DICKSON: Any other questions on that?

24 MEMBER HALNON: On the earlier question
25 on peer review for the PRA and the technical aspect,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 did you all have a discuss about what, how far that
2 needs to go and how much it needs to look like the
3 traditional peer reviews?

4 MR. VASAVADA: I'll, pardon my, what we
5 did on way back along. If you look at OR, a condition
6 of use, bravo, is basically asking for consistency with
7 the established guidance for PR technical acceptability
8 which will include the peer review.

9 We do recognize that at certain stages in
10 the design, or when this article of methodology is used,
11 not every aspect of the supporting requirements as they
12 are called for the PRS standard can be excused.

13 For example, operating experience. NSRC
14 does talk about how when the results of seismic tech
15 was of a review being formed by what's called a ISG
16 028 which talks about making allowances for such cases.

17 MEMBER HALNON: Okay, --

18 MR. VASAVADA: There's nothing like --

19 MEMBER HALNON: -- depending on what stage
20 they're in. Thanks.

21 MR. VASAVADA: Anything else?

22 MEMBER KIRCHNER: Marie, I don't want to
23 cut out questions. Can you do your conclusion and then
24 I'll go around? Because we've run --

25 MR. VASAVADA: No, no, go ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: -- over.

2 MR. VASAVADA: Okay, no, no, go ahead.

3 MEMBER KIRCHNER: Okay. If you want to
4 conclude. We've run over a little bit on time.

5 PARTICIPANT: Walt.

6 MEMBER KIRCHNER: Thank you. We've gone
7 over a little on time, but that's okay. We're asking
8 questions that we might have asked later. Could you
9 just go through your conclusions and then we'll go
10 around and ask for Member questions.

11 MR. VASAVADA: Absolutely. So on Slide
12 30, this provides kind of the overarching conclusions
13 that the Staff primarily Maria, Elijah, and I would
14 support from those acute reach.

15 We found that the Topical Report
16 methodology is generally consistent with the underlying
17 basis in 0396 and it provides a reasonable assurance
18 that the methodology is adequate for assessing the plume
19 exposure causeway emergency planning zone ties.

20 Obviously, the applicants have to meet the
21 scope of applicant ready in Section 2.5 which defines
22 the characteristics for the NuScale design and it's
23 definitiveness and the conditions of use in Section
24 5 of the Staff's safety evaluation.

25 We also think that the NuScale EPZ TRA is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 indeed of this conformed and reflective of the
2 underlying approach in 0396. It meets all of the
3 principles of risk informed decision making either on
4 its own or in conjunction with the Staff's conditions
5 of use.

6 And I'll end by providing some caveats.
7 I think they're important. Firstly, the methodology
8 and the Staff's findings are applicable only to this
9 TR for EPZ sizing and they do not extend to the design
10 and operation or licensing.

11 The QHOs are applicable to those and they
12 also do not cover other aspects of emergency planning
13 besides these. On the screen thresholds are only
14 applicable for this particular methodology not for the
15 underlying PR development which needs to follow either
16 endorsed PRA standards or justified alternates.

17 And finally, the Staff is not making or
18 defining what is meant by credible events or any hazard
19 through the screening thresholds for this particular
20 Topical Report.

21 That's outside the scope of the Topical
22 Report and we are not making any findings of that.
23 That I'll end and open up for any questions. Thank
24 you.

25 MEMBER KIRCHNER: So let me turn to Dave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 first. Thank you.

2 MEMBER PETTI: So you know, my sense is
3 that a, this is an incredibly important topic for the
4 advanced reactors -- adding the NuScale. Others are
5 going to look to this.

6 And it seems like you guys have really
7 broken ground in terms of kind of connecting dots
8 between what was then in 0396, what the intent of 0396
9 was and how to turn that into something more
10 quantitative for today with today's tools, today's PRA
11 capabilities.

12 I just think some of these nuggets need
13 to be in guidance somewhere. That the Topical Report
14 is good, as long as you can make sure you don't, you
15 know, touch on proprietary stuff with NuScale.

16 I think what you guys have done deserves
17 a little bit more elevation in the infrastructure of
18 this. One Member's thoughts.

19 MR. VASAVADA: Thank you.

20 MEMBER KIRCHNER: Other Members?

21 MEMBER DIMITRIJEVIC: Walt?

22 MEMBER KIRCHNER: Yes, go ahead Vesna.

23 MEMBER DIMITRIJEVIC: Well I've kept
24 actually too many questions to ask so I decided that
25 are we going to have additional, I was looking at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 schedule, meeting on this because this is before we
2 write the letter.

3 MEMBER KIRCHNER: So what I would propose
4 here is we still need to allow for public comment.
5 If you have questions, that's good. Hold onto them,
6 Vesna, because I think we would be best served if we
7 go into a closed session and proceed then. Can you
8 hold onto those questions until then?

9 MEMBER DIMITRIJEVIC: I can hold on
10 actually which I was going to do is actually take some
11 -- because I went through all these documents except
12 that I didn't really went through the NUREG 03, you
13 know, the 396 and see how it complement to the WASH-1400
14 to see how this all fits together. So I have already
15 the question which starts with this very high-level
16 picture.

17 And then I was going to devote more time
18 in my own research before I, you know, reduced the
19 questions. So I was just wondering how own schedule.

20 But I will check on that much during the break so

21 And then I will decide when should I, you
22 know, ask my questions. All right?

23 DR. BLEY: Well, it's not, Vesna, you're
24 not going to find it on the rainbow chart.

25 MEMBER KIRCHNER: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR BLEY: It's going to be the next full
2 Committee meeting. There's going to be another --

3 MEMBER KIRCHNER: In October.

4 DR. BLEY: Yes, another meeting like this
5 going a little further. Right?

6 MEMBER DIMITRIJEVIC: Well, yes, I was
7 going to check on the AWS, when do we write letter on
8 this and how --

9 MEMBER KIRCHNER: It's --

10 MEMBER DIMITRIJEVIC: -- this will look
11 like.

12 MEMBER KIRCHNER: -- in the October full
13 Committee meeting. So it would --

14 MEMBER DIMITRIJEVIC: So that's what it
15 is, okay.

16 CHAIRMAN REMPE: Vesna, there was supposed
17 to have been an extra meeting on September 1st or 2nd,
18 I forgot which day. And we moved it into this full
19 Committee meeting. Remember?

20 And we did that because of various reasons,
21 but anyhow, this is what would have been the
22 subcommittee meeting, but always this has been proposed
23 for a topic for October full committee letter writing
24 as indicated on the AWS. Okay?

25 MEMBER DIMITRIJEVIC: Okay. All right,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's good to know. Okay, so I will hold on to my
2 questions to then today and then hopefully I can use
3 them myself. All right?

4 MEMBER KIRCHNER: Okay, thank you. Other
5 members?

6 CHAIRMAN REMPE: Yes, a couple of things.
7 Maybe the answers are kind of related to this adequacy
8 of the peer review and guidance, but I also believe
9 that this is like a start of something new or you might
10 have a much smaller EPZ.

11 And so the questions I raise to NuScale
12 are the kind of ones that I am interested in the Staff's
13 thoughts on this because one, to me it seems like the
14 adequacy of the MELCOR model that was used for the design
15 certification is suddenly becoming, the integrity of
16 that model might become more important since you're
17 deciding on whether you need to think about the size
18 of the EPZ.

19 And so I'm just curious if maybe in that
20 guidance you might say we need to think more carefully
21 in the peer review of what and it's just one Member's
22 comment, but I am interested if you're thinking about
23 that because suddenly if I, this is just a review of
24 the Topical Report, but someone comes in and says, I
25 want to have it to be the plant boundary and follow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EPZ.

2 So I don't need to worry about any sort
3 of emergency planning and they don't do what is in the
4 NEI report to think about how to expand for emergency
5 planning.

6 I might have a different view of the this
7 than I do for something that's theoretical. And have
8 you thought about where this is going and maybe this
9 is beyond the scope of your review for the Topical
10 Report, but I'm just a little concerned and I'm curious
11 to hear your thoughts on it.

12 MR. VASAVADA: Hello, this is Shilp. From
13 my point of view, I think the items that you are talking
14 about they will part of the review somewhere else, maybe
15 in the scope of the SDR or DCA or some other speaker.

16 And then they'll flow into this Topical
17 Report because I mean, at the end of the day, they have
18 to use the underlying PRA morals which have been record
19 either by the Staff or through the peer review process.

20 Which in the peer review process and PRA
21 standard, does have specific supporting requirements
22 for the containment and all methodology in the Level
23 I are kind of aspects.

24 CHAIRMAN REMPE: Okay, we were reviewing
25 this very accident phenomena when we were reviewing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the severe accident phenomena for something that was
2 a very low frequency even though there wasn't a lot
3 of data.

4 We might have said, okay, it's a low
5 frequency, but now suddenly there's this screening
6 frequency. I've heard you talk about the non-seismic
7 hazards that though a spectrum of events and having
8 a bypass failure for a more severe accident being the
9 dictating.

10 Well maybe we might have, so maybe we need
11 more integrity in the MELCOR vessel failure model or
12 the containment vessel failure model. And I just am
13 wondering if what we thought was okay for some things
14 if we, in our mind we thought well we'd always have
15 some sort of sight emergency planning in place.

16 You get where I'm going? I'm sorry if I'm
17 too vague on what I'm trying to say here.

18 DR. BLEY: Well I think it's, Joy. This
19 is Dennis.

20 CHAIRMAN REMPE: Yes.

21 DR. BLEY: This, maybe the Staff will
22 comment on this a little bit. 0396 essentially points
23 to we got to be real careful on things that we think
24 are very low and at least have an idea that we'll be
25 able to reduce the consequences if any of those happen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I, from what you folks have said and
2 written, I think that's where you're headed. If
3 there's even a, what appears to be extremely low
4 frequency event, you want to be somehow convinced that
5 it will be possible to take steps immediately following
6 an accident to deal with those and that there's an
7 infrastructure to support that. Is that the reason
8 for --

9 CHAIRMAN REMPE: Well okay, I look and it's
10 not in the proprietary markings of the Topical Report,
11 but for the more severe accidents, they only considered
12 bypass failures. They didn't and so how big was the
13 release?

14 Did they really have a severe accident?
15 From what I recall from the DC, no they didn't have
16 the orb out of the vessel into the containment. I just
17 wondering if you, did your spectrum of accidents
18 consider that or was that just below the threshold?

19 And I again, I know that the containment
20 failure thing was very little data to support that
21 analysis. It was okay for the DC, yes, you're going
22 where I'm going, Dennis, about saying do they still,
23 will they still have the capability and will that still
24 be considered? And it's in the NEI document.

25 MS. POHIDA: I'd like to take a stab at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that and I recall what you're discussing. Because
2 there was a lot of discussion during design
3 certification of NuScale design regarding issues on
4 in-vessel retention.

5 So now I would anticipate that those issues
6 would be re-evaluated during, you know, the standard
7 design review.

8 CHAIRMAN REMPE: Yes, because it's a
9 higher power. I would hope so. But if this, again,
10 when we're doing this, I hope people realize that
11 someday we may need more integrity in the PRA than we
12 need if they're going to say that the emergency planning
13 zone is a site boundary.

14 MS. POHIDA: Yes, now this is the Topical
15 Report so we're reviewing the process, but when it comes
16 well not logical uncertainties like we're discussing
17 regarding in-vessel retention that were evaluated and
18 designed, you know, in design cert and I anticipate
19 it will be re-evaluated under SDA approval.

20 They will, they would be considered, they
21 could be potentially considered as sources on
22 certainty. You know, that would have to be
23 re-evaluated in this Topical Report as it impacts the
24 results.

25 CHAIRMAN REMPE: Yes, the -- again, maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the SDA just like the DC would make it through that
2 hoop if we don't consider that there's this, they may
3 not have an emergency planning zone option.

4 And we might, what I'm wondering is if like
5 Dave was saying, maybe some guidance is needed for
6 accident event selection. Maybe we ought to say that
7 we get, somebody may say I want a 25 mile emergency
8 planning zone or ten mile or whatever.

9 But maybe that there needs to be some
10 guidance about and you've said that we want a spectrum
11 of events not just cut off frequency and that would
12 be a good way to address what I think is my concern.

13 And then having a peer review of the
14 phenomena for addressing that concern for this would
15 be something that would help too. But again, maybe
16 that's the ultimate answer is having some sort of
17 guidance document that say there's an additional
18 considerations because if an applicant comes in and
19 says I don't need an emergency planning zone.

20 Does that make sense and what are your
21 thoughts on something like that?

22 MR. VASAVADA: This is Shilp. I think we
23 will have to take that back. I mean, the point about
24 guidance, yes, it makes sense, but and we'd have to
25 take that back electively and make a decision of where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we land and how do we need this? I don't think at least
2 I can give you an answer right now.

3 CHAIRMAN REMPE: It's beyond the scope of
4 this Topical Report although we can say guidance is
5 needed in our letter if that's what the Committee wants.

6 But I just think that where this is going
7 that the Staff may want to think about it and how to
8 anticipate what could occur for something like this
9 in some cases.

10 MEMBER PETTI: I still anticipate that the
11 advanced reactors will engineer away the internal
12 events if you will. And that's why the seismic stuff
13 here is so important because it really sort of breaks
14 some new ground and it's going to dominate I think when
15 you look at the advanced reactors.

16 CHAIRMAN REMPE: But there's always the
17 unknown unknowns and then if you can have a way to say
18 --

19 MEMBER PETTI: It's like, Joy, but Joy,
20 we're supposed to be risk informed. The unknown
21 unknowns out there at a level, right now, was it forward
22 as a magnitude and frequency between the internal events
23 and the seismic. Okay, we're off.

24 By a factor of a hundred, by a factor of
25 a thousand and seismic still dominates. And that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the perspective --

2 CHAIRMAN REMPE: Right.

3 MEMBER PETTI: -- that I think we just have
4 to keep in mind.

5 CHAIRMAN REMPE: And what I believe in
6 analysis that --

7 MEMBER PETTI: Well we --

8 CHAIRMAN REMPE: -- but unplanned things
9 happen and then I want to be able to expand.

10 MEMBER PETTI: But Joy, you can't, you
11 can't in my opinion, you can't, you can't regulate
12 unknown unknowns.

13 CHAIRMAN REMPE: But you need to have the
14 take that the --

15 MEMBER PETTI: And it depends on --

16 CHAIRMAN REMPE: -- NEI said.

17 MEMBER PETTI: What do you mean, what do
18 you mean, I didn't understand what you meant by the
19 capability to expand.

20 CHAIRMAN REMPE: That's what's in the NEI
21 documents and the --

22 MEMBER PETTI: Well, tell me what that
23 means.

24 CHAIRMAN REMPE: -- Topical Report.

25 MEMBER PETTI: But I don't understand what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that means.

2 CHAIRMAN REMPE: Means that you make sure
3 that the outside agencies and that there's some way
4 of path even though you don't have drills, it means
5 you have a path and you've thought about it somehow.
6 What you would do --

7 MEMBER PETTI: To make sure that, to make
8 sure -- so similar to what we've already been doing.

9 CHAIRMAN REMPE: Absolutely.

10 MEMBER PETTI: Okay.

11 CHAIRMAN REMPE: That's where I'm going.

12 MEMBER PETTI: I just didn't understand
13 that logic and --

14 CHAIRMAN REMPE: That's where I'm going
15 and I -- just thinking of the future where it could
16 go. Okay?

17 MR. VASAVADA: I just wanted to add again
18 --

19 CHAIRMAN REMPE: Sorry we're arguing.

20 MEMBER PETTI: No, we're not.

21 MR. VASAVADA: Because you brought up
22 this, the Topical Report is only for the EPZ sizing
23 and then some EPZ that need to be met after the, after
24 we --

25 MEMBER DIMITRIJEVIC: Sorry, I cannot hear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you.

2 MEMBER KIRCHNER: Use your mics please.

3 CHAIRMAN REMPE: Okay. You'll have to get
4 close to your mic.

5 MR. VASAVADA: Okay. I just wanted to
6 reiterate that this Topical Report and the slide, on
7 the side this is Shilp Vasavada from the NCR Staff.
8 The Topical Report is only about EPZ size.

9 CHAIRMAN REMPE: I agree.

10 MR. VASAVADA: The other elements of EP,
11 emergency planning, are not within the scope. They
12 still have to be met, regulations still have to --

13 CHAIRMAN REMPE: But right now we're
14 looking at everybody wants to try and reduce what the
15 requirements are and I'm just looking at where it's
16 all kind of coming together and pointing toward that
17 additional review of the phenomena is also one of the
18 things that it falls into that.

19 DR. SCHULTZ: This is Steve Schultz. The
20 major requirement here is that the applicant has to
21 perform a site specific seismic PRA and use this
22 technical report to perform the evaluation to determine
23 whether they can do anything associated with the
24 emergency planning zone limits.

25 MR. VASAVADA: Not just seismic. You're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 right. But also site specific PRA is part of the --

2 DR. SCHULTZ: Yes, and it has issues too.

3 MR. VASAVADA: -- part of the NuScale.

4 DR. SCHULTZ: But that all has to be done
5 as part of the application.

6 MR. VASAVADA: Correct.

7 DR. SCHULTZ: As you indicated in the
8 safety evaluation.

9 MR. VASAVADA: That's correct and the
10 conditions of use have to be met so an applicant has
11 to demonstrate all of that.

12 MEMBER KIRCHNER: Other questions? At
13 this point let me take a pause here and turn to the
14 public. This is an opportunity for public comment.
15 If you would like to make a comment, please state your
16 name and make your comment.

17 And I think for those of you on Teams, just
18 unmute your microphone and for those of like listening
19 in for on the bridge line, I think you have to press
20 star six to unmute.

21 We have about 15 seconds here for someone
22 to make a comment. I'm not hearing anyone out there.

23 One last time, any public comments? Okay, thank you.

24 At this point, I think we need to take a break.

25 We have from both the applicant and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Staff closed presentations. There's none, I don't know
2 if you during the time of the break and organize your
3 questions, but this will give you another opportunity
4 if you have some questions that you would like to ask
5 today before next month when we go to a letter writing
6 exercise.

7 MEMBER DIMITRIJEVIC: Yes, after I hear
8 --

9 MEMBER KIRCHNER: So with that --

10 MEMBER DIMITRIJEVIC: Yes. Right after
11 I hear the new schedule presentation too. Okay?

12 MEMBER KIRCHNER: Okay. So with that, let
13 us close the open session, take a break for 15 minutes
14 and then come back and we'll be in closed session for
15 those presentations and any final questions. Okay,
16 Larry, yes, I see your hand up. Thank you.

17 MR. BURKHART: Yes, I just wanted to say
18 that depending on what the Chairman and the Committee
19 decide, the Committee may go into letter report writing
20 and later on and that would be in the public. So we
21 may be back --

22 MEMBER KIRCHNER: Yes.

23 MR. BURKHART: -- on this line so I don't
24 know if the Chairman wanted to say anything about that.

25 CHAIRMAN REMPE: It depends on how long

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it takes. I'd rather just hold off if that's okay,
2 Larry.

3 MR. BURKHART: Oh, it's totally up to the
4 Committee. There is the option of going to report
5 writing if things do --

6 MEMBER MARCH-LEUBA: Keep it open. Keep
7 the possibility open.

8 MR. BURKHART: Yes.

9 CHAIRMAN REMPE: Yes, keep the possibility
10 open.

11 PARTICIPANT: Keeps us out on that.

12 CHAIRMAN REMPE: Yes, and just somebody
13 can maybe you could get Quynh to -- or you could put
14 some messages out, Larry.

15 MR. BURKHART: We can do that. We'll do
16 that.

17 CHAIRMAN REMPE: Thank you.

18 MEMBER KIRCHNER: Thank you. We are on
19 recess for the moment.

20 (Whereupon, the above-entitled matter
21 went off the record at 3:48 p.m.)
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

NuScale Nonproprietary

1



Emergency Planning Zone (EPZ)

Licensing Topical Report (LTR)
ACRS Subcommittee Meeting
(Open Session)

September 8, 2022

Liz English, Licensing Supervisor
Jeremiah Doyle, EPZ Technical Lead, PRA

Acknowledgement and Disclaimer

This material is based upon work supported by the Department of Energy under Award Number DE-NE0008928.

This presentation was prepared as an account of work sponsored by an agency of the United States (U.S.) Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

Agenda

- Purpose
- Introduction
- Overview of NuScale topical report TR-0915-17772, Revision 3
- Summary

Purpose

- Present content of NuScale topical report TR-0915-17772, Revision 3
- Provide a general understanding of the NuScale method to identify a spectrum of accident sequences and the associated severe accident and dose consequence analyses that form the basis for sizing plume exposure pathway (PEP) emergency planning zones (EPZs) surrounding NuScale plant sites

Introduction

- Topical report provides a method for determining the size of the off-site PEP EPZ surrounding NuScale plant sites
- Applicable to NuScale small module reactor (SMR) designs only
- Consistent with the technical basis in NUREG-0396 and WASH-1400
 - Identifies and evaluates a spectrum of accident sequences and potential releases
 - Satisfies the same dose criteria at and beyond the EPZ boundary to provide an equivalent level of protection to the health and safety of the public
 - Risk-informed, consequence based method based on a combination of quantitative evaluation and qualitative engineering judgement
- Implements state-of-the-art codes and methods established in the 40+ years since the development NUREG-0396 and WASH-1400
- Designed to be self-contained, consistent, and repeatable


Conditions of Applicability

- Applicable to only the NuScale SMR designs
 - small modular integral pressurized light water reactors,
 - operating modules partially immersed in water that serves as the ultimate heat sink (UHS),
 - the UHS is retained below grade in a structure with up to 12 reactor modules per UHS,
 - a safe shutdown earthquake with a peak ground acceleration of 0.5g, and
 - structures, systems, and components (SSCs) capable of performing their safety functions without AC electric power, DC electric power, or operator actions for at least 72 hours following a design basis event.
- The following conditions apply to the PRA used in implementing the EPZ methodology:
 - Condition 1: The PRA addresses internal and external hazards and all operating modes
 - Condition 2: The PRA is demonstrated to be technically acceptable for this purpose

Overview of the NuScale EPZ Method

- Quantitative evaluation
 - Identify the spectrum of accidents sequences that form the basis of EPZ sizing
 - Core damage design basis source term (DBST) from final safety analysis report (FSAR) Ch 15
 - Probabilistic risk assessment (PRA) single and multi-module sequences from FSAR Ch 19
 - Other radiological releases outside of the DBST and PRA
 - Identify accident severity
 - Calculate the time-dependent source term to the environment
 - Final EPZ distance is the smallest distance at which all dose criteria are satisfied
 - Criterion a – total effective dose equivalent (TEDE) dose from the DBST ≤ 1 rem mean and 5 rem 95th percentile
 - Criterion b – TEDE dose from less severe accidents ≤ 1 rem mean and 5 rem 95th percentile
 - Criterion c – substantial reduction in early health effects, acute whole body dose from more severe accidents ≤ 200 rem
- Qualitative evaluation
 - Evaluation of plant-level defense-in-depth against INSAG-10 and RG 1.174
 - Review and disposition of key assumptions and uncertainties in the underlying PRA

Overview of the NuScale EPZ Method Quantitative Evaluation



Spectrum of Accidents

- Design basis source term (DBST) from FSAR Ch 15
- Severe accidents from the site and design-specific PRA
 - Identify non-seismic single module and multi-module sequences with core damage frequency (CDF) $\geq 1E-07$ per year
 - Screening at $1E-07$ captures a spectrum of accidents with similar frequencies to the EPZ basis in NUREG-0396
 - Use of CDF as the screening mechanism conservatively ignores the conditional probability of radionuclide release
 - Non-seismic sequence uncertainty against screening threshold considered consistent with NUREG-1855
 - Retain sequences with point-estimate CDF $> 1E-08$ and 95th percentile CDF $> 1E-07$
 - Ensures cliff-edge sequences are captured in the spectrum of accident sequences
- Other releases – potential radionuclide releases not captured by the DBST and PRA
 - For example: spent fuel pool risks or mechanical damage to the fuel
 - One of the following criteria are met
 - The release meets the dose-based criteria for the appropriate accident severity
 - The consequences of the release are bounded by the DBST and screened-in PRA sequences
- Accident severity
 - Intact containment accidents are less severe
 - Containment failure or bypass accidents are more severe

Off-site Dose Consequences

- Dose criteria provide level of protection to the public that meets or exceed the basis in NUREG-0396
 - Criterion a – total effective dose equivalent (TEDE) dose from the DBST \leq 1 rem mean and 5 rem 95th percentile
 - Criterion b – TEDE dose from less severe accidents \leq 1 rem mean and 5 rem 95th percentile
 - Criterion c – substantial reduction in early health effects, acute whole body dose from more severe accidents \leq 200 rem
- Modeling of dose receptors consistent with the NUREG-0396 basis
 - Stationary individual located:
 - outdoors
 - in the azimuthal direction of maximum exposure
 - at and beyond the site boundary distance
 - No sheltering, relocation, or evacuation
 - Cloudshine, groundshine, inhalation, resuspension inhalation, and skin deposition dose pathways
 - No shielding from cloudshine, inhalation, and skin deposition
 - Natural groundshine shielding due to variations in terrain
 - 96 hour exposure for TEDE, 24 hour exposure for acute red marrow
 - Parametric evaluation of uncertainty in source term and dose calculations

Defense-in-Depth Evaluation and Review of PRA Uncertainties

- Defense-in-depth evaluation using the guidance in INSAG-10 and RG 1.174
 - Highlight design features and SSCs available to prevent and mitigate the consequences of postulated accidents
 - Confirms the existence, functionality, and capability of features and strategies to provide confidence in the acceptably low plant risk and demonstrate protection of the health and safety of the public
- Review of PRA Uncertainties
 - Complete a review of the assumptions and sources of uncertainty in the underlying PRA to identify and address any potential impact to EPZ sizing
 - Key assumptions in the PRA
 - Model uncertainty
 - Completeness uncertainty

Summary

- Topical report provides a method for determining PEP EPZs surrounding NuScale plant sites consistent with the EPZ technical basis in NUREG-0396 and WASH-1400
- Provides a level of protection to the public that meets or exceeds the NUREG-0396 EPZ basis
- Applicable to NuScale SMR designs only

Acronyms

CDF	core damage frequency
DBST	design basis source term
EPZ	emergency planning zone
FSAR	final safety analysis report
LTR	licensing topical report
PEP	plume exposure pathway
PRA	probabilistic risk assessment
RAI	request for additional information
SMR	small modular reactor
SSC	structures, systems, and components
TEDE	total effective dose equivalent
UHS	ultimate heat sink




Staff Presentation to the ACRS Sub-Committee

NuScale Licensing Topical Report

Methodology for Establishing the Technical Basis for Plume Exposure Emergency Planning Zones at NuScale Small Modular Reactor Plant Sites (TR-0915-17772, Revision 3)

Open Session

SEPTEMBER 8, 2022



Topical Report Review Chronology

- NuScale submitted topical report TR-0915-17772, Revision 2, “Methodology for Establishing the Technical Basis for Plume Exposure Emergency Planning Zones,” on August 4, 2020
- NRC issued requests for additional information (RAIs) 9828 and 9830 in April 2021
- Initially, TR was applicable to light-water small modular reactors (SMRs) and non-light water reactors (non-LWRs). In May 2021, in response to RAI 9830, NuScale removed applicability to non-LWRs.
- NRC performed a regulatory audit as part of its review of the methodology in Revision 2, from November 2021 to April 2022
- NuScale provided response to RAI 9828 and submitted Revision 3 of the TR on June 10, 2022, titled “Methodology for Establishing the Technical Basis for Plume Exposure Emergency Planning Zones at NuScale Small Modular Reactor Plant Sites,” applicable only to the NuScale design and its derivatives and incorporating the RAI responses
- NRC issued the advanced safety evaluation on August 8, 2022



NRC Staff

Reviewers:

- Marie Pohida, Sr. Reliability and Risk Analyst, NRR/DRA/APLC
- Shilp Vasavada, Sr. Reliability and Risk Analyst, NRR/DRA/APLC
- Elijah Dickson, Sr. Reliability and Risk Analyst, NRR/DRA/ARCB
- Raymond Hoffman, Emergency Preparedness Specialist, NSIR/DPR/RLB
- Todd Smith, Sr. Level Advisor for Emergency Preparedness, NSIR/DPR

Project Managers:

- Alina Schiller, TR Project Manager, NRR/DNRL/NRLB
- Getachew Tesfaye, Sr. Project Manager, NRR/DNRL/NRLB

Outline

- Regulatory and technical basis for staff's evaluation
- Overview of TR methodology
- Dose-distance criteria and figures-of-merit (FoMs)
- Source term and consequence assessment
- Screening of Probabilistic Risk Assessment (PRA) sequences
- Treatment of uncertainty
- Conditions of use



Regulatory and Technical Basis for Staff's Evaluation

10 CFR 50.47, Appendix E to Part 50, 10 CFR Part 20

NUREG-0396 (1978)

Probabilistic Risk Assessment (PRA) Policy Statement

SRM-SECY-98-144

RG 1.174

RG 1.200

NUREG-0396 (1978)

- Identifies the purpose of the EPZ
 - Area within which prompt protective actions may be necessary to provide dose savings in the event of a radiological release
- Technical basis for current prescribed plume exposure pathway EPZ radius of 10 miles
- Based on a review of licensed design-basis events and a spectrum of accident sequences from WASH-1400

Staff's Method of Review

- Consistent with technical basis in NUREG-0396
- Consistent with risk-informed decision making and use of PRA in risk-informed applications
- Supported by regulatory audit
 - Included example calculations implementing nearly entire methodology



Staff's Review of Applicability of NuScale's EPZ TR Methodology

- Only applicable to NuScale design and its derivatives, including Standard Design Approval
- TR Section 2.5.1 provides high-level design characteristics that determine applicability
 - All characteristics must be met
- Applicability limitations are acceptable
 - High-level design characteristics capable of identifying NuScale designs with the features and risk profile considered by the staff in its review



Staff's Review Approach for Dose-Distance Criteria and FoMs

- Considered recent research efforts to re-assess current 10-mile EPZ technical bases in NUREG-0396
- Considered updated information from guidance, methods, models, and analytical tools
- Assessed TR methodology consistency with analyses, assumptions and considerations of NUREG-0396 and current information
- Important topic areas:
 - Radiological consequence assessment modeling approaches
 - Dosimetric criteria and dose-distance curves
 - Considerations derived from assessments

Dose-Distance Criteria and FoMs¹

Criterion	Description	Source Term	Figure of Merit and Acceptance Criteria
a	Encompass those areas in which projected dose from DBAs could exceed the early phase PAGs	NUREG-0800 Chapter 15 analysis	1 rem and 5 rem TEDE over 96 hours, consistent with the EPA PAG Manual early phase PAGs
b	Encompass those areas in which consequences of less severe accident (containment intact) sequences could exceed the early phase PAGs	PRA-specific accident sequences with MELCOR analyses utilizing mitigation design features and operator actions	1 rem and 5 rem TEDE over 96 hours, consistent with the EPA PAG Manual early phase PAGs
c	Sufficient size to provide for substantial reduction in early severe health effects in the event of more severe accident sequences	PRA-specific accident sequences with MELCOR analyses and separate effects models utilizing additional mitigation design features and operator actions	200 rem red marrow dose, within 24 hours, is less than the TR specified acceptance criteria, consistent with NUREG-0396

1 – See staff report, *Use of MACCS Dose Coefficient Files to Compute Total Effective Dose Equivalent*, which provides information on how to compute TEDE and red marrow FOMs using the MACCS computer code. (ADAMS Accession No. ML21211A584)



Staff's Review of Source Term and Radiological Consequence Analysis

- For source term and radiological consequence analyses, the TR:
 - Recommends computational codes such as MELCOR and RELAP to develop design-specific source terms
 - Requires the MACCS code to perform radiological consequence analyses
- The staff finds these computer codes to be appropriate to perform these analyses



Fundamentals of Event Selection for EPZ Sizing Consistent with NUREG-0396


- Spectrum of accidents \neq licensing and design against QHOs
- Spectrum of accidents for EPZ sizing includes characteristics of radiological consequences from DBAs and BDBAs
 - Includes some of the key characteristics of more severe accidents (with large releases)
 - Ensures capability to reduce early severe health effects (injuries or deaths) in the event of the most severe BDBAs
- Selection of spectrum of accidents for EPZ sizing does not alter the design or operation




Fundamentals of Event Selection for EPZ Sizing Consistent with NUREG-0396 (cont'd)

- Purpose of EPZ is dose savings and not dose avoidance
 - NUREG 0396: “...while the EPZ should not be solely dependent on the most severe and most improbable BDBEs, the determination of the EPZ size needs to include some of the key characteristics of very large releases.”
- Seismic risk expected to dominate NuScale risk profile and EPZ sizing
 - Design reduces the risk from internal events
 - Timing of seismically-initiated sequences different compared to non-seismic events
 - Inclusion in spectrum of accidents maintains consistency with NUREG-0396

Seismic Risk – Potential Dominant Contributor for the NuScale Design




NuScale Core Damage Frequency (per year) Profile Without Seismic Contribution



Estimated NuScale Core Damage Frequency (per year) Profile for Site Within NuScale Certified Design Response Spectrum

Staff Review of Non-Seismic Single Module Sequence Screening

- TR sequence screening of $1E-7$ per reactor year CDF would have screened in all the WASH-1400 release sequences
 - None of these release sequences had a frequency less than $1E-7$ per reactor year



Staff Review of Consideration of Multi-Module Impacts for Non-Seismic Hazards

- WASH 1400 did not explicitly model “common mode mechanisms” such as fire, flood, and tornadoes (which have the potential to impact multiple modules) in the event trees and fault trees
- Appendix IV of WASH 1400: “common mode mechanisms” were assessed as impacts on the system fault trees
- Core damage sequence screening of $1E-7$ per reactor year was also applied to multi-module core damage sequences
 - None of WASH 1400 release sequences had a frequency less than $1E-7$ per reactor year



Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 2

- Proposed threshold was 1E-5 per year initiating event frequency
- Proposed threshold did not provide spectrum of accidents consistent with NUREG-0396
 - Negligible beyond design basis seismic risk
 - Excluded key characteristics of more severe seismic accidents
 - Risk gap in EPZ sizing insights
- Proposed threshold was inconsistent with technical basis in NUREG-0396 and consideration of seismic events in WASH-1400

Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 3

- TR identified a proprietary screening threshold for seismic hazard
- “Risk gap” approach developed by staff for evaluation
 - Determine appropriateness of screening threshold for seismic hazard consistent with basis in NUREG-0396



Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 3 (cont'd)

- Overview of “risk gap” approach
 - Step 1: Collect ensemble of hazard curves representing different sites within the certified seismic design response spectrum
 - Step 2: Identify plant-level fragility and spectral ratios
 - Step 3: Convolve hazard curves with plant-level fragility
 - Step 4: Calculate simple average absolute and relative “risk gap” below screening threshold value

Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 3 (cont'd)

- Staff evaluation used “risk gap” approach with 9 operating reactor sites
 - Within NuScale Certified Seismic Design Response Spectra
 - Using NuScale high confidence of low probability of failure (HCLPF) plant-level fragility
 - Threshold captures 20% – 50% of seismic risk for the NuScale design across majority of 9 sites

Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 3 (cont'd)




Figure 1 in NRC staff's safety evaluation (ML22118A760)



Staff Review of Screening Threshold for Seismic Hazard in TR, Revision 3 (cont'd)

- Achieves consistency with NUREG-0396 and WASH-1400 for seismic events
 - Results in a complete spectrum of accidents
 - Avoids extremely unlikely seismic accelerations
 - Does not 'penalize' NuScale for its risk profile
- Addresses multi-module risk (details in subsequent slide)
- Uses quantified seismic sequences because they can be dominant contributor to plant risk and EPZ sizing



Technology-Inclusive Applicability of “Risk Gap” Approach for Risk- Informed EPZ Sizing

- Provides design- and site-specific screening threshold value(s) consistent with technical basis in NUREG-0396
 - Single value across technologies and sites is difficult to defend
- Uses accessible design-specific information
- Compatible with risk metrics other than CDF or LERF
- This approach provides regulatory stability

Staff Review of Treatment of Uncertainty in Screening Threshold for Seismic Hazard

- Sufficient to identify new insights
 - Addresses uncertainty in context of identification of spectrum of accidents for EPZ sizing
 - Addresses potential for cliff edge effect (i.e., large change in EPZ size decision with small change in event screening)
- New sequences included in remaining steps of methodology

Staff Review of Consideration of Multi-Module Impacts for Seismic Hazard

- Methodology appropriately identifies and includes multi-module impacts from seismic events
- Considerations in staff evaluation:
 - Seismic events are a common-mode initiator
 - Screening threshold results in inclusion of accelerations with potential multi-module impacts
 - Dominant contributors to NuScale's seismic large release frequency impact multiple modules
 - Impact of multi-module sequences reflected in source term for those sequences

Information at Various Licensing Stages Under 10 CFR 52



Part 52:	PRA Based Seismic Margins Analysis (SMA) Allowed	PRA Based SMA Allowed	Site-Specific Seismic PRA
EPZ TR:	Not Applicable	Site-Specific Seismic PRA	Site-Specific Seismic PRA





Staff's Review of Treatment of Modeling Uncertainty for Seismic and Non-Seismic Hazards and Staff Review

- TR contains broad discussion of consideration of assumptions and sources of uncertainty in the underlying PRA
- Staff determined that consistency with established guidance applied for voluntary risk-informed applications is important
 - RG 1.200, Revision 3 and NUREG-1855, Revision 1
- Includes a corresponding Condition of Use

Staff Review of Consideration of Defense-In-Depth

- Methodology identifies key plant design and operational characteristics necessary for achieving defense-in-depth
 - Includes consideration of severe accident management strategies and diverse and flexible coping strategies
- Consistent with PRA Policy Statement and RG 1.174, Revision 3
- Five levels of defense in INSAG-10 adds confidence in consideration of defense-in-depth

Staff's Conditions of Use

- Ensure user addresses key inputs for methodology and staff findings
- Eight (8) conditions of use:
 - A. Consistency in use between applicant for operating license application under Part 50 and COL under Part 52
 - B. Consistency of PRA technical acceptability with established guidance
 - C. Treatment of PRA key assumptions and sources of uncertainty consistent with established guidance
 - D. Limit seismic event screening threshold to sites with GMRS bounded by NuScale's CSDRS
 - E. Limit seismic event screening threshold to NuScale's HCLPF plant-level fragility
 - F. Demonstration of GMRS and HCLPF plant-level fragility at application and prior to fuel-load
 - G. Monotonic decrease of 200 rem dose exceedance curve
 - H. Periodic evaluation to ensure (1) E is met AND (2) conclusion on EPZ size remain valid. Periodicity consistent with 10 CFR 50.71(h)(2)

Staff's Conclusion

- TR methodology is generally consistent with technical basis of current 10-mile EPZ prescribed in 10 CFR 50.47 (i.e., NUREG-0396)
- Reasonable assurance that methodology is adequate for assessing plume exposure pathway EPZ sizing
- Applicants using the methodology as the technical basis for assessing plume exposure pathway EPZ sizing need to meet :
 - Scope of applicability in Section 2.5 of the TR
 - Conditions of Use listed in Section 5.0 of staff's SE

Staff's Conclusion (cont'd)

- NuScale EPZ TR is risk-informed and reflective of NUREG-0396 approach
 - Uses risk information from design- and site-specific PRAs, with explicit consideration of uncertainty
 - Explicitly addresses defense-in-depth
 - Staff evaluated impact on safety margins
 - Includes performance monitoring (based on corresponding Condition of Use)

Caveats on Scope of Staff's Findings

- Only applicable to this TR for EPZ sizing
 - Not extended to design and operation for licensing
 - Quantitative Health Objectives applicable for design and operation for licensing
- Screening threshold, especially for the seismic hazard, not applicable to PRA development
 - Follow applicable endorsed PRA Standard
- Does not define “credible” events for any hazard

Acronyms

BDBA/E	beyond design basis accident/event
CDF	core damage frequency
CSDRS	certified seismic design response spectrum
DBA	design basis accident
EPZ	emergency planning zone
GMRS	ground motion response spectrum
HCLPF	high confidence of low probability of failure
LERF	large early release frequency
LRF	large release frequency
LWR	light water reactor
Non-LWR	non-light water reactor
ONT	other nuclear technology
PRA	probabilistic risk assessment
QHO	quantitative health objective
RG	regulatory guide
SMR	small modular reactor
WASH-1400	Nuclear Regulatory Commission Reactor Safety Study, 1975



References

10 CFR 50.47 “Emergency Plans”

10 CFR Part 50 Appendix E “Emergency Planning and Preparedness”

10 CFR Part 20 “Standards for Protection Against Radiation”

NUREG-0396, “*Planning Basis For The Development Of State And Local Government Radiological Emergency Response Plans In Support Of Light Water Nuclear Power Plants*” (ML051390356)

Use of Probabilistic Risk Assessment Methods in Nuclear Regulatory, 60 FR 42622

SRM-SECY 98-144, “*White Paper Risk Informed and Performance-Based Regulation*” (ML003753601)

Regulatory Guide (RG) 1.174, “*An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis*,” Revision 3 (ML17317A256)

RG 1.200, “*Acceptability of Probabilistic Risk Assessment Results for Risk-Informed Activities*,” Revision 3 (ML20238B871)