

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: **Advisory Committee on Reactor Safeguards
Thermal Hydraulics Subcommittee**

Docket Number: (n/a)

Location: teleconference

Date: Thursday, October 20, 2022

Work Order No.: NRC-2139 Pages 1-95

**NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

11 The contents of this transcript of the
12 proceeding of the United States Nuclear Regulatory
13 Commission Advisory Committee on Reactor Safeguards,
14 as reported herein, is a record of the discussions
15 recorded at the meeting.

17 This transcript has not been reviewed,
18 corrected, and edited, and it may contain
19 inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 THERMAL HYDRAULICS SUBCOMMITTEE

8 + + + + +

9 THURSDAY

10 OCTOBER 20, 2022

11 + + + + +

12 The Subcommittee met via Video
13 Teleconference, at 9:30 a.m. EDT, Jose March-Leuba,
14 Chairman, presiding.

15

16 COMMITTEE MEMBERS:

17 JOSE MARCH-LEUBA, Chair

18 RONALD G. BALLINGER, Member

19 CHARLES H. BROWN, JR., Member

20 VESNA DIMITRIJEVIC, Member

21 GREGORY HALNON, Member

22 DAVID PETTI, Member

23 JOY L. REMPE, Member

24 MATTHEW SUNSERI, Member

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 ACRS CONSULTANT:

2 DENNIS BLEY

3 STEPHEN SCHULTZ

4

5 DESIGNATED FEDERAL OFFICIAL:

6 KENT HOWARD

7

8 ALSO PRESENT:

9 PAUL KLEIN, NRR

10 AHSAN SALLMAN, NRR

11 STEVE SMITH, NRR

12 JIM STECKEL, RES

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 P R O C E E D I N G S

2 9:30 a.m.

3 CHAIR MARCH-LEUBA: The meeting will now
4 come to order. This is a meeting of the ACRS Thermal
5 Hydraulics Subcommittee. I am Jose March-Leuba, the
6 Subcommittee Chairman. This meeting is being
7 conducted remotely via MS Teams.

8 I see the following ACRS members in
9 attendance, Ron Ballinger, Charles Brown, Greg Halnon,
10 Dave Petti, Joy Rempe, and Matt Sunseri. We also note
11 that our consultants, Dennis Bley and Steve Schultz,
12 are present.

13 Today's topic is Revision 5 of Regulatory
14 Guide 1.82, Water Sources for Long-Term Recirculation
15 Cooling Following a Loss-of-Cooling Accident. This
16 Reg Guide describes an approach to meet requirements
17 for water sources available for emergency core cooling
18 and other safety systems, like containment cooling.
19 This revision of the guide was issued in final form in
20 August 2022.

21 Let me give you a short introduction on
22 the history of this topic from my personal point of
23 view to remind the members of our past interactions
24 with the staff. Most relevant point is that this
25 provides guidelines for evaluating the adequacy and

the availability of water sources for long-term recirculation cooling following a LOCA. It includes the issues of the regeneration and the use of containment accident pressure. ACRS has been involved with both issues over a long time with multiple meetings and letters. We have reviewed the containment issue as part of the resolution of GS-191 and wrote letters agreeing with the staff approach, including actual plant implementations.

On the issue of containment accident pressure, or CAP, we wrote three letters in 2009, '10, and '11 and concluded that credit for CAP should be allowed only if plan modifications are not practical and the use should be limited in amount and duration, and it should include a risk assessment. We also recommended that the guide, Revision 3 in 2009, should be modified to recommend the type of analysis that the staff will expect to credit CAP use. In my opinion, Revision 5 implements our second recommendation, but high-level disagreements may remain, especially on the need for risk analysis. Members should keep this in mind while we are reviewing it today because it is a critical issue that will affect our letter.

Finally, even though it is not part of the guide, I have asked the staff to give us their

1 perspective on the defense-in-depth that FLEX
2 equipment would provide in these type of accidents.
3 This is not part of our guide review, but this
4 provides useful information since (audio
5 interference). We are expected to have a full
6 committee meeting on this topic and likely write a
7 letter on November 1st. We expect that this meeting
8 will be conducted entirely over this public line.
9 Portions of our meeting may be closed to the public to
10 protect proprietary information, if necessary. If we
11 go to a closed line, we will have an opportunity for
12 public comments before we start the closed session of
13 the meeting.

14 The ACRS was established by a statute that
15 is governed by the Federal Advisory Committee Act,
16 FACIA. As such, the Committee can only speak with
17 published letter reports. The ACRS section of the
18 U.S. NRC public website provides our charter, bylaws,
19 agendas, letter reports, full transcripts for the open
20 portions of all full or subcommittee meetings,
21 including the slides presented there.

22 The Designated Federal Official today is
23 Kent Howard.

24 A transcript of the meeting is being kept.
25 Therefore, speak into the microphones clearly and

1 state your name for the benefit of the court reporter.
2 Please keep the microphone on mute when not in use and
3 minimize the use of video feed to avoid bandwidth
4 problems for people assessing the meeting remotely.

5 At this point, I will give the floor to
6 the staff to commence their presentation. Jim, can
7 you go ahead.

8 MEMBER REMPE: Hey, Jose?

9 CHAIR MARCH-LEUBA: Hold on. Yes, Joy?

10 MEMBER REMPE: I'm sorry. Maybe it's just
11 my connection, but sometimes you cut in and out, and
12 I guess I don't know if other people have that problem
13 but I could not hear where you said in my opinion the
14 Reg Guide. Could you repeat what you said? Because
15 I --

16 CHAIR MARCH-LEUBA: Let find that part
17 because I have it written.

18 MR. BLEY: While he's looking, I don't
19 know --

20 (Simultaneous speaking.)

21 CHAIR MARCH-LEUBA: Do you have --

22 MEMBER REMPE: No, it's me, not someone
23 else. But would you repeat it for my own benefit
24 because I think that's an important statement I'd like
25 to hear.

1 CHAIR MARCH-LEUBA: Yes. For the benefit
2 of everybody, let's see, let me change my --

3 (Simultaneous speaking.)

4 MEMBER REMPE: -- said he was fine, so it
5 may be just me, but just repeat it for me, please.

6 CHAIR MARCH-LEUBA: Do I sound better now?

7 MEMBER PETTI: Way better, Jose. Yes,
8 you sounded like you were on the end of a long
9 line.

10 CHAIR MARCH-LEUBA: Okay. So what I
11 said is, I'm repeating now, in my opinion,
12 Revision 5 implements our second recommendation,
13 that being that they have to document the type of
14 analysis that the staff expects to review to
15 credit CAP use, but high-level disagreements may
16 remain, especially on the need for a risk
17 analysis.

18 MEMBER REMPE: Thank you very much.

19 CHAIR MARCH-LEUBA: So, basically, there
20 were two recommendations. One is whatever the staff
21 expects from an applicant to take credit for CAP, they
22 need to document it, and that's what Appendix B of the
23 Revision 5 is. But we also had a recommendation that
24 maybe we do some risk analysis with this modification.

25 Okay. Any more comments before we move to

1 the staff? No? Jim, staff, go ahead.

2 MR. STECKEL: Thank you, Jose. I'm going
3 to briefly open the camera just so you have an idea
4 who you're speaking with. I'm going to introduce
5 myself and the two technical leads responsible for the
6 revision of this Reg Guide 1.82.

7 My name is Jim Steckel, and I'm a Program
8 Manager in the Office of Research, Division of
9 Engineering, and was designated to be the project
10 manager on this particular revision. Ahsan Sallman,
11 a Senior Nuclear Engineer with NRR DSS, is one of the
12 revision engineers that worked on this particular
13 upgrade to the Reg Guide; and Mr. Steve Smith, Senior
14 Plant Systems Engineer, also with NRR DSS.

I'm going to briefly describe what we're going to present to you today. We are going to talk about the main changes in Rev 5, and these include the following. GSI-191. This issue constitutes the main body of the Reg Guide and Appendix A. The next item is containment accident pressure, CAP. There will be a brief CAP description and how it is accounted for in Appendix B. Also to be discussed is how this revision provides some background on the relation of Reg Guide 1.81, Revision 5, to GSI-191, including a summary of the GSI-191 issue, changes made in Reg Guide 1.82 for

1 GSI-191, and Reg Guide 1.82 status with respect to
2 GSI-191.

3 Additionally, we'll touch on Revision 5
4 public comment resolutions. And, finally, we'll
5 discuss the role of FLEX equipment regarding defense-
6 in-depth.

7 I would now like to turn over the screen
8 to Steve Smith. Thank you.

9 MR. SMITH: Okay. We're just rearranging
10 here so that we can be in front of the camera and
11 control the screen. I guess we'll turn the camera off
12 to save bandwidth, as you recommended.

13 I'm going to try to go to the next slide.

14 CHAIR MARCH-LEUBA: We can see it.

15 MR. SMITH: There we go. All right. I'm
16 going to turn my, I'll turn the camera off here so you
17 pay more attention to the slides.

18 Okay. So this is slide two. We have the
19 presentation split up into two parts. I'm Steve
20 Smith, and I'm going to talk about the main body of
21 the Reg Guide and Appendix A. Those two we had
22 relatively minor changes to just to update references
23 and add some information about GSI-191 things.

24 Ahsan is going to talk about Appendix B,
25 which is a new appendix for containment accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 pressure, or CAP. It's just easier to say CAP, so
2 we're going to say CAP. I will also talk about the
3 public comments. We just did a very high-level
4 summary of that, and then we have a couple of slides
5 that also talk about how FLEX could provide defense-
6 in-depth for these two issues.

7 This slide just provides a brief
8 description of the technical changes and the
9 applicability for Appendix B, and you'll see more
10 about that later on. So I'm going to move on to slide
11 three. If you have any questions at any time, just go
12 ahead and let me know and I'll stop and try to answer.

13 All right. So this is slide three, and
14 I'm going to be just providing a brief background on
15 GSI-191. This slide shows a few of the additions we
16 made to the Reg Guide and, in parentheses, we have the
17 approximate times that the NRC staff positions were
18 developed or items were published. So some of these
19 have some items published or letters sent, you know,
20 providing guidance to the industry.

21 All right. The next few slides, slides
22 four through seven, this might not make any sense, but
23 this is a brief long history. This slide shows the
24 pre-GSI-191 highlights. I'm not going to spend a lot
25 of time sitting on any of these slides, so I'm just

1 going to let you guys take a look through it and if
2 you have any questions. On this slide, this is
3 everything that occurred -- not everything. This is
4 a lot of the things that are related to the GSI-191
5 issue that occurred prior to the time that GSI-191 was
6 initiated.

The next slide shows the initial NRC actions with respect to GSI-191. So it was actually initiated in 1996, and then, starting in 2003, we sent out a bulletin. In 2004, we sent out the General Letter 0402, which is still ongoing. The GSI remained open for a long time because some of the technical issues were not fully understood, and we'll talk about that a little bit on the next slide.

15 This slide, slide six, is the more recent
16 GSI history, and the things that really slowed the
17 closure down were chemical effects and in-vessel
18 effects were not well understood when we sent the
19 issue out to industry for resolution. Chemical
20 effects methodology was relatively quickly resolved,
21 and we had an acceptable method in 2007. But the in-
22 vessel effects methodology was really not accepted by
23 the NRC staff until 2019. And chemical effects do
24 interrelate with in-vessel effects, so there was some
25 interplay there, too.

1 But, anyway, for stringers, the chemical
2 effects were figured out by 2007, and then in 2019 we
3 figured out how to resolve in-vessel effects and we
4 put some guidance out for that.

5 Once we understood -- yes?

6 MR. BLEY: This is Dennis Bley. I've been
7 working my brain trying to remember some of this
8 history as it went on. Wasn't it during the chemical
9 effects investigations that we had some contradictory
10 experiments that took some time to get worked out? I
11 don't quite remember how that was settled.

12 MR. SMITH: I'll tell you what, I'm hoping
13 that Paul Klein is on the line, and he might be able
14 to help us out with that because he's our chemical
15 effects expert. Are you on, Paul?

16 MR. KLEIN: Yes, Steve, I'm on. This is
17 Paul Klein. So I guess a very short summary of how
18 the chemical effects evaluation happened, as Steve
19 mentioned, we understood early on after initial
20 testing that chemical effects could be a problem, but
21 there really wasn't a very good understanding of
22 timing with respect to chemical effects. So that took
23 quite a bit of time to really fully understand timing.
24 We knew that, if chemical effects occurred, it could
25 cause very large head losses.

And so the contradictory testing that I think you're referring to is some of the early in-vessel tests where they added the pre-mixed precipitate. The actual head loss that was incurred by chemical effects was really dependent upon the particulate and fiber bed that had formed at the inlet to the fuel. So I think that, over time, the particulate-to-fiber ratio, when the composition of the bed at the fuel inlet became better understood and, more importantly, the timing became understood. And then as alternate fuel paths were evaluated, it became clear that, for most plants, in-vessel chemical effects would not occur until after the point where there was sufficient alternate water paths into the vessel.

16 || MR. BLEY: Thanks. That helps.

17 MR. SMITH: All right. Thank you, Paul.

18 So the last thing, as we sort of just discussed, the

19 last thing that was not resolved for GSI-191 was the

20 understanding of in-vessel effects. Once we provided

21 a guidance for how to resolve the in-vessel effects,

22 GSI-191 was closed because all the technical issues

23 were well enough understood to make that happen.

1 to respond. And on the next slide, I have a summary
2 of what the status is for all the plants. This is
3 slide seven coming up.

Okay. So this shows the status of the plants. At the top are the deterministic plants, and at the bottom is where we stand with risk-informed resolution. So we had nine low-fiber plants that closed out using the original in-vessel guidance, which was probably at least ten years before the final in-vessel guidance. And then we had ten plants close out deterministically after we released the 2019 guidance. We have seven plants that have deterministic submittals under review and two plants we haven't received their final in-vessel submittals yet.

Okay. Slide eight, we're going to shift

gears a little bit. This just shows some of the things that we changed or added to the Reg Guide. The first thing is we added a reference to the draft Reg Guide 1.229 for risk-informed evaluation. This is what licensees have been using, that draft Reg Guide, when they submit risk-informed LARs to us.

7 And then we also did a BWR evaluation of
8 lessons learned. Since the BWRs closed many years
9 ago, we've learned quite a few things, and they did a
10 lot of work and NRC staff did a lot of evaluation to
11 ensure that they had adequately addressed the major
12 areas.

On slide nine, this shows the changes that were made. This is the biggest changes to in-vessel downstream effects, so we did the safety-significant technical evaluation report, which the ACRS looked at. And we also developed the review guidance for the same issue. And I just tried to put the important references here.

One of the other important references is
on slide ten, and that is the WCAP-17788, which is --
was a large body of work that industry did to help us
understand the issue. And then back on slide three,
there was a few other things that we added. I didn't
put the numbers down for those, but we added

1 || references to cover those, as well.

On slide 11, this is kind of a wrap-up as far as GSI-191 and Reg Guide 1.82. We expect this revision to be basically inclusive of all our guidance for GSI-191. We understand that, you know, we may learn a few things in the future and we might make some minor changes, but this is basically the last revision we're going to make to the Reg Guide for this issue.

The other thing that's kind of important
is the rulemaking 10 CFR 50.46(c) is still with the
Commission. And so that may get, that may change the
way that we do risk-informed LARs. The only thing is
this rulemaking has taken such a long time that we
think we'll have all the risk-informed LARs probably
done before the rule is actually implemented. So kind
of depending on how that rulemaking goes, we'll decide
what to do with the draft Reg Guide 1.229 on the risk-
informed evaluation of the issue. Now --

20 MR. SCHULTZ: Steve, this is Steve
21 Schultz. Before you go on, so the Reg Guide right now
22 is still a draft guide?

23 MR. SMITH: Yes, 1.229 is still draft.

24 MR. SCHULTZ: Still a draft guide. And
25 right now there is no further work that is ongoing,

1 and it will depend upon what the Commission determines
2 with regard to the rulemaking.

3 MR. SMITH: We didn't think it was
4 appropriate to finalize that Reg Guide because it is,
5 it's right now connected to the rulemaking. So we
6 didn't want to finalize or go any further with that
7 draft Reg Guide until the rulemaking is complete.

8 MR. SCHULTZ: The risk-informed submittals
9 you've already reviewed and they're coming in are
10 using the draft?

11 MR. SMITH: They are using the draft, yes.

12 MR. SCHULTZ: Good. Thank you.

13 MR. SMITH: Okay. So at this point, I am
14 pretty much done with the GSI-191 part of this. I
15 have slides on public comments and then how FLEX
16 provides, can provide defense-in-depth for the issue.
17 It's up to you whether we do those now, or we can do
18 them at the end if that seems more appropriate.
19 Whatever you guys, the ACRS Committee members think
20 would be the best thing to do. I can either go
21 through those now, or we can wait until after the CAP
22 presentation.

23 CHAIR MARCH-LEUBA: I think you're on a
24 roll. Let's keep going. You're doing well. Just
25 continue on this. It makes sense to finish this.

You're doing well.

2 MR. SMITH: Okay, all right. So we're
3 going on to slide 12, and this is just these public
4 comments. We didn't go into a lot of detail here. We
5 didn't receive a ton of public comments. We received
6 four sets of public comments from three entities, and
7 I list the areas here. They were basically
8 applicability and scope definitions, clarifications,
9 and references, and add risk-informed guidance. And
10 for these, we made changes where we thought it was
11 appropriate.

We didn't think that Rev 5 was intended to cover new reactors, except where the guidance would be applicable to them. There was some comments that thought that we should make it clear that this was not applicable to new reactors, and that wasn't the intent of this revision. Maybe the next revision will be more specific with that, but we didn't do any work to try to make this applicable to new reactors. So we just expect them to use the guidance if it's applicable.

22 And then we made some minor changes just
23 for clarifications and references, and we did not add
24 risk-informed guidance. We're awaiting the 50.46(c)
25 rulemaking. That was one of the comments. And I

1 think we have a couple more.

On the next slide, slide 13, there were some comments that said we should be more specific with the methodology, and the NRC thought that the methodology was adequately specified. We did change some references to make them public so that, you know, people could look at those. And, basically, editorial comments we incorporated.

9 Okay. We're going to move on to talk
10 about FLEX a little bit in slide 14. Okay. Now, the
11 thing about the FLEX is we are not FLEX experts. So
12 we talked to some people who worked on, we got input
13 from them to help create these slides. What we
14 figured out is BWRs have direct RCS injection points
15 that include high-volume flow, and those injection
16 points are predetermined and set up so they can just
17 take the FLEX equipment and pick it up and it will
18 inject to the RCS.

PWRs have some low-volume RCS flow and
high-volume steam generator flow. So if there was a
LOCA, and it was a large LOCA, they don't have pre-
existing connection points to provide high-volume flow
to the RCS. They have, you know, they could provide
probably tens of gallons.

So the guys we talked to who reviewed this

1 for the BWRs and PWRs, they said that they could
2 reconfigure, plants could probably reconfigure the
3 steam generator pumps to inject to the RCS, but it's
4 not pre-set-up. It would take time, and it's kind of
5 a plant-dependent thing. So it depends how the plant
6 is designed and how their FLEX equipment is designed
7 as to how easy it would be to do that.

8 So with that in mind, we can go through
9 the next couple of slides. I kind of went through
10 slide 14 there, and then this slide 15 provides just,
11 slide 15 talks about strainer blockage, and it's
12 relatively similar. We looked at relatively similarly
13 to CAP blockage or CAP, you know, if you've lost
14 containment accident pressure, which is shown on the
15 next slide.

16 But, anyway, for most strainer blockage
17 events, the pressure in RCS would be low. BWRs would
18 have no problem hooking up FLEX capacity. So we look
19 at BWRs as having pretty good defense-in-depth. And
20 as we discussed on the previous slide, the PWR FLEX
21 strategies may be less effective for long-term
22 cooling. The PWR injection to the RCS is on the order
23 of tens of GPM, but that does include boron, you know.
24 They would have borated water to inject. Those are
25 designed for pump seal leakage usually or shutdown

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

conditions where you'd have a very low requirement for volume of flow.

So, generally, it seems to us that BWRs have better defense-in-depth, then probably pretty good defense-in-depth, and the PWR would not have as readily available defense-in-depth. It might take, you know, depending on how long it takes the plant to hook a higher-volume pump up, that would be important as far as defense-in-depth is available. Eventually, they could get there, but it might take, you know, we don't know how long it would take.

12 CHAIR MARCH-LEUBA: So this is Jose. I
13 ask you to think about this area, even if it's not
14 part of the Reg Guide. When we go visit the plant, we
15 see this beautiful FLEX equipment, and we wonder if
16 it's useful. And what I'm hearing is, and I'm jumping
17 to Appendix B at the CAP credit, if we give CAP credit
18 to a boiling water reactor and some additional
19 accident loses the pressure in the containment by
20 cooling it or venting it or whatever mechanism, FLEX
21 would provide some defense-in-depth and probably it
22 would not be cause of the accident in boilers.

23 MR. SMITH: That's correct. Slide 16 was
24 more focused on the CAP credit issue, although, you
25 know, the way that the FLEX equipment works is similar

1 for both. So we concluded that the BWRs would be more
2 likely to use FLEX equipment to provide RCS injection,
3 in the case of a loss of NPSH, would include both the
4 loss of CAP or a clogged strainer. And PWRs would
5 have challenges to do that because they'd have to take
6 time to hook up the larger volume pumps to the RCS.

7 MEMBER BALLINGER: This is Ron Ballinger.
8 I think we need to be a little bit careful since we're
9 on the record of using the words defense-in-depth. I
10 think what you're saying is that the FLEX equipment
11 may or may not augment existing defense-in-depth.
12 You're not saying that we don't have defense-in-depth
13 and the FLEX equipment doesn't help. So I think we
14 need to be a little bit careful of when we use the
15 word defense-in-depth in this context.

16 CHAIR MARCH-LEUBA: I think you're wrong.
17 The way I read it, I understand it, is it provides
18 additional defense-in-depth.

19 MEMBER BALLINGER: Right, right. That's
20 what I'm saying. We need to be careful about the
21 words and be careful that somebody doesn't read this
22 at some point and say, oh, my gosh, what do you mean
23 they don't have defense-in-depth.

24 CHAIR MARCH-LEUBA: Well, the reason why
25 I was asking this is to do a risk analysis in our

1 minds of if you lose your CAP and suddenly your pumps
2 just start cavitating, what do you do? And what I'm
3 seeing from the analysis the staff performed is, in
4 boiling water reactors, you just run to the FLEX
5 building and bring those pumps in, and you're out of
6 the problems.

7 MEMBER BALLINGER: Right.

8 CHAIR MARCH-LEUBA: In PWRs, you have to
9 think a little more. It's good to have them, but
10 they're not designed to plug in in five minutes.

11 MEMBER BALLINGER: Right. But you're not
12 starting from a zero defense-in-depth point.

13 CHAIR MARCH-LEUBA: Correct. And we'll
14 talk about it a little more on CAP, but my
15 understanding is it's more challenging for boiling
16 water reactors than for pressurized water reactors.

17 Okay. Staff, continue.

18 MR. SMITH: If I just go back, if you go
19 back to slide 14, that provides a little bit more
20 background. We say on there the FLEX strategies are
21 not, they're not designed for the events that we're
22 talking about now. They're for beyond design basis
23 external events that come from natural phenomena.
24 They're not for LOCAs or events that would be likely
25 to end us up using containment accident pressure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So this is exactly what the FLEX guides
2 were saying. We do need to be careful how we
3 characterize this. This equipment is not designed for
4 this kind of accident. However, it can provide some
5 mitigative capacity, and it seems like BWRs would have
6 better mitigative capacity than PWRs.

7 MR. BLEY: Yes, this is Dennis Bley. I
8 want to go back to what Ron was saying, and I guess
9 the main defense-in-depth here is the containment,
10 which ought not lose its pressure. And that's where
11 the old arguments were hanging about just a small
12 amount and not for long. And then we had an applicant
13 come in that was proposing what seemed like a large
14 amount for a very long time, and then you start
15 worrying about could something happen to the
16 containment.

17 So the fact that FLEX, which Steve said is
18 designed for something else, can be very helpful here
19 is common with a lot of places people have found they
20 can use FLEX that gives us really a backup for things
21 that we thought very good anyway. So, yes, I'm
22 agreeing with Ron and I think Jose fell in the same
23 position. We're pretty well okay here, and FLEX can
24 really help if you need it, which is very unlikely.
25 That's enough.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MR. SMITH: Yes, I agree. I think, yes,
2 it's not part of the design basis, which is, you know,
3 what we're trying to do with this other thing. It's
4 just something additional that could be available.

5 So that was my last slide. I'm going to
6 turn it over to Ahsan unless there's other questions.

7 CHAIR MARCH-LEUBA: I think that's a good
8 plan.

9 MR. SMITH: Okay.

10 CHAIR MARCH-LEUBA: So we're moving now to
11 containment accident pressure.

12 MR. SMITH: Yes. Just rearranging the
13 room here. Be with you in a second.

14 MR. SALLMAN: This is Ahsan Sallman. I'm
15 in the Nuclear Performance Branch in DSS, and I'll
16 talk about the guidance for the use of the containment
17 accident pressure for the net positive suction head
18 margin for ECCS and containment heat removal pumps in
19 BWRs and PWRs.

20 So this is the contents showing, this
21 slide shows the contents with the topical background,
22 ECCS, the role of ECCS pumps, and the regulatory
23 requirements, use of CAP in NPSH margin, cavitation,
24 erosion, effect of non-condensables, gas, loss of
25 containment isolation, containment cooling if CAP is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 used, illustration of the CAP available quantifying
2 margin, the guidance summary. And then I have a list
3 of acronyms and symbols if anybody wants to look at
4 this at the end of this presentation.

5 This slide shows the CAP issue. CAP is
6 used in determining the NPSH available for ECCS and
7 containment heat removal pumps, and this was highly
8 criticized by the ACRS during maybe 15 - 20 years ago
9 when there were a couple of LARs from Browns Ferry and
10 Monticello, which, because of the CAP issue, they were
11 using CAP and the review was, you have to hold or
12 suspend it because of this. Then at that time we
13 requested BWR Owner's Group to submit a topical
14 report, which is NEDC-33347, and the BWR Owner's Group
15 developed a standard approach for requesting CAP.

16 Then staff wrote a white paper, and that
17 documented the staff position for the CAP, usage of
18 CAP. And then we had some ACRS letters that were
19 written to EDO and showed what is a position of ACRS,
20 and that is, I've written them down here, CAP credit
21 should be limited in amount and duration, and the
22 operator reactions, if the control CAP should be
23 reliable.

24 The next slide is ACRS wanted SRP-622,
25 which is on the containment heat removal, to be

1 revised and include the risk information in the CAP.
2 And the ones that are on star (phonetic) -- these
3 recommendations of ACRS were incorporated in this Reg
4 Guide, like modification of the plant before we give
5 CAP credit and we show that it is practical or
6 impractical.

7 And then this report, Owner's Group report
8 which provided a standard approach for use of CAP, the
9 statistical method of calculating the uncertainty in
10 that BSH. So then other suggestions or other
11 recommendations from ACRS was a hardware modification
12 or risk studies would not be needed if CAP credit is
13 small in deterministic analysis.

Okay. There was an ACRS letter that was written to the Commission chairman about a disagreement between the ACRS and staff, and the ACRS position was a CAP should be, the CAP credit should show the deterministic analysis, as well as plant-specific PRA, that should be included. And the staff position was not for the deterministic, not for the PRA but only the deterministic analysis.

22 At that same time, staff requested a pump
23 consultant to give us the different -- on different
24 tasks, there were four tasks assigned to the pump
25 consultant, and these tasks are written down here in

1 this slide.

2 The next slide is --

3 CHAIR MARCH-LEUBA: Go back and let's
4 understand --

5 MR. SALLMAN: Yes, sir.

6 CHAIR MARCH-LEUBA: That 2011 letter is
7 our last, well, last position I know of. What the
8 staff is saying that, if you created CAP in your
9 analysis and you show your NPSH is acceptable, you
10 don't need to do anything else, you can take credit
11 for the CAP. And the ACRS position was that, for a
12 short time and if you don't use too much of your CAP
13 margin, that is certainly okay; but, if you want to do
14 it for more than a hundred hours, then maintaining the
15 containment pressurized involves a number of events,
16 like operator errors of omission or commission;
17 additional failures of containment, if you had a big
18 seismic event that necessitated the whole thing.

19 So is that your position, and this is the
20 position in the Reg Guide now that --

21 MR. SALLMAN: Yes. The Reg Guide position
22 is now that you do the deterministic analysis using
23 CAP. And if CAP is used -- then I'll go over that in
24 the new few slides. If the CAP is used, which is
25 above the vapor pressure at the suppression of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 pool temperature, then that has to be, there should be
2 additional analysis which was recommended in this BWR
3 Owner's Group report, and that is what we do the Monte
4 Carlo analysis to show how much margin it is. And
5 that was what was recommended by the ACRS at that
6 time.

7 CHAIR MARCH-LEUBA: Yes. But after you do
8 an LAR, for example if you want to do a power operate,
9 and now you need a CAP credit --

10 MR. SALLMAN: Yes.

11 CHAIR MARCH-LEUBA: -- need before, are
12 the operators required to update the PRA with the
13 consequences of creating CAP? I mean, there should be
14 a branch on the PRA, a number of sequences that
15 include failure of containment after having the
16 accident where CAP is needed, and they're not required
17 to evaluate that?

18 MR. SALLMAN: Well, that is not in the Reg
19 Guide at this time because -- I'll go to the next
20 slide, what happened when the Commission paper was
21 submitted, the SECY paper was submitted to the
22 Commission, and then they worded on the Commission
23 paper, SECY paper, and that determined that there was
24 no plant-specific PRA required and only the
25 deterministic analysis with some recommendation that

1 are in this slide from the ACRS that are included in
2 the guidance.

3 CHAIR MARCH-LEUBA: From a technical point
4 of view and a logical point of view, I'm making a
5 change to my plan, just, for example, a power operate,
6 that requires me now to credit CAP for my ECCS pumps
7 to work as advertised, and they have to operate for an
8 amount of time, X hours. I would like to know what is
9 the condition of probability that the containment
10 pressure would remain high for those X hours and
11 consider if allowing operation for those six hours
12 introduces an additional risk. And my gut feeling is,
13 if we do the analysis, it would come out to be
14 irrelevant, I mean, very small. But we don't do the
15 analysis, the probabilistic analysis.

16 MR. SALLMAN: No, it is not in the
17 guidance.

18 CHAIR MARCH-LEUBA: Yes, I know. Okay.
19 Thank you.

20 MEMBER DIMITRIJEVIC: This is Vesna. I
21 just want to tell you, based on my experience, if you
22 can credit CAP, that's not part of the PRA model. You
23 don't ask that, so you just assume the pump will
24 operate with no issue with the NPSH. So I have not
25 seen, based on my experience, that, but I did not

1 really have a, I didn't really look at the latest that
2 CAP shows as, that probabilistic CAP shows as input in
3 the PRA model.

4 CHAIR MARCH-LEUBA: Yes, that is what I
5 was saying. The Reg Guide 1.82, that's not required,
6 and apparently nothing else requires it. And
7 logically, I mean, if we are going to be a modern
8 risk-informed regulator, we should know what the risk
9 is.

10 MEMBER DIMITRIJEVIC: Remember the PRA
11 cover only injection for 44 hours after accident, I
12 mean, except for containment performance, which is
13 sometimes asked for 72 hours. But the coolant plant
14 in that period is only 24 hours.

15 CHAIR MARCH-LEUBA: The CAP credit for
16 preventing NPSH is a short duration. I mean, it's
17 maybe 24 hours, right, Ahsan? What is typically the
18 time that you need a credit?

19 MR. SALLMAN: Well, we submitted this
20 guidance in the form of an interim guidance to the
21 owner's groups and we received some LARs on EPUs that
22 were reviewed by the staff and the ACRS. And
23 following this guidance, some of them, they did not
24 use CAP. They improved their plant, one of them, they
25 improved their plant. But mostly, in Appendix R

1 analysis for the fire, Browns Ferry was using several
2 hours of CAP; I don't remember exactly how much, but
3 that was an issue when this whole thing started in
4 2007 - 2009 and that review was suspended.

5 But the duration was, in Appendix R
6 analysis, they used maybe more than 50 hours or
7 something.

8 CHAIR MARCH-LEUBA: Yes, 50 hours --

9 MR. SALLMAN: I'm not sure whether the
10 number, but it was a very high number.

11 CHAIR MARCH-LEUBA: Yes, 50 hours is not
12 a very high number to keep the, when you're talking
13 about containment integrity, in my opinion. If you
14 have to --

15 MEMBER REMPE: Well, just --

16 (Simultaneous speaking.)

17 CHAIR MARCH-LEUBA: -- that would be --

18 MEMBER REMPE: But to give some more
19 background.

20 CHAIR MARCH-LEUBA: Yes. Okay. Dennis --

21 MEMBER REMPE: But to give some more
22 background, Browns Ferry got rid of their CAP credit
23 before they got --

24 MR. SALLMAN: Yes, that is correct. They
25 got rid of the CAP credit by improving the heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 exchanger performance parameter, the K value of the
2 heat exchanger, and so did Peach Bottom. They got rid
3 of the CAP by putting a cross tie between the two
4 loops of the RHR heat exchanger. And some of the BWRs
5 are using CAP, but the CAP is less than the vapor
6 pressure at the sump temperature, and that is allowed
7 in the guidance. So I'll go over that in the next few
8 slides.

9 CHAIR MARCH-LEUBA: Just a moment. Dennis
10 has a comment.

23 MR. SCHULTZ: Dennis, this is Steve, and
24 Ahsan, as well. The point that you've just made about
25 addressing the issue on a plant-specific basis is

1 important, and, as you were speaking about resolution,
2 Ahsan, one of the ACRS's, their comments was that,
3 rather than to use CAP credit, plants should
4 investigate and see if there were changes that could
5 be made to the plant design that would either
6 eliminate or lower the need, reduce the need for CAP
7 credit in the event of an accident.

8 MR. SALLMAN: Yes, that is correct. This
9 guidance is included that they should look at a plant
10 modification before they take credit, and they should
11 say that this is, they should tell us that this is
12 impractical to modify the plant, and then we can allow
13 them the CAP credit. That was one of the
14 recommendations from ACRS also and the staff.

15 MR. SCHULTZ: I appreciate your listing of
16 the number of elements that were provided by the ACRS
17 to the staff, and, obviously, there were several
18 discussions associated with it, and you've provided a
19 good indication of what the staff had agreed to with
20 regard to the ACRS recommendation and had implemented
21 in the going forward processes.

22 MR. SALLMAN: Right. Those are in the,
23 the asterisks in this, on slide 20 show those ones
24 that were included in the guidance. Okay.

25 So I'll go to the next slide now, I guess,

which is still the SECY paper that was written by the staff gave two options. One was the staff approach to use a deterministic to calculate uncertainty in margins, and the option two was the ACRS recommendation to use the staff approach plus a plant-specific PRA. So the Commission voted for option one. Then the SECY paper was approved, SECY-11-0014, with option one.

Okay. This slide is just showing what the definitions of NPSH, available NPSH, and the CAP. So I'll go to the next one. Okay. Here is the definition of required NPSH which the vendor is supposed to provide, and that definition, according to the Hydraulic Institute Standard 14.6, and that is NPSH results in cavitation sufficient to reduce the pump total dynamic head by three percent. And the figure shows at different flow rates the drop in the dynamic head, and that's where the NPSH is. And the NPSH margin is defined, we defined it as available minus the required, and the required is what is given to us by the vendor.

I'll go to the next slide. And then there's another term that we use here, NPSH margin ratio, and that is a ratio of the available to the required NPSH.

Okay. In the BWRs, the two systems, RHR system and the low-pressure coolant injection -- I'm sorry -- the low-pressure based system, these are the ones that are the main systems, they're pumps. They draw water from the suppression pool and spray the vessel by the LPSCS and the RHR is LPCI injection, the low-pressure coolant injection, drawing water from the suppression pool. So when the suppression pool gets higher in temperature, that's when its vapor pressure increases and that's when the CAP is requested. In the PWRs, the safety injection pumps in the recirculation mode of the PWR and also the containment spray cooling for efficient products removal and cooling of the containment. So those are the pumps that mainly require CAP for the NPSH.

20 CHAIR MARCH-LEUBA: Ahsan, in the
21 analysis, containment spraying has two effects. It
22 removes contamination, of course, but it helps cool
23 the containment and gives you additional NPSH and the
24 sump conditions margin.

25 MR. SALLMAN: Exactly. That's because

1 NPSH is, the available NPSH is a transient thing, and
2 that keeps on changing as the transient goes on.

3 CHAIR MARCH-LEUBA: So if you turn on the
4 spray, there is a race. You know, on the one side,
5 you start lowering the pressure of the CAP, lowering
6 the pressure in containment. On the other side, you
7 also increase your margin.

8 MR. SALLMAN: Yes.

9 CHAIR MARCH-LEUBA: So the calculation
10 from the Reg Guide procedures requires you to do the
11 calculation properly for --

12 MR. SALLMAN: Yes, yes. The calculation
13 of the containment, calculation consists of the
14 suppression pool or the sump temperature conservative
15 calculation of the suppression pool with conservative
16 inputs and also for the PWRs the sump calculation,
17 sump temperature calculation, which are transients.
18 So based on those temperatures of the sump temperature
19 or the suppression pool temperatures, the NPSH is
20 calculated, the available NPSH is calculated.

21 CHAIR MARCH-LEUBA: Yes. But my point,
22 maybe I'm not really properly -- containment spray is
23 likely to be an operator action.

24 MR. SALLMAN: Yes.

25 CHAIR MARCH-LEUBA: Which will happen at

1 random times. The procedure will tell you one thing,
2 and the actual human factors engineer will tell you
3 something else. And I see it's a difficult
4 calculation because you're likely to reduce the
5 pressure of containment faster than you will reduce
6 the temperature of the sump.

7 MR. SALLMAN: Yes. When they do the
8 analysis for the containment cooling or the
9 suppression pool cooling, they follow whatever the
10 procedure is, and the safety analysis is based on --
11 like for BWRs, there's ten minutes allowed for the
12 operator action to switch from the LPCI mode to the
13 containment, to the suppression pool cooling mode. So
14 that is an operator action, and the PWRs, PWRs,
15 mainly, it is at the sump recirculation mode when the
16 containment sprays are initiated. So that is, more or
17 less, several minutes, I think, maybe a half an hour,
18 after a LOCA, a large-break LOCA initiation. So
19 there's plenty of operator refinement; and if they
20 follow the procedures for the containment spray,
21 that's how the calculation analysis is done.

22 CHAIR MARCH-LEUBA: Okay. Thank you.

23 MR. SALLMAN: The recirculation is, you
24 know, in the BWR, it is more critical, the operator
25 action is more critical because it's only -- but the

1 PWRs, there's a lot of time before the sump flow is
2 initiated.

Okay. Go to the next slide. The regulatory requirements are GDC 35, which is for the safety, for the RHR LPCI injection, and the GDC 38 is the containment heat removal for both, and that is RHR pump on the containment spray pumps.

The guidance initially was also included, some of the guidance was included in the Reg Guide 1.82 before this revision, and that is in this section which I've noted here, 131, which requires conservative calculation for the transients and for a typical test for crediting containment operation and cavitation, calculation of the pump water temperature and head loss in the suction strainer.

Okay. The uncertainty analysis and the NPSH margin, that was a recommendation also from the ACRS following the BWR Owner's Group topical report, which provided us with a Monte Carlo calculation to calculate the margin, and that was also recommended. And then special, for special events, which is, in the BWRs, it's station blackout event and Appendix R fire event and an adverse event. Those three events are the special events in which it was cited and agreed upon that the realistic, instead of conservative

calculation, realistic inputs or nominal inputs can be used.

3 CHAIR MARCH-LEUBA: And this is consistent
4 with how we analyze special events.

5 MR. SALLMAN: Right.

6 CHAIR MARCH-LEUBA: For all the other
7 analyses we do.

8 || MR. SALLMAN: Right.

9 CHAIR MARCH-LEUBA: Nothing unusual about
10 it.

1 air content in the -- so that is given in the next
2 slide. I'll talk about that also.

Pump speed is one of the factors that would affect the difference. Water temperature, the water temperature which is different at the factory -- the water temperature was recommended not to be considered because if there's an increase in the water temperature at the site, that means that NPSHR would go down. So that was not included in this guidance.

10 The third one is a suction, the suction
11 piping configuration, which is different. So that is
12 another uncertainty. And the last one is the air
13 content in the water, which may be different at the
14 site.

15 So all these uncertainty values were
16 evaluated by the staff with a pump consultant. He
17 gave us the guidance on how to use these
18 uncertainties.

19 So it was decided and it was also
20 recommended by the ACRS to use the NPSHR effective,
21 which includes uncertainties in the NPSH for the DBA
22 LOCA. And for the special events, for the BWR special
23 events, station blackout and Appendix R events, you
24 can use the three percent which is provided by the
25 site.

The ones that we reviewed, some of the EPUs that were reviewed, they decided to use 21 percent uncertainty, which is the pump consultant gave us a bounding value of that. And the guidance says either, you know, the plant licensee should come up with a justification of the uncertainty, and they decided to use what was suggested by the pump consultant. That is in his report, 21 percent.

Okay. This slide shows if there's a negative NPSH margin then it should be, then the test should demonstrate that the pump will perform its safety function. Operation for a limited duration, less than a hundred hours. And if the test is done on the actual pump or a similar model and the testing at the same speed, so, in that case, if it is properly tested using these recommendations, then the guidance says that, yes, you can use negative margin.

18 CHAIR MARCH-LEUBA: Could you explain a
19 little? Go back to Slide 14.

20 || MR. SALLMAN: Okay.

21 CHAIR MARCH-LEUBA: Negative NPSH margin,
22 even after applying the CAP? What do you mean by
23 negative margin?

24 MR. SALLMAN: Negative means NPSHa is less
25 than NPSHr.

1 CHAIR MARCH-LEUBA: With or without the
2 CAP credit?

3 MR. SALLMAN: For DBA -- for DBA, it has
4 to be effective. Effective means uncertainty.

5 CHAIR MARCH-LEUBA: Yes.

6 MR. SALLMAN: If you use that -- if you
7 use that credit, so you use NPSH effective, and you
8 use CAP credit, and then that -- that means that you
9 have applied certainties and you compared NPSH --
10 availability of the NPSH required. So that's how you
11 come to the NPSH margin or the DBA.

12 And, similarly, for the special events,
13 you subtract available minus the fee percent NPSH.

14 || CHAIR MARCH-LEUBA: So --

15 MR. SALLMAN: If there is a negative
16 margin -- if there is a negative margin in such cases,
17 I think which is very rare, you know, we haven't seen
18 such thing, but the guidance allows that, and then it
19 -- the pump is tested for these conditions.

20 CHAIR MARCH-LEUBA: So they're testing,
21 running the pumps with an NPSH negative.

22 MR. SALLMAN: Yes.

23 CHAIR MARCH-LEUBA: And it -- eventually,
24 the pump destroys itself. But for the first
25 100 hours, available to operate in a slightly

1 different mode, but not --

2 MR. SALLMAN: Well, I don't know if this
3 test has been done, but we are saying that this --
4 this is -- this is required to be tested if -- if the
5 licensee say we're going to operate a negative margin.
6 Okay. Then let's do this test.

7 CHAIR MARCH-LEUBA: Okay. But nobody is
8 really --

9 MR. SALLMAN: No. No, yeah. Yeah.

10 CHAIR MARCH-LEUBA: Yeah.

11 MR. SALLMAN: This is in the guidance.

12 CHAIR MARCH-LEUBA: Okay.

13 MR. BLEY: Can I -- can I jump in? This
14 is Dennis Bley again. I think for me -- and I kind of
15 think for most of the members at the time -- the
16 staff's pump consultant's reports were really
17 enlightening. At least for me, with an operating
18 background, I always thought you're losing -- loss of
19 suction head, you're done; the pump is gone.

20 But there is the idea that, you know, two
21 things that are happening. The pump, as you begin to
22 lose it and go negative, you -- and start cavitating
23 slightly, you lose pump efficiency, but you also start
24 doing damage. And there is a pretty extensive time
25 period before you really destroy the pump.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So it was a very interesting set of
2 reports that they brought forward.

3 MR. SALLMAN: Yeah. You know, I have --
4 I have a backup slide on that. What erosion damage
5 would be done to the pump, it would be thousands of
6 hours I guess, I think it mentioned in this report.
7 That the erosion damage, because of the cavitation and
8 negative NPSH, pump operation could take -- take that
9 while operating several -- several hours, several --
10 I think it has been closing for thousands of hours.

11 MEMBER HALNON: Yeah. This is Greg.
12 Those low-pressure injection pumps and PWRs are very,
13 very robust. Matter of fact, I think they are
14 repurposed from old paper slurry, slur plants that
15 they use. So they are very resistant to any kind of
16 major or quick erosion or cavitation problems.

17 MR. SALLMAN: Okay. We'll go to the next
18 slide. So this slide is presenting on the cavitation
19 erosion, insufficient NPSH margin resulting in pitting
20 of the propeller blade and other pump parts due to
21 condensation caused by the vapor bubble implosion.

22 So the recent study, the acoustical
23 measurements experience shows maximum erosion rate
24 after the NPSHa value, which is between three percent
25 and the cavitation's inception margin ratio of four.

1 So this -- this slide shows the erosion
2 zone and cavitation, non-cavitating zone, the three
3 percent head drop curve.

4 CHAIR MARCH-LEUBA: So what was the story
5 of this slide and the previous discussion is that
6 there is no sharp edge at which you hit it, the pump
7 blows up, because it -- vibrating so much it kills
8 itself. It's a slow erosion, a slow degeneration, so
9 you can have cavitation for 100 hours for pumps and it
10 still survive.

11 MR. SALLMAN: Yeah. Even more than that,
12 the pump consultant report, it was -- and I can open
13 that backup slide if you want me to.

14 CHAIR MARCH-LEUBA: No need. I think I
15 hear what you're trying to say, that we always tend
16 to think you cavitate, your pump is just vibrating, and
17 it falls to the ground. And it's not the case. It
18 just has some erosion, has some vibration, has some
19 degrading, and eventually it will fail. But they are
20 very strong pumps.

21 MR. SALLMAN: Yeah.

22 || CHAIR MARCH-LEUBA: Thank you.

23 MEMBER DIMITRIJEVIC: This is Vesna. I
24 just want to make a comment that at this time, I mean,
25 you hopefully recover your suction, because once you

1 fail those pumps, doesn't matter how many hours. You
2 are doomed. You don't have any more means to cool the
3 reactor, because those are your RHR pumps in the PWR.

4 So it doesn't matter, the last 1,000 hours
5 we have to recover section before they fail. I mean,
6 this is just my comment in this case, because those --
7 all the pumps you have available to cool the plant
8 down, you know, after you are shutdown. So --

9 CHAIR MARCH-LEUBA: I agree, Vesna. But
10 typically this loss of NPSH is important. Eventually,
11 you are going to cool down your suppression pool and
12 recover your NPSH, of course using these pumps. So,
13 the better one.

14 MEMBER DIMITRIJEVIC: Right.

15 MR. SALLMAN: Yeah. The number of hours
16 that -- that these pump operate for the safety-related
17 operation, that is -- you know, during those hours,
18 even if there is minor degradation taking place in a
19 pump, nothing will happen to the pump. That was from
20 the report, consultant's report.

21 Okay. Go to the next slide.

22 Effect of non-condensable gas on
23 mechanical performance. That -- that is also one of
24 the points that the pump consultant mentioned that the
25 -- that's why for -- for the entrained air from the

1 suction source vortices or release pump solution can
2 affect the pump performance.

3 So the configuration of the PWR pump or
4 BWR suppression pool should consider eliminating
5 entrainment of air by spraying the vortices. These
6 are all guidance in there -- in this.

7 The last one is the time of operation in
8 the region of maximum relationship be limited.

9 Okay. This is one of the items that was
10 included in the guidance that if -- to demonstrate the
11 loss of containment isolation and containment leakage.
12 So if CAP is used, the licensee should demonstrate
13 that there is no preexisting leak in the containment.

14 And one of the -- one of the licensees --
15 I think Monticello -- they used CAP for I think
16 Appendix R analysis or the DBA LOCA also. They were
17 required to monitor the containment during plant
18 operation for preexisting leak. And this is how they
19 were monitoring, and that is also in the guidance.

20 In the EPU report that they gave us, they
21 included that -- that we will monitor the containment
22 during plant operation for a preexisting leak.

23 Another thing is, the licensee should
24 demonstrate sprays and coolers will not reduce the
25 needed CAP. Operator reaction to control CAP by

1 spraying a pool is acceptable, justified, and
2 operating procedures should include proper guidance
3 for operator action.

4 Go to the next slide.

5 CHAIR MARCH-LEUBA: Hold on. This is
6 Jose. Go back to there. The guide mentions -- I
7 don't know about which section -- that the risk for --
8 that the time -- that limiting the time at which you
9 can operate with CAP credit is not risk significant,
10 because the risk is controlled by preexisting leaks in
11 the containment, like this containment isolation, loss
12 of containment isolation, that you are talking about
13 at the time of the accident.

14 And the additional risk of the containment
15 development a risk -- a leak during the CAP credit
16 operation is very small.

17 Do you care to expand on that? I mean, is
18 this what you're saying here? That you mean that
19 raised by monitoring the containment before the
20 accident --

21 MR. SALLMAN: Yes. That is correct.
22 During plant operation, the licensee was using CAP --
23 either PWR or BWR -- and be required to monitor an
24 existing leak in the containment.

25 CHAIR MARCH-LEUBA: Right. But they --

1 MR. SALLMAN: For that --

2 CHAIR MARCH-LEUBA: They got -- the
3 recommendation from ACRS was that CAP should only be
4 used for short periods of time, and the rationale
5 behind it in my mind is that you don't want to develop
6 a leak 10 hours after the accident.

7 But the argument in the guide is that
8 there really -- there should be -- there is no need to
9 put a serious limit on the CAP credit time because if
10 you do a risk analysis, you find out all the risk is
11 controlled by preexisting leaks.

12 MR. SALLMAN: Right. Right.

13 CHAIR MARCH-LEUBA: Is that correct?

14 MR. SALLMAN: So that is correct, that
15 initially it was short period of time. But when we
16 included these uncertainties in the analysis, and
17 tried to see that the plant has -- the NPSHa is
18 compared with NPSHr effective, then we are also doing
19 this containment monitoring prior to the accident, or
20 during plant operation we are monitoring the
21 containment for -- for preexisting leaks.

22 These are all guidance that are in this --
23 in this guidance, in this Reg Guide to minimize or to,
24 you know, to -- for acceptable CAP, that the CAP is
25 acceptable, or not just for short period of time but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 they can use -- for the amount -- they're not really
2 necessary for the entire cooldown of the containment.

3 It could be -- some plan may be for short
4 period of time. Some plan may be during long-term
5 cooling. But it's -- it was initially for short
6 period as ACRS recommended. But with this guidance
7 that we have approved, or we have -- we have given to
8 the licensees, this will allow them to use the CAP as
9 needed, but to -- to use the CAP, then, to follow this
10 -- the guidance for the preexisting leak.

11 CHAIR MARCH-LEUBA: Okay. Thank you. You
12 can continue.

13 MR. SALLMAN: Thank you. Okay. This is
14 -- this is how the CAP is used, would be used for this
15 curve. This graph represents the containment
16 pressure. ATM is the containment pressure, and this
17 line here represents the atmospheric pressure or the
18 initial pressure in the containment before an
19 accident.

20 And during an accident, if the -- if the
21 pressure of the suppression pool or the sump goes
22 above -- above the vapor pressure at this -- at the
23 sump -- at the initial temperature, that's the -- this
24 line, HVP, is representing the vapor pressure at the
25 sump temperature or the suppression pool temperature.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 So if it is -- if the CAP is requested
2 within -- below this value, below this curve value,
3 the lower curve value, then that is mostly -- that is
4 mostly acceptable because you cannot -- if the
5 temperature in the pool is high, you cannot lose that
6 pressure.

7 So that is mostly PWRs. There is some
8 temperature goes higher than the 212 degrees, which is
9 atmospheric. So if that temperature -- if the
10 pressure goes -- the temperature goes higher than 212,
11 then the CAP is allowed to be used up to the vapor
12 pressure of the sump temperature.

If they -- if they are requesting CAP above that, above that HVP curve, that means that now they have to follow the guidance, which is a preexisting leak monitoring and whatever is in this guidance. And BWRs, mostly they -- their sump suppression pool temperature scales below 212 degrees during a LOCA, some of them which have notice that goes slightly -- maybe slightly above 212. It's 220 degrees.

22 And if they -- if they are using CAP, they
23 are asking to use CAP, then for that situation, that's
24 similar to the -- that's going above the HVP -- HVP
25 curve. So that means that they have to follow the

1 guidance of the preexisting leak, monitoring the
2 preexisting leak.

3 MR. BLEY: So, Dennis again. The HVP
4 curve --

5 MR. SALLMAN: Yes.

6 MR. BLEY: -- essentially we're saying
7 there, since that's arising from the kind of place you
8 end up after everything flashes and you -- you've
9 equilibrated, it would take a pretty big hole in
10 containment to really affect that very much.

11 MR. SALLMAN: Right. That's true.

12 MR. BLEY: So there's not much one could
13 -- could challenge on that one. Okay. Go ahead.

14 MR. SALLMAN: Yeah. So that's how the PWR
15 -- most PWRs that I have reviewed, they stayed below
16 that HVP -- HVP curve, and they are allowed without
17 any preexisting leak monitoring.

18 Okay. So now this slide is showing how we
19 want to quantify the monitoring for LOCA, perform
20 realistic analysis. Sorry, first they do the bounding
21 conservative analysis for the containment and NPSH,
22 both with bounding inputs, and perform realistic
23 analysis to determine the margin.

24 If the CAP is used, then in order to show
25 the margin, they are required to do the 95/95 lower

1 tolerance limit of Monte Carlo calculation to show the
2 margin. This Monte Carlo is only introduced in this
3 guidance in order for them to demonstrate that there
4 is -- there is margin, good margin.

5 And then for the DBA LOCA, the requirement
6 is that NPSH required -- should include uncertainty.
7 That is, the available must be compared with the
8 required, which is NPSH_r effective.

9 But for the special events, it's only
10 realistic inputs for the NPSH analysis, like the
11 suppression pool or the sump temperature. Doing a
12 realistic analysis is acceptable, nominal inputs, and
13 -- and then NPSH_r may be used without uncertainty.
14 That is a three percent provided by the vendor.

15 So this is how the margin is quantified.

16 MR. SCHULTZ: Ahsan?

17 MR. SALLMAN: Yes.

18 MR. SCHULTZ: This is Steve Schultz. Just
19 on the -- on this slide here where we're talking about
20 addressing these events with realistic analyses plus
21 uncertainty, I'm particularly interested in the BWR
22 special events. Have any of the licensees had
23 difficulties in applying the guidance in terms of
24 demonstrating that the results are favorable?

25 MR. SALLMAN: Not that I've known so far.

I viewed Monticello, Browns Ferry, Grand Gulf, three of them, and I didn't see any issues with them. I think mostly Browns Ferry got rid of the CAP because they demonstrated their heat exchanger performance was much better, and they were doing the monitoring of the heat exchanger also.

MR. SCHULTZ: Right.

MR. SALLMAN: And they got rid of the CAP, but Monticello used CAP. Monticello is the only plant that I know used CAP for Appendix R and for -- also for DBA LOCA, I believe. I'm not sure, but this is what I remember.

And they -- they did -- they followed this entire guidance.

MR. SCHULTZ: Yes.

MR. SALLMAN: You know, the demonstrated using effective -- NPSH_r effective and NPSH_a available. And also they introduced the preexisting monitoring of the previous D&D (phonetic). But the special events also in Monticello I remember, only that -- I think Appendix R.

MR. SCHULTZ: Okay. Thank you.

MR. SALLMAN: Yeah. Okay. This slide is the guidance summary, which we have almost discussed all of these things. But I just -- just to repeat

them here in the slide, that NPSH for DBA, it should be compared with NPSH_r effective, including the uncertainty, especially when you can use three percent NPSH_r effective.

The flow rate that should be used for the NPSHa analysis should be greater than the flow rate used in the safety analysis. That is one important point that is in there.

13 CHAIR MARCH-LEUBA: This is Jose. And
14 that's accomplished via procedures, modifying the
15 EOPs?

21 CHAIR MARCH-LEUBA: But venting is in the
22 procedures to protect containment. I mean, you don't
23 vent unless it is absolutely necessary. It's a good
24 thing to say, hey, I want to protect my pumps, so
25 protect my pumps. But if you do it by destroying the

1 containment --

2 MR. SALLMAN: That's a severe accident
3 situation, destroying the --

4 CHAIR MARCH-LEUBA: Yes, it is.

5 MR. SALLMAN: -- containment. That is not
6 the design basis. In the design basis scenarios, I
7 don't know if there is any plant that would do that,
8 but --

9 CHAIR MARCH-LEUBA: Not from design basis.

10 MR. SALLMAN: Not for design -- you're
11 talking about design basis. If any plant has some
12 procedure in which they talk about containment
13 venting, that should not authorize the CAP is used
14 (phonetic). That's one of the points in this
15 guidance.

16 CHAIR MARCH-LEUBA: Okay. And by CAP --
17 excuse me. If I --

18 MEMBER DIMITRIJEVIC: How about
19 containment cooling or containment spray?

20 MR. SALLMAN: Containment spray is one of
21 the safety -- one of the safety systems which is used,
22 and containments sprays are used. You know, that is
23 a normal thing for -- during a LOCA. I mean --

24 MEMBER DIMITRIJEVIC: No, no. Of course,
25 but that will cool the containment, and, therefore,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 reduce the pressure also.

2 MR. SALLMAN: Yes. Yeah, of course. Of
3 course.

4 MEMBER DIMITRIJEVIC: So is that part also
5 -- you said that he monitors the containment pressure.
6 That means, you know, the impacts venting and cooling,
7 right?

8 MR. SALLMAN: I cannot say cooling.
9 Cooling is -- cooling is a regular item in the
10 containment safety -- you know, the safety analysis.
11 Containment cooling is a part of the safety analysis.
12 While venting --

13 CHAIR MARCH-LEUBA: What you're trying to
14 say, Ahsan, is that the analysis that determined the
15 CAP credit assumed that sprays were working.

16 MEMBER DIMITRIJEVIC: Okay. Well, that's
17 exactly --

18 MR. SALLMAN: See, the CAP credit can be
19 at any time during short term, long term, in the PWRs,
20 in the short term if it is -- well, the short term
21 does not require CAP in PWR, because it is only -- the
22 CAP is only -- would be required when the sump
23 recirculation starts.

24 That time -- that's -- that time if the
25 CAP is required, it means, you know, the sprays aren't

1 operating. But one -- if the CAP is required, one
2 should not have a procedure which includes containment
3 venting.

4 CHAIR MARCH-LEUBA: Okay. And then --

5 MEMBER DIMITRIJEVIC: So they have
6 included the cooling in the CAP calculation.

7 MR. SALLMAN: Yeah. The cooling is --
8 cooling is included in the analysis. The regular --
9 the safety analysis includes everything, all of the --
10 all of the systems that come in operation during
11 containment cooling during an accident.

12 CHAIR MARCH-LEUBA: Yeah. The issue will
13 be, Vesna, the inadvertent actuation of the spray when
14 it's not supposed to.

15 MEMBER DIMITRIJEVIC: Yeah. But the spray
16 is not -- you know, spray is actuated by the operator.
17 I mean, you know, like, for example, in PWR, if you
18 have a large LOCA and you switch to recirc, let's say,
19 in half hour, that's -- you know, those are all after
20 all -- this is all operator action. So that's what I
21 want to say. This is not something which happened
22 automatically, so it can be controlled by operators.

23 MR. SALLMAN: Yes, yes. Yeah. The
24 analysis does consider that action, operator action.
25 And that's how the analysis is -- what determines how

1 much CAP is needed.

2 MEMBER REMPE: So this Joy.

3 MR. SALLMAN: Yes.

4 MEMBER REMPE: I guess I'm still thinking
5 about this loss of containment integrity. Venting
6 shouldn't occur during CAP use. When the Monticello
7 EPU came through, it was around 2013, and we were
8 still reacting to post-Fukushima insights.

9 And I know our letter -- at least I
10 thought our letter mentioned that as folks were
11 revising the severe accident (audio interference) that
12 that might be an issue. And I don't -- I think we
13 haven't seen anyone else that uses CAP for -- from the
14 BWRs or even -- and help me understand. How will the
15 staff ensure that there isn't any sort of operator
16 guidance that would conflict with what's here?

17 MR. SALLMAN: Can you repeat what -- the
18 question? Venting -- the regular analysis that we do
19 for safety analysis, based on which we determine the
20 CAP, would not include venting. If the CAP is used,
21 not including venting.

22 But I -- I am not sure how if you -- if --
23 when would the venting be opening and --

24 MEMBER REMPE: Well, there has been an
25 emphasis on early venting. In the revised guidance,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 there has been an emphasis on early venting for severe
2 accidents, you know, for prevention and mitigation.
3 And I just am wondering how the staff will ensure that
4 that revised guidance doesn't conflict with this
5 guidance that says we shouldn't have venting.

6 (Audio interference), others, Jose, do you
7 understand what I'm trying to say?

8 MR. BLEY: Joy, this is Dennis. Let me
9 cut in. At least for me, you're cutting out. We're
10 missing part of what you're saying. But I think I get
11 your question, and I'll try to repeat it because I
12 think others missed out.

13 And that is during a severe accident, we
14 have severe accident guidance now that says to vent
15 the containment. But if we got that -- if we have --
16 we're melting the core, we're beyond our concerns here
17 about CAP. So I don't think -- I don't see how they
18 conflict.

19 And Joy was worried that that guidance
20 could lead people to vent when they're still trying to
21 maintain CAP. But if you've lost the core, you've
22 lost that game of maintaining CAP, unless I missed
23 what you were getting at, Joy.

24 MEMBER REMPE: Okay. So I apologize for
25 my connection. And I understand that it is in the

1 severe guidance that this early venting is (audio
2 interference). So I guess I am looking into timing.
3 I mean, so basically, you're saying all the revised
4 guidance would wait until you really clearly see
5 you've had cladding heat up, and that there is some
6 sort of release before they would say we're going to
7 vent.

And so the timing is carefully monitored,
and there is no chance that the operators would vent
early and adversely affect this CAP use. And the
staff is aware of this (audio interference)
emphasizing early venting, and it will not occur at a
time -- for example, if you're trying to get rid of
hydrogen, and you're having oxidation of the cladding,
I just am wondering about, is the timing that precise
in that they would be careful that they are not
worrying about this long-term cooling capability?

18 I think you understand where I'm going,
19 Dennis, and --

20 MR. SALLMAN: Yeah, yeah, I understand.
21 But we are -- we are within the design basis. This
22 guidance does not go into the severe accident
23 scenario. So we are just talking about venting. Is
24 there a design basis accident? And the procedure --
25 one of the procedures for mitigation of a design basis

1 accident says, hey, you need to vent the containment.

2 That is not allowed if the CAP -- if they
3 use CAP, because, you know, then they lose the
4 pressure, and then of course it -- the pump will not
5 operate. But this is within the design basis. So
6 severe accident is a different, you know, area that
7 is --

8 MR. BLEY: What Joy is -- what Joy is
9 getting at -- and I suspect she has cut out for you
10 folks, too -- is that some of that guidance is trying
11 to jump the gun and save the containment by venting
12 it. And you don't have -- I'm still in the design
13 basis meter on the board. The operators are trying to
14 save the core. But at the same time, they have this
15 guidance saying to get an early jump on venting the
16 containment, and that one needs to be careful that
17 those two sets of guidance don't conflict.

18 And I -- I think that's a good point, and
19 somebody needs to -- to track that. I don't think it
20 -- I don't know that it goes in your guidance here,
21 but it ought to be somewhere.

22 MEMBER REMPE: Thank you.

23 MEMBER HALNON: Yeah, this is Greg.

24 MEMBER REMPE: Thank you, Dennis. That
25 helps. Thank you for interpreting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MEMBER HALNON: I think I'm a little
2 confused. We're talking now about an actual event and
3 what the procedures say as opposed to I thought this
4 was to be applied to the analysis that shows you can
5 credit containment pressure.

6 And I guess I'm confused now. Are we
7 still talking about the rules of a game to do the
8 analysis versus how operators actually respond? I
9 mean, I guess my question is, is this -- if the
10 analysis shows that -- and if you want to credit
11 accident pressure but the analysis shows that at some
12 point you have to vent, then you can't credit the
13 pressure at that point, or you have to change your
14 procedures to prevent venting.

15 MR. SALLMAN: That is correct, sir. If
16 the analysis is showing that you should not vent the
17 containment, if you want to use a CAP, and if -- if --
18 then there would be a different analysis. The
19 licensee -- if they say we want to vent the
20 containment during a design basis accident, then that
21 analysis would be a different analysis.

22 MEMBER HALNON: Right. And if you're
23 going to vent --

24 MR. SALLMAN: That is not --

25 MEMBER HALNON: Well, if you're going to

1 vent outside of your procedures that were part of the
2 analysis, then you're in a -- you're in a position of
3 declaring 50.54X and going outside your procedures
4 because something else is happening.

5 And as Dennis said, you are probably well
6 beyond the need for a containment pressure credit
7 anyway. So the analysis uses the procedures. The
8 procedures are followed by the operators. And if you
9 have to go outside of those procedures, that's one
10 thing. But if you follow the procedures that you've
11 used in the analysis, then you can credit the
12 containment pressure.

13 If the procedures are such that you can't
14 -- that you have to vent, then you can't credit
15 containment pressure.

16 MEMBER REMPE: Right. And I'm trying to
17 say that when somebody applies this analysis, they'd
18 better be careful that their procedures do indeed not
19 allow any sort of venting. Dennis put it well. There
20 is not a -- we're staying in the design basis region
21 here. I just want to make sure that that interface is
22 carefully monitored is what I'm trying to get at.

23 MEMBER HALNON: I agree, Joy, and that
24 should be part of the analysis and --

25 MR. SALLMAN: That's what -- this bullet

1 point is guiding the licensee that there should not be
2 any venting in the procedure if they are using CAP.
3 It's like -- it's like a precaution I guess, or one of
4 the things that the licensee should consider or look
5 at. If they want to use CAP, they should not vent the
6 containment in their procedure. So that should be
7 consistent with the analysis and the procedure.

8 MEMBER HALNON: But the point I made is
9 that the operator is not during the response to an
10 accident is not -- it's not in his mind whether or not
11 he is crediting containment pressure or not.

12 MR. SALLMAN: No. But the procedure -- I
13 believe the procedure should be developed based on the
14 analysis.

15 MEMBER HALNON: That's what I'm saying.

16 MR. SALLMAN: Yes.

17 MEMBER HALNON: They have to follow
18 procedures. And if they follow procedures, they
19 should be fine, because --

20 (Simultaneous speaking.)

21 MR. SALLMAN: Yes.

22 MR. SCHULTZ: This is not -- this is not
23 an operator activity statement. This is a go or no-go
24 statement as to whether CAP credit can be used.

25 MEMBER HALNON: It's built into the

1 procedural steps.

2 MR. SALLMAN: Yes.

3 Okay. The other items in this -- well, in
4 this slide, the likelihood of a preexisting leak, that
5 -- you know, during plant operation they should
6 monitor the containment for a preexisting leak. And
7 negative margin is acceptable, as we discussed about,
8 you know, that testing should be done.

9 Then the goal of maximum erosion should be
10 between 1.2 and 1.6. That was information that was
11 given to us by the pump consultant.

12 The topical BWR should follow the topical
13 report, which is -- which was submitted to NRC and
14 also there was an SER in that topical report, which
15 provided Monte Carlo, you know, uncertainty analysis.

16 For the PWRs, the CAP options are to use
17 the vapor pressure corresponding to the sump, sump
18 water temperature, or use a procedure similar to the
19 Owners' Group, Monte Carlo.

20 Emission time for the pump using CAP, to
21 include the recovery time from the accident. So these
22 are the guidance -- summary of the guidance, these few
23 bullets.

24 Okay. This slide is showing what EPU LARS
25 that were reviewed, and I was involved in reviewing

these LARs for the containment only. And the CAP, Monticello, Browns Ferry -- and Monticello was, you know, reactivated. Actually, it was suspended when we started the SECY paper.

And Browns Ferry was also suspended, but
they resubmitted their LAR. Then other ones were
Peach Bottom. They modified the hardware. Grand Gulf
was fine. Turkey Point -- not using Turkey Point 3
and 4. St. Lucie, Point Beach.

10 All these PWRs, they -- they use the CAP
11 up to the vapor pressure. None of them used both the
12 vapor pressure and the sump pressure.

13 CHAIR MARCH-LEUBA: So just to understand,
14 all these plans are taken clearly for CAP.

15 MR. SALLMAN: They're -- no, I'm not
16 saying they're taking CAP. But they followed the
17 guidance. And Monticello is the only one which took
18 credit of the CAP. Browns Ferry, they did some
19 modification of the heat exchanger I think, a
20 monitoring of the heat exchanger.

21 Peach Bottom is the one that modified the
22 hardware. And when I say modified the hardware, it
23 means they follow -- they follow this guidance, did
24 not use any CAP after they modified the plant.

25 Grand Gulf did not -- as I remember, did

1 not use CAP. Turkey Point, St. Lucie, Grand Gulf is
2 a BWR, so they did not use CAP. Turkey Point,
3 St. Lucie, and Point Beach, these plants they use CAP
4 but up to the vapor pressure, which is allowed in the
5 guidance.

6 So the only plant that I can think about
7 is the Monticello that they used CAP, and they did all
8 the analysis according to this guidance, and they also
9 have a preexisting leak monitoring in the facility.

10 CHAIR MARCH-LEUBA: Let me see if I can
11 summarize. The use of containment accident pressure
12 credit is not widespread among the fleet. It's only
13 a few plants here and there.

14 MR. SALLMAN: Well, it is --

15 CHAIR MARCH-LEUBA: It's allowed.

16 MR. SALLMAN: Yeah. When it started, Reg.
17 Guide 1.1, which is the Safety Guide 1.1, only allowed
18 -- did not allow to use CAP. But then, at that time,
19 some plants were using some CAP, like, you know,
20 mainly the Browns Ferry and Monticello, they were the
21 one that was using a lot of CAP in the analysis for
22 DBA and Appendix R fire analysis.

23 And at that time, when they were using a
24 lot of CAP, at that time the whole thing started
25 between ACRS and the staff, and the reviews and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

these, you know, letters were written and the SECY
paper was developed.

3 But later on when we got the revised
4 Browns Ferry LAR, they did not use -- they
5 demonstrated by analysis that they have an improved
6 heat exchanger which did not -- which required --
7 which has enough performance of the heat exchanger
8 that it is able to cool the suppression pool without
9 using CAP. And the vapor pressure was -- and
10 especially the Browns Ferry Appendix R analysis was
11 using too much -- too much CAP.

12 CHAIR MARCH-LEUBA: Okay. Thank you.

13 || Does any --

14 MEMBER REMPE: And I think, as I recall,
15 Monticello is a very low power BWR. So it was -- it's
16 a much lower power I guess is something to mention,
17 too, here.

18 || MR. SALLMAN: Yeah.

19 MR. SCHULTZ: So, Ahsan, what you're
20 saying about Monticello is that they used the
21 quidance, but they didn't have --

22 MR. SALLMAN: Yes. If you --

23 MR. SCHULTZ: -- to take credit for CAP.

24 MR. SALLMAN: Yes. Yeah. This guidance
25 was in the form of an interim guidance that we sent to

1 the Owners' Group, and that's what they used.

2 MR. SCHULTZ: Then you mentioned other
3 analyses that -- where CAP credit has been taken. Are
4 all of the ones in the third bullet there EPU LARS?

5 MR. SALLMAN: Yeah. All of them are EPU.

6 MR. SCHULTZ: Okay. Thank you.

7 CHAIR MARCH-LEUBA: So, Ahsan, this ends
8 your presentation?

9 MR. SALLMAN: Yeah. These are the ones
10 that I reviewed. There was maybe some others which I
11 don't know, somebody else -- the staff may have
12 reviewed. But I don't know the status. But the ones
13 that I put here are the ones that I reviewed.

14 Yeah. This is the end of the
15 presentation, and if any more questions or any
16 questions, I can try to respond.

17 CHAIR MARCH-LEUBA: So, members, any
18 questions from the staff or discussion? I hear none.

19 I am going to --

20 MR. SCHULTZ: Excuse me. Jose, this is
21 Steve. I had a question for clarification. It was in
22 Steve's presentation where a comment was made that the
23 revised -- Rev 5 is for operating units, and then
24 there was a comment, something about additional
25 guidance could be provided for new reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 applications. Did I get that right? That this is not
2 -- this is not available for guidance or the guidance
3 would have to be modified for any new reactor
4 applications?

5 And one reason I'm asking that is, as I
6 saw -- was looking at references for the review, the
7 last -- the last ACRS letter I saw where CAP credit
8 was discussed was for the USA PWR application. And
9 some issues came up in the -- in that review where CAP
10 credit was being supported by the -- by the PRA or
11 there was some suggestion that it could be supported
12 by the PRA.

13 And the ACRS wrote a letter that suggested
14 that the PRA for the USA PWR was not sufficiently
15 developed to make that determination, and that in the
16 final discussion that an approach that would use best
17 estimate plus uncertainty would be the appropriate way
18 to go.

19 I'm not sure how that finally got resolved
20 in the approval, but, again, there is a new reactor
21 application, and it came up also in EPR. I was
22 wondering, what is the plan for new reactor
23 applications with regard to CAP credit?

24 MR. SMITH: Okay. So this is -- this is
25 Steve Smith. I discussed the comments. And basically

1 for new reactors, we -- or the public comments I
2 should say to make it -- make it clear. I discussed
3 the public comments.

4 Ahsan may want to jump in and discuss how
5 we would apply this to new reactors.

6 The reactor designs that you're talking
7 about are similar. Do you -- as far as GSI-191 stuff,
8 these reactors used basically the same guidance that
9 the reactors -- you know, the operating reactors used
10 for strainer and -- strainer testing, strainer issues,
11 and all that.

12 As far as CAP is concerned, I think we're
13 still -- we're still saying that if this guidance
14 would be applicable to those reactors, which I believe
15 it would be, it should be used.

16 We were not looking forward to the newer
17 -- you know, we weren't trying to do these reactors
18 that are going to be different. You know, they're
19 going to be, you know, molten salt reactors or that
20 kind of thing. We weren't trying to write the
21 guidance to be applicable to those kind of reactors.
22 But if it's applicable, if these are light-water
23 reactors, there is a good chance that this -- at least
24 some of the guidance that's included in this revision
25 of the Reg Guide is going to be applicable to them.

1 MR. SCHULTZ: And going back to the public
2 comments, then, there were a number of comments that
3 were made by NuScale. And I -- I think you may want
4 to expand on what you just said because I -- my
5 impression was that NuScale was saying that -- that
6 the guidance should be adjusted because in their
7 designs there is equipment that is described that
8 isn't in the NuScale design.

9 Could you elaborate on the NuScale
10 comments and how you've responded to those?

11 MR. SMITH: Right. So for those comments,
12 basically what we said, we -- we have responded
13 relatively generically, and we said that they should
14 look at the guidance. And if it's applicable to their
15 plant design, they should use it.

16 And our intention with the Revision 5 was
17 not to -- was not to determine which plants it is or
18 is not applicable to. We didn't want to -- we wanted
19 to allow, you know, the staff doing the review and the
20 licensees or the applicants who are designing the
21 plants to determine whether the guidance is applicable
22 to them or not and use it if it is -- you know, if it
23 would be applicable.

24 MR. SCHULTZ: Good. And then, just to
25 expand on that a little bit, in any case, what the

1 guidance is saying is that any change or any
2 application that's associated with CAP credit needs to
3 be evaluated on a -- needs to be evaluated by the
4 staff on a plant-specific basis and an application-
5 specific basis.

6 MR. SALLMAN: Yeah. That's correct. I'm
7 not sure what the new plants, which one required CAP
8 credit. I haven't seen any. But I am expecting that
9 if a new plant comes, I think I -- I have seen some --
10 some -- for the Korean plant, which was which one,
11 EPR? Yeah, EPR.

12 Yeah. That one -- that was a PWR, and
13 that was applying CAP credit up to the vapor pressure
14 of the sump pressure. And that's all they needed.
15 They did not go beyond that vapor pressure.

16 MR. SCHULTZ: That's how it was finally
17 resolved and addressed.

18 MR. SALLMAN: Yes. Yes, yes, yes. I
19 talked to some of the new reactor staff, and they --
20 they told me that this is how they use CAP.

21 CHAIR MARCH-LEUBA: Steve, any more
22 comments?

23 MR. SCHULTZ: No. That's fine. Thank
24 you.

25 CHAIR MARCH-LEUBA: Okay. Anybody else

1 have more discussion or questions for the staff?

2 Any member of the public has any comments
3 they want to place on the record? If so, please
4 unmute yourself and -- and say it now. I don't see
5 any phone numbers. So if you are on a phone number,
6 you can just star six.

7 I hear no members of the public wanting to
8 make a comment, so this will end the presentation.

9 We are now going to talk administrative a
10 little bit. We expect to have a full committee
11 meeting on November 1st, which is a couple weeks from
12 now, and write a letter. And any other members wants
13 to oppose the idea of having a full committee meeting?
14 Because I assume we all say that we should write that
15 letter up. Yes?

16 I hear no opposition to writing a letter,
17 so we will write a letter on November 1st.

18 My proposal to the staff is that you
19 provide us a reduced presentation, at most half an
20 hour, during the full committee to give us plenty of
21 time to have discussions, and the committee on the
22 open session and prepare the letter.

23 So certainly summarize GSI-191 and FLEX,
24 but I am looking for one or two slides each and
25 concentrate on the CAP issues that we have been asking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 you about.

2 And that's it. I am going to start
3 drafting a letter, which I have some basis for, but
4 this is going to be a difficult letter to write. To
5 the members, if anybody wants to provide me input on
6 which direction using the conclusions should go, or
7 provide me some write-up for the discussion, that
8 would be fine, too. Please do so soon, because we
9 need -- I mean, we have only really next week to work
10 on this.

11 I am going to propose to write the
12 conclusions maybe this week. Let me see. But I will
13 try to get the conclusions and socialize them with the
14 committee to see -- to get feedback. Then we'll get
15 the letter done and keep going from there.

16 Any more comments or questions? Because
17 we have plenty of time.

18 Okay. I hear nothing. Can somebody make
19 some noise and affirm that I am still connected?

20 MR. SCHULTZ: Yeah. We hear you.

21 CHAIR MARCH-LEUBA: Okay.

22 PARTICIPANT: We are still there, Jose.

23 CHAIR MARCH-LEUBA: All right.

24 MR. SCHULTZ: The Reg Guide has been
25 published.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 CHAIR MARCH-LEUBA: Yeah.

2 MR. SCHULTZ: We're not -- the committee
3 is not commenting on a draft guide that is going to be
4 modified. It would be commenting on proposed changes
5 in the future.

6 CHAIR MARCH-LEUBA: That is correct. So,
7 basically, we are commenting on Revision 6. If we
8 have a serious issue, we are commenting on Rev 6.

9 MR. SCHULTZ: Yes.

10 CHAIR MARCH-LEUBA: Now my -- my
11 inclination now -- we are still on the transcript. My
12 inclination now will be for reaffirming that we -- we
13 still support previous ACRS recommendations and
14 conclusions with the proviso that I believe the staff
15 has done a fantastic job recommending the methodology.

16 So at least if somebody uses CAP, we know
17 how to calculate it and what uncertainties are used.
18 But we still believe it's not -- it reduces the -- an
19 additional defense-in-depth layer, because the primary
20 basis for -- for the way we work with reactors is that
21 the layers, the protected boundaries are independent
22 from each other.

23 And now by allowing CAP, you are defending
24 the vessel with the containment. And they are not
25 independent anymore, but we will work on the language

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 and see if we can make it happen.

2 MR. SCHULTZ: Okay. Great idea, Jose.

3 CHAIR MARCH-LEUBA: Any comments?

4 MEMBER HALNON: Yeah. This is Greg. That
5 to me was the key issue coming out of this. It's not
6 so much that the physics don't -- don't allow for
7 pumps to survive as long as the pressure is there.

8 So, yeah, I need to think about that
9 portion a little bit more and understand how the
10 interplay between that and the other areas of defense-
11 in-depth might be overlapping. Because you're
12 basically right, we're reducing the independence of
13 the barriers, which is a key portion of the defense-
14 in-depth concept in my mind.

15 So, you know, I appreciate you voicing
16 that because that's what I was struggling with
17 throughout the presentation was the physics are fine
18 to me.

19 CHAIR MARCH-LEUBA: Yes. The calculations
20 are good.

21 MEMBER HALNON: Yeah. It's the concept
22 and the policy and then the overall effect on the
23 defense-in-depth barriers.

24 CHAIR MARCH-LEUBA: Yeah. And likely on
25 the letter we need to take a position about advanced

1 reactors. I like the position of the staff that says
2 that, well, if it applies to you, you use it. If
3 you're like NuScale and you don't have CCS pumps,
4 well, it doesn't apply to you.

5 And, Joy, you have some comments?

6 MEMBER REMPE: Well, it's just a thought
7 that was kind of in my mind, since we're -- we have
8 time to opine a bit.

9 The more -- the plants that are having
10 difficulty in dealing with GSI-191 often use a risk-
11 based argument to get over that hump. And the request
12 that they evaluate this in a risk assessment is kind
13 of interesting. You know, what we had suggested that
14 was denied, and then yet that's what plants rely on
15 when they want to try and keep operating, is my
16 connection enough you can understand me?

17 CHAIR MARCH-LEUBA: Yeah. You sometimes
18 break up a little bit. But you're doing good now.

19 MEMBER REMPE: Oh, okay. Well, the --
20 anyway, just a thought that has been running through
21 the back of my mind that might be worth thinking about
22 for the letter, but it's up to you. I don't feel that
23 strongly about it, but it's just an interesting angle.

24 CHAIR MARCH-LEUBA: Yeah. God knows --
25 and you all know, too -- that I'm not a big proponent

1 of risk-informed anything. But for something like
2 this, I would like to be informed about the risk that
3 we are taking. I mean, it -- just saying no, we don't
4 want to do it because we're doing it
5 deterministically, it sounds hollow to me.

6 MEMBER PETTI: So I've been sitting
7 listening, and of course, you know, I wasn't involved
8 with any of the previous ACRS discussion. But it
9 seems like, if you just think about how different a
10 place we are in today than back when those letters
11 were written, in terms of risk-informed regulation
12 being more ingrained in the agency as part of its DNA,
13 the letter, you know, can serve a really good purpose
14 to reflect how different things are today than they
15 were back then, even the fact that there is different
16 Commissioners, right?

17 So some of that is important, and I -- I
18 do want to explore this defense-in-depth thing a
19 little bit more, because I -- what I really don't want
20 to see is a -- there's sort of a practicality to using
21 CAP. That's what the physics says, you know, would
22 actually happen.

23 And if you have to weaken defense-in-depth
24 a little in this small particular area, I just worry
25 about sort of rigid -- I call it safety theology if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 you will in light of, you know, some tactical
2 considerations and how you balance that. To me,
3 that's important and something we can I think talk
4 about, you know, in full committee.

5 MEMBER BROWN: This is Charlie.

6 CHAIR MARCH-LEUBA: Yes. Yes.

7 MEMBER BROWN: I think I was here back
8 when we started all this stuff back in 2008, '09, and
9 all those -- the initial stuff. So was Dennis. And
10 we went -- all the math that we went through today,
11 the physics of the whole thing, was developed and
12 presented in spades. And my memory was that we were
13 very, very concerned as -- you know, I'm not much of
14 a risk-informed person either, so it's deterministic.

15 But our emphasis was really on what was
16 perceived as a -- in my mind, the gradual reduction in
17 defense-in-depth type -- the defense-in-depth type
18 concepts. And that's why the letter fundamentally --
19 that I think the last letter fundamentally said that.
20 It was a defense-in-depth type issue.

21 And we've -- I understand Dave's comment
22 relative to how things are more -- you know, the DNA
23 is changing in terms of the risk-informed mode. But
24 I think that needs to be tempered with the realistic
25 thought process of not degrading the committee's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 | emphasis on defense-in-depth either.

2 So I agree with Jose's fundamental thrust.
3 We may want to tailor it somehow, but that's -- Dennis
4 can chime -- he was there also, and I -- I'm not sure
5 -- Joy, I'm not sure when you -- you were there in
6 2011, weren't you?

7 MEMBER REMPE: Yeah. I started in 2010.

8 MEMBER BROWN: 2010. Okay. So you should
9 have been party to some of this discussion as well, if
10 I remember correctly.

11 MEMBER REMPE: You remember correctly.

12 MEMBER BROWN: Okay. So that's my memory.
13 You know, admittedly, I'm pretty old now, so -- but
14 the defense-in-depth issue weighed heavily on most of
15 the members' minds. I think it was a fairly unanimous
16 type approach. We did not -- it wasn't an eight to
17 seven vote in terms of the tone of the letter. So
18 that's also my memory.

19 But anyway, we didn't -- we don't have
20 transcription during that voting period, so I don't
21 know how we could recover that.

22 Dennis, do you have any other different
23 memories than I do?

24 MR. BLEY: No. That's pretty close. The
25 letter was -- letters were unanimous as far as I can

1 remember. I'm almost certain of that.

2 MEMBER BROWN: Yeah. That's my memory.

3 MR. BLEY: One of our members later became
4 a Commissioner and voted against this, and some have
5 held that against him ever since.

6 MEMBER BROWN: Was it George? You're
7 talking about George?

8 MR. BLEY: Yeah. You know, the risk here
9 is almost surely very low, but you ought to be more
10 sure than you can from that statement by me. That's
11 kind of it.

12 There had been a history of looking at CAP
13 as not much for a very short time, and very short
14 times had been just a few minutes, and then all of a
15 sudden we had an application that really went much
16 closer to losing that positive suction head.

17 And that time extended over a pretty long
18 period of time, at least by comparison to anything
19 they didn't look at before. And that was kind of a --
20 I think a shock for most people who first saw it.

21 But you had it right.

22 MEMBER BALLINGER: this is Ron. I mean,
23 is it time for us to say in this letter, or some other
24 place, that there is a -- in this case, there has been
25 a bit of a conflict between risk-informing and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 deterministic and having a little bit of a gray area
2 there.

3 But that we ought to be sure that in the
4 future -- or we should say something that this is --
5 this issue -- not CAP, but this issue of risk-based or
6 risk-informed decision-making has the likelihood of
7 running up against defense-in-depth again. And we
8 ought to be sure that we say something like that, so
9 that we're on the record, because it might be
10 important in some future negotiation or discussion
11 that we should have said this.

12 MR. BLEY: I think one thing you -- you
13 folks who are still on the committee should consider
14 is we had a series of essentially debates with the
15 staff on this, and then we escalated it by sending a
16 letter to the Commission saying, you know, we can't
17 come to agreement with the staff.

18 And the Commission said, in terms of one
19 of the Commissioners at the time, reasonable assurance
20 is what we say it is, they said no, we're going with
21 the staff. So whatever you write ought to be -- keep
22 that in mind.

23 MEMBER BALLINGER: Yeah. I mean, we
24 should think about reminding people of this.

25 MR. SCHULTZ: This is Steve. The other

piece that -- when the staff -- the committee presented its positions to the Commission, and the staff did as well, in the staff's presentation to the Commission -- and I think in the Commission's deliberations -- I haven't read the statements by the Commissioners.

7 But there were two things. One was the
8 staff promoting an approach -- the analytical
9 approach, which has been discussed today and now
10 documented in the Reg Guide.

11 The second piece of that was looking at
12 what the ACRS Committee was proposing, which was a
13 strongly-based probabilistic risk assessment, fully-
14 based probabilistic risk assessment, including
15 external events, and so forth, that that was the
16 approach that was being proffered.

17 And the staff and the Commission both
18 evaluated what impact that would have on those
19 licensees that were -- would need to reevaluate their
20 use of containment accident pressure. And that was
21 part of their -- I mean, that was part of their
22 considerations. I don't know how much it affected
23 their determination, but it was -- it was fully
24 presented and evaluated by the staff in terms of what
25 it would take for the staff to put together such an

1 approach and what it would mean with regard to
2 licensees' not only reaction to it but the imposition
3 that that could impose on the licensees and whether
4 that was something that the Commission could do or
5 would do.

6 So it's worthwhile -- it's worthwhile
7 going back and reading -- reading the Commission's
8 statements and the staff's presentation to the
9 Commission at that time.

10 MR. BLEY: Yeah. I'd back Steve up on
11 that. But read the Commissioners' vote sheets.
12 They're still interesting, and kind of see where they
13 stand.

14 Probably the strongest feeling on the
15 committee at the time was unless there is some really
16 outrageously expensive reason not to do it, you ought
17 to fix this instead of coming in on -- relying on
18 analysis.

19 MEMBER BROWN: Amen. I remember that we
20 made those comments. It had to be really a very
21 expensive approach to making a fix, and so it should
22 be only under extenuating circumstances.

23 MR. BLEY: And I think the staff is -- I
24 have to go back and read their words, but from their
25 presentation it sounds like that's where they -- where

they stand. The first choice is to not have it as an issue.

3 MR. SCHULTZ: I saw that in the -- in the
4 discussions, and it's reaffirmed in the guide.

5 CHAIR MARCH-LEUBA: Yeah. The guide says
6 if -- if it's practicable to fix it, fix it. And
7 then, if not, then start calculating.

8 Going back to what Steve said, I mean,
9 because on -- from the logical point of view, having
10 a Level 3 full-blown PRA, with all external events and
11 everything, it's very expensive. And we keep getting
12 comments back from industry, even on Part 53, saying
13 gee, I have a little two-megawatt reactor that doesn't
14 need it. Why do you want me to spend this many
15 million dollars on a PRA that doesn't do anything?

16 So we need to be conscious that even
17 though logically you should know the risk to the full
18 extent of the calculation of ability, sometimes it's
19 not worth the money.

20 MEMBER PETTI: Except that 52 requires it,
21 and 50 will -- if the rule passes, would also require
22 it for new plants. So --

23 || CHAIR MARCH-LEUBA: Yeah.

24 MEMBER PETTI: -- there's an inconsistency
25 here. So --

1 MR. BLEY: Well, you can found this stuff.
2 You know, if you're simple, you just assume the worst
3 case happens and see what -- what it looks like.

4 You know, the staff's position that the
5 most likely way you lose pressure is to -- to have
6 lost it initially by a bad valve lineup or something,
7 so there's a leak. That's true.

8 But the idea of a really strong seismic
9 event that could fail the containment and fail -- lead
10 to a LOCA somehow is -- while it's pretty unlikely,
11 but the combination is -- those kind of combinations
12 come up in external events, fires, or seismic events
13 -- in some old plants, wind events -- as the most
14 likely way you get those combinations of things
15 happening. So that's kind of where folks were coming
16 from back then.

20 CHAIR MARCH-LEUBA: Yeah. And Steve sent
21 me a reference to the APWR letters, and I would
22 include them -- we'll include them back into the
23 SharePoint and we'll send you a link, so you can read
24 them. I haven't had time to read it myself. I just
25 saw it was APWR.

1 Going back to a comment that Ron made half
2 an hour ago, the way I put it is we, in ACRS, have a
3 concern with this topic. We raised it, and we raised
4 it, and we elevated it all the way to the
5 Commissioners.

10 MEMBER BALLINGER: It's not a complaint.
11 It's a reminder.

12 CHAIR MARCH-LEUBA: Yeah, yeah. It would
13 be nice if we can gain some broader perspective that
14 the problem applies -- the problem of not using risk
15 information applies not only to RG 182 but new
16 reactors, GSI-191, other things.

If we could frame it in -- in a lesson learned for other topics, it would sound more valuable, in my opinion.

20 MEMBER BALLINGER: Yeah. That's -- that
21 I think was what -- the point I was trying to make.

22 CHAIR MARCH-LEUBA: Yes.

23 MEMBER REMPE: So that's --

24 MEMBER BALLINGER: I mean, P&P is kind of
25 an academic exercise in some respects. But there may

1 be cases later on which aren't.

2 CHAIR MARCH-LEUBA: Joy?

3 MEMBER REMPE: Well, that's the reason I'm
4 thinking this angle about what's going on, like with
5 the Vogtle 1 and 2 request for GSI-191. They relied
6 on risk assessment. South Texas Project did this,
7 too, to get rid of GSI -- or get around GSI-191.

8 It's so related to this topic. I think
9 it's a way to broaden it and point out that the more
10 difficult ones have had to rely on risk assessment.

11 CHAIR MARCH-LEUBA: Yeah. I mean, it's
12 not fair that the applicants get to rely on risk
13 assessment only when they want to, only when it's good
14 for them.

15 MEMBER REMPE: Yes. That's where I'm kind
16 of thinking of going, but anyway, it's just an idea.

17 CHAIR MARCH-LEUBA: This letter is going
18 to be very difficult, speaking of which, Joy, we have
19 scheduled it for November. But the guide has been
20 issued. If we are extremely busy and we cannot finish
21 it in November, we can do it in December, we can do it
22 in February.

23 MEMBER REMPE: This is all fine. Right
24 now, we have three letters for November, and I've
25 actually seen one draft and I think it's in really

1 good shape. But I think Dave's letter will be more
2 difficult on Part 53, and this one may be.

3 But, you know, let's just see what we can
4 get done. We have an extra half day in December.

5 CHAIR MARCH-LEUBA: I was just offering
6 the fact that the guide was issued in August, and
7 there is no hurry for our letter.

8 MEMBER REMPE: Sure. I meant to say, by
9 the way, an extra half day in November. So, and we
10 have time in November -- or December also, so let's
11 see what we can do.

12 MEMBER HALNON: Jose, you stated that
13 licensees shouldn't be able to just use risk
14 information anytime they want to. That doesn't apply
15 in this case. These plants that couldn't solve
16 GSI-191 deterministically had to turn to the risk
17 because of the -- it's not just because they wanted
18 to. It's because it -- that was the best course of
19 action.

20 I think that licensees should be able to
21 use risk information if the deterministic and
22 mechanistic areas of -- you know, just putting in
23 bigger strainers is not possible. So I don't know.
24 I just -- I'm not sure that's what you meant, but it
25 sounded to me like you meant --

1 CHAIR MARCH-LEUBA: That's not what I
2 meant. What I meant is I -- I don't know what the
3 risk is when you allow CAP use. We suspect it's very
4 small, but I don't know.

5 MEMBER HALNON: Okay. I got it. I
6 thought you were making a broader statement, so I
7 apologize.

8 CHAIR MARCH-LEUBA: Okay. I wanted to
9 make another broad statement, Joy, and this is for
10 your ears. This was -- half an hour was fantastic.
11 We should have these discussions of the two committees
12 more often, because more often than not, the committee
13 chairman --

14 (Simultaneous speaking.)

15 CHAIR MARCH-LEUBA: -- then we complain
16 about the commas and whiches (phonetic). We should do
17 this more often. Just offering that for thought.

18 MEMBER REMPE: I agree. It's nice to have
19 that flexibility.

20 MEMBER BALLINGER: But, you know, it
21 really depends on the subject I think.

22 CHAIR MARCH-LEUBA: Yeah.

23 MR. BLEY: Well, it does, you know, but
24 the committee is offering in a hurry to wrap up these
25 --

1 MEMBER PETTI: I'm on a call that's going
2 to end soon, yeah.

3 MEMBER REMPE: Dave, did you know you're
4 -- you need to mute.

5 MEMBER PETTI: So should we just set a
6 time for you to --

7 MEMBER REMPE: David, I'm going to mute
8 you. Okay.

9 CHAIR MARCH-LEUBA: Okay. I'm going to
10 mute everybody. Any more discussions?

11 MR. BLEY: Well, I was just going to make
12 a suggestion to the committee. In recent few years,
13 we've been really focused on not extending a meeting
14 beyond the expected closing time and hurrying to
15 close.

16 If you go back 20, 30 years, when I used
17 to come to the committee, if there was an issue,
18 they'd keep going until, you know, 10:00 at night to
19 -- to make sure that they get everything worked out
20 that they wanted to work out. And I don't see a
21 problem with that, but that's up to you folks.

22 CHAIR MARCH-LEUBA: Yeah. I remember
23 being trained on using the side door on Saturdays. We
24 hadn't used it in the last four years.

25 Any more comments, guys?

1 MEMBER REMPE: Well, I have a comment for
2 Ron that I'm hoping that November subcommittee SHINE
3 will have that day when we're going through the memos
4 and the letter and we'll have a similar type of
5 discussion for him.

6 MEMBER BALLINGER: I have absolutely no
7 doubt whatsoever.

8 (Laughter.)

9 MEMBER REMPE: Okay. Thank you, Ron. I
10 just thought I'd kind of point that out.

11 CHAIR MARCH-LEUBA: Okay. So, with that,
12 I'm going to let the Court Reporter go home. The
13 official part of this meeting is over. You can -- you
14 can stop it now.

15 (Whereupon, the proceedings in the above-
16 entitled matter went off the record at 11:53 a.m.)

17

18

19

20

21

22

23

24

25

Reg Guide 1.82, Revision 5

GSI-191 Issues

ACRS T/H Subcommittee, October 20, 2022

Ahsan Salman

Steve Smith

RG 1.82 Changes in Rev. 5

- GSI-191 (Main body of RG and Appendix A)
 - New information on the effects of debris on long-term core cooling
 - Added specific information and references to evaluate debris in-vessel effects
- Use of CAP (Appendix B)
 - Added new Appendix B - guidance on the use of CAP in determination of NPSH margins
 - Applies to existing and new BWRs and PWRs licensed under 10 CFR Parts 50 and 52
 - Some plants are licensed to use CAP for determining available NPSH for ECCS and CHR pumps
 - RG 1.1 states only containment pressure prior to LOCA should be used in NPSH calcs
 - RG 1.1 withdrawn (4/2015); new CAP guidance to be included in RG 1.82, Rev 5.

Background

- GSI-191 Summary
- Regulatory Guide (RG) 1.82 Revisions Related to GSI-191
 - In-Vessel Guidance Updates (2019)
 - Penetration Testing Guidance
 - Improved Clarity and Detail
 - Updated Knowledge Base Report (2014)
 - BWR Evaluation of Lessons Learned (2018)
 - Updated Jet Testing (2012)
 - Test Debris Preparation Guidance (2012)

GSI-191 Summary

- USI A-43 sump strainer blockage unresolved issue identified in 1979
 - Closed in 1985
- Several generic communications after 1985 regarding debris and adequate NPSH margins
 - Some were BWR specific
- Through 1990s many cases of debris problems
 - Affecting pump operation
 - In containment and pumps (and suction lines)
- Several cases of damaged strainers
 - Debris could go downstream
- BWRs evaluated and closed issue in 2000

GSI-191 Summary

- Opened GSI-191 in 1996 for PWRs
- NRC completed review in 2002 finding sump clogging to be a credible concern
- Issued BL 03-01 and GL 04-02 requesting
 - Licensees to take mitigative actions
 - Provide assurance that long-term core cooling (LTCC) would be successful considering the effects of debris
- GSI remained open because some technical issues were not fully understood

GSI-191 Summary

- Licensees evaluated debris effects and replaced strainers with models with much greater area and better filtering designs
- Chemical and In-vessel effects were not well understood
- Methodology for chemical effects accepted in 2007
- Final methodology for in-vessel effects developed in 2019
- Upon establishing accepted method for in-vessel effects, GSI-191 was closed in 2019 (ML19203A303)
- Licensees must still respond to GL 04-02

GSI-191 Summary

- GL 04-02 Plant Status
 - 9 low fiber plants closed using original in-vessel guidance
 - 10 plants closed out deterministically after 2019 in-vessel guidance issued
 - 7 plants have deterministic submittals under review
 - 2 plants – NRC awaiting final deterministic submittals
 - Risk-informed resolution
 - 2 plants closed
 - 2 plants under review (1 of these in concurrence)
 - NRC Awaiting LARs from 2 plants

Reg Guide 1.82 Changes for GSI-191

- Reference to Draft RG 1.229 for RI evaluation of debris effects (ML15335A179)
- BWROG evaluation of lessons learned since the BWROG closure
 - BWROG stating issues reviewed, no further concerns - ML17326A393
 - NRC Staff Technical Evaluation - ML18058A602
 - NRC letter accepting BWROG position - ML18078A061

Reg Guide 1.82 Changes for GSI-191

- NRC In-vessel Downstream Effect (IVDE) Safety Significance TER - ML19073A044
 - Evaluates risk of physical aspects of in-vessel debris effects on long-term cooling
 - Discussed with ACRS TH Subcommittee in April and September 2019
- NRC Staff Review Guidance for IVDEs - ML19228A011
 - Provides guidance commensurate with plant conditions and reactor/fuel design ability to accommodate debris in the vessel
 - Relies on findings from WCAP-17788-P and TER (above)
 - Discussed with ACRS TH Subcommittee in May 2021 (Vogtle LAR)

Reg Guide 1.82 Changes for GSI-191

- WCAP-17788-P, Revision 1 – Package - ML20010F181, Volume 1 - ML20010C854
 - Significant headloss testing, chemical testing, and TH analysis
 - No SE written by NRC, but found to provide significant increase in knowledge of behavior of the system with debris effects
 - NRC validated TH work using TRACE
- Added a few other references noted on slide 3

RG 1.82 Status With Respect to GSI-191

- Revision 5 to RG 1.82 was performed after the closure of GSI-191
- RG 1.82, Rev 5 is a complete guidance document for the effects of debris on long-term core cooling
- Additional guidance may be issued as the result of the 10CFR50.46c rulemaking currently with the Commission
 - RG 1.229 on risk-informed evaluation of debris on LTCC
 - Unlikely for the RG to be used after the rule is finalized
 - RG contingent upon the rulemaking and may be left as-is, deleted or revised

Reg Guide 1.82, Rev. 5 Public Comments

- NRC received 4 sets of public comments from 3 entities
- Comments received in areas of:
 - Applicability and Scope – relevance to alternate designs
 - NRC position is that RG is guidance, only applied where appropriate
 - Rev. 5 not intended to cover new reactors except when guidance is applicable
 - Definitions, Clarifications, and References
 - NRC made changes where appropriate
 - Add Risk-Informed Guidance
 - No changes made, awaiting 50.46c rulemaking

Reg Guide 1.82, Rev. 5 Public Comments

- Comments in the area of:
 - Specificity of Methodology and Failure Criteria
 - NRC concluded methodology is described as desired
 - Requested additions assumed that information included as an example in a SECY paper referenced in the RG was intended to have global applicability to all plants
 - Made reference in the SECY public in ADAMS
 - Comments suggested including methods for evaluations outside the scope of the RG
 - No changes made
 - Editorial comments in Appendix B
 - Incorporated

FLEX Equipment – Defense-in-Depth

- FLEX strategies are designed for beyond-design-basis external events initiated by natural phenomena
 - Not intended or reviewed for response to postulated accidents
 - However, some equipment may be available for accident response DID
 - There is adequate FLEX electrical power (or diesel) for all equipment
- Flex equipment and strategies are different between BWRs and PWRs
 - BWR FLEX includes equipment for direct connection to the RCS and the ability to vent containment if needed
 - RCS Blowdown is typically via SRVs to the suppression pool
 - BWR strategy is typically to vent containment for pressure reduction, if needed
 - PWR FLEX RCS injection only has low volume pumps with connections to the RCS
 - For Shutdown or low leakage only, includes borated water supply
 - Decay heat is removed via the steam generators with higher volume pumps
 - Connecting steam generator FLEX pumps to the RCS may be possible for some plants but has not been pre-planned or verified to be feasible in general
 - No pre-determined strategy for containment pressure reduction

FLEX Equipment – Defense-in-Depth

- Strainer blockage
- For most strainer blockage events RCS pressure would be low
 - BWRs have deployable FLEX capability to supply the RCS
 - Unclear if PWRs would be able to reconfigure the SG FLEX pumps and provide piping connections to inject large volumes of water within required timeframe
 - PWRs have low volume injection (typically 10s of gpm) for shutdown conditions or for pump seal leakage that are pre-configured for connection
- BWRs FLEX strategies may provide DID for long-term cooling
 - May need to consider containment venting and water level control strategies, etc.
- PWRs FLEX strategies may generally be less effective as DID for long-term cooling
 - Effectiveness depends on plant-specific equipment capacities, layouts, connections, etc.
 - No boration available at higher flow rates
 - Lower flows could be adequate if it takes a long time for strainer blockage to occur
 - Depends on plant-specific pump capacity

FLEX Equipment – Defense-in-Depth

- Loss of CAP that is credited to assure NPSH margin
- This scenario is likely very similar to the strainer blockage case
- For the FLEX scenarios, PWRs do not assume high containment pressure
 - Small energy release to containment from RCP seals
 - Similar constraints to those for the strainer blockage case
- BWRs may be able to use FLEX to provide RCS injection in the case of loss of NPSH
- PWRs would have challenges like those for a blocked strainer



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

RG 1.82, REVISION 5, APPENDIX B

**GUIDANCE FOR THE USE OF CONTAINMENT ACCIDENT PRESSURE IN DETERMINING
THE NET POSITIVE SUCTION HEAD MARGIN FOR EMERGENCY CORE COOLING SYSTEM
PUMPS AND CONTAINMENT HEAT REMOVAL PUMPS IN BOILING WATER REACTORS
AND PRESSURIZED WATER REACTORS**

CONTENTS

1. Background
2. Key Terms
3. Role of ECCS and CHR Pumps
4. Regulatory Requirements and Guidance
5. Use of CAP in Determining NPSH Margin
6. Cavitation Erosion
7. Effect of Non-Condensable Gas on Pump Mechanical Performance
8. Loss of Containment Isolation and Containment Leakage
9. Containment Cooling if CAP Is Used
10. Illustration of h_{atm} and CAP Available
11. Quantifying NPSH Margin
12. Guidance Summary
13. EPU LARs Approved (Using CAP Guidance in SECY-11-0014)
14. Acronyms and Symbols

1. Background

- CAP Issue
 - Use of CAP in determining NPSHa for ECCS and CHR pumps critiqued by the ACRS
 - Published regulatory guidance was not clear and consistent
- EPU LAR reviews discontinued because of CAP issue
 - Browns Ferry Units 2 & 3 EPU (15%), June 2004, 5% was previously approved
 - Browns Ferry Unit 1 EPU (20%); only 5% was approved, June 2004,
 - Monticello EPU, October 2009
- BWROG submitted topical report NEDC-33347P / NEDO-33347 (2/2008) providing a standard approach for requesting CAP in NPSH analysis.
- Staff transmitted white paper (11/2008) to ACRS summarizing regulatory and technical bases on CAP.
- ACRS recommendations to EDO (letters 3/18/09 & 5/19/10)- key items (item with * are included in guidance)
 - CAP credit should be limited in amount and duration
 - *Licensees to use RG 1.82, Rev 3 (current version at that time) to demonstrate +ve NPSH margin
 - *Revise RG 1.82 to incorporate guidance.
 - *Operator actions to control CAP should be reliable, risk should be acceptably small.

Background (Continued)

- SRP 6.2.2 should be revised to state if CAP is granted based on risk info.
- *Before CAP credit, licensees to justify impractical to modify plant
- For licensing, CAP deterministic calc should be complemented by PRA
- *Support staff reassessment of problems with $NPSH_a \leq NPSH_r$
- *Agree with BWROG statistical calcs to understand NPSH margin
- *Margin ($NPSH_a - NPSH_r$) to consider uncertainty in $NPSH_r$
- *Hardware modification or risk studies not needed for small CAP credit (in deterministic analysis)
 - If no CAP credit is needed for special events
 - 95/95 lower tolerance bound for LOCA using acceptable method shows no CAP credit is needed.
- Staff PRA studies presented are helpful, to assess risk need plant-specific studies.
- EDO Letters to ACRS (6/4/2009 & 6/10/2010)
 - Staff is reviewing ACRS recommendations
 - Submittal of BWROG report a significant milestone
 - Address policy issues before including risk in non-risk informed LARs.

Background (Continued)


- ACRS Letter to Commission Chairman (2/17/2011)
 - Disagreement between ACRS and staff
 - ACRS Position - CAP credit is a serious compromise of independence of prevention and mitigation which is a basic element of defense-in-depth philosophy; CAP is granted only if design cannot be practicably altered.
 - Staff Position - Analysis showing CAP provides adequate NPSH is as acceptable as design change that eliminates the need for CAP credit. No regulatory basis to request licensees to provide plant-specific risk information to assess the challenge to defense-in-depth.
- Pump Consultant – Allan R. Budris Reports (October & November 2009)
 - Task # 1- Review Sulzer Browns Ferry RHR and LPCS pump report (ML062920156), and evaluate overall methods for NPSH_r
 - Task # 2 – Determine accuracy and uncertainty in NPSH_{r3%}
 - Task # 3 – Evaluate technical justification for allowing pump operation in cavitation
 - Task # 4 – Evaluate NRC criteria of basing CAP at zero NPSH margin (Nov 2009)

Background (Continued)

- SRM (6/25/2010) & SECY-11-0014
 - Staff paper to discuss where staff aligns and where it disagrees with ACRS including risk, defense-in-depth and hardware changes to eliminate CAP.
 - Staff responds to SRM (1/31/2011); SECY-11-0014; options for Commission vote:
 - Option 1, Staff approach, deterministic, uncertainty and margins
 - Option 2, ACRS approach includes staff approach + plant specific PRA
 - Commission votes (3/2011), Option 1 – four votes; Option 2- one vote
 - Commission approved (3/15/2011) SECY-11-0014 with Option 1
- Commission directed staff to credit CAP using guidance in SECY-11-0014, Enclosure 1.
- Draft guidance based on SECY-11-0014 sent to PWROG and BWROG (2/25/2011)
- RG 1.82, Revision 5, Appendix B is based on SECY-11-0014, Enclosure 1.

2. Key Terms (RG Sections B-1 and B-6)


NPSH Available (NPSHa) (RG Figure B-6)



- $\text{NPSHa} = h_{\text{atm}} + h_{\text{static}} - h_{\text{loss}} - h_{\text{vp}}$
- h_{vp} = vapor pressure at suppression pool or sump water temperature
- CAP = pressure greater than containment pressure prior to accident or an event.

Key Terms (Continued)

NPSH Required (NPSH_r)



- $NPSH_{r3\%}$ according to ANSI/HI 14.6-2016 is the NPSH that results in cavitation sufficient to reduce the pump total dynamic head (TDH) by 3%.
- $NPSH_{r3\%}$ (from factory test) depends on pump design, flow and water temperature.
- In-plant installed pump NPSH_r may differ from $NPSH_{r3\%}$ due to difference in test conditions and plant conditions.
- NPSH Margin = $(NPSH_a - NPSH_r)$

Key Terms (Continued)

- NPSH Margin Ratio = (NPSHa / NPSHr)
- Cavitation
 - Occurrence of vapor-filled cavities in a liquid (Grist, *Cavitation and the Centrifugal Pump: A Guide for Pump Users* (RG Ref. B-1)).
 - In a pumped liquid, cavitation is the formation of vapor-filled cavities in the liquid flow due to a decrease in the local static pressure below its vapor pressure.

3. Role oF ECCS and CHR Pumps (RG Section B-2)

- BWRs (RHR and LPCS Pumps)
 - Cooling of RCS during shutdown (RHR)
 - Suppression pool cooling normal operation when heat is added (RHR)
 - LPCI and core spray in reactor following LOCA (RHR and LPCS)
 - Suppression pool cooling during LOCA or special events (RHR)
 - Containment spray for containment cooling and fission product removal (RHR)
- PWRs (RHR and CS Pumps)
 - Safety injection following LOCA during sump recirculation phase (RHR)
 - Containment spray following LOCA to cool containment & remove fission products (CS)
 - RCS cooling during shutdown (RHR)

4. Regulatory Requirements and Guidance (RG Section B-3)

- 10 CFR Part 50. Appendix A
 - GDC 35, “*Emergency core cooling*,”
 - GDC 38, “*Containment heat removal*,”
- Guidance in this RG Section C.1.3.1 includes:
 - RG 1.1 position
 - Conservative calculation of transient NPSHa and available CAP.
 - Prototypical test for crediting pump operation in cavitation
 - Calculation of pumped water temperature
 - **Head loss in the suction strainer and piping**
- Uncertainty Analysis & NPSH Margin
 - For NPSH margin, current approach assigns bounding inputs for LOCA containment temperature, NPSH analysis
 - For DBA, in BWROG topical report NEDC-33347P-A/NEDO-33347-A, CAP is determined by Monte Carlo calculation.
 - For special events, realistic inputs may be used, and licensee to quantify uncertainty.

5. Use of CAP in Determining NPSH Margin (RG Section B-4)

- NPSH_r should correspond to acceptable level of cavitation that allows the pump to perform its safety function for accident duration and recovery time.
- NPSH_{r3%} is typically obtained by factory testing of the actual pump or a similar one in accordance with ANSI/HI 14.6-2016.
- NPSH margin = (NPSH_a – NPSH_{r_{eff}}), where NPSH_{r_{eff}} = NPSH_{r3%} + uncertainties
- NPSH margin should be greater than or equal to zero.
- Difference in the factory test NPSH_{r3%} and field NPSH_{r_{eff}} is due to the following:
 - Pump speed (because of motor slip)
 - NPSH_r varies as square of the pump speed, which changes with motor slip.
 - Pump may operate at slightly higher speeds in field compared to a factory test speed
 - Water temperature
 - The NPSH_r decreases as water temperature increases.
 - Factory tests mostly at lower temps than field resulting in increased NPSH margin.
 - Effect of water temperature should not be considered in the field NPSH_r


Use of CAP in Determining NPSH Margin (Continued)

- Suction piping configuration
 - For acceptable pump operation, uniform inlet flow, free of swirl, and vortices.
 - Short and straight suction piping for better performance, may not be possible in field
 - Pressure loss in suction piping should be minimized to obtain the maximum NPSHa.
- Air content of water (may be lower in the vendor's test than in the field)
 - Dampens the effect of cavitation
 - It increases the NPSH_r,
 - Release of the noncondensable gases affects the NPSH margin
 - May interfere with the water cooling of pump seals.
- Licensee to determine and propose uncertainty in NPSH_{r3%}
- For DBA NPSH analysis, NPSH_{req} should be used to determine the NPSH margin.
- For BWRs SBO, ATWS, and Appendix R fire events NPSH_{r3%} may be used for NPSH margin, and realistic assumptions may be used for NPSHa analysis
- EPU LARs in DBA analysis used bounding value of 21% uncertainty (Budris report)

Use of CAP in Determining NPSH Margin (Continued)

- Negative NPSH margin is acceptable if tests done to demonstrate that the pump will perform its safety function(s), and following should apply:
 - Operation for a limited duration (less than 100 hours)
 - Actual pump or similar (model, size, materials, and seal/flush system) is tested.
 - Tested at same speed as at the plant site.
 - Tested at the actual predicted NPSHa,
 - Test duration is for the time during which NPSH margin is negative
 - Flow and discharge head should be greater than required for safety analysis.

6. Cavitation Erosion (RG Section B-5 and Figure B-4)



- Insufficient NPSH margin results in pitting of impeller blade and other pump parts due to condensation caused by vapor bubble implosion near a solid surface.
- Visual studies, acoustical measurement, field experience shows maximum erosion rate occurs at $NPSH_a$ value between $NPSH_{R3\%}$ and cavitation inception (margin ratio 4)
- Pump tests indicate that the zone of maximum erosion rate lies between NPSH margin ratios of 1.2 and 1.6 for pumps operating outside of the zone of suction recirculation

7. Effect of Non-Condensable Gas on Pump Mechanical Performance (RG Section B-7)

- Large quantity of entrained air from suction source, vortices, or released from solution can affect pump mechanical performance.
- Configuration of the PWR sump or BWR suppression pool should consider eliminating entrainment of air (by sprays) and vortices.
- NUREG-0897 - vortices decay to negligible levels within 14 pipe diameters.
- For NPSHa close to NPSH_{r3%}, vapor or entrained air could damage the shaft seal faces, therefore dual seal with external cold water flush system should be provided.
- If CAP used is determined assuming NPSHa = NPSH_{req}, then safety analysis flow should be equal to or less than flow resulting from a 3-percent decrease in TDH.
- Time of operation in the region of maximum erosion should be limited.

8. Loss of Containment Isolation and Containment Leakage (RG Section B-7)

If CAP is used, the licensees should-

- Demonstrate loss of containment integrity and loss of containment isolation cannot occur.
- Reduce the likelihood of a preexisting leak by determining minimum leakage rate sufficient to lose the needed CAP.
- Propose a method to determine whether the actual leakage rate exceeds the calculated.
- For inerted containments, periodic measurement of nitrogen makeup or oxygen content.
- Propose a time limit plant can operate without losing the needed CAP.

9. Containment Cooling if CAP Is Used (RG Section B-7)

- Licensees should demonstrate sprays and coolers will not reduce needed CAP.
- Operator action to control the CAP by sprays or coolers is acceptable if justified.
- Adequate guidance should be included in the operating procedures.

10. Illustration of h_{atm} and CAP Available (RG Section B-6, Figure B-8)




Figure B-8: Illustration of “ h_{atm} ” and “CAP head available” for $T_{pmax} > T_{sat}$

Perform conservative containment analysis to determine T_{pmax} and transient h_t , T_p and h_{vp} - [A]

- If $T_{pmax} > T_{sat}$ and needed CAP $\leq (h_{vp} - h_{min})$
 - Determine the needed CAP for NPSHa = NPSH_{ref}
 - Perform NPSH analysis - [B]
 - [A] and [B] is the design basis
- If $T_{pmax} > T_{sat}$ and needed CAP is between h_t and h_{vp} , i.e., ($h_t \geq CAP > h_{vp}$)
 - Determine the needed CAP for NPSHa = NPSH_{ref}
 - Perform statistical (Monte Carlo 95/95) containment and NPSH analysis to determine margin
 - Perform NPSH analysis - [C]
 - [A] and [C] is the design basis

11. Quantifying NPSH Margin (RG Section B-8)

- DBA LOCA
 - Conservative (bounding) containment and NPSH analysis using bounding inputs.
 - Perform realistic analysis to determine margin
 - NRC calculation showed conservative NPSH values are close to 95/95 lower tolerance limit of Monte Carlo calculation of same problem.
 - Monte Carlo lower tolerance limit of NPSHa is acceptable for conservative case
 - NPSHr should include its uncertainty
- BWR special events
 - Realistic NPSH analysis is acceptable, i.e., nominal inputs based instead of TS LCOs or bounding inputs
 - Use conservative inputs if realistic values are not available
 - NPSHr may be used without uncertainty

12. Guidance Summary (RG Section B-9)

- For DBA, NPSH analysis should use $NPSH_{\text{reff}} = (1 + \text{uncertainty}) NPSH_{r3\%}$
- For BWR special events, $NPSH_{r3\%}$ may be used to calculate margin
- Maximum flow rate for NPSHa analysis \geq flow rate used in safety analysis
- Loss of containment integrity (venting) should not occur during CAP use.
- NRC-approved operator action to control CAP is acceptable.
- Negative NPSH margin is acceptable if tests done to demonstrate that the pump will perform its safety function(s) with certain conditions.
- To reduce the likelihood of a preexisting containment leak, following should apply:
 - Determine the minimum leakage rate to lose CAP needed for +ve NPSH margin.
 - Propose a method to determine leakage rate.
 - Propose a time limit for operation while the actual leakage exceeds rate determined
- Zone of maximum erosion rate should be between NPSH margin ratios of 1.2 and 1.6.
- BWRs, CAP should follow topical report NEDC-33347P-A/NEDO-33347-A
- PWRs, CAP options are: use the vapor pressure corresponding to the sump water temperature or use a procedure similar to the BWROG Monte Carlo method.
- Mission time for pump using CAP to include recovery time from the accident.

13. EPU LARs Approved (Using CAP Guidance in SECY-11-0014)

- Monticello LAR review reactivated
- Browns Ferry Units 1, 2, & 3 LAR resubmitted
- Other LARs following CAP Guidance in SECY-11-0014 include
 - Peach Bottom 2 & 3 (modified hardware)
 - Grand Gulf
 - Turkey Point 3 & 4
 - St Lucie 1 & 2
 - Point Beach Units 1 & 2

14. Acronyms and Symbols

Acronym	Description	Symbol	Description
ATWS	Anticipated Transient Without Scram	h_{atm}	Containment pressure head
BWR	Boiling Water Reactor	h_{min}	Minimum pressure head at normal plant operation
BWROG	BWR Owners Group	h_t	CAP head
CAP	Containment Accident Pressure	h_{vp}	Transient vapor pressure at supp pool (BWRs) or sump water (PWRs) temperature during an accident
CS	Containment Spray		
DBA	Design Basis Accident	h_{loss}	Strainer and pump inlet piping head loss
CHR	Containment Heat Removal	h_{static}	Static head at pump inlet
ECCS	Emergency Core Cooling System	T_{pmax}	Maximum suppression pool or sump water temperature
EPU	Extended Power Uprate	T_{sat}	Saturation temperature at h_{min}
LAR	License Amendment Request		
LOCA	Loss-of-Coolant Accident		
LPCI	Low Pressure Coolant Injection		
LPCS	Low Pressure Core Spray		
NPSH	Net Positive Suction Head		
NPSHa	NPSH Available		
NPSHr	NPSH Required		
NPSHr _{3%}	NPSHr corresponding to 3% pump TDH drop at a given flow		
NPSH _{eff}	NPSHr Effective		
OG	Owners' Group		
PWR	Pressurized Water Reactor		
RCS	Reactor Coolant System		
RG	Regulatory Guide		
RHR	Residual Heat Removal		
SBO	Station Black Out		
TDH	Total Dynamic Head		