



Overview of USNRC Research Activities to Update PRA Treatment of High Energy Arcing Faults

Kevin Coyne, Kenneth Hamburger, Nicholas Melly,
Gabriel Taylor, Mark Henry Salley




26th International Conference on Structural Mechanics in Reactor Technology (SMiRT 26)
17th International Post-Conference Seminar on
"FIRE SAFETY IN NUCLEAR POWER PLANTS AND INSTALLATIONS"



HEAF Background

A High Energy Arcing Fault (HEAF) is a failure mechanism postulated for equipment at 440 V and higher

- Caused by poor or degraded electrical connections, foreign material ingress, misaligned breakers
- Rapid release of energy, including ionized gases, molten metal, and overpressures. Often accompanied by ensuing “classical” thermal fire



Regulatory **Context**

Appendix R

Prescriptive requirements
for nuclear fire protection

NRC Endorses NFPA-805

Reg Guide 1.205

Endorses NUREG/CR-
6850

1980

2001

2004

2005

2006

2010

NFPA-805

Performance-based
standard for nuclear fire
protection

NUREG/CR-6850

Fire PRA Methodology

NUREG/CR-6850

Supplement 1

Includes bus ducts

Original HEAF **ZOI**

Documented in Appendix M of NUREG/CR-6850. Based largely on 2001 HEAF at San Onofre (pictured on right)

- ZOI was 3 feet (0.9 m) horizontally and 5 feet vertically (1.5 m)
- Insensitive to parameters affecting the severity of the HEAF (voltage, current, duration, geometry, materials, etc.) – “One-size-fits-all”




Original HEAF **ZOI**

Bus ducts addressed in NUREG/CR-6850 Supplement 1 as part of the “FAQ” process

- ZOI was sphere of 1.5 ft (0.45 m) radius, and a 30-degree right cone extending downward for 20 feet (6 m).
- Like switchgear, this model also neglected parameters affecting the severity of the HEAF (voltage, current, duration, geometry, materials, etc.) – “One-size-fits-all”



HEAF Research **Motivation**



“...to perform experiments for obtaining comprehensive scientific fire data on the HEAF phenomena known to occur in NPPs through carefully designed experiments...”



Phase I Test 23 – potential for increased ZOI where aluminum is involved

Research Activities **Overview**

The NRC developed a comprehensive project plan, consisting of five main tasks:



Development of a CFD Model
for predicting a wide variety of electrical and equipment configurations




Survey of the US Nuclear Fleet
to ensure that full-scale experiments are representative



Physical Testing
to support the development and validation of the CFD model




Fragility Testing
to assess target damage from HEAF events



PRA Method Development
to improve the realism of the model and update fire ignition frequencies

Development of a **CFD Model**

Leverage experimental data and provide information for configurations that were not subject to full-scale testing. This provides a cost-effective and flexible approach.



Low Voltage Switchgear

Bus bar material (aluminum, copper), arc duration, arc location, arc energy
34 FDS simulations



Medium Voltage Switchgear

Bus bar material (aluminum, copper), arc duration, arc location, arc energy
42 FDS simulations



Non-segregated Bus Ducts

Duct material (aluminum, steel), bus bar material (aluminum, copper) arc duration, duct geometry, arc energy
57 FDS simulations

Survey of US **Nuclear Fleet**


Conducted by the Electric Power Research Institute (3002020692)

Bus Bar Insulation
MV bus bars primarily insulated;
LV bus bars are usually not


SAT Fault Clearing Times
50% of units had SAT FCTs of 2
seconds or less

Switchgear Style
83% of switchgear use horizontal
draw-out style; the remainder use
vertical-lift style


Presence of Aluminum
Typically located in the main
bus bars and primary cable
compartment



Physical **Testing**



Aluminum/copper particle size distributions, rates of particle production, particle morphology, and oxidation



Direct observation of the arc, enclosure breach, material loss, arc spectral emissions



Enclosure breach, event progression, pressure rise, thermal/visual imaging. Served as benchmark cases for CFD model.

Fragility **Testing**

The need for defining fragility criteria with respect to HEAFs was a key conclusion of the 2017 Phenomena Identification and Ranking Table (PIRT).




Physical Testing

Conducted at SNL's Solar Furnace facility to simulate the effects of a short duration, high heat flux exposure

Engineering Analysis

Data analysis, operating experience review, and consensus building to establish fragility criteria

PRA Method **Development**



Fault Zone Analysis


Location of fault within plant EDS determines maximum fault duration and provides credit for circuit protection features



Generator-Fed Faults & GCB

Accounts for potential generator-fed fault and provides credit for generator circuit breakers

PRA Method Development



Zone 1 - 30 MJ/m ² target fragility				Default ZOI dimensions (inclusive of horizontal and vertical-lift circuit breakers)				ZOI dimensions for vertical-lift style circuit breakers			
Fault location	Power source and duration	Arc Energy (MJ)	End State	Left/Right (feet)	Front (feet)	Back (feet)	Top (feet)	Left/Right (feet)	Front (feet)	Back (feet)	Top (feet)
Normal supply (0.57) and Secondary supply (0.28)	UAT - Generator fed	132	GF-30	1.5	1	2*	1	1	1	None	1
	SAT - 0 to 2.00 s	68	SAT2-30	0.5	None	1*	None	None	None	None	None
	SAT - 2.01 to 3.00 s	101	SAT3-30	1	0.5	1.5*	0.5	0.5	0.5	None	0.5
	SAT - 3.01 to 4.00 s	135	SAT4-30	1.5	1	2*	1	1	1	None	1
	SAT > 4.01 s	169	SATMAX-30	2	2	2.5*	1	1.5	2	None	1
Loads: Supply breaker limited (.14)	4 seconds or less (generic)	135	SBL4-30	1.5	1	2*	1	1	1	None	1
	2 seconds or less	68	SBL2-30	0.5	None	1*	None	None	None	None	None
	2.01 to 3 seconds	101	SBL3-30	1	0.5	1.5*	0.5	0.5	0.5	None	0.5
Loads (0.01)	UAT - 0 to 0.5 s + GF	132	GF-30	1.5	1	2*	1	1	1	2**	1
	UAT - 0.51 to 2 s + GF	199	UAT2-30	2	1.5	2.5*	1.5	1.5	1.5	2.5**	1.5
	UAT - 2.01 to 3 s + GF	233	UAT3-30	2.5	2	3*	2	2	2	3**	2
	UATMAX-30										
	UAT - > 3 s + GF	300	UATMAX-30	3	2.5	3.5*	2.5	2.5	2.5	3.5**	2.5
	SAT - 0 to 2.00 s	68	SAT2-30	0.5	None	1*	None	None	None	1**	None
	SAT - 2.01 to 3.00 s	101	SAT3-30	1	0.5	1.5*	0.5	0.5	0.5	1.5**	0.5
	SAT - 3.01 to 4.00 s	135	SAT4-30	1.5	1	2*	1	1	1	2**	1
	SAT > 4.01 s	169	SATMAX-30	2	2	2.5*	1	1.5	2	2.5**	1

Supply vs. Load Configuration

Additional specificity based on the function of the switchgear within the lineup (breaker set points)


Direction-Specific ZOIs

ZOIs are formulated for each face of the enclosure (left/right, front, back, and top)

Breaker Style Refinements

Additional refinements for horizontal draw-out or vertical lift breakers due to mass and position of the breaker

PRA Method **Development**



Revised NSBD ZOI Geometry

Testing and operating experience leveraged to redefine the “waterfall” portion of the ZOI

Additional Guidance

- Ensuing fire modeling guidance
- Updated HEAF frequencies and bins
- Updated non-suppression probabilities



<https://www.nrc.gov/about-nrc/regulatory/research/fire-research/heaf-research.html>