



Constellation Energy Generation, LLC (CEG)
Braidwood Station
35100 South Route 53, Suite 84
Braceville, IL 60407-9619

www.constellationenergy.com

November 30, 2022
BW220078

10 CFR 50.73

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Braidwood Station, Unit 1
Renewed Facility Operating License No. NPF-72
NRC Docket No. STN 50-456

Subject: Licensee Event Report 2022-001-00 – Liquid Penetrant Indications in Control Rod Drive Mechanism Nozzle Seal Weld Repair due to Subsurface Weld Defects Opening Up from Thermal and Pressure Stresses during Operation

The enclosed Licensee Event Report (LER) is being submitted in accordance with 10 CFR 50.73, "Licensee Event Report System."

There are no regulatory commitments contained in this letter. Should you have any questions concerning this submittal, Mr. Dane Brunswick, Regulatory Assurance Manager, at (815) 417-2800.

Respectfully,

A handwritten signature in black ink, appearing to read "Gregory Gugle".

Gregory Gugle
Site Vice President
Braidwood Station

Enclosure: LER 2022-001-00

cc: NRC Project Manager, NRR, Braidwood and Byron Stations
Illinois Emergency Management Agency – Division of Nuclear Safety
US NRC Regional Administrator, Region III
US NRC Senior Resident Inspector, Braidwood Station
Illinois Emergency Management Agency – Braidwood Representative