

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
SHINE Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Friday, October 21, 2022

Work Order No.: NRC-2137

Pages 1-73

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

SHINE SUBCOMMITTEE

+ + + + +

FRIDAY

OCTOBER 21, 2022

+ + + + +

The Subcommittee met via Video
Teleconference, at 9:30 a.m. EDT, Ronald Ballinger,
Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chair

VICKI BIER, Member

CHARLES H. BROWN, JR., Member

VESNA DIMITRIJEVIC, Member

GREGORY HALNON, Member

JOSE MARCH-LEUBA, Member

JOY L. REMPE, Member

MATTHEW SUNSERI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ACRS CONSULTANT:

2 DENNIS BLEY

3 KEN CZERWINSKI

4 STEPHEN SCHULTZ

5

6 DESIGNATED FEDERAL OFFICIAL:

7 CHRISTOPHER BROWN

8

9 ALSO PRESENT:

10 MICHAEL BALAZIK, NRR

11 JOSH BORROMEO, NRR

12 NORBERT CARTE, NRR

13 CATHERINE KOLB, SHINE

14 SCOTT MOORE, ACRS

15 RYAN MYERS, SHINE

16 TRACY RADEL, SHINE

17 BILL WATSON, SHINE

18 DANIEL ARIZAGA, SHINE

19

20

21

22

23

24

25

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Page

Opening Remarks and Objectives 4

Staff Opening Remarks 7

Section 7.4.3, "Process Integrated Instrument Control System"

 By Shine Medical Technologies LLC 8

Section 7.4.3, "Process Integrated Instrument Control System"

 By NRC Staff 24

Phased Startup Operations Supplement 35

Phased Startup Operations, SER, Appendix A . . . 51

Public Comment 60

Committee Discussion 60

Adjournment 73

P R O C E E D I N G S

9:30 a.m.

1
2
3 CHAIRMAN BALLINGER: All right. It's
4 9:30. Let's begin the meeting. This is a meeting of
5 the SHINE Subcommittee of the Advisory Committee on
6 Reactor Safeguards. I'm Ron Ballinger, Chairman of
7 today's subcommittee meeting.

8 ACRS members in attendance are Charlie
9 Brown, Greg Halnon, Jose March-Leuba, Joy Rempe, Matt
10 Sunseri, and I see Vesna somewhere here, Vesna
11 Dimitrijevic. And if I've missed somebody, I'm sure
12 I'll get reminded.

13 MEMBER BIER: Yes, Ron.

14 CHAIRMAN BALLINGER: Yes, yes.

15 MEMBER BIER: This is Vicki Bier. I just
16 joined, and I don't know if you saw my email. I will
17 have to duck out for a while at around 11 Eastern.

18 CHAIRMAN BALLINGER: Yes, got it. Thanks
19 again. We also have our consultants, Dennis Bley and
20 Steve Schultz present. Chris Brown of the ACRS staff
21 is the Designated Federal Official for this meeting.

22 During today's meeting, the subcommittee
23 will have a discussion with the NRC staff and SHINE
24 Medical Isotope, Incorporated, concerning process
25 integrated instrument control system (PICS). They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 start up in any other remaining questions concerning
2 life cycle. I might add that this is the last
3 subcommittee meeting for this effort, so it's been a
4 long road but we're almost at the end.

5 The rules for participating, part of the
6 presentations by the applicant may be closed. We
7 don't think that will be the case, but, if it is,
8 we'll have to make arrangements to close the meeting.

9 The rules for participating in all ACRS,
10 including today's, were announced in the Federal
11 Register on June the 13th, 2019. The ACRS section of
12 the U.S. NRC public website provides our charter,
13 bylaws, agendas, letter reports, and full transcripts
14 of all full and subcommittee meetings, including
15 slides presented there. The meeting notice and agenda
16 for this meeting were posted there. We have received
17 no written statements or requests to make an oral
18 statement from the public.

19 The subcommittee will gather information,
20 analyze relevant issues and facts, and formulate
21 proposed positions and actions, as appropriate, for
22 deliberation by the full committee. The rules for
23 participation in today's meeting have been announced
24 as part of the notice for this meeting previously
25 published in the Federal Register.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Today's meeting is being held virtually
2 over Microsoft Teams. A telephone bridgeline allowing
3 participating for the public using their computer
4 using Teams or by phone was made available.
5 Additionally, we have made an MS Teams link process
6 and password available on the published agenda.

7 A transcript of today's meeting is being
8 kept. Therefore, we request that meeting participants
9 on Teams and on the Teams call-in line identify
10 themselves when they speak and to speak with
11 sufficient clarity and volume so they can be readily
12 heard. Likewise, we request that meeting participants
13 keep their computer and/or telephone lines on mute
14 when not speaking to minimize disruptions. The chat
15 features on Teams should not be used for any technical
16 exchanges. Let's see. I can control -- most
17 everybody looks like they're muted.

18 Again, I'd like to note that this is our
19 final SHINE Subcommittee interaction with the staff
20 and SHINE. We do have a November 15th subcommittee
21 meeting from 8:30 to 5, it's a whole day, in which the
22 subcommittee will work on remaining memos and work on
23 the draft final letter report. That subcommittee will
24 be open to the public.

25 We'll now proceed, and Josh, I see you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there. So please give any opening remarks that you
2 would like.

3 MR. BORROMEO: Thank you, Professor
4 Ballinger. My name is Josh Borromeo. I'm Chief of
5 the Non-Power Production and Utilization Facility
6 Licensing Branch. Today you're going to hear
7 presentations from the staff and SHINE on PICS, the
8 process integrated control system, which is a non-
9 safety related system for the facility. And you'll
10 also hear an overview of the phased construction
11 approach and also our associated license and controls
12 the staff is putting in place to ensure a safe
13 operation while SHINE moves from phase to phase of
14 construction.

15 Now, I do want to recognize it's been a
16 long road, right, and in our internal chat we were
17 saying, okay, we've started these in February. So I
18 wanted to recognize that we still have some work to do
19 to get this thing over the finish line, but I do want
20 to express my appreciation for all the hard work that
21 the staff and SHINE has done to get us to this point.
22 And I also want to highlight my appreciation for ACRS
23 and ACRS staff for being flexible and identifying ways
24 to efficiently work to get us through this review.

25 So with that, I'll turn it over to SHINE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for their PICS presentation.

2 CHAIRMAN BALLINGER: Okay. Before we add
3 again, we now have Ken Czerwinski, another one of our
4 consultants in the chemistry area, that's joined the
5 meeting.

6 Okay. Let's go.

7 MR. MYERS: Hello. My name is Ryan Myers.
8 I'm an I&C engineer here at SHINE. Welcome to the
9 process integrated control system, PICS, presentation.

10 Next slide, please. Here's a look at the
11 topics that will be covered. First will be an
12 overview of the PICS main functions, then PICS network
13 security features. After that, we'll look at PICS
14 interfaces with safety-related systems. Next, our
15 PICS communications with vendor-provided non-safety
16 related control systems. And, finally, we'll look at
17 operator access to the PICS network using PICS
18 workstations.

19 Next slide, please. Here's Figure 7.1-1
20 from the FSAR showing the instrumentation and control
21 system architecture. The upper right corner of the
22 figure shows the PICS external interfaces with safety
23 and non-safety related systems. Unidirectional and
24 bidirectional communications with PICS are captured
25 here. The safety-related systems in the center of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 this figure were covered in previous NRC audit
2 discussions. PICS communications with the supervisor
3 and operator workstations and indication displays in
4 the facility control room are shown at the bottom of
5 the figure, along with PICS production facility HMI
6 communications.

7 Next slide, please.

8 MEMBER BROWN: Could you go back to the
9 other slide for a minute? This is Charlie Brown.

10 MR. MYERS: Sure.

11 MEMBER BROWN: I noticed, it's just a
12 question and maybe you've got an overarching answer
13 for this. This is the -- you primarily show Figure
14 7.1-1, which is the excellent representation of the
15 safety systems that we addressed in the last meeting.
16 The process control, process integrated control system
17 has a big box with nothing in it, which not unexpected
18 since that's separate. And there is a figure in the,
19 I think it's 7.3-1, but that one is nowhere near what
20 I call the detail that the 7.1-1 is for the safety
21 systems. It's, fundamentally, some block diagrams
22 with one line going everywhere, which leaves a little
23 bit -- you talked about ethernet inside of your PICS
24 operations, and it would be nice to hear a little bit
25 about how integrated these overall PICS things is when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we get to that point in the slides.

2 I'm just giving you a heads-up, there's a
3 question I had relative to the detail and how
4 integrated the -- because you do call it an integrated
5 system and how diverse -- not diverse; that's the
6 wrong word. I'm not looking for diversity. I'm
7 looking for separation of functions because there's
8 two or three dozen process systems that are part of
9 this overall process integrated control system. And
10 my question really boils down to is it a giant
11 computer that's running all those giant set of servers
12 where all the software is on one or two servers, or
13 are they independent systems which feed independently
14 into the control functions for the operators?

15 You don't have to answer that now. It's
16 just when we get to the appropriate point. Did I get
17 that across very well?

18 MR. MYERS: Yes.

19 MEMBER BROWN: Okay.

20 MR. BROWN: Excuse me. This is Chris
21 Brown. It looks like you were trying to go to full
22 screen. Can you -- this diagram is very small. Can
23 you try to change the view?

24 MR. MYERS: Yes, I'm just having a
25 challenge doing that. There we go. Sorry. It's my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 first time driving.

2 MEMBER BROWN: We've got our magnifying
3 glass. A little humor to start the meeting.

4 MR. MYERS: So on to the next slide then.
5 PICS is a non-safety related control system used by
6 the plant operators to control and monitor facility
7 equipment throughout the radiation facility and
8 radioisotope production facility. PICS supports the
9 facility control room which contains the operator
10 workstations and the main control board.

11 The non-safety related instruments and
12 controls used throughout the plant are wired to the
13 local remote idle panels which then route back to the
14 PICS main distribution switch in the server room over
15 copper or fiberoptic cabling. The PICS HMI
16 workstations, including five system-specific remote
17 workstations, use thin clients connected to virtual
18 machines running on a server in the server room.

19 Next slide, please.

20 MEMBER BROWN: Did that just answer part
21 of my question?

22 MR. MYERS: I think so.

23 MEMBER BROWN: That these, all these 20 or
24 30, whatever it is, the large number -- and I'm not
25 arguing about the number. You obviously have a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 things you have to control. So, fundamentally,
2 there's a giant server where all the software is
3 located for these systems. They're not separate PLCs
4 for every system. Is that a correct assumption, for
5 other than the ones shown up in the upper block of
6 Figure 7.3-1?

7 MR. MYERS: There are separate PLCs split
8 up by system. On the PICS side, there are five
9 separate, well, actually, seven PLCs and then three
10 for TPS. Those are split up, but they do communicate.
11 They're virtual machines, like HMI screens run
12 through, are on a stratus fault tolerant server that's
13 located in the server room.

14 MEMBER BROWN: Okay. So there is a -- so
15 this is stuff is, fundamentally, fed into -- if that
16 server fails, what happens? You lose all your
17 controls?

18 MR. ARIZAGA: Sorry. This is Dan Arizaga,
19 I&C engineer.

20 MEMBER BROWN: Yes.

21 MR. ARIZAGA: So, essentially, there is
22 redundancy in that with multiple thin clients, so, if
23 one of the servers goes down, you would have several
24 backup servers that would be able to pick up, so you
25 would have no interruption of the actual control PICS.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: Okay. So you've got
2 backups. So you've got parallel servers running,
3 which are all up to date for whatever is going on so
4 that the workstation operator can move from one to the
5 other server, as needed, to carry on operations; is
6 that correct?

7 MR. MYERS: Yes. It will switch to the
8 backup server automatically if the primary server were
9 to fail.

10 MEMBER BROWN: Okay, all right. Go ahead.

11 MR. MYERS: I can go into a little more
12 detail as we progress.

13 MEMBER BROWN: Okay. That's fine. Thank
14 you.

15 MR. MYERS: PICS network, architecture and
16 security, did I get through this one? Okay. The most
17 important PICS security feature is that there is no
18 connection to the internet, and the PICS devices are
19 not WiFi capable. PICS does have an outbound only
20 connection through a one-way data diode to the PICS
21 historian. The PICS manufacturing control network is
22 separated from the SHINE business network behind its
23 PLC, and its PLC communications are split into ten
24 virtual local area networks, or VLANs, one for each of
25 the ten PLCs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PICS has physical security implemented,
2 including the locking of control cabinets, the server
3 room, and physically blocking unused network ports.
4 The ethernet IP with CIP communication protocol used
5 for PICS is widely used to secure plants worldwide.
6 No remote access for monitoring or maintenance of the
7 plant is allowed either.

8 Next slide, please.

9 MEMBER BROWN: Stay there for a minute.
10 This is Charlie Brown again. You say the
11 manufacturing network is segregated from the SHINE
12 business network. Does that mean it's not connected?

13 MR. MYERS: It's not connected at all.

14 MEMBER BROWN: Okay. That's all I was
15 looking for. Segregation could mean you have
16 segregated software within your servers that allows
17 you to operate, but you're totally disconnected.
18 That's all I wanted to know. Thank you.

19 MR. MYERS: PICS interfaces with safety-
20 related systems. The safety-related systems, the
21 target solution vessel reactivity protection system,
22 TRPS, and the engineered safety features actuation
23 system, ESFAS, communicate with PICS through a one-way
24 isolated rs485 Modbus gateway. While the information
25 exchange is unidirectional from TRPS/ESFAS to PICS,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PICS does send two cyclic redundancy checks, CRCs, per
2 Modbus message for error checking and verifying the
3 identity of the data.

4 Under normal operating conditions, PICS
5 allows operators to manually actuate TRPS/ESFAS
6 controlled components. The PICS controlled relays
7 have contacts in series with the TRPS/ESFAS controlled
8 relay contacts, so the safety and non-safety system
9 controls remain electrically isolated. TRPS/ESFAS can
10 remove component power, causing the components to fail
11 to their safe positions, regardless of PICS output
12 state.

13 After safety actuations, the enabled non-
14 safety switch must be physically moved from the
15 disabled to the enabled position on the main control
16 board by the operator before a component reset request
17 can be sent from PICS. The actuation and priority
18 logic in TRPS/ESFAS must not be prevented by higher-
19 priority inputs before TRPS/ESFAS will reset the
20 component, as requested by PICS.

21 The TRPS mode transition and component
22 reset request signals are sent from PICS to the safety
23 systems using a bit stream or binary pattern of
24 discrete relay outputs that are decoded by TRPS/ESFAS.
25 Unrecognized PICS output patterns will do nothing in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 TRPS or ESFAS. PICS is designed so that it cannot
2 fail or operate in a mode that could prevent the TRPS
3 or ESFAS from performing its designated functions.

4 CHAIRMAN BALLINGER: This is Ron
5 Ballinger. On bullet number one, two, three, four,
6 five, PICS provides signals to TRPS/ESFAS to
7 reposition components, da, da, da, da, da. Is this an
8 area where errors of commission or omission can impact
9 the safety side?

10 MR. MYERS: Can you --

11 MEMBER BROWN: Let me interpret his
12 question for you. If the operator doesn't do
13 something, does that affect the safety side --

14 CHAIRMAN BALLINGER: Yes, either
15 intentionally or not intentionally.

16 MEMBER BROWN: Right.

17 MS. RADEL: This is Tracy. So the -- no,
18 no operator action is needed to respond to an accident
19 condition, so they don't need to do anything. We have
20 assessed thoroughly to ensure that, if they do,
21 anything that they do cannot impact the safety systems
22 from performing their safety functions.

23 MS. KOLB: And this is Catherine Kolb. So
24 the purpose of this is for the reset, which I believe
25 we discussed at a previous meeting. So after an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actuation from TRPS or ESFAS, you'd ensure that the
2 non-safety, enabled non-safety switch was in the
3 enabled position, and then you would be able to use
4 the PICS component, the PICS interface to reopen
5 components that had closed, for example to reset
6 things that had actuated.

7 There's no time requirements associated
8 with that in our design. There's no, you know, no
9 analogs, like power reactors sometimes have time
10 required actions in order for operators to do things.
11 This is just recovering from an accident at the
12 operator's discretion once the accident has been
13 mitigated or otherwise dispositioned to be safe.

14 CHAIRMAN BALLINGER: Thank you.

15 MR. MOORE: This is Scott Moore. I just
16 ask that each of the speakers identify themselves with
17 a full name before speaking, at least for the first
18 time. Thank you.

19 CHAIRMAN BALLINGER: Good point. Thank
20 you.

21 MR. MYERS: Next slide, please. PICS
22 vendor-provided non-safety related control system
23 interfaces. There are several vendor-provided control
24 system interfaces with PICS that provide the operators
25 in the facility control room with important process

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 monitoring information. Some of the vendor-supplied
2 control systems include the neutron driver assembly
3 system, NDAS; a super cell; and various auxiliary
4 control systems. Again, the most important thing is
5 that none of the PICS vendor-provided devices have
6 internet connections. Similarly, no remote access is
7 allowed. In unused communication, ports are blocked
8 or disabled. Many of the vendor-provided control
9 systems use ethernet, Modbus, or other industry
10 standard protocols to communicate with PICS. The
11 safety benefits of the object-oriented CIP protocol
12 over ethernet IP are employed by many of the vendor-
13 supplied control systems.

14 Next slide, please. Vendor-provided non-
15 safety related control system interfaces continued.
16 The Modbus connections tie into the PICS network via
17 Modbus interface modules or gateways, which provide
18 independently-configured communication ports specific
19 to their devices and systems. PICS Modbus networks
20 only communicate with read/write registers approved by
21 the vendors. Like the plant equipment using internet
22 IP with CIP, the building automation system, or BAS,
23 equipment uses BACnet/IP, another protocol commonly
24 used in plants for HVAC and system facility controls.

25 PICS monitors information from the non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 safety related vendor provided super cell and
2 radioactive liquid waste immobilization PLCs, along
3 with radiation monitors throughout the plant. PICS
4 communicates with the vendor-supplied NDAS control
5 system through providing permissive signals and
6 monitoring information.

7 Next slide, please.

8 MEMBER BROWN: Before you go on, this is
9 Charlie Brown again. The super cell, I'm trying to
10 think back to the facility figure. Are the super
11 cells within the irradiation units, or is that a big
12 separate -- I've forgotten.

13 MR. MYERS: That's on the RPF side.

14 MEMBER BROWN: Okay. So that's on the
15 production facility side. And there's how many super
16 cells, just one or I thought there were multiple super
17 cells.

18 MR. MYERS: Just the one.

19 MS. RADEL: This is Tracy Radel. Just to
20 clarify, there's one super cell that has ten
21 individual hot cells within it.

22 MEMBER BROWN: Okay. That's what, I was
23 trying to get to that. I was looking at your figures
24 from the text. I saw a number of workstations for
25 various super cells. Okay, I got it. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. MYERS: PICS workstations and network
2 access. Users who require access to the FactoryTalk
3 View Site Edition Supervisory Control and Data
4 Acquisition system will have independent accounts
5 created on the manufacturing domain. When logging in
6 to a PICS workstation, the operator's credentials are
7 authenticated against the valid accounts on the
8 manufacturing domain and workstation graphics are
9 view-only when no user is logged in.

10 Each PICS domain user will be assigned to
11 one of five domain groups, including maintenance,
12 operator, supervisor, administrator, or quality.
13 SCADA permissions are limited based on the assigned
14 domain group.

15 In addition to domain groups, users are
16 assigned to security areas which allow control of PICS
17 equipment. Control room operators and supervisors are
18 assigned to all security areas.

19 Next slide, please. And now for the final
20 slide, PICS workstations and network access continued.
21 A PICS workstation user can only take control of a
22 remote HMI after access is granted by the control room
23 supervisor. The control room supervisor can also take
24 back control of the PICS equipment at any time. Each
25 workstation and main control board thin client have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 their own ten-minute backup power supplies provided by
2 a local UPS. The standby generator system should be
3 providing backup power before the local UPS runs out
4 of battery. If power to a remote operator workstation
5 were lost, that thin client's virtual machine session
6 would continue to run on the stratus fault tolerant
7 server in the server room.

8 That concludes the PICS presentation.
9 Thank you.

10 MEMBER BROWN: Can I ask -- this is
11 Charlie Brown again. Can I ask another question or
12 maybe two, if I can figure it out here.

13 MR. MYERS: Sure.

14 MEMBER BROWN: I just wanted to confirm
15 something. I think you said this earlier, but I
16 wanted to connect it with words in the FSAR. In
17 Section 7.3.5, 7.3.3.5, that's the access control and
18 cybersecurity section, second paragraph reads, the
19 PICS and other vendor-provided non-safety related
20 control systems do not allow remote access. You
21 talked about that a minute ago. Let me finish the
22 next point.

23 Paragraph six says vendor-provided non-
24 safety related control systems communicate with the
25 PICS via ethernet or other industry standard digital

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 communication protocols. I'm assuming that the
2 ethernet is, there is no connection of any ethernet.
3 You're running an ethernet bus through the PICS. I
4 think you told us that in the previous meeting. Is
5 that correct? Is my memory correct?

6 MR. MYERS: Yes, it's a local internet
7 hardwired connection within the plant itself.

8 MEMBER BROWN: Okay. But it's strictly a
9 local interior internet communication systems, so you
10 can control multiple systems.

11 MR. MYERS: Right.

12 MEMBER BROWN: There is no connection to
13 that particular network or internet network to any
14 remote networks.

15 MR. MYERS: Correct.

16 MEMBER BROWN: Outside the facility,
17 outside the facility. I think you've said that. I
18 just wanted to -- the words were a little bit dicey in
19 terms of how it's phrased; that's all.

20 MR. MYERS: Yes, you're correct. There
21 are no ethernet connections outside of the facility.

22 MEMBER BROWN: Okay, all right. Thank
23 you. Let me see if -- go ahead.

24 MR. WATSON: Charlie, this is Bill Watson,
25 interim I&C manager. I did want to correct the record

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 on one point. There is an outbound data stream from
2 PICS to the PICS historian for sending information,
3 outbound only.

4 MEMBER BROWN: Yes.

5 MR. WATSON: That communication occurs
6 through a data diode or what the NRC calls a
7 deterministic device, so it, in no physical way, can
8 even allow any kind of external communications to come
9 in to PICS. It's basically a one-way, you know,
10 hardware device. It only allows PICS to report, you
11 know, performance data out to the historian. So I
12 didn't want --

13 MEMBER BROWN: Go ahead, go ahead.

14 MR. WATSON: I just wanted to make sure we
15 were clear on that point, that there actually is a
16 connection but it is outbound only and it's a hardware
17 outbound only. It can't be defeated in any way.

18 MEMBER BROWN: Yes, mentioned that a few
19 minutes ago. I guess my question on that is -- how
20 can I phrase this properly? You've probably read
21 this, I've reiterated this many times. A hardware-
22 based device can have bidirectional hardware-based
23 devices, but it's configured by software. A true data
24 diode is not configured by software. In other words,
25 it's hardwired and it can only have one unit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 directional. Nothing from external can backfill
2 through it or be captured somewhere else and then
3 reverse that or turn it into a bidirectional.

4 So I presume the data diode interpretation
5 in this is strictly one way of passing data in and
6 only one thing to couple it and send it out, and
7 there's no software package that configures that.
8 It's hard configured.

9 MR. WATSON: That's absolutely correct in
10 the case of the data diode that's used for PICS.

11 MEMBER BROWN: Okay. That's all I wanted
12 to know. Thank you very much. And thank you all for
13 doing that so I didn't have to say anything.

14 CHAIRMAN BALLINGER: So that was your last
15 slide?

16 MR. MYERS: That's correct.

17 CHAIRMAN BALLINGER: Okay. If there
18 aren't any questions from the members or consultants
19 on this presentation, we can switch over. Here we
20 are. We're already there. I don't know who is the
21 presenter in this case.

22 MR. CARTE: Norbert Carte from I&C, NRR.

23 CHAIRMAN BALLINGER: I'm a slow reader.
24 Thanks.

25 MR. CARTE: Once again, this is Norbert

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Carte from the Instrumentation & Control Branch.
2 We're assisting DANU in the review of the application.

3 Next slide, please. So, predominantly,
4 the review involves the same reviewers as you've seen
5 previously. However, the bulk of the review for PICS
6 was done by me, although there was some minor
7 involvement by others.

8 Next slide, please. We use the same set
9 of guidance, obviously different sections, for our
10 review of PICS. Next slide, please. I used red a
11 little bit to highlight what's new and different from
12 what you've seen before.

13 Next slide, please. So what we're looking
14 now is at PICS. What you've seen before was basically
15 HIPS, TRPS/ESFAS radiation monitoring systems.

16 Next slide, please. So the PICS
17 description is actually a little bit segmented in the
18 sense that there is some description in 7.3 and
19 obviously 7.2, and as well as 7.6, which is the
20 control console display instruments. Most of the
21 control console and display stuff is addressed by HFE,
22 but it is technically part of PICS, so it was covered
23 in the SER section on PICS.

24 And, again, the SHINE facility has two
25 distinct parts in a radiation facility and a refuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 radioisotope processing facility and one control room
2 and one PICS for everything. Well, yes, the TRPS is
3 for each irradiation unit.

4 So the safety of the facility is, in part,
5 defined by two things: the criteria on the PICS
6 systems and the criteria on the protection systems.
7 But the requirements that the protection system be
8 independent from the PICS system is not a requirement
9 placed on the PICS, it's a requirement placed on the
10 protection systems, and that was covered separately.
11 Now, there isn't necessarily a requirement that they
12 be diverse or different, but they are just by the
13 nature of the technologies used.

14 Next slide, please. So the following
15 three slides are three depictions from the FSAR of
16 what constitutes the PICS. I won't spend a lot of
17 time on this, but this is a little bit more detailed
18 and is a little bit what Charlie was asking about on
19 the other slides.

20 So next slide, please. This is the
21 gateway communication between the safety system and
22 the non-safety and basically what it's showing is that
23 there are two predominant communication paths; and,
24 within those communication paths, there are multiple
25 instances of one-way communication. So it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 possible to communicate effectively into the TRPS or
2 ESFAS, and that is one of the things that ensures
3 independence.

4 The other thing that ensures independence
5 is that, in general, the safety systems are failsafe
6 on loss of power and the safety actuation is to lose
7 power. Those two relays are in series, as described
8 in the previous presentation, so that's a little bit
9 how, another way that the systems are independent.
10 This is the digital communication independence that
11 the series power relays are the actuation
12 independence.

13 Next slide, please. So, in essence, the
14 control board has some static displays, as well as
15 some manual switches. What you see is a little bit
16 the ESF, which has, it's the middle display. It has
17 that little operate safe shutdown position for the
18 enable facility operation key switch.

19 Next slide, please. So, again, we need to
20 summarize a little bit the NRC's approach to safety
21 regulation. So it's a layered approach, and, in that
22 layer, we do certain types of review. So the
23 application identifies the principal safety concerns,
24 the design criteria effectively establish the
25 performance objectives that, if met, will ensure that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the reasonable assurance of adequate safety against
2 the safety considerations. The design bases are, in
3 effect, the functions and values performed by the
4 system and used in the analysis to demonstrate that
5 normal operation, as well as anticipated events, will
6 not cause the performance criteria to be exceeded.

7 Then, finally, the last layer of the
8 review, and this is predominantly where I&C falls in,
9 is that the equipment performs the design basis
10 functions and values and misbehaviors of the equipment
11 do not exceed the assumptions in the safety analysis.
12 So predominantly -- next slide, please -- our review
13 is to ensure that the misbehaviors of the equipment do
14 not violate the safety analysis. So that, in essence,
15 required us to look at a subset of the design criteria
16 in the FSAR, and what you see in the safety evaluation
17 and summarized below is the subset of criteria that we
18 looked at to ensure safety.

19 Next slide, please. So the safety
20 analysis, and so, as we were summarizing before, in
21 effect, a system, our view of the world is that there
22 are two types of systems in a facility, ones that
23 generate events and ones that either prevent or
24 mitigate or alarm and notify about those events. So
25 the analysis demonstrates that the protection system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ensures that all events generated do not endanger the
2 health and safety of the public, and the PICS review,
3 the FSAR, includes an analysis of the HIPS equipment
4 or a summary of the analysis of the HIPS equipment,
5 which we did look at during the audit, and that
6 summary concluded that the failure modes of the HIPS
7 equipment were bounded by the safety analysis
8 documented in the FSAR or summarized in the FSAR.

9 There were two sort of exceptions to that
10 which impose additional requirements on the
11 architectural design so that those failures would not
12 exceed what was already analyzed. But that level of
13 detail is not really necessary in the FSAR and,
14 therefore, is not in the FSAR. It was looked at
15 during the audit.

16 So, again, the PICS is independent from
17 the TRPS and ESFAS by multiple ways, the digital
18 communication we saw earlier, the series, relays for
19 power to the controlled components. And the analysis
20 of the failure, the effects of failures is described
21 in the FSAR as summarized on this slide.

22 MEMBER BROWN: Norbert?

23 MR. CARTE: Yes.

24 MEMBER BROWN: You can correct me if I'm
25 wrong, but I hope I'm not. When we say the PICS is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 independent from the TRPS and ESFAS, there are
2 communications from the facility control room that go
3 through the PICS, but it comes up through the hardware
4 module or something like that, I've forgotten what
5 it's called, for specific, but it's unidirectional
6 type information. It's not stuff, it's control
7 functions is what I'm saying. It's nothing that could
8 interfere with the operation of the TRPS or ESFAS.

9 MR. CARTE: Right. Actually, maybe the
10 wording on that slide is slightly --

11 MEMBER BROWN: Yes, I'm looking at Figure
12 7.1-1, and you can very clearly see that there are
13 interactions from the workstations to the PICS and
14 then go out up to that, whatever it's called, I can't
15 read it. I don't have my magnifying glass right now.

16 MR. CARTE: Yes, technically, you're
17 correct. The wording on this slide, it's not a
18 bidirectional wording, and it's actually, I would say,
19 incorrect. The TRPS and ESFAS are independent from
20 PICS. The PICS is not necessarily independent from
21 the TRPS. But our view is that any failure of the
22 PICS would not inhibit the TRPS and ESFAS from
23 performing its function and, in that sense, they're
24 independent.

25 MEMBER BROWN: Yes, I got that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CARTE: There is some information --

2 MEMBER BROWN: I just wanted to point out
3 the discrepancy; that's all.

4 MR. CARTE: Yes. So there is information
5 that goes from the TRPS and ESFAS to the PICS and
6 failures of that information would result in loss of
7 that information to PICS. But the TRPS and ESFAS is
8 failsafe, so if that information were missing, like
9 sensor failures, then the TRPS would failsafe to the
10 safe state. But, in essence, you're correct. That
11 statement is wrong. TRPS and ESFAS are independent
12 from PICS.

13 CHAIRMAN BALLINGER: Yes, this is Ron
14 again. It seems like we're, Charlie and I, are kind
15 of beating a dead horse on this, but this is the crux
16 of the analysis after all.

17 MR. CARTE: Yes. And so we talked about,
18 and I guess there was mention of the third. What I
19 initially talked about was the digital communications,
20 which is one way out from TRPS to PICS. I also
21 mentioned the relays interrupting power to the
22 controlled or protection devices, controlled and
23 protection devices, we would say the actuated devices.

24 What was mentioned in the PICS discussion
25 that was a third point was that there is a priority

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 module in effect that prioritizes the non-safety
2 inputs, and those non-safety inputs, if you examine
3 the logic in TRPS, can only work when there is no
4 manual or automatic safety actuation commanded by the
5 protection system. And in those instances, you can
6 then reset the protective action of the protection
7 system. In other words, basically, the condition
8 requiring the protective action needs to clear, for
9 the most part, before you can reset.

10 MEMBER BROWN: I got that out of the
11 reading of the FSAR and your SER.

12 MR. CARTE: Okay. Thank you. Next slide.
13 So, in essence, the design bases is essentially
14 included in Section 7.3.1, which describes the
15 variables monitored and alarmed, the control
16 functions, the interlocks and permissives that are
17 performed by the PICS system.

18 Next slide, please. And based on the
19 review of the independence aspects of the TRPS from
20 PICS, as well as the detailed analysis by SHINE
21 summarizing the FSAR, PICS equipment failures are all
22 bounded by the analysis summarized in the safety
23 analysis sections of the FSAR. We reached a
24 conclusion that PICS performs its role in providing
25 reasonable assurance of adequate safety.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide, please. Are there any
2 questions?

3 MEMBER BROWN: I'm trying to figure it
4 out. I lost track of one of my questions here. This
5 is Charlie again. Hold on for a second. Oh, okay.
6 There was one area, and I understand what the FSAR
7 said, it was in Section 7.3.1.3.11, and this is the
8 target solution vessel protection in ESFAS and its
9 relationship. There were words like safety-related
10 components that are capable of being actuated by the
11 TRPS or ESFAS but also have a non-safety related
12 function related to production achieve their safe
13 state by having power removed. And then the converse
14 of that is safety-related components that are capable
15 of being actuated but do not have a non-safety related
16 production are not controlled directly by PICS, but
17 there is -- the way I read this is, the TRPS does have
18 a non-safety related function and it feeds those
19 functions.

20 Can you explain -- it achieves a safe
21 state as a result of what? A malfunction so that it
22 can't affect the facility functions? You know what
23 I'm talking about?

24 MR. CARTE: A little bit. Let me, I think
25 the way to think about the scheme is a rod control

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 system. So, basically, in a power reactor, PWR, rod
2 control system, you have non-safety control of the
3 rods, but the safety system removes power and the rods
4 drop, and it goes to a safe state. And it's that same
5 configuration on the TRPS and ESFAS. All of the safe
6 states are achieved by loss of power, so, if you get
7 failures in the TRPS, you remove power, and that
8 includes sensor failures or self-diagnostic failures
9 of equipment, and that's how safety is assured.

10 So, in essence, the non-safety side
11 control is sort of irrelevant. All you're worried
12 about is that the failures are either detected and
13 protected against and/or do not exceed the assumptions
14 in the safety analysis.

15 MEMBER BROWN: Let me -- okay, I got that.
16 I'm looking at how it achieves it functionally. There
17 was another sentence where it said, in other words, it
18 has some connection to some production function, but
19 then it says -- so it's sending information to a
20 production function of some kind. Then it says should
21 a safety actuation be required, the TRPS or ESFAS
22 opens a contact in series with the power supply to
23 whatever component it was interacting with, causing it
24 to achieve its safe state also, regardless of the
25 control signals from the PICS. I read that positively

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and that, if you have some production function going
2 on, you get a trip, the TRPS will terminate that
3 function by turning off its power supply via a relay
4 contact.

5 MR. CARTE: Correct.

6 MEMBER BROWN: That's the way I read that
7 sentence, and I don't have a problem with that, at
8 least as long as that reflects satisfaction with
9 whatever production is going on. I mean, SHINE
10 proposed it, so I presume they've looked at that.

11 MR. CARTE: Right. That is correct.

12 MEMBER BROWN: Okay. So I understand
13 what's going on correctly then.

14 MR. CARTE: Right. It's basically,
15 everything follows the pattern of a rod control
16 system.

17 MEMBER BROWN: Okay. I got it. I
18 understand the analogy. Thank you. That's all I had.
19 Ron, I'm done.

20 CHAIRMAN BALLINGER: Okay. Thank you.
21 Are there any other questions from members or
22 consultants on this presentation? Hearing none, now
23 we need to shift topics and go into the phased startup
24 presentation. So I guess SHINE needs to bring up
25 their slides. Who's the presenter?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MS. RADEL: Hi, this is Tracy Radel. I'll
2 be presenting on the phased startup.

3 CHAIRMAN BALLINGER: Thanks.

4 MS. RADEL: So here's the outline of what
5 we'll go through today. I'm going to start out with
6 the philosophy around phased startup operations, move
7 into descriptions of each of the phases, and then more
8 specifically into the IF systems, RPF systems, I&C
9 systems, electrical aux, and then finally conclude
10 with the safety analysis aspects.

11 Next slide. So the overall philosophy is
12 to meet the national need for Moly-99 production as
13 soon as possible while also ensuring all requirements
14 related to public health and safety are met. We've
15 proposed phased startup operations to provide
16 flexibility for challenges that we expected to arise
17 during procurement, installation, and testing.

18 The key considerations we had for the way
19 the phases are structured were to ensure that all the
20 design criteria and safety functions were met during
21 all phases. Our goal was to simplify the process
22 boundary isolations, as well as the confinement
23 boundary isolations, and to minimize the impact on
24 operating portions of the facility.

25 I do want to note that our procurement and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 installation philosophy was not inherently impacted by
2 phased startup operations approach. SHINE is
3 procuring the equipment for all irradiation units at
4 the same time. No phasing on that. Fabrication for
5 most of the equipment is naturally being done and set
6 for batches because there are eight units' worth of
7 equipment, resulting in a staggered delivery. And as
8 challenges have been encountered in the fabrication
9 process, we have prioritized the phase one equipment.

10 Equipment will be installed as soon as
11 possible after it's received on site. So while the
12 primary focus is on getting phase one equipment
13 installed, we will not hold off installation of
14 equipment for later phases if it is ready to go in and
15 the construction team has bandwidth for installation.

16 Next slide. The phases are described
17 here. So for phase one, the facility structure and
18 nitrogen system structure fully installed, IUs one and
19 two are fully installed, and when I refer to an
20 irradiation unit, or IU, it includes the IU-specific
21 instances of the subcritical assembly systems, the
22 neutron flux detection systems, target solution
23 vessel, off-gas systems, primary cooling systems like
24 water pool system, and radiological ventilation Zone
25 1 equipment located in the cooling room. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 includes both RVZ1r and RVZ1e equipment.

2 For phase one, the tritium purification
3 system train A will be installed, and then the
4 auxiliary and support systems, with the exception of
5 the IU-specific instances of PCLS, LWPS, and RVZ1
6 equipment that were mentioned above. And then the
7 radioisotope production facility systems, with the
8 exception of the iodine and xenon purification and
9 packaging and the radioactive liquid waste
10 mobilization selective removal capabilities.

11 So Figure 1.1-1 of the phased startup
12 supplement provides a visual representation of the
13 phasing showing the physical areas for installation in
14 each phase can be helpful for understanding what's
15 installed for each phase of operation.

16 Next slide. Phase two brings in
17 irradiation units three, four, and five and TPS train
18 B. Phase three brings in irradiation units six,
19 seven, and eight and train C of the TPS equipment,
20 along with the RLWI selective removal capability and
21 the material staging building. Phase four is bringing
22 in the iodine and xenon purification and packaging
23 capability.

24 Next slide. On the irradiation units
25 specifically, they are designed and operated at a unit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 level. Each IU has unit-specific instances of ESFAS,
2 NDAS, light water pool, irradiation biological shield;
3 and each IU is supported by a unit-specific instance
4 of PCLS.

5 The support system and process interfaces
6 with the IUs are isolated to support the phased
7 startup operation. Specifically, the auxiliary
8 systems, RPCS, facility nitrogen handling system,
9 facility chemical reagent system, nitrogen system, and
10 radiological ventilation zone include isolations to
11 support the phasing.

12 Next slide. In the tritium purification
13 system trains, the TPS as a whole consists of three
14 independent trains, and each TPS train supports
15 specific NDAS units. These train divisions are
16 supporting the phased operation, so each of these
17 trains includes independent thermal cycling absorption
18 process, or TCAP; the TPS NDAS interface lines;
19 secondary enclosure cleanup systems; vacuum impurity
20 treatment systems; connections to the NDAS secondary
21 enclosure cleanup; and TPS gloveboxes.

22 The tritium confinement boundary for each
23 TPS train is independent and isolated from the other
24 TPS trains, and no portion of the tritium confinement
25 boundary is shared between TPS trains. Isolations are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 provided at the TPS interface points to facility
2 systems to allow the trains to be connected and
3 commissioned without impacting other TPS train
4 operation.

5 Next slide. On the RPF side of the
6 facility, the RPF systems are installed to support
7 phase one operation, with the exception of the IXP
8 system and selective removal within the RLWI. Note
9 the capability to solidify liquid waste is installed
10 as part of phase one. During phase one through three
11 operations, the IXP system is not installed and the
12 IXP hot cell is exploited from the super cell
13 containment boundary. Connections to the IXP system
14 are isolated during phase one through three.

15 The capability of the RLWI system to
16 remove the classification driving isotopes is not
17 available during phase one and phase two operation.
18 During phase one and phase two, liquid waste is stored
19 in the subgrade. We do not anticipate having to
20 solidify liquid waste prior to phase three operation
21 due to the capacity of the storage within the RLWS.
22 Waste solidifying during phase one and phase two may
23 be higher dose and higher waste classification than
24 waste solidified during phase three or four.
25 Solidified liquid waste would be stored in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 portholes prior to shipment to disposal site.

2 Next slide. During phased startup
3 operations, the instrument and control systems are
4 installed to the extent practicable, given the extent
5 of equipment installation. IU-specific instances of
6 the TPS reactivity protection system are brought
7 online with the associated IUs and the applicable
8 phases.

9 There are nine TRPS cabinets installed in
10 the facility control room. All cabinets will be
11 installed prior to phase one operations. Those
12 cabinets are divided in the following way: So the
13 first three cabinets are the division A, B, and C for
14 IUs 1 and 2. The second set of three cabinets are
15 division A, B, and C for IUs 3, 4, and 5. And the
16 final set of three are the Division A, B, and C
17 cabinets for IUs 6, 7, and 8. So the division amongst
18 the TRPS cabinets does support phased startup
19 operations.

20 The engineering safety feature actuation
21 system is installed to support phase one operations.
22 We did implement a new capability to disable the
23 inputs that are not used during later phases. These
24 disabled inputs are restored and verified to be
25 operable prior to entering the technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 specifications mode of applicability associated with
2 the given input. Disabled inputs are listed in Table
3 7.5-1 of the supplement, and the safety functions not
4 utilized during particular phases are listed in Table
5 7.5-2 of the supplement.

6 MEMBER BROWN: This is Charlie Brown. Can
7 I ask you a question relative to the last bullet?

8 MS. RADEL: Yes.

9 MEMBER BROWN: I understand what you've
10 just gone through, but the ESFAS is an overall
11 facility piece of equipment, not like the TRPS which
12 is identified with each IU. And I'm only bringing
13 this up because of past experience of doing things
14 piecemeal in my Navy programs when we were building
15 submarines or aircraft carriers.

16 Your ESFAS is going to have all functions.
17 You talked about disabling outputs. It's not just
18 outputs, it's also inputs that you have to be careful
19 of, depending on how they're used in the software.
20 I've been there and done that and you've got to be --
21 all I'm doing is providing a little unneeded advice
22 probably. It's just very difficult to ensure you
23 don't have some stray piece of information come in and
24 all of a sudden gum up the works.

25 I'm not disagreeing with the approach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you're taking. I totally agree with the phased
2 approach. It's just a matter of, for an overall total
3 facility system, which has all that information
4 already built into the software, you're not going to
5 be piecemealing that software. It should be complete
6 when you start at the very beginning, and I've taken
7 that's correct based on what you've just said. I'm
8 just --

9 MS. RADEL: Just to clarify, the disable
10 function is for the inputs into the system and is done
11 through the maintenance workstation and verification
12 of those inputs being disabled for a particular phase
13 or enabled to support a particular phase.

14 MEMBER BROWN: I got that, but you've also
15 got outputs.

16 MS. RADEL: Yes, so that is the --

17 MEMBER BROWN: You can't ignore that.

18 MS. RADEL: So that's the safety function,
19 you know, the safety functions that wouldn't be
20 actuating during particular phases. Those are very
21 limited within the ESFAS.

22 MEMBER BROWN: Okay. I'm just, before you
23 start lighting off the first three, you've just got to
24 make sure those outputs are truly not going to affect
25 anything, that's all, so that you don't mess up the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 systems that you are actuating. I'm just a
2 grandfather offering advice.

3 MS. RADEL: I appreciate the advice.
4 Thank you.

5 MEMBER BROWN: Okay. Thank you.

6 MS. RADEL: Okay. The IU-specific
7 instances of the neutron flux detection system are
8 brought online with the associated IU. The safety-
9 related process radiation monitors are installed, to
10 the extent practical, given the extent of equipment
11 installation. There are safety-related process
12 radiation monitors associated with the individual IUs,
13 as well as the TPS trains, and those are installed as
14 that equipment is brought online.

15 Safety-related process radiation monitors
16 associated with the IXP cell are installed prior to
17 phase four operations. Table 7.7-1 provides a
18 detailed listing of the radiation monitor phasing.

19 Process integrated control system hardware
20 is installed prior to phase one operations, with the
21 exception of hardware associated with TPS trains B and
22 C. PICS monitoring and controls associated with
23 equipment that's not yet installed or not yet operable
24 to support phase one are tested and placed into
25 operation as required for the given phase.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide.

2 MR. SCHULTZ: Tracy?

3 MS. RADEL: Yes.

4 MR. SCHULTZ: This is Steve Schultz.
5 There are non-safety related radiation monitors
6 associated with the PICS system. The PICS system
7 reads them. Are they going to be installed? What is
8 the schedule for --

9 MS. RADEL: All of the non-safety related
10 radiation monitors, yes, are installed as part of
11 phase one.

12 MR. SCHULTZ: I'm sorry. I didn't catch
13 the last part of the response.

14 MS. RADEL: Sorry. Yes, the non-safety
15 related radiation monitors are all installed as part
16 of phase one.

17 MR. SCHULTZ: Great. Thank you.

18 MS. RADEL: Next slide. The normal
19 electrical power supply system, or NPSS, and the
20 uninterruptible electrical power supply system, UPSS,
21 are installed in full to support phase one operations.
22 Loads on the NPSS and UPSS that are not yet installed
23 or not yet operable have the associated isolation
24 device removed or placed into an out-of-service
25 condition. Cabling associated with equipment not yet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 installed is installed to the extent practical with
2 the power removed at the associated panel or load.

3 The non-safety related standby generator
4 system is also installed to support phase one
5 operations.

6 MR. BLEY: Tracy, Dennis Bley. Do you
7 anticipate -- well, I guess you've already told us
8 this. Never mind. I was wondering about the amount
9 of unconnected cable that's going to be there, but it
10 really doesn't matter. It will be from the source to
11 where the equipment will eventually be installed for
12 the most part?

13 MS. RADEL: The cabling and panels will be
14 installed out to the remote panels as part of phase
15 one and then --

16 MR. BLEY: And that includes the remote
17 panels?

18 MS. RADEL: Yes, it includes the remote
19 panels. And then the cabling beyond that will be
20 installed depending on equipment installed.

21 MEMBER BROWN: Okay. Along with the final
22 connection back to the power supply?

23 MS. RADEL: Yes. Auxiliary systems. The
24 RVZ1 recirculating subsystems. Our RVZ1r units
25 support individual IU cells and are installed with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 corresponding IU. A portion of the RVZ1e subsystem is
2 also installed with the corresponding IU that is the
3 portion of the system that is located within the
4 cooling rooms.

5 Supply lines from auxiliary systems that
6 are supplying each of the irradiation units have
7 manual isolation valves and blank flanges or caps to
8 support phased startup operations. And because of
9 normal variation and flexibility in facility
10 operations, the auxiliary systems are designed to
11 handle the variable loads without any modifications.

12 Next slide. For the accident analysis, a
13 hazard evaluation was performed to identify new or
14 different accident scenarios, including changes to
15 likelihood or consequence of existing accident
16 scenarios. The likelihood and consequence for these
17 new or different accident scenarios were then
18 evaluated and compared to the risk matrix and safety-
19 related controls were applied to prevent or mitigate
20 the accident scenarios in the method that was
21 consistent with what's described in Chapter 13(a)(2)
22 of the FSAR.

23 No new accident categories were identified
24 as part of phased startup operations. And no
25 increases to the consequences of existing accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 scenarios covered in Chapter 13 of the FSAR were
2 identified.

3 There were five new accident sequences
4 within the existing accident categories that were
5 identified and five existing accident scenarios were
6 re-evaluated for increased likelihoods. Four new
7 credited entry controls and three new credited
8 administrative controls were added during phased
9 startup operations to prevent the new or different
10 accident scenarios.

11 And this is the final slide of my
12 presentation. Any questions?

13 MEMBER SUNSERI: Tracy, this is Matt
14 Sunseri. I've got a question for you. All these
15 physical analysis controls seem pretty thought out to
16 me. Can you speak a little bit towards the controls
17 that you will have in place for personnel access,
18 construction personnel access, operations personnel
19 access, such that, for a lack of better word, I'll use
20 the term unauthorized individuals aren't exposed to
21 radioactive material or radiation and that the
22 construction workers don't impede operators from
23 getting where they need to be to operate the plant?

24 And one last component of that is what
25 oversight of the construction activities will be in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 place such that they won't drift from their
2 construction activities and work on operational
3 equipment? That's a long one, but it's kind of the
4 administrative controls that you're going to have.

5 MS. KOLB: Yes, this is Catherine Kolb.
6 I'll respond to that question. So SHINE will
7 implement our physical security plan, our radiation
8 protection program, which includes access control to
9 the facility. So if workers, construction workers,
10 need to have regular access to the facility, they'll
11 be badged and trained as rad workers if they need to
12 to be able to access their normal work locations or
13 else, per the provisions of the plan, they will be
14 escorted by people who are trained and authorized, and
15 we intend to fully implement those two plans.

16 The other question about oversight of
17 construction activities, once the facility has its
18 operating license for phase one, we would expect and
19 have processes in place for people doing work for the
20 facility to check in with the control room as if we
21 were doing normal maintenance for the facility so that
22 the operators are cognizant of large activities that
23 are going on in the facility.

24 I know we don't have the general
25 arrangement drawing in the presentation, but it is in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the phase supplements. And you will notice that most
2 of the activity is localized to the specific radiation
3 unit cells that would be worked on during the phased
4 approach, so we would not expect, you know, large
5 construction activities to be taking place, you know,
6 like throughout the facilities. So it should be, we
7 are expected to be able to coordinate that during the
8 phased approach installation activities.

9 MEMBER SUNSERI: Okay. That sounds
10 reasonable to me. I was just thinking about when we
11 talked through the plant a few weeks ago there was a
12 couple of places, and I just remember one and I
13 probably will get the equipment mixed, but I think the
14 irradiation units were on one side and the tritium
15 purification was on the other side of the hall in this
16 real long hall, so I can imagine that might get pretty
17 busy in there when you're operating half of it and
18 working on the other half. Thanks.

19 MS. KOLB: Yes. I understand your point
20 there, and your recollection is correct on the
21 arrangement of the facility. You know, we intend to
22 install everything that we can to the extent practical
23 to minimize that, but, yes, we're just intending to
24 implement the processes and procedures as we have
25 described them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER SUNSERI: Thank you.

2 MS. RADEL: Any other questions? Okay.
3 Thank you.

4 CHAIRMAN BALLINGER: Hearing none, thank
5 you very much. I think we would sort of be scheduled
6 for a break around now, say at 11, if we were to go
7 that far, but we only have one more presentation to go
8 and then discussion. So why don't we go with this
9 presentation, and then, if we think discussions are
10 going to take a longer time, we'll have a break before
11 that.

12 So unless I hear an objection from
13 members, let's go with the NRC presentation. Thank
14 you.

15 MR. BALAZIK: Can everybody hear me okay?

16 CHAIRMAN BALLINGER: I can hear you fine.

17 MR. BALAZIK: Perfect. Thank you. Good
18 morning. My name is Michael Balazik. I'm the NRC
19 project manager for SHINE in the Office of Nuclear
20 Reactor Regulation within the Division of Advanced
21 Reactors and Non-Power Production and Utilization
22 Facilities. And this morning, I'll be presenting the
23 staff's review of the phased approach to startup.

24 Next slide, please. Okay. So the
25 regulatory requirements that the staff applied to this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 portion of the review were 50.34, contents of
2 applications and technical information; 50.40, common
3 standards; and probably the most important one, 50.57,
4 the issuance of operating license.

5 Next slide, please. Guidance hasn't
6 changed. We pretty much use the standard guidance
7 we've been using for this entire review. NUREG-1537
8 and the final Interim Staff Guidance for licensing of
9 radioisotope production facilities.

10 Next slide, please. All right. So,
11 quickly, I'll just go over a summary of the
12 application. Tracy provided a lot more detail than I
13 would. Back in January of this year, SHINE did
14 supplement the SR-described four-phase approach to
15 startup operations. This phased approach is staggered
16 over a couple of years and planned to be completed in
17 the 2025 time frame.

18 So within the supplement, SHINE describes
19 the impacts, the technical impacts, along with
20 information differences for each chapter of what I'll
21 call the full design facility FSAR. Within the
22 supplement, SHINE identifies equipment isolation
23 points and the isolation methods for each phase for
24 the different equipment.

25 So some of the chapters that were most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 impacted by this phased approach to startup were
2 Chapter 4, Chapter 7, Chapter 9, and 13.

3 Next slide, please. All right. Just
4 continuing on with a summary of the application. Back
5 in February of this year when we provided an overview
6 to ACRS full committee on the SHINE review, we did
7 talk about this phased approach to startup. And I
8 remember one member saying that, you know, this is
9 kind of analogous to plug and play. I can't remember
10 if he said that, but that's, you know, pretty much our
11 look on a majority of these items.

12 So the irradiation units, they're designed
13 and operated as independent units. The TPS, which
14 consists of three independent trains to support the IU
15 operation, so TPS train Alpha will support phase one,
16 and trains Bravo and Charlie, they'll support the
17 operation of the subsequent phases.

18 With the exception of the iodine and xenon
19 purification and packaging system and the radioactive
20 liquid waste isolation, all systems for the production
21 facility will be installed to support phase one
22 operations. And for instrument and control for TRPS,
23 it's IU-specific, and some of the inputs for the
24 ESFAS, which Member Brown was talking about, is an
25 entire facility system and, along with PICS, some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 those inputs are disabled and brought on as the phases
2 come in.

3 And discussing Chapter 13, there were five
4 new accident sequences that were identified and five
5 existing sequences that had an increase in likelihood.
6 The new accident sequences were improper target
7 solution routing, damage to a TPS train, damage to the
8 process vessel vent system, Talk's interface, and back
9 flow of target solution to the IXP.

10 And the likelihood increase that was
11 evaluated by SHINE, there were heavy load drops on the
12 TPS, heavy load drops on an operating irradiation unit
13 or Talk cell, and a heavy load drop on the radioactive
14 liquid waste isolation enclosure super cell. And
15 then, of course, as the phases go in, as construction
16 is continued, you know, there's an increase in the
17 fire, the irradiation facility or the radioisotope
18 production facility.

19 Next slide, please. So how we started our
20 approach to this review is that we wanted the exact
21 same staff members to review the phased startup
22 approach that reviewed the full design. So for our
23 technical and safety review, the NRC staff reviewed
24 the information, the SHINE supplement, against
25 regulatory requirements, regulatory guidance and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 acceptance criteria, that I discussed earlier. Staff
2 evaluated the effect of the phased approach of startup
3 on the sufficiency of the facility descriptions,
4 design basis, facility operation, and SSCs, and as the
5 facility as a whole. And we also reviewed the kinds
6 and quantities of radioactive material expected to be
7 produced in the operation of the SHINE facility and
8 the means for controlling and limiting radioactive
9 exposures within 10 CFR Part 20.

10 We also reviewed the methods and
11 sufficiency of system level isolations for the
12 different phases just to ensure safe operation of
13 facility and health and safety of the workers and
14 public.

15 Next slide, please. Okay. We did perform
16 an audit. Right now, we're just finishing, just some
17 final touches on that is in draft form right now. We
18 can share that with members if requested. We're
19 hoping to have that issued here very soon.

20 I'll say that, early on in our review, we
21 had some areas of perceived risk significance in some
22 of those areas where the human system interfaces and
23 training of operators, because there will be a lot
24 going on in these different phases, that we wanted to
25 make sure, like the operators, you know, there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 minimal distractions to them while operating the
2 facility.

3 Tracy and Charlie discussed this earlier
4 on disabling and enabling instrumentation and control
5 inputs. Also, with construction, there will be
6 increased clean operations with heavy loads during
7 operation and also on radiological dose to workers on
8 completing construction. And what we looked at is if
9 there was a construction going on in an adjacent IU
10 cell, you know, what would those doses look like to
11 that individual in there.

12 Next slide, please. So 10 CFR 50.57,
13 which is issuance of operating license, it requires
14 that each license issued by the Commission to include
15 appropriate provisions with respect to uncompleted
16 items of constructions required to ensure that the
17 operation during the period of the completion of such
18 items will not endanger public health and safety. So
19 in their response to an RAI, SHINE did provide phased
20 specific listing of installation and functional
21 testing that was needed to support each phase of the
22 operation. And the staff is imposing a license
23 condition to ensure that the operation of these
24 subsequent phases will not commence until the
25 uncompleted items are completed and that NRC oversight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of completion of these uncompleted items is
2 maintained.

3 So next slide, please, is the actual
4 license condition that we're proposing. The first
5 part of this just points to the supplement submitted
6 by SHINE, and then the two conditions below talk
7 about, you know, 14 days prior to planned commencement
8 of operation of the next phase, that SHINE has to
9 notify the NRC in writing that all uncompleted items
10 of construction have been completed. And item B there
11 talks about SHINE providing updates to the NRC after
12 issuance of the operating license, which, you know,
13 would authorize phase one. Every six months, SHINE
14 needs to provide the NRC an update on the information
15 and the status of the schedule for completion of
16 uncompleted items of construction. And we could use
17 this information to inform our oversight inspection
18 activities for SHINE.

19 And last slide here, these are evaluations
20 and conclusions that SHINE did describe the design of
21 the systems and identified major features or
22 components affected by the proposed phase approach to
23 startup, also that the process is performed; operating
24 procedures and equipment; use of the facility; provide
25 reasonable assurance that they'll comply with Part 50

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and Part 20 regulations and that the health and safety
2 of the public will be protected during the phased
3 approach to startup; and, 50.40, the issuance of the
4 operator license will not be inimical to the common
5 defense and security of health and safety of the
6 public and that the descriptions and discussions of
7 the SHINE systems affected by the approach are
8 sufficient to meet the applicable regulatory
9 requirements and acceptance criteria for issuance of
10 an operating license.

11 That's my last slide. Are there any
12 questions?

13 MEMBER HALNON: Yes, Michael. This is
14 Greg Halnon. Do you guys have a plan for how you're
15 going to do the oversight during this time frame?
16 There was some discussion whether Region III would be
17 doing it or Region II. Since you'll have operation
18 and construction going on at the same time, will there
19 be different oversight centers or --

20 MR. BALAZIK: Yes, Member Halnon. Right
21 now, Region II is the lead for the construction
22 activities at SHINE. Once we get into that pre-
23 operational readiness, there's a combination of Region
24 II oversight activities and NRR oversight activities.
25 So office of NRR has the lead for the pre-operational

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 readiness.

2 Now, for these parts of construction, we
3 haven't figured out exactly who would have the lead on
4 these inspection activities and what the inspection
5 activities look at this time. So I can't give you a
6 definite answer who is going to have the lead on this.

7 MEMBER HALNON: Okay. I think, as you go
8 forward and figure that out, we'd be interested in at
9 least seeing the documents or some kind of plan. I'm
10 not sure that the Operations Subcommittee wants a
11 full-blown meeting or anything, but let's stay in
12 touch and, when you get that set, communicate it with
13 me.

14 MR. BALAZIK: Yes, sir. I got it.
15 Appreciate it. Any other questions?

16 CHAIRMAN BALLINGER: This is Ron
17 Ballinger. With respect to that request, do you
18 anticipate the timing for that?

19 MR. BALAZIK: I think that would be based
20 on SHINE providing us the information when they would
21 be, you know, ready to move to the next phase. But --

22 CHAIRMAN BALLINGER: Okay. So that's long
23 after, long after we're done with the letter, right?

24 MR. BALAZIK: Long is a relative term. I
25 don't know if SHINE wants to chime in on their planned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 schedule.

2 MS. RADEL: Yes, so this is Tracy Radel.
3 We're approximately a year or so out from substantial
4 completion, roughly, as far as receipt of the
5 operating license, you know, subsequent to that.

6 CHAIRMAN BALLINGER: I would consider that
7 long compared to December.

8 MR. BALAZIK: Yes, sir, I do agree with
9 that. Thank you, Tracy.

10 CHAIRMAN BALLINGER: Okay. So absent
11 further questions by members or consultants, we need
12 to now ask for public comment. If you are a member of
13 the public and you're listening and would like to make
14 a comment, please state your name and make your
15 comment, reminding, I think, that if you're on the
16 phone you have to use the star 6 procedure to get
17 access.

18 So are there members of the public out
19 there that would like to make a comment? Apparently
20 none.

21 Okay. So we are, more or less, at the end
22 of the presentations. I don't think we need a closed
23 session, so now I think we need to just open up the
24 discussion for any other comments or discussion points
25 that members would like to deal with. Deafening

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 silence. Okay.

2 MEMBER DIMITRIJEVIC: Ron, this is Vesna.

3 CHAIRMAN BALLINGER: Vesna, how are you?

4 MEMBER DIMITRIJEVIC: Good. How are you
5 doing?

6 CHAIRMAN BALLINGER: Your name is not on
7 this list for some reason.

8 MEMBER DIMITRIJEVIC: I don't know why.
9 I can see my name on the list.

10 CHAIRMAN BALLINGER: Okay, all right.

11 MEMBER DIMITRIJEVIC: I was thinking maybe
12 we can devote some short time on just discussing how
13 can we help you in writing this letter and do you have
14 some structure in mind, you know, so that we can get
15 ready for writing --

16 CHAIRMAN BALLINGER: Yes. I sent a note
17 out to the members probably late last night. The way
18 I see it, we now have, with the exception of two of
19 the memos, all of the memos may have ML numbers, and
20 so those are available. And my plan is to use those
21 memos as not only the starting point but the major
22 input for the letter and any other comments, which
23 I've asked people for -- from time to time, members
24 have sent paragraphs or such and such to me related to
25 what might be in the letter. Like I said last night,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there are various vintages. So if there are members
2 that have additional comments or issues related to
3 what might be in the letter, then I'd appreciate those
4 because, come next week or starting this weekend, I'll
5 be putting together the draft letter.

6 Now, the format will be, unless I hear
7 something different, there are no showstoppers, no
8 buts, that would be in the letter that would require
9 response from the staff, I don't think. And so the
10 front-end of the letter, we already have some of that,
11 some of the background that we've seen before. And so
12 then the conclusion will be quite simple in words we
13 approve and then some minimal discussion that hits the
14 high points and then a referral because all of the
15 memos will be attached to the final letter. So what
16 it amounts to is a summary up-front and then the
17 detailed references also included in the letter.

18 So that's the general format, and I'd
19 appreciate comments from members related to that
20 because I'm going to start doing it tomorrow.

21 MEMBER DIMITRIJEVIC: So this was one of
22 my, actually, curiosities. Every writer has, you
23 know, comments or suggestions or conclusions in the
24 front. You don't plan to put those in the final
25 letter, you're just going to reference other letters?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIRMAN BALLINGER: No, no, I'm sorry.
2 I guess I wasn't detailed enough. There will be a
3 section after the results and the conclusions and
4 recommendation for sort of, I guess I would call it
5 general comments, I'm not sure I'd want to use the
6 word suggestions, that would contain the kinds of
7 things that we've had discussions of at the various
8 subcommittee meetings, and that's where input, the
9 little paragraphs and the like that we've asked people
10 to provide, would be very important.

11 So, yes, there will be, you know, again,
12 since we don't anticipate, at least right now, any
13 what I call showstoppers, the buts, that's just a for
14 information section, in effect.

15 MEMBER DIMITRIJEVIC: Yes. You know, I
16 was just thinking that these comments we have provided
17 throughout the sessions, some of them are different
18 types, you know. Like, for example, some are
19 suggestions, something we would like to see later, you
20 know. For example, Charlie had the comments on the
21 electrical system, which he asked for the, you know,
22 the changes. So I was sort of wondering because we're
23 having these different type of comments --

24 CHAIRMAN BALLINGER: Yes, we'll have to
25 reconcile --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER DIMITRIJEVIC: -- define the
2 categories. I wasn't sure what's the best way to
3 organize them, you know.

4 CHAIRMAN BALLINGER: I'm sure that, during
5 our discussions of the draft, we'll get that all
6 reconciled.

7 MEMBER DIMITRIJEVIC: All right, okay. So
8 then next --

9 CHAIRMAN BALLINGER: We got to have a
10 strawman to shoot at first.

11 MEMBER MARCH-LEUBA: This is Jose. The
12 way I envisioned it was we would have all the memos,
13 the full memos, in the appendices.

14 CHAIRMAN BALLINGER: Yes, yes.

15 MEMBER MARCH-LEUBA: Any comments, any
16 recommendations, any conclusions that you would like
17 to see on the main body of the letter, on the area
18 responsible for the memo, it would be convenient for
19 Ron if you write two or three paragraphs that you'd
20 ask him to say this is the summary of what the memo
21 says that I think merits inclusion in the body of the
22 letter.

23 CHAIRMAN BALLINGER: Yes, that's, you
24 know, we've asked that question quite a few times and
25 asked for input, and we've gotten some input. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we'll ask it again, yes. That would be very, very
2 helpful because, other than that, I will use the memos
3 themselves, which also contain these kinds of
4 comments. But it would be a lot easier if, now that
5 we've had the complete set of presentations, where, if
6 a member would like to provide a paragraph or so, that
7 would be very helpful. That's my story and I'm
8 sticking to it.

9 MEMBER BROWN: I had one question, Ron.
10 Is this meeting on the, whatever day it is, the 15th,
11 is that an in-person meeting, or are we going to be
12 trying to do this all day by virtual?

13 MEMBER REMPE: No, it's in person. We
14 decided that several months ago. Of course, if
15 someone wants to, they can still stay and do it
16 remotely, but there will be some folks in the room is
17 what we decided.

18 MEMBER BROWN: Okay. I was just trying to
19 confirm that that week was going to be an in-person
20 week. I wasn't at the meeting so --

21 CHAIRMAN BALLINGER: Yes, I think the
22 invitation was just sent out for anybody that wants to
23 do remote, but yes.

24 MEMBER BROWN: Yes, okay. That's all I
25 had.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: So, Ron, this is Greg.
2 Now I can kind of understand why you asked me to
3 revise one of the memos.

4 CHAIRMAN BALLINGER: Oh, wait a minute,
5 hold on a minute. Revising the memos, no, please.

6 MEMBER HALNON: Well, I mean, it's not the
7 actual issues, it's what we expected for the follow-
8 up. If we don't, you know, sometimes time heals some
9 of these comments and then --

10 CHAIRMAN BALLINGER: Right, yes.

11 MEMBER HALNON: -- come up that don't
12 really warrant anymore time being spent on it.

13 CHAIRMAN BALLINGER: Yes, yes.

14 MEMBER HALNON: I assume you'd like to
15 make sure the memos are up to date from the standpoint
16 of what we want follow-up and what we don't, kind of
17 to Vesna's question, what --

18 CHAIRMAN BALLINGER: Well, I think now I'd
19 have to ask Larry or Chris about this. I think those
20 memos now have ML numbers, and so those are kind of in
21 violet unless something else, unless we can -- I don't
22 know what we would do if somebody wants to change a
23 memo.

24 MEMBER REMPE: This is Joy. I mean, Larry
25 and Chris can give you ultimate, but I would say that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 no, those were a snapshot in time, and perhaps the
2 letter can say these were a snapshot in time and
3 these, you know, this letter has our final comments
4 that we want to mention about this review.

5 CHAIRMAN BALLINGER: Yes, that's --

6 MEMBER REMPE: I think that's what we've
7 done in the past.

8 CHAIRMAN BALLINGER: -- you know, the sort
9 of one- or two-paragraph vehicle is a way to do that.

10 MEMBER HALNON: Okay. And that was where
11 I was going with it. So in a paragraph, that should
12 be the endpoint. I mean, that's finally where our
13 mind is at relative to any issues that we have, both
14 specific and general.

15 CHAIRMAN BALLINGER: Yes. A lot of these
16 chapters are sort of interwoven, if you will, and so
17 it's entirely appropriate to have a different outlook
18 once you've heard them all.

19 MEMBER HALNON: Okay. And --

20 MEMBER DIMITRIJEVIC: So, Ron, when you
21 said now, we definitely don't have showstoppers, but
22 if there's suggestions for the changes in the chapter,
23 like Charlie did on electrical, then what's happening
24 with those?

25 CHAIRMAN BALLINGER: Well, if they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 suggestions, again, I need to make sure I'm not
2 violating a rule, if they're suggestions, the
3 applicant can either say, okay, we'll do that or, no,
4 we won't do that. That will be at the staff's or the
5 applicant's discretion. People can correct me if I'm
6 wrong.

7 MEMBER REMPE: Well, I would point out
8 that we only provide suggestions to the staff, right?

9 CHAIRMAN BALLINGER: Yes, yes.

10 MEMBER REMPE: I mean, we can make
11 comments to the applicant, but our charter is to help
12 the staff review.

13 CHAIRMAN BALLINGER: Yes, yes, yes.

14 MEMBER BROWN: If there's anything we want
15 a response from the staff for, we ought to say it in
16 your memo, not in one of the enclosures. It ought to
17 be brought up to the memo and we ask for a staff
18 response to our memo; that's all.

19 CHAIRMAN BALLINGER: And I think that
20 actually has happened for many of them.

21 MEMBER BROWN: Yes, that's the way we've
22 done all of our letters, so we sent a letter out, a
23 report, and we ask for a response or we don't. If we
24 want a response, then we get it. And if we've got
25 suggestions, we ask for a response.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIRMAN BALLINGER: Yes, yes.

2 MEMBER BROWN: This is not complicated.

3 CHAIRMAN BALLINGER: No, hopefully.

4 MEMBER HALNON: And the purpose of the
5 final memo is to give the Commission our overall
6 impression of the license application; is that
7 correct?

8 MEMBER REMPE: That's true, except it's a
9 letter, it's not a memo.

10 CHAIRMAN BALLINGER: It's a letter, it's
11 a letter.

12 MEMBER BROWN: It's a letter report.

13 MEMBER HALNON: Yes, that's words. But
14 the letter report.

15 MEMBER BROWN: It's a regular letter
16 report.

17 MEMBER HALNON: Yes, okay.

18 MEMBER REMPE: But I'm bean-counting
19 memos, Ron. You've said we've had all but a couple.
20 I know they're posted out there, but we're going go
21 actually go through how many? Isn't it like going to
22 be four or five, depending on what's happening with
23 this space --

24 CHAIRMAN BALLINGER: No, two or three.

25 MR. BROWN: Four. Four memos are left:

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cyber, life cycle, I&C, and help me, Jose. Oh, tech
2 specs, tech specs.

3 CHAIRMAN BALLINGER: Yes.

4 MEMBER REMPE: Isn't there a Chapter 7
5 also or something?

6 MR. BROWN: Yes, I&C. That's four.

7 CHAIRMAN BALLINGER: Yes. And there's
8 potentially a fifth, but I haven't decided, and that
9 is related to the phase approach. I waited until
10 after the presentations, and I'm going to think about
11 that a little bit, and it would be nice to hear from
12 the members on this. I'm leaning towards not having
13 a separate memo on the phased approach but including
14 discussion in what we would call the preamble and some
15 of the discussion in the letter because, in effect,
16 what the phased approach is is just a different method
17 of construction. Maybe I'm reading things wrong, but
18 it would be nice to hear from other members on what
19 their opinion would be.

20 MEMBER HALNON: It's not all that
21 different than what's going on in Vogtle or any other
22 multi-unit plant, so I don't see anything special
23 about it. It's just a matter of making sure that they
24 complied.

25 CHAIRMAN BALLINGER: Yes, yes, that's what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'm coming down to, but there are other opinions
2 probably. Oh, Scott Moore. Scott, you've raised your
3 hand.

4 MR. MOORE: Yes, Chairman Ballinger.
5 Previously, the staff had asked for the Committee's
6 final report on SHINE by the end of December. Are
7 they still looking for the report on that same time
8 line?

9 CHAIRMAN BALLINGER: I haven't heard
10 anything different, but we have an informal after this
11 meeting, and I'm sure we can confirm that. But I
12 think, Josh or Michael, can you confirm that?

13 MR. BORROMEO: That seems like a
14 reasonable time, but we can discuss if there's
15 resource issues at our informal afterwards.

16 MEMBER REMPE: This is Joy. And what
17 would be a reason for us to delay? We've gotten all
18 the information we need, and we have planned our
19 schedule, and so I wouldn't, even if the staff
20 decides, well, we can wait until, it would be February
21 if we don't do it in December because January we don't
22 have a full Committee meeting. So is there a reason
23 that we wouldn't want to try and meet that deadline,
24 Scott?

25 MR. MOORE: No, and I wasn't suggesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that. The only -- I just wanted to confirm that that
2 is when the staff needed the final report. And the
3 only reason I'd say that the Committee should delay
4 would be if there's new information or if the staff
5 hasn't responded to anything yet, and I'm not aware of
6 any of that.

7 CHAIRMAN BALLINGER: Right. So unless
8 death or plague occurs, December is it.

9 MEMBER REMPE: You know, with all the
10 pandemic stuff, don't say plague.

11 CHAIRMAN BALLINGER: I didn't say
12 pandemic. I said plague.

13 (Laughter.)

14 MEMBER REMPE: Never mind.

15 CHAIRMAN BALLINGER: Okay. So we've had
16 our discussion. Once again, I'd like to thank the
17 staff and the applicant and our staff actually for
18 seeing this through, and we're approaching the end,
19 and I'm looking forward with some fear and trepidation
20 to the November meeting where we have a discussion.

21 So if there aren't any further questions,
22 I think we need to close off this meeting. But,
23 Chris, should you and I and --

24 MR. BROWN: I have a separate invite.
25 Check your --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIRMAN BALLINGER: Oh, it's a separate
2 invite. Okay.

3 MR. BROWN: Yes.

4 CHAIRMAN BALLINGER: All right. We're
5 good.

6 MR. BURKHART: Hey, Ron, this is Larry.
7 Do you want to have an opportunity for public comment?

8 CHAIRMAN BALLINGER: Did that.

9 MR. BURKHART: Okay, all right. Sorry.

10 CHAIRMAN BALLINGER: Did that and didn't
11 hear anything. Okay. So thanks again everybody, and
12 we'll see Josh and whoever in a few minutes.

13 (Whereupon, the above-entitled matter went
14 off the record at 11:16 a.m.)

15

16

17

18

19

20

21

22

23

24

25



Process Integrated Control System (PICS)

RYAN MYERS, I&C ENGINEER

Outline

- PICS Overview
- PICS Network Architecture and Security
- PICS Interfaces with Safety-Related Systems
- PICS Vendor-Provided Nonsafety-Related Control System Interfaces
- PICS Workstations and Network Access

PICS Overview

- PICS is a nonsafety-related digital control system whose principal functions are to control and monitor facility systems and components within the irradiation facility (IF) and radioisotope production facility (RPF).
- A portion of the PICS supports the main control board (MCB) and operator workstations in the facility control room (FCR) by receiving operator commands and collecting and transmitting facility information to the operators.
- The PICS system network routes signals to the main distribution switch located in the server room.
- Information from the FCR, remote input/output (RIO) cabinets, remote human machine interface (HMI) panels, programmable logic controllers (PLCs), vendor-provided control systems, and virtual machines communicate through the main distribution switch with a combination of copper and fiber optic cabling.

PICS Network Architecture and Security

- PICS has no connection to the internet and no Wi-Fi capable devices.
- The PICS manufacturing control network (MCN) is segregated from the SHINE business network.
- The PICS PLC communications on the MCN is split into 10 separate virtual local area networks (VLANs), one for each of the 10 PICS PLCs.
- PICS cabinets are locked requiring a key administratively controlled by Operations personnel.
- PICS server room which houses the PICS ControlLogix PLCs and servers, has restricted access.
- Unused ports (e.g., Ethernet, USB) are physically blocked or electronically disabled.
 - The port keys are controlled by Operations personnel.
- Ethernet/IP with CIP (common industrial protocol) is the communication protocol used for communication between the PICS PLCs, RIO racks, servers, workstations, and thin clients.
 - CIP is widely used to secure plant networks.
- Electronic access to PICS is not available from outside the site.

PICS Interfaces with Safety-Related Systems

- The target solution vessel reactivity protection system (TRPS) and engineered safety features actuation system (ESFAS) provide signals to PICS via a one-way isolated nonsafety-related Modbus gateway.
- PICS normally has manual electrically isolated control of TRPS/ESFAS controlled components.
- PICS provides valve and damper position indication to TRPS/ESFAS for verification of completion of protective function through electrically isolated relay outputs.
- PICS provides mode transition signals to TRPS, when manually initiated by the operator.
- PICS provides signals to TRPS/ESFAS to reposition components, when manually initiated by the operator and the main control board enable nonsafety switch is in the “enable” position.
- Both the mode transition and reposition request signals from PICS are encoded using a bitstream method with a pattern of discrete relay outputs that are then translated by TRPS/ESFAS.
- PICS is designed so that its failures cannot directly or indirectly impact the ability of the TRPS or ESFAS to perform its safety functions.

PICS Vendor-Provided Nonsafety-Related Control System Interfaces

- PICS interfaces with several vendor-provided nonsafety-related control systems which consist of the neutron driver assembly system (NDAS) controls, supercell controls, and various auxiliary control systems.
- There are no internet connected or Wi-Fi enabled devices for the vendor-provided equipment.
- Like PICS, the vendor-provided nonsafety-related control systems do not allow remote access and include the capability to disable unneeded networks, communication ports, and removable media drives, or provide engineered barriers.
- Vendor-provided nonsafety-related control systems communicate with PICS via Ethernet, Modbus, or other industry standard digital communication protocols.
- Many of the PICS vendor equipment interfaces communicate with CIP over Ethernet/IP, utilizing the protocol's built in safety features.

PICS Vendor-Provided Nonsafety-Related Control System Interfaces

- PICS Modbus connections to vendor-provided control systems use custom configured gateways to only read from or write to vendor-approved addresses.
 - The plant's power supply systems interface with PICS via Modbus.
- The building automation system (BAS) provides control for many of the ventilation and facility systems.
 - BAS provides information to PICS for monitoring only using BACnet/IP, a building automation and HVAC industry standard.
- PICS communications with vendor-supplied supercell and radioactive liquid waste immobilization (RLWI) system PLCs are read-only communications used for monitoring purposes only.
- The NDAS control system receives permissive signals from the PICS to allow or disable use of the system and provides information to PICS for monitoring.
- PICS monitors vendor-supplied nonsafety-related radiation monitors throughout the plant.

PICS Workstations and Network Access

- Users who require access to the FactoryTalk View (FTV) Site Edition (SE) Supervisory Control and Data Acquisition (SCADA) system will have individual accounts created on the manufacturing domain.
 - Users are required to set a password for their manufacturing domain account.
 - When users log in to PICS with their unique credentials, their accounts authenticate against the manufacturing domain.
 - When no user is logged in, graphics and alarms are view-only, with no control/interactive functions available.
 - Domain users will only be assigned to one domain group.
 - The five domain groups are Maintenance, Operator, Supervisor, Administrator, or Quality.
- In conjunction with domain groups, users will be assigned to security areas which will coincide with various equipment areas in the SHINE production facility.
 - This will allow SHINE to give certain user accounts limited control of PICS equipment.
 - Facility control room operators and supervisors will be assigned to all security areas.

PICS Workstations and Network Access

- Users will not be able to log in or operate remote HMI locations without being granted access by the facility control room supervisor.
 - The facility control room supervisor can take back control of the PICS equipment at any time.
- In the event of a power outage, each operator workstation has a local uninterruptable power supply (UPS) capable of supplying 10 minutes of backup power, by which time, the standby generator system (SGS) will be fully engaged providing power
 - The operator workstation thin client sessions are not lost with a local loss of power, they continue to run on the Stratus fault tolerant server (ftServer) in the server room.



Phased Approach to SHINE Facility Operations

TRACY RADEL, VICE PRESIDENT OF ENGINEERING

Outline

- Philosophy
- Phase Descriptions
- Irradiation Facility Systems
- Radioisotope Production Facility Systems
- Instrumentation and Control Systems
- Electrical Power Systems
- Auxiliary Systems
- Accident Analysis

Overall Philosophy

- Purpose: Meet the national need for Mo-99 production as soon as possible while also ensuring all requirements related to public health and safety are met
 - Provide flexibility for challenges that may arise during procurement, installation, and testing
- Key considerations:
 - Ensure that all design criteria and safety functions can be met
 - Simplify process boundary isolation strategy
 - Simplify confinement boundary isolation strategy
 - Minimize impact on operating portions of the facility

Procurement and Installation Philosophy

- The SHINE approach to phased startup operations does not inherently affect how SHINE is approaching procurement and installation
 - Equipment for all eight irradiation units (IUs) being procured at the same time
 - Fabrication for most equipment is naturally being done in sets or batches, resulting in staggered delivery
 - As challenges are encountered in the fabrication process, equipment for Phase 1 will be prioritized
- Equipment will be installed as soon as possible once it is received on site

Phase Descriptions

- Phase 1:
 - Facility structure (FSTR) and nitrogen purge system (N2PS) structure
 - IUs 1 and 2, including IU-specific instances of the subcritical assembly system (SCAS), neutron flux detection system (NFDS), target solution vessel (TSV) off-gas system (TOGS), primary closed loop cooling system (PCLS), light water pool system (LWPS), and radiological ventilation zone 1 (RVZ1) equipment located in the cooling room
 - Tritium purification system (TPS) train A
 - Auxiliary and support systems, with the exception of IU-specific instances of PCLS, LWPS, and RVZ1 equipment located in the cooling room
 - Radioisotope production facility (RPF) systems, with the exception of iodine and xenon purification and packaging (IXP) and radioactive liquid waste immobilization (RLWI) selective removal capabilities

Phase Descriptions

- Phase 2:
 - IUs 3, 4, and 5, including IU-specific instances of the SCAS, NFDS, TOGS, PCLS, LWPS, and RVZ1 equipment located in the cooling room
 - TPS train B
- Phase 3:
 - IUs 6, 7, and 8, including IU-specific instances of the SCAS, NFDS, TOGS, PCLS, LWPS, and RVZ1 equipment located in the cooling room
 - TPS train C
 - RLWI selective removal capability
 - Material staging building
- Phase 4:
 - IXP capability

Irradiation Facility Systems

IRRADIATION UNITS

- IUs are designed and operated at the unit level.
 - Each IU has unit-specific instances of the SCAS, NDAS, light water pool, and irradiation cell biological shield (ICBS), and each IU is supported by unit-specific instances of the PCLS and TOGS.
 - Support system and process line interfaces with the IUs are isolated to support phased startup operation (i.e., interfaces with IUs 3 through 8 are isolated during Phase 1 operation, interfaces with IUs 6 through 8 are isolated during Phase 2 operation).

Irradiation Facility Systems

TRITIUM PURIFICATION SYSTEM TRAINS

- The TPS consists of three independent trains and each TPS train supports specific NDAS units.
 - Each TPS train includes independent train specific instances of the isotope separation system (Thermal Cycling Adsorption Process [TCAP]), TPS-NDAS interface lines, secondary enclosure cleanup (SEC), vacuum/impurity treatment subsystem (Vac/ITS), NDAS SEC, and TPS glovebox.
 - The tritium confinement boundary for each TPS train (including the TPS glovebox, SEC, isolation valves, TPS-NDAS interface lines, and tubing up to isolation valves) is independent and isolated from the other TPS trains; no portion of the tritium confinement boundary is shared between TPS trains.
 - Isolation is provided at TPS interface points to facility systems to allow TPS trains to be connected and commissioned without impacting operating TPS trains.

Radioisotope Production Facility Systems

- RPF systems are installed to support Phase 1 operations, with the exception of the IXP system and the RLWI selective removal capability.
- During Phase 1 through Phase 3 operations, the IXP system is not installed within the IXP hot cell, and the IXP hot cell is isolated from the supercell confinement boundary.
 - The interfacing process and supporting system connections to the IXP system are isolated during Phase 1 through Phase 3.
- The capability of the RLWI system to remove classification-driving isotopes is not available during Phase 1 and Phase 2 operations.
 - During Phase 1 and Phase 2, liquid waste is stored in the subgrade radioactive liquid waste storage (RLWS) system tanks prior to transfer to RLWI in order to maximize the decay time and limit the volume of solidified waste requiring disposal.
 - Waste solidified during Phase 1 and Phase 2 may have higher dose rates and higher waste classifications than wastes solidified during Phase 3 and Phase 4.

Instrumentation and Control Systems

- During phased startup operations, the instrumentation and control (I&C) systems are installed to the extent practicable given the extent of equipment installation.
- IU-specific instances of the TSV reactivity protection system (TRPS) are brought online with the associated IU in the applicable phases.
 - The nine TRPS cabinets are installed in the facility control room (FCR) prior to Phase 1 operations but are brought into operation with the corresponding IU phasing as described in Chapter 1.
- The engineered safety features actuation system (ESFAS) is installed to support Phase 1 operations.
 - During phased startup operations, inputs to the ESFAS for equipment that is not required to be operable are disabled using the maintenance workstation (MWS).
 - These disabled inputs are restored and verified to be operable prior to entering the technical specification mode of applicability associated with the given input.

Instrumentation and Control Systems

- IU-specific instances of the neutron flux detection system (NFDS) are brought online with the associated IU in the applicable phases.
- The safety-related process radiation monitors are installed to the extent practicable given the extent of equipment installation.
 - Safety-related process radiation monitors associated with individual IUs (inputs to TRPS) and TPS trains (inputs to ESFAS) are installed during the phase associated with that IU or TPS train.
 - Safety-related process radiation monitors associated with the IXP cell (input to ESFAS) are installed prior to Phase 4 operations.
- Process integrated control system (PICS) hardware (i.e., cabinets, power supplies, controllers, programmable logic controllers [PLCs]) is installed prior to Phase 1 operations, with the exception of hardware associated with TPS trains B and C.
 - PICS monitoring and controls associated with equipment that is not yet installed or not yet operable to support Phase 1 operations are tested and placed in operation as required for a given phase.

Electrical Power Systems

- The normal electrical power supply system (NPSS) and uninterruptible electrical power supply system (UPSS) are installed in full to support Phase 1 operations.
 - Loads on the NPSS and UPSS that are not yet installed or not yet operable in Phases 1, 2, or 3 have the associated isolation device removed or placed in an out-of-service condition.
 - Cabling associated with equipment that is not yet installed or not yet operable for a given phase is installed to the extent practicable with the power removed at the associated panel or load.
- The nonsafety-related standby generator system (SGS) is installed in full to support Phase 1 operations.

Auxiliary Systems

- RVZ1 recirculating subsystem (RVZ1r) units support individual IU and TOGS cells and are installed with the corresponding IU.
- Portions of the RVZ1 exhaust subsystem (RVZ1e) located in the cooling rooms are installed with the corresponding IU.
- Supply lines from auxiliary systems include manual isolation valves and blind flange or caps to support phased startup operations.
- Auxiliary systems are designed to handle the variable loads without modifications.

Accident Analysis

- A hazard evaluation was performed to identify new or different accident scenarios, including changes to likelihood or consequences of existing accident scenarios.
- The likelihood and consequences for these new or different accident scenarios were then evaluated and compared to the risk matrix and safety-related controls were applied to prevent or mitigate the accident scenario, in a method consistent with that described in Chapter 13a2 of the FSAR.
- Phased startup operations do not result in any new accident categories or increased consequences from existing accident scenarios.
- Five new accident sequences were identified, and five existing accident scenarios were reevaluated with increased likelihoods.
- Four new credited engineered controls and three new credited administrative controls are added during phased startup operations to prevent the new or different accident scenarios.

Advisory Committee on Reactor Safeguards

SHINE Medical Technologies Operating License Application

Chapter 7 – Instrumentation and Controls PICS

**October 21, 2022
Norbert Carte**

Office of Nuclear Reactor Regulation

I&C Technical Review Team

- **Dinesh Taneja** – Senior Electronics Engineer
(HIPS, ESFAS, RMS)
- **Norbert Carte** – Senior Electronics Engineer
(TRPS, NFDS, PICS)
- **Duane Hardesty** - Sr. Project Manager
(Technical Specifications)
- **Rossnyev Alvarado** – Electronics Engineer

Guidance and Acceptance Criteria

- NUREG-1537, Part 1, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors, Format and Content,” issued February 1996;
- NUREG-1537, Part 2, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors, Standard Review Plan and Acceptance Criteria,” issued February 1996;
- Final Interim Staff Guidance (ISG) Augmenting NUREG-1537, Part 1 and Part 2, for Licensing Radioisotope Production Facilities and Aqueous Homogeneous Reactors

SAFETY EVALUATION OVERVIEW

Chapter 7 Safety Evaluation


- **Current Scope**
 - PICS
- Previous Briefings
 - I&C Design Criteria
 - Highly integrated Protection System (HIPS)
 - Target solution vessel reactivity protection system (TRPS)
 - neutron flux detection system (NFDS)
 - Engineered safety features actuation system (ESFAS)
 - radiation area monitoring system (RMS)

PICS Description

- FSAR Sections
 - 7.3, “Process Integrated Control System”
 - 7.6, “Control Console and Display Instruments”
- SER Section 7.4.3, “Process Integrated Control System”
- SHINE Facility
 - Two Distinct Parts (IF & RPF)
 - One Control Room & one PICS (with many parts)
- Protection Systems (i.e., TRPS & ESFAS) & Control Systems (i.e., PICS) are:
 - Independent
 - Diverse


PICS Systems

Figure 7.3-1 – Process Integrated Control System Architecture




Gateway Communications Architecture

Figure 7-15-1: TRPS and ESFAS Gateway Communications Architecture



Background Information - Main Control Board

Figure 7.6-2 – Main Control Board Sections



PICS REVIEW

Layered Approach to Safety

- Design Criteria – Performance Objectives
 - Provide criterion for achieving reasonable assurance of adequate safety
 - Some are more safety significant than others
- Design Bases – Functions and Values
 - Events Described in other FSAR Chapters
 - Analysis Demonstrates Misbehavior of DB is addressed
 - Variables Monitored & Functions Performed
 - Setpoints and Response Times (Analytic Values)

PICS –Design Criteria in Context

- FSAR Design Criteria for PICS
 - SHINE facility design criteria: 3,6, & 13
 - PICS Criteria: 1-26
 - SHINE facility design criteria for independence of TRPS & ESFAS from PICS are imposed on TRPS & ESFAS
 - SHINE facility design criteria 14, 16, & 18
- Staff evaluated PICS against Design Criteria
 - SHINE facility design criterion 3,6, & 13
 - PICS Criterion 1-10

PICS –Design Criteria in Context

- NRC review focus(given preceding context):
 - PICS equipment failures analyzed to ensure:
Effects are bounded by events analyzed in safety analysis, see FSAR Section 7.3.2.2.4, “Effects of Control System Operation/Failures”
 - PICS Independent from TRPS/ESFAS
 - Description in FSAR Section 7.3.1.3.11, “Target Solution Vessel Reactivity Protection System and Engineered Safety Features Actuation System”
 - Description in FSAR Section 7.3.2.2.4, “Effects of Control System Operation/Failures”
 - SHINE facility design criteria 14, 16, & 18 (imposed on TRPS & ESFAS)

PICS – Design Bases

- FSAR Section 7.3.1, “System Description”
 - Has subsection for each: IU & RPF
 - Each has subsections for each system controlled, which describes applicable PICS functionality:
 - Variables Monitored and Alarmed
 - Control Functions
 - Interlocks and Permissives

Staff Evaluation of PICS

- Based on its review of the information provided, the NRC staff concludes the design of the PICS meets the applicable design acceptance criteria in Section 7.3 of NUREG-1537, Part 2.
- Based on the information reviewed, the NRC staff concludes that SHINE established the necessary design, fabrication, construction, testing, and performance requirements for the PICS to provide reasonable assurance that the facility be operated without undue risk to the health and safety of the public.

Questions



BACKGROUND

Acronyms

APL	actuation and priority logic (see HIPS TR)
ASAI	application specific action item (see HIPS TR)
BF3	boron trifluoride
BIST	built-in self-test (see HIPS TR)
CAAS	criticality accident alarm system
CAMS	continuous air monitoring system
CCF	common cause failure
CDA	critical digital asset
CM	communication modules (a HIPS module)
COTS	commercial off-the-shelf
CTB	calibration and test bus (see HIPS TR)
EIM	equipment interface module (a HIPS module)
EMI	electromagnetic interference

Acronyms

ESFAS	engineered safety features actuation system
FAT	factory acceptance test
FCR	facility control room
FDCS	facility data and communications system
FPGA	field programmable gate array (see HIPS TR)
HIPS	highly integrated protection system (see HIPS TR)
HVPS	high voltage power supply
HW-SM	hardwired submodule (a HIPS module)
HWM	hardwired module (a HIPS module)
I&C	instrumentation and control
IEEE	Institute of Electrical and Electronic Engineers
IF	irradiation facility

Acronyms

ISG	interim staff guidance
ISM	input submodule (a HIPS module)
IU	irradiation unit
MI-CM	monitoring and indication communication module (see HIPS TR)
MIB	monitoring and indication bus (see HIPS TR)
MWS	maintenance workstation (see HIPS TR)
NDAS	neutron driver assembly system
NFDS	neutron flux detection system
NPSS	normal electrical power supply system
NVM	nonvolatile memory (see HIPS TR)
OOS	out of service(see HIPS TR)
PDC	Principal Design Criteria
PICS	process integrated control system

Acronyms

PLDS	programmable logic design specification
PLRS	programmable logic requirements specification
QA	quality assurance
RAMS	radiation area monitoring system
RCA	radiologically controlled area
RDS	radioactive drain system
RFI	radio-frequency interference
RISM	remote input submodule (a HIPS module)
RVZ1	radiological ventilation zone 1
RVZ1e	radiological ventilation zone 1 exhaust subsystem
RVZ1r	radiological ventilation zone 1 recirculating subsystem
RX	receiver (Figure 7.1-x)
SASS	subcritical assembly support structure
SBM	scheduling and bypass modules (a HIPS module)

Acronyms

SBVM	scheduling, bypass, and voting modules (a HIPS module)
SCAS	subcritical assembly system
SDB1	safety data bus 1 (see HIPS TR)
SDB2	safety data bus 2 (see HIPS TR)
SDB3	safety data bus 3 (see HIPS TR)
SDE	secure development environment (see HIPS TR)
SFM	safety function module (a HIPS module)
SOV	solenoid operated valve
SR	safety-related
SRM	stack release monitor
SRMS	stack release monitoring system
SVM	scheduling and voting module (a HIPS module)
SyRS	system requirements specification

Acronyms

TMR	triple modular redundant
TOGS	TSV off-gas system
TPS	tritium purification system
TR	topical report
TRPS	target solution vessel reactivity protection system
TSPS	target solution preparation system
TSSS	target solution storage system
TSV	target solution vessel
TX	transmitter (Figure 7.1-x)
UPSS	uninterruptible electrical power supply system
V&V	verification & validation
VTS	vacuum transfer system

Advisory Committee on Reactor Safeguards

SHINE Medical Technologies, LLC Operating License Application

Appendix A - Phased Approach to Startup

Michael Balazik
Project Manager/Inspector
Office of Nuclear Reactor Regulation

October 21, 2022

Regulatory Basis

- Regulatory Requirements
 - 10 CFR 50.34, “Contents of applications; technical information”
 - 10 CFR 50.40, “Common standards”
 - 10 CFR 50.57, “Issuance of operating license”

Guidance and Acceptance Criteria

- NUREG-1537, Part 1, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors, Format and Content,” issued February 1996;
- NUREG-1537, Part 2, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors, Standard Review Plan and Acceptance Criteria,” issued February 1996;
- Final Interim Staff Guidance (ISG) Augmenting NUREG-1537, Part 1 and Part 2, for Licensing Radioisotope Production Facilities and Aqueous Homogeneous Reactors

Summary of Application

- On January 27, 2022, SHINE supplemented the FSAR to describe a four-phase approach to startup operations.
 - Phased completion is staggered over a few years and planned for completion in 2025.
 - In the supplement, SHINE describes the technical impacts and information differences for each chapter of the full-design facility FSAR.
 - SHINE identifies equipment isolation points and methods for each phase.
 - SHINE FSAR Chapters 4, “Irradiation Unit and Radioisotope Production Facility Description,” 7, “Instrumentation and Control Systems,” 9, “Auxiliary Systems,” and 13, “Accident Analysis,” are most impacted.
-

Summary of Application (continued)

- Irradiation units (IU) are designed and operated independently (unit specific equipment).
- Tritium Purification System (TPS) consists of three independent trains to support IU operation.
- Except for the iodine and xenon purification/packaging (IXP) system and the radioactive liquid waste isolation (RWLI) selective removal capability, all systems for the Radioisotope Production Facility are installed to support Phase 1 operations.
- Instrumentation and Control Systems are IU specific (TRPS), or inputs are disabled (ESFAS and PICS)

Summary of Application (continued)

- Five new accident sequences were identified, and five existing accident sequences had an increase in likelihood
- New accident sequences
 - Improper target solution routing (Uninstalled IU or IXP)
 - Damage to the TPS train
 - Damage to the process vessel vent system(PVVS)/TOGS interface
 - Backflow of target solution to the IXP
- Likelihood increase
 - Heavy load drop on the TPS
 - Heavy load drop on an operating IU or TOGS cell
 - Heavy load drop on the RLWI enclosure or supercell
 - Fire in the irradiation facility or radioisotope production facility

Staff Evaluation

- The same NRC staff that reviewed the full-design FSAR Chapter reviewed the same chapter in the SHINE Supplement (Phased Approach to Startup)
 - Evaluated the effect on the sufficiency of the SHINE facility description and the design bases, the limits on facility operation, and the safety analysis of the structures, systems, and components (SSCs) and of the facility as a whole as presented in the SHINE FSAR.
 - Reviewed the kinds and quantities of radioactive materials expected to be produced in the operation of the SHINE facility and the means for controlling and limiting radioactive effluents and radiation exposures.
 - Reviewed the methods and sufficiency of system-level isolations for the different phases to ensure safe operation of the facility and to ensure health and safety of the workers and public.

Staff Evaluation (continued)

- The NRC staff audited information supporting the phased approach to startup.
- Initial areas of perceived risk significance for phased approach to startup
 - Human system interfaces/training of operators
 - Disabling/enabling instrumentation and control inputs
 - Increase crane operation with heavy loads during operation
 - Radiological dose to workers completing construction

Phased Startup Operation License Condition

- 10 CFR 50.57(b) requires each operating license issued by the Commission to include appropriate provisions with respect to uncompleted items of construction and such limitations or conditions as are required to ensure that operation during the period of the completion of such items will not endanger public health and safety.
- SHINE provided a phase-specific listing of installation and functional testing activities required to support operation of Phase 2, Phase 3, and Phase 4.
- NRC staff is imposing a license condition to ensure that the operation of the subsequent phases of the SHINE facility will not be commenced until the associated uncompleted items of construction have been completed and that appropriate NRC oversight of the completion of the uncompleted items of construction is maintained.

Phased Startup Operation License Condition (cont.)

License Condition is as follow:

The Licensee shall conduct activities for startup of facility operations in Phases, as described in SHINE Technologies, LLC Application for an Operating License Supplement No. 31, Enclosure 3, Phased Startup Operations Application Supplement, dated September 28, 2022 (ADAMS Accession Nos. ML22271A963 and ML22271A966), as amended. Operation of Phase 2 or of any subsequent Phase shall not commence prior to satisfaction of conditions (a) and (b) below:

- a) No later than 14 days before the planned commencement of operation of Phase 2, and thereafter no later than 14 days before the planned commencement of operation of each subsequent phase, the Licensee shall notify the NRC in writing that all uncompleted items of construction related to that Phase have been completed.*
- b) Prior to the operation of Phase 4, the Licensee shall provide to the NRC in writing, six months after the issuance of this operating license and every six months thereafter, information on the status and schedule for completion of uncompleted items of construction.*

Evaluation Findings and Conclusions

- SHINE described the design of the systems and identified the major features or components affected by the proposed phased approach to startup for the protection of the health and safety of the public.
- The processes to be performed, the operating procedures, the facility and equipment, the use of the facility, and other TSs, provide reasonable assurance that the applicant will comply with the regulations in 10 CFR Part 50 and 10 CFR Part 20 and that the health and safety of the public will be protected during the phased approach to startup.
- The issuance of an operating license for the facility would not be inimical to the common defense and security or to the health and safety of the public.
- The NRC staff finds that the descriptions and discussions of SHINE's systems as affected by the phased approach to startup are sufficient and meet the applicable regulatory requirements and guidance and acceptance criteria for the issuance of an operating license.