

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Fuels, Materials, and Structures Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Wednesday, November 16, 2022

Work Order No.: NRC-2170

Pages 1-91

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

FUELS, MATERIALS, AND STRUCTURES SUBCOMMITTEES

+ + + + +

WEDNESDAY

NOVEMBER 16, 2022

+ + + + +

The Subcommittee met via hybrid in-person and Video Teleconference, at 1:00 p.m. EST, Ronald Ballinger, Chairman, presiding.

COMMITTEE MEMBERS:

- VICKI BIER, Chair
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- VESNA DIMITRIJEVIC, Member
- GREGORY HALNON, Member
- WALT KIRCHNER, Member
- JOSE MARCH-LEUBA, Member
- DAVID PETTI, Member
- JOY L. REMPE, Member
- MATTHEW SUNSERI, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MIKE SNODDERLY

ALSO PRESENT:

RYAN HOSLER, Framatome

ANDREW MORLEY, Public Participant

CAROL MOYER, NRR

DAVID RUDLAND, NRR

CHRIS WAX, EPRI

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks and Objectives

    By Professor Ronald Ballinger, ACRS . . . . . 4

Staff Opening Remarks

    By David Rudland, NRR . . . . . 6

Issue and Staff Perspective

    By Carol Moyer, NRC Staff . . . . . 7

Industry Perspective EPRI/PWROG Focus Group

    By Ryan Hosler, Chris Wax, EPRI . . . . . 52

Public Comments

    By Professor Ronald Ballinger . . . . . 90

Adjourn

    By Professor Ronald Ballinger . . . . . 90

P-R-O-C-E-E-D-I-N-G-S

1:00 p.m.

CHAIR BALLINGER: Okay, the meeting will now come to order. This is a meeting of the Fuels, Materials, and Structures Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Ron Ballinger, chairman of today's subcommittee meeting. ACRS members present are Jose March-Leuba, Dave Petti, I think Matt Sunseri will be here, is here.

MEMBER SUNSERI: Yeah, I'm here.

CHAIR BALLINGER: He's here. Joy Rempe, Vicki Bier, Greg Halnon, Charlie Brown was here, I think he'll be here, and let's see who else is here. Vesna Dimitrijevic, and if I've missed anybody, I -- Walt Kirchner, and that probably should cover it, that covers it. Mike Snodderly is the ACRS staff member that's designated federal official for this meeting. During today's meeting, the subcommittee will have an information briefing with the NRC staff, and EPRI on the French PWR safety injection system cracking.

I need to say ahead of time, this is an open meeting. Nothing that we are going to have presented here today is not publicly available. Personally, I was on the committee in France for EDF, along with another person who is here today, and we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 will -- I will refrain from making any comments  
2 related to the presentations, because for fear that I  
3 might say something that's not open.

4           So, just to be careful with that, and we  
5 would be happy to send these presentations to our  
6 colleagues at EDF, just so that they know what was  
7 said here. The rules of participation in all ACRS  
8 meetings including today's were announced in the  
9 Federal Register on June the 13th, 2019. The ACRS  
10 section of the U.S. NRC public website provides our  
11 charter, bylaws, agendas, letter reports, and full  
12 transcripts of all full, and subcommittee meetings  
13 including the slides presented here.

14           The meeting notice, and agenda for this  
15 meeting were posted there. We have received no  
16 written statements, or requests to make an oral  
17 statement from the public. The subcommittee will  
18 gather information, analyze relevant issues, and  
19 facts, and formulate positions, and actions as  
20 appropriate for deliberation by the full committee.  
21 The rules for participation in today's meeting have  
22 been announced as part of the notice of this meeting  
23 previously published in the Federal Register.

24           Today's meeting is a hybrid meeting, is  
25 being held in person, and over Teams. The bridge line

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 allowing participation of the public over the meeting  
2 has been made available. A transcript of today's  
3 meetings is being kept, therefore we request that  
4 meeting participants on Teams, and on the Teams call  
5 in line identify themselves when they speak, and to  
6 speak with sufficient clarity, and volume so that they  
7 can be readily heard.

8 Likewise, we request that meeting  
9 participants keep their computer, and, or telephone  
10 lines on mute, otherwise we get feedback, and things.  
11 The chat feature on Teams should not be used for any  
12 technical exchanges. Okay, make sure everybody's  
13 muted, okay. So, Dave? At this point I'll turn it  
14 over to Dave Rudland of the NRC staff for initial  
15 comments.

16 MEMBER SUNSERI: Thanks Ron. For those of  
17 you who don't know me, my name is Dave Rudland, I'm a  
18 senior technical advisor for materials in the division  
19 of new and renewed licenses in NRR. And first off, I  
20 want to thank you for the opportunity to come here, to  
21 talk to you about this very important foreign  
22 operational experience. And I wanted to let you know  
23 that the NRC staff have been heavily involved in the  
24 evolution of this issue.

25 We were first informed of it about a year

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 ago with the first cracking at Civaux Plant, and we  
2 have been following it with the help of our  
3 counterparts at ASN, the French regulator, as well as  
4 at IRSN, ASN's technical service organization. So,  
5 again, I just want to say thank you, the staff have  
6 been following this, and we're happy to present some  
7 of the things that we've learned over the last year.

8 And to hear from our EPRI counterparts  
9 about their efforts, and how this relates to the U.S.  
10 fleet. So, thank you very much.

11 CHAIR BALLINGER: Okay, I guess Carol, are  
12 you on?

13 MS. MOYER: My name is Carol Moyer, I'm a  
14 senior materials engineer in the Nuclear Regulatory  
15 Commission Nuclear Reactor Regulation Office --

16 CHAIR BALLINGER: You're sounding like  
17 you're a little bit in, and out, these microphones are  
18 highly directional, so.

19 MS. MOYER: Is that better? Okay, I have  
20 to slouch. Great, so thank you for this opportunity  
21 to discuss this topic. As Dave already explained,  
22 this is not our firsthand knowledge, this is a  
23 compilation of what we've been able to glean from  
24 various sources, and so we hope that we can add value  
25 by pulling these facts together. But we're looking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 forward to the discussion.

2 Okay, a quick overview of the operating  
3 fleet. There are 56 reactors in operation, all of  
4 them are pressurized water reactors built in the 70s,  
5 through the 90s. They're in three main styles,  
6 roughly classed as the 900 megawatt, 1300 megawatt,  
7 and 1450, and up megawatt. The original 900 megawatt  
8 version was based on a Westinghouse design, and the  
9 others have been an evolutionary development from  
10 there with some modifications to make them fit well in  
11 the French grid.

12 Okay, so this is an overview of the time  
13 line of these observations. As David mentioned  
14 earlier, this was first discovered a little over a  
15 year ago in last October. Flaw indications were  
16 detected near welds in safety injection lines during  
17 their scheduled ten year safety inspections. So, they  
18 were first discovered at Civaux One and Civaux Two and  
19 Poly One, and I'm going to try not to butcher the  
20 French names too much.

21 Civaux One and Civaux Two, then at the end  
22 of last year. The indications that were found in the  
23 safety injection lines, and residual heat removal  
24 lines on the IDF pipes circumferentially located  
25 oriented -- jumping to the end. The laboratory

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 analysis confirmed that these were intra granular  
2 stress corrosion cracking cracks. So, the regulator  
3 ASN decided to expand the inspections, and reevaluate  
4 prior NDE data to get an idea of the extended  
5 condition.

6 MEMBER HALNON: This is Greg, is that near  
7 welds, or in the welds, flaw indications? Is it a  
8 heat affected zone?

9 MS. MOYER: Yes, adjacent to welds would  
10 be a description.

11 MEMBER HALNON: Okay, so it is a part of  
12 the weld essentially, issue.

13 MS. MOYER: Essentially, yeah. And you'll  
14 see in the cross section that most of the cracks were  
15 associated with welds, but not all. This was a nice  
16 photo that I lifted from an EDF slide with permission  
17 that shows that layout of the affected loops. This  
18 diagram at the bottom, you'll see again, if I can  
19 point at things. So, there are welds at elbows, and  
20 various sections of pipe, and the cracking, as I said,  
21 has been mostly associated with welds throughout the  
22 injection lines.

23 So, with four separate loops, they're  
24 stainless steel pipes, they are roughly an inch thick,  
25 and eight inches diameter, give, or take.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: One thing I'm reading  
2 on the slide is that the long pipes with the stagnant  
3 flow, or no flow at all.

4 MS. MOYER: Yes, we're going to get to  
5 that too. Yes, there are pipelines of varying  
6 lengths, and that we think is important.

7 MEMBER PETTI: Which alloy of stainless  
8 steel is it, do you know?

9 MS. MOYER: 316LN. So, this is another  
10 just blow up of -- well, a hand drawing, and a for  
11 real photograph of the location of some of these  
12 cracks. So, again, they are at the connections  
13 between pipes, and elbows for example. Okay, so as I  
14 said, they expanded the inspections, and tried to  
15 understand the extent of condition. EDF was asked to  
16 accelerate their plans to inspect safety injection  
17 piping for similar degradation from the spring, and  
18 through the summer.

19 The regulator also requested additional  
20 information to assess the degradation in its extent to  
21 determine whether it was a generic issue. Starting  
22 with this summer, EDF deployed a new NDE method to  
23 detect, and size flaws, and we'll talk about that a  
24 little bit more also. So, they used a couple of  
25 different methods to detect flaws, and to characterize

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 what was found.

2 The stress corrosion cracking indications  
3 were mostly found in the 1300 megawatt, and 1450  
4 megawatt type reactors, that I believe only one crack  
5 was found in the 900 megawatt plants, and that we  
6 think is also important. So, there is a list here of  
7 plants that either had confirmed flaws, or had results  
8 that suspected flaws that needed to be further  
9 evaluated.

10 The list is not comprehensive, because it  
11 kept changing as I looked at different reports, and  
12 things, because no one was quite sure what was  
13 confirmed, but let's say it's a lot. So, the pipes  
14 were at -- the cracks were at pipe ID, located at all  
15 those. When they did destructive examination of pipe  
16 sections removed, they confirmed that these were  
17 intragranular stress corrosion cracking in the base  
18 metal 316L, or LN I later learned, and heat affected  
19 zone adjacent to the welds.

20 Coming up in a couple slides I have a  
21 photo, it seems in many cases the cracks started in  
22 the heat affected zone, and grew to the weld, and then  
23 stopped. But in some cases the extension could reach  
24 the full circumference of the ID. Because of the  
25 design of these lines, and the stagnant, or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 intermittent flow, there was a suspicion that they  
2 could be susceptible to thermal fatigue cracking, and  
3 that's really what they were looking for with the  
4 ultrasonic test that they were doing on these pipes.

5           Although I'm told that they did not really  
6 expect thermal fatigue cracking at this stage of life,  
7 and the plant, for defense in depth reasons, they were  
8 inspecting anyway, and were somewhat surprised to find  
9 -- obviously were surprised to find the SCC cracking.  
10 Most of the cracks were shallow, around a millimeter  
11 deep. A few at heat affected zones were as much as  
12 six millimeters deep. So, about an inch, or about a  
13 quarter of the way through the wall of the pipe.

14           And yes, stagnant flow, and thermal  
15 stratification are potential contributing conditions.  
16 Okay, so it's our understanding that over 100 of these  
17 faults have now been examined, either with a sensitive  
18 penetrate test, or destructive examination, cutting  
19 them apart, and actually opening the cracks, looking  
20 at them. Cracked elbows were sent to the EDF's hot  
21 lab.

22           Some were also examined by IRSN, the  
23 technical support organization to the regulator, and  
24 they were able to confirm then that there were IGSCC  
25 cracks in the base metal, and heat affected zone, as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 I said, max depth was about a quarter of the way  
2 through wall. They also found elevated hardness in  
3 the vicinity of the weld root pass. Not extreme, but  
4 somewhat elevated, enough to have that noted I guess.

5 They also found unusual weld geometry in  
6 some cases. There was the first pass, the root pass  
7 of the weld in some of the cross sections was  
8 unusually deep, or high. Without really a good  
9 explanation for that, so it is possible that some off  
10 normal welding conditions led to unexpected residual  
11 stresses. However, there was no evidence of chemical  
12 contamination.

13 You always look for chlorides, and things  
14 like that that might exacerbate a CC, that was not  
15 found. Okay, so here's a cross section. So, the  
16 center picture shows one of these cracks that's five,  
17 or six millimeters deep, and it's in the heat affected  
18 zone adjacent to a weld, the crack tip goes up to the  
19 fusion line, and then stops.

20 MEMBER MARCH-LEUBA: So, for us, the  
21 people who don't know exactly what we're looking at,  
22 the connect is the little hair line that we see at the  
23 top of the cone, or where is it?

24 MS. MOYER: Yes, I'm sorry, if I can  
25 figure out how to point on this. There we go, okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 So, this is the pipe ID, the pipe inner wall, outer  
2 wall, weld crown, weld root pass is here, and then  
3 this small dark line beside the weld is the crack.

4 MEMBER MARCH-LEUBA: And the cone, the  
5 thing that looks like a mountain is the weld?

6 MS. MOYER: That's the weld, yes. So,  
7 this is the cast elbow on the left I believe. I don't  
8 have an annotated picture in front of me, but I'm  
9 pretty sure this is the cast elbow on the left, and  
10 this would be a wrought stainless pipe on the right.

11 MEMBER HALNON: Was it always on the  
12 vertical section that side of the elbow, on the  
13 vertical?

14 MS. MOYER: I don't know the answer to  
15 that, I don't think so, I think they were distributed  
16 throughout these loops. And there were some that were  
17 cracked on both sides of the same weld.

18 MEMBER KIRCHNER: This is Walt Kirchner,  
19 I'd like to ask, you said the elbow is cast?

20 MS. MOYER: That is my understanding.

21 MEMBER KIRCHNER: That's -- when you lay  
22 down a weld like this next to a cast, I don't know  
23 Ron, that's not surprising to me.

24 CHAIR BALLINGER: I know nothing.

25 MEMBER KIRCHNER: Okay, you're our expert.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 CHAIR BALLINGER: Can you say something?

2 MR. RUDLAND: I'm actually not sure if  
3 they're cast, or not.

4 CHAIR BALLINGER: I don't think so, but --

5 MEMBER KIRCHNER: I would be surprised,  
6 that's why I raised the question. Because the  
7 difficulty of welding with castings is well known, but  
8 --

9 MR. RUDLAND: But there's a sufficient  
10 number of cast elbows in the French plants, because  
11 they had an awful lot of thermal embrittlement issues  
12 with their elbows, that they actually went through a  
13 replacement.

14 MEMBER KIRCHNER: Yeah, of course.

15 MR. RUDLAND: But I'm not sure about these  
16 to be honest.

17 MS. MOYER: It's second hand information,  
18 but I think these are 316 elbows as well, not CFAs  
19 like that, so perhaps they are -- nevertheless. So,  
20 this is a cross section of a butt weld. So, you have  
21 -- sorry for the folks online, it's a pipe, and an  
22 elbow, and the weld, you start at the root pass, and  
23 then grow out. So, the ends would have been dressed  
24 at an angle, and then that gap is filled with weld  
25 metal as you increase the circumference.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, then these cracks occurred at the ID  
2 surface, at the inner surface, and grew towards the  
3 outer surface, but not very far.

4           MEMBER MARCH-LEUBA: It's easy to see how  
5 you would leave a seal on the stresses there. Is  
6 there any treatment afterwards, or? Because this is  
7 --

8           MS. MOYER: It's my understanding that  
9 these were plant welds, not shop welds. So, there is  
10 likely not any post weld heat treatment applied, they  
11 would be in the as welded conditions.

12          CHAIR BALLINGER: That I can say, you  
13 don't post weld heat treat stainless steel welds,  
14 otherwise you'd sensitize them. So, it's one of those  
15 things where you just can't. It's good news, and bad  
16 news with stainless steel, that's the good news, the  
17 bad news, it's stainless steel.

18          MEMBER MARCH-LEUBA: I'm going back with  
19 the CRE, with the professional, since the suspicion is  
20 that this is stress corrosion cracking, it makes sense  
21 that the internal, where you have the water. Can you  
22 say yes for the record?

23          MR. RUDLAND: Yeah, the cracks are on the  
24 wet surface.

25          MEMBER MARCH-LEUBA: On the wet surface,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 where you will have the corrosion mixing.

2 MR. RUDLAND: That's correct.

3 MEMBER BROWN: That means the inside of  
4 the pipe?

5 MR. RUDLAND: That's correct.

6 MEMBER BROWN: How in the world did you  
7 find them in the first place then? You had to drain  
8 everything, and then inspect it? I'm an electrical  
9 guy, so I've got to ask.

10 MS. MOYER: They're inspected by  
11 ultrasonic.

12 MEMBER BROWN: Okay, so exterior you can  
13 pick it up?

14 MR. RUDLAND: They inspect on the outside.

15 MEMBER BROWN: I got that part. My memory  
16 goes back 20 years --

17 MS. MOYER: They're running a probe down  
18 the outside of the pipe.

19 MEMBER BROWN: So I'm starting to remember  
20 some stuff.

21 MEMBER MARCH-LEUBA: This is actually an  
22 ultrasonic picture, right?

23 MS. MOYER: No, this is a destructive  
24 examination. They found the crack by ultrasonic, so  
25 non-destructive examination, NDE, and then once they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 had located a crack, they cut that section of pipe  
2 out, replaced it with a new one, and took the broken  
3 one to the lab.

4 MEMBER MARCH-LEUBA: So, that's a  
5 microscope picture.

6 MS. MOYER: This is a cross section,  
7 polished.

8 MEMBER SUNSERI: This is Matt, I have a  
9 question, Matt Sunseri.

10 MS. MOYER: Yes?

11 MEMBER SUNSERI: So, maybe I don't  
12 remember this correctly, but my recollection is for in  
13 a granular stress corrosion cracking that occurs, you  
14 need three things to happen. One is to have  
15 susceptible material, two corrosive environment, and  
16 three high temperature. So, it sounds like one, and  
17 two are met, but the temperature seems a little low to  
18 me, this is something south of 600 degrees Fahrenheit,  
19 300 degrees C, so are these welds exposed to higher  
20 temperature than that?

21 MS. MOYER: No, the essential requirements  
22 are susceptible material, environment, and stress, not  
23 necessarily temperature. You can get to stress by  
24 temperature perhaps, and we may have here by  
25 differential heating, but temperature alone doesn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 necessarily alone get you to SCC.

2 MR. RUDLAND: This is Dave Rudland, it's  
3 more the environment, the chemistry of the water that  
4 could cause that. So, there's certain chemicals in  
5 the water that can cause susceptibilities to be worse.  
6 So, if you have a high oxygen content in the water, it  
7 makes that location more susceptible. So, when they  
8 talk about the environment, they're talking in this  
9 case more about the water chemistry than they are  
10 about the temperature.

11 The temperature feeds into the growth rate  
12 more so than the --

13 MEMBER MARCH-LEUBA: Asking questions  
14 about the theory, 100 percent theory, is this an  
15 accident event, I mean a transient, of having a crack  
16 in a second, or is it a very long corrosion that goes  
17 crack, crack, crack over months?

18 MR. RUDLAND: Yeah, it's a time dependent  
19 cracking event.

20 MEMBER MARCH-LEUBA: It's a long time?

21 MR. RUDLAND: It took a while for the  
22 crack to initiate, and a while for the crack to form.

23 MEMBER MARCH-LEUBA: So, it was not like  
24 a surge of some very hot water.

25 MR. RUDLAND: That is correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Matt, go ahead if you need  
2 to finish your question.

3 CHAIR BALLINGER: I think it was done.

4 MEMBER DIMITRIJEVIC: I have a question,  
5 this is Vesna Dimitrijevic. My question is we usually  
6 don't see IGSCC in the pressurized water reactors in  
7 the U.S., right? That's a more BWR problem. I mean  
8 we might --

9 MS. MOYER: I think the answer to your  
10 question is --

11 MEMBER DIMITRIJEVIC: You know, when we  
12 analyze the degradation mechanism in class one piping  
13 in the PWRs, that was never damage mechanisms. It was  
14 the damage mechanism we saw in the BWRs.

15 MS. MOYER: Yeah. IGSCC has been reported  
16 in BWRs primarily. When we see stress corrosion  
17 cracking in pressurized water reactors, we tend to  
18 call it primary water stress corrosion cracking,  
19 PWSCC, but it's not really that different.

20 MR. RUDLAND: Yeah, and actually I think  
21 -- this is Dave Rudland again -- the susceptibility of  
22 the stainless steel in pressurized water is not as  
23 high as it is in the water in BWRs, because of the  
24 chemistry again. And so the cases in the U.S. where  
25 we have seen stress corrosion cracking in stainless

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 steel have been kind of limited to locations where  
2 there's something special going on.

3 There's been excessive grinding, or  
4 something that really increases the stresses at the ID  
5 surface, or in stagnant conditions, where you may have  
6 water chemistry issues.

7 MEMBER DIMITRIJEVIC: I see, I mean I was  
8 a little surprised to see this, but you know, I know  
9 we have IS, integration stress corrosion cracking  
10 program for BWRs, but -- all right, thanks.

11 MS. MOYER: Okay, as I was starting to  
12 say, cracks were detected by manual ultrasonic  
13 testing. So, in this case you're putting a sound wave  
14 into the pipe from the outside, and listening for,  
15 checking for a response, a reflection back to the  
16 transducer. They use a 45 degree shear wave at 2.25  
17 megahertz. This is pretty normal for looking for  
18 thermal fatigue cracks, which is what they were doing.

19 It's manual scanning, which means there is  
20 a human actually moving the transducer over the pipes.  
21 Part of the story I think, the conjecture is that may  
22 have been a contributing factor in the sense that  
23 there's a dose implication to putting a human there to  
24 do this examination. And one of the modifications  
25 that was made in the later designs was to increase

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 certain piping run lengths.

2 Putting the person farther away from the  
3 exposure, but also changing the configuration of the  
4 pipe, so again, there's a trade-off. This ultrasonic  
5 procedure, as I said, was designed for thermal fatigue  
6 cracks, not really optimized to detect, nor to size,  
7 or as we would say, characterize SCC cracks. But when  
8 they did start to find some indications, they  
9 confirmed the SCC cracks with destructive examination.

10 MEMBER HALNON: Carol, does that mean that  
11 the SCC cracks had to get big enough beyond what  
12 normally you would expect in order to see them? Or is  
13 it just something that the inspector needs to be cued  
14 into?

15 MS. MOYER: Yeah, SCC cracks tend to be  
16 slow growing, and they tend to be very tight. And  
17 sometimes they have adherent oxide in them that's  
18 still somewhat conductive, and so it's not an easy  
19 kind of flaw to find in the first place. But yes,  
20 they do tend to be small, and tight, and a sure wave  
21 that's just looking for a big sound bounce may look  
22 past it.

23 MEMBER HALNON: They had to get bigger  
24 than what we -- if we had a probe designed, or  
25 optimized to detect SCC cracks, it would have caught

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1       them a lot earlier?

2                   MS. MOYER:   Conceivably.

3                   MEMBER HALNON:     I guess that's the  
4       inference, okay.

5                   MS. MOYER:   The other interesting thing  
6       is, as I showed --

7                   MEMBER DIMITRIJEVIC:   I'm sorry, I have  
8       another -- how does the extracting exams, you know,  
9       which piping they have been performed on? I mean what  
10      does --

11                   MS. MOYER:   I'm sorry, I don't understand.

12                   MR. MORLEY:   They've cut the pieces out of  
13      the plant, and destructively examined those.

14                   MEMBER DIMITRIJEVIC:   Cut the pieces from  
15      some retired plant?

16                   MS. MOYER:   No, the pipes that were found  
17      to be cracked were cut out, and taken to a laboratory,  
18      and replaced with new pipe sections.

19                   MEMBER DIMITRIJEVIC:   I see, so they have  
20      to drain RCS?

21                   MS. MOYER:   Yes, this was done during  
22      their ten year inspection.

23                   MEMBER DIMITRIJEVIC:   Yeah, but inspection  
24      is done with the water in the piping, and the stress  
25      exam, they don't have installation valves, so they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 have to drain the RCS to do this, right?

2 MS. MOYER: That's my understanding, I  
3 don't know for sure how extensive that was, but yes,  
4 that was part of the problem, and why it has taken a  
5 long time for them to recover from this experience.

6 MEMBER DIMITRIJEVIC: I mean I -- so,  
7 that's something I didn't see there, replacing the  
8 class one piping. So, I mean okay.

9 MR. HOSLER: Yeah, this is Ryan Hosler,  
10 they would have to drain down to the level of the cold  
11 leg, and hot leg, clearly to get this done. But that  
12 would remain above the majority of the reactor vessel.

13 MS. MOYER: Right, the injection point for  
14 these lines is the cold leg.

15 MEMBER MARCH-LEUBA: Can you show us slide  
16 four? Very clear.

17 MS. MOYER: Okay.

18 MEMBER MARCH-LEUBA: You can see the level  
19 right there, right? It's the copper pipes, which are  
20 not made of copper, but copper colored pipes in there.

21 MEMBER KIRCHNER: Yeah, you can't drain  
22 the whole primary system with the core still in it, so  
23 either they have to take the entire core out to drain  
24 the primary system, before they drain the primary  
25 system. Or, they take suitable precautions to -- if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the fuel is still in the core, to ensure that the  
2 system doesn't drain out. Can you give us more  
3 information on how they actually did the repairs?

4 MS. MOYER: I cannot, I have just been  
5 looking at the materials implications of it, but I  
6 think we'll get to that later in the meeting.

7 MEMBER KIRCHNER: Okay, thank you, yeah.

8 MEMBER HALNON: This is Greg, the industry  
9 has cold leg plugs they stick in the cold legs, and  
10 you go to mid loop operations, and that's how they can  
11 drain the pipes.

12 MS. MOYER: So, all of the pipes that are  
13 shown in this diagram, this cartoon, are here at the  
14 hot leg, and cold leg level. So, all of the welds of  
15 interest are in these loops, and in these pipes that  
16 feed them. So, the vessel itself would not have to be  
17 drained any lower than the hot, and cold leg level.

18 MEMBER HALNON: Correct.

19 MEMBER DIMITRIJEVIC: They go to mid loop  
20 operation, my guess would be they had the fuel  
21 outside, so.

22 MEMBER HALNON: Yeah, they had to defuel  
23 the reactor, I mean you can't do this with fuel in it,  
24 the dose rates would be too high anyway to do that.  
25 The experience of this, cutting out the hot leg, was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 paramount in figuring out how to do this probably.

2 MR. RUDLAND: Before Carol moves on, I'm  
3 getting live emails from my French friends, and I just  
4 wanted to point out that the elbows are forged,  
5 they're not cast.

6 CHAIR BALLINGER: And now you said it,  
7 okay.

8 MR. RUDLAND: Yeah, the elbows are forged.  
9 And also there was a comment about the 900 megawatts,  
10 there was a defect found in one of the reactors in the  
11 RHR system, but it was due to lack of fusion, and not  
12 due to SCC. So, there were no SCC cracks found in the  
13 900 megawatts.

14 MR. MORLEY: I think it was emanating from  
15 a weld defect in the 900.

16 MEMBER REMPE: We need to have whoever  
17 just spoke say their name for the transcript please.

18 MR. MORLEY: I'm sorry, Andy Morley here,  
19 Rolls Royce.

20 CHAIR BALLINGER: Say again?

21 MS. MOYER: Andy Morley from Rolls Royce.

22 CHAIR BALLINGER: Okay.

23 MS. MOYER: So, as Dave said, looking more  
24 closely at all of the NDE data that they had in  
25 history also might find other things along the way,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 like this weld defect in one of the 900 megawatt  
2 plants, and other non-relevant indications. So, that  
3 was one of the things that was a concern too, was  
4 whether it was possible that some other indications  
5 from prior NDE examinations had been improperly  
6 characterized, and were in fact cracked.

7 So, they looked again at some older data.  
8 I don't have a breakdown of how those results came  
9 out, I just know that these are complicated joints.  
10 There's geometry, there's counterbore, there's the  
11 weld tow, the welds were not crowned, so there's a  
12 weld crown, which means it's difficult to inspect  
13 right up close to the weld, because the transducer  
14 just doesn't physically fit flat against the pipe  
15 because of the crown on the weld.

16 So, some of these challenges may have  
17 impacted the inspectability of some of the pipes. And  
18 so, it was worth looking again just to make sure  
19 nothing was overlooked. And then EDF developed a plan  
20 for an accelerated schedule to inspect all of the  
21 analogous piping. Okay, as I mentioned we were told  
22 that there were inspections by remote penetrant test,  
23 or ultrasonics, then some by destructive tests.

24 I've been informed that the new, and  
25 improved, if you will, NDE procedure that was rolled

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 out is something called total focusing method full  
2 matrix capture, and plain wave imaging. Total  
3 focusing method plain wave imaging. So, this is still  
4 a manual technique, but it's encoded, so you keep  
5 track of the location, and there's a bracket that goes  
6 around the pipe, and encodes the location information.

7 It's a very sensitive technique, it is a  
8 developing technique. It is not fully qualified, at  
9 least not in the U.S., and to my understanding, it's  
10 not qualified in France either, by their standards  
11 organizations. It's an emerging technique, and again,  
12 as I said, very sensitive, and creates a great deal of  
13 data. We among the NRC staff, when we were discussing  
14 this, had some questions why a qualified phased array  
15 ultrasonic technique was not selected.

16 Not to second guess anyone, but just in  
17 the course of conversation, we said I wonder why they  
18 went to such a sensitive technique, instead of a well  
19 known phased array UT technique, but there we are.  
20 Okay, so a little bit more about the root cause  
21 analysis, as we've been saying, IGSCC was not  
22 expected. It really didn't line up with international  
23 operating experience, there was no SCC on the French  
24 900 megawatt plant series after 30 years.

25 There was no contamination observed, like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 chlorides, or something that didn't belong in the  
2 water chemistry. However, there were some weld  
3 repairs, and there were some unusual weld geometries  
4 that were found. Again, I don't know a lot about  
5 this, it is second hand somewhat, but EDF, I know did  
6 a welding simulation to estimate hardening, and  
7 residual stresses that were observed near the ID of  
8 these pipes.

9 And found that there was an area of  
10 limited depth on the ID that was subject to tensile  
11 stress. But the stresses weren't compressive within  
12 the weld, which does line up with the observation that  
13 the cracks started in the heat affected zone, and then  
14 grew to the weld, and stopped. That was confirmed by  
15 their destructive examination.

16 MEMBER KIRCHNER: Carol, this is Walt  
17 Kirchner again. Did the 900 series plants have those  
18 cast elbows for those lines?

19 MS. MOYER: They apparently were forged  
20 elbows, that was my bad information, sorry. Dave  
21 Rudland has now confirmed those were forged stainless  
22 elbows in both cases.

23 MEMBER KIRCHNER: Forged, not cast.

24 MS. MOYER: Right.

25 MEMBER KIRCHNER: Okay, thank you. But it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 was the same material selection, same fabrication for  
2 the 900s as the larger techniques?

3 MS. MOYER: Yes, as far as I know, it's  
4 316LN, possibly with a nitrogen strengthening, so a  
5 very common place material.

6 MEMBER KIRCHNER: Okay, thank you.

7 MS. MOYER: Okay. So, the regulator was  
8 aware of some weld repairs. I think they knew which  
9 welds had been repaired, or at least which pipes had  
10 had weld repairs, but they weren't necessarily sure of  
11 exactly where. Weld repairs may leave the pipes in  
12 unusual, or unknown residual stress condition, that's  
13 always a possibility. So, those welds were  
14 especially, carefully reinspected.

15 Another thing that could be a contributor,  
16 so it's worth checking out, is oxygenated water.  
17 Chlorides certainly are very bad news for stress  
18 corrosion cracking, but oxygen can be a contributor.  
19 This is something that we learned from our colleagues  
20 at IRSN, that some of the flows, like from core makeup  
21 tanks, the boric acid tank, and then peroxides  
22 injected at shutdown for various good reasons may also  
23 bring along with them some oxygen that would  
24 potentially throw off the chemistry in these lines.

25 Especially given that they are stagnant,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 or mostly stagnant, so that's one other possible  
2 concern. Thermal stratification is another concern  
3 that could impose its own cyclic loading on the pipes.  
4 As I mentioned, in the M4 type reactors, there were  
5 some horizontal runs of pipe that were extended, had  
6 a good justification for inspectability, but may have  
7 contributed to having longer pipes that were stagnant,  
8 and that had thermal stratification.

9 So, uneven temperature because of thermal  
10 expansion means uneven stresses in those pipes. So,  
11 I think IRSN has been doing some work to estimate just  
12 how much of an effect that might have been. Okay,  
13 mitigation plans include, as I mentioned, cracked  
14 sections have been removed, and replaced with new.  
15 From this fall, through 2025 EDF has a plan for a  
16 complete examination program on all their operating  
17 reactors on areas that might be affected by this  
18 concern.

19 They're using this advanced UT procedure  
20 that is optimized now for IGSCC detection. And I'm  
21 told that they plan to seek qualification of that  
22 technique, but anybody who's worked on standards knows  
23 that's not a quick, or one step thing. That's usually  
24 a protracted effort. The reactors that were  
25 considered most sensitive, just based on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 population of flaws found so far are the N4 type, and  
2 those have been stopped to carry out inspection, and  
3 repairs where needed.

4 And looking forward, there is a plan for  
5 a periodic reinspection program, with periodicity  
6 based on the sensitivity of the NDE, the crack growth  
7 rate of IGSCC, and mechanical, plastic fracture  
8 mechanics analyses to try to stay ahead of it. So, at  
9 present, and this at present is probably a week, or so  
10 old, so it might not be quite accurate. There are 26  
11 reactors down, 15 for stress corrosion problems, and  
12 11 for other scheduled maintenance.

13 The repair work has been completed for six  
14 reactors, and repairs on this problem are underway at  
15 four.

16 MEMBER MARCH-LEUBA: When you say  
17 currently, you mean today, or you mean --

18 MS. MOYER: About a week, or so I think.

19 MEMBER MARCH-LEUBA: I mean it's not nine  
20 months ago.

21 MS. MOYER: Right, this is -- my notes are  
22 this is from World Nuclear News Daily on November the  
23 4th.

24 MEMBER MARCH-LEUBA: At what speed are  
25 they testing them, do they have more than one sensor,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 one machine?

2 MS. MOYER: There are multiple machines,  
3 but keep in mind, that you need operators, and you  
4 need welders, and if there's an exposure component,  
5 those folks have limits on how much they can do.

6 MEMBER MARCH-LEUBA: I'm kind of asking  
7 what's your projection of when they'll be up, and  
8 running?

9 MS. MOYER: I wouldn't even hazard a  
10 guess.

11 MEMBER MARCH-LEUBA: Is it a matter of  
12 weeks, a matter of years?

13 MS. MOYER: The whole inspection program  
14 I was told was to be done by 2025. So, going all the  
15 way through every plant ensuring that these lines have  
16 been fully inspected, and repaired if needed may take  
17 a couple of years. But when they can get to a point  
18 where they can operate these plants, that's probably  
19 a different answer, and I don't have enough  
20 information to say.

21 MEMBER DIMITRIJEVIC: This is Vesna  
22 Dimitrijevic, so, when you say the 15 for stress  
23 corrosion, I know this is also outside information for  
24 you too, so does that mean that they're doing testing,  
25 or that means they've identified problems, and they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 have to do the pipe replacement? What does it mean  
2 for stress corrosion problems, is it for testing, or  
3 for replacement?

4 And what does -- for maintenance, is that  
5 totally independent of IGSCC, or sorry, I have a  
6 problem pronouncing this for some reason. Or is this  
7 for the independent maintenance, or these are also  
8 related to this? So, the maintenance, is that  
9 independent of this problem, or it's for what?

10 MS. MOYER: It is my understanding that 15  
11 of the plants had some indication of cracking in these  
12 lines that was being further investigated, or  
13 repaired. So, 15 of these were suspected, or  
14 confirmed stress corrosion cracking, and 11 of the  
15 plants were down for other maintenance, whether  
16 scheduled, or unscheduled. Does that help?

17 MEMBER DIMITRIJEVIC: That gives me some  
18 information. And my other question is also is your  
19 understanding that the testing related to this will be  
20 done in -- they will be scheduled on all these plants  
21 in these couple years independent of the regular  
22 service testing, it will be just for this, so they  
23 will be shutting down all plants to do this testing?

24 MEMBER DIMITRIJEVIC: You were --  
25 (Simultaneous speaking.)

1 MS. MOYER: I would have to ask --

2 MEMBER DIMITRIJEVIC: In order to perform  
3 these tests, are they going to perform them on all the  
4 plants, or are they just going to do them on the  
5 plants where they have the most suspicion that this  
6 corrosion cracking can be? And also I have a  
7 question, do you have an idea what percentage of welds  
8 they think is in the region which can be exposed to  
9 that?

10 Because let's say that we have within 400,  
11 600 welds in the cross run piping, what percentage of  
12 those welds will need to be tested, do you have an  
13 idea about that too?

14 MR. RUDLAND: This is Dave Rudland, if I  
15 go back to your first question, I really need to  
16 emphasize that this is still an ongoing, developing  
17 issue in France. And discussions between EDF, and the  
18 regulator are continuing to be ongoing. So, I hate  
19 for us to speculate too much about their plans on what  
20 they do, and when they plan to be up, and things like  
21 that.

22 That really needs to be left to those  
23 discussions between the EDF, and their regulators. In  
24 terms of the number of welds, I know that them being  
25 very conservative in the number of welds that they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 looking at. I think Carol pointed out earlier that  
2 they were doing a lot of penetrant testing on a lot of  
3 the welds that had any types of suspicion at all, so  
4 they're being conservative in how they're looking for  
5 these.

6 And so, I think they're suspecting that  
7 most of them that are in the same lines as the ones  
8 where they've had cracks before are considered  
9 susceptible enough that they want to do some kind of  
10 non-destructive evaluation. In a lot of cases it is  
11 this penetrant that they're planning to use.

12 MEMBER DIMITRIJEVIC: I'm really curious,  
13 because that's a really terrible timing with this  
14 energy crisis in Europe, they're shutting 50 percent,  
15 or more of their plants, it's just really bad timing.

16 MS. MOYER: Certainly.

17 MEMBER MARCH-LEUBA: Yeah, I'm reluctant  
18 to put unverified data on the record, but Google says  
19 that France intends to restart 27 of the reactors by  
20 December of this year, and they're still working on  
21 five more, they expect to be restarting in February,  
22 but of course that's Google.

23 MS. MOYER: Okay, thank you.

24 MR. MORLEY: Andy Morley, Rolls Royce  
25 here, do we now, have they only looked at these branch

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 lines, the SIS, and the RHR system, or have they  
2 looked at the main loops as well? And if they haven't  
3 looked at the main loops, is there a reason why?

4 MEMBER REMPE: I'm sorry to interrupt, and  
5 I'm chairman of the ACRS, and this is not a time when  
6 the public can ask questions.

7 MR. MORLEY: I'm sorry, I didn't realize  
8 that.

9 MEMBER REMPE: I realize that it's a  
10 different country, and all that, and I don't mean to  
11 be rude. But at the end of this meeting, I assume the  
12 supplementary chairman will ask for public comment,  
13 and if you have a comment, you can state it for the  
14 record at this time, but that's all we can do.

15 MR. MORLEY: My apologies.

16 CHAIR BALLINGER: My apologies, I thought  
17 that you were one of us in some respect, so that's the  
18 reason why I said okay. And nobody corrected me until  
19 now. Now we can keep going.

20 MS. MOYER: Okay. As a regulator, I found  
21 it interesting that the utility, that EDF in this case  
22 performed a stress analysis, and proposed a flaw  
23 evaluation criteria for continued operation. That is  
24 they essentially requested permission to restart a  
25 reactor with known cracks saying well, they're very

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 small, and we know where they are, and we can show by  
2 a stress analysis, and crack growth data, that we can  
3 operate to the next outage, or something like that.

4 The regulator, with support from their  
5 PSO, evaluated that proposal, and the level of  
6 uncertainty associated with the data that went into  
7 it, and decided that that was not prudent, and as a  
8 result, that reactor was not given permission to come  
9 back online with flaws in place. I found that  
10 interesting.

11 CHAIR BALLINGER: I can say, I might add  
12 that the rules in France are different than the rules  
13 in the U.S. In the U.S. my guess is that it's allowed  
14 by the code, they would have done a risk analysis, and  
15 probably be able to operate, but in France, the rules  
16 are much more final if you want to use that word.

17 MS. MOYER: Right, that's true.

18 MR. RUDLAND: To add to what Ron said, I  
19 agree, I would suspect that we would probably prefer  
20 it to be mitigated, and not an -- an SCC left in  
21 service. By mitigated, a weld overlay, or something  
22 like that.

23 MS. MOYER: Okay, so we talked about  
24 extent of condition, we talked about root cause. One  
25 of the other things that we would normally look at is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 similar operating experience. What have we seen that  
2 looked anything like this in any other reactors? A  
3 similar appearing crack was found in the Japanese  
4 plant, OE unit three pressurizer spray weld in August  
5 of 2020.

6 That flaw was attributed to hardening from  
7 high weld stress on the inside diameter surface.  
8 Again, as Dave mentioned earlier, we've typically seen  
9 this kind of cracking when you have a lot of grinding,  
10 or a really unusual weld upset, a weld procedure that  
11 was off normal in some way. And you would have  
12 unusually high residual stresses. So, that was  
13 essentially the conclusion in that case.

14 In the U.S., PWRs have observed stress  
15 corrosion cracking in 316 only when there was cold  
16 work, grinding contamination, very oxygenated water  
17 conditions, something like that, that you can really  
18 point to. Okay. So, in the U.S., we have the ASME  
19 code, American Society of Mechanical Engineers Boiler  
20 and Pressure Vessel Code. Section 11 covers in  
21 service inspection.

22 That code is mandated by U.S. regulations,  
23 by 10 CFR 5055A. Most plants use an NRC approved risk  
24 informed in service inspection plan as an alternative  
25 to section 11. So, they have to meet at least one of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 those. U.S. plants examined 10 to 15 percent of the  
2 class one safety injection, and RHR piping under their  
3 programs. So, they do inspect these class one pipes  
4 looking for this kind of flaw.

5 They do apply a sampling, they don't  
6 necessarily look at 100 percent of the welds every  
7 outage, they cycle through them --

8 MEMBER MARCH-LEUBA: So, you have a  
9 population, this number, 10 to 15 percent is every  
10 year, or ever?

11 MS. MOYER: Every inspection interval,  
12 which is ten years.

13 MEMBER HALNON: There is an escalation  
14 aspect to it.

15 MS. MOYER: Certainly, if anything is  
16 found, then you have to expand --

17 MEMBER HALNON: This 10 to 15 percent has  
18 got to be clean.

19 MEMBER DIMITRIJEVIC: It is not certain,  
20 they always inspect the same 10 percent, or 15  
21 percent. There is no -- I mean they don't cover every  
22 ten years, the same ten percent, more than that is  
23 inspected.

24 MS. MOYER: I'm sorry, was there a  
25 question? No, okay, I missed the beginning of that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER DIMITRIJEVIC:   My point was if  
2 we're inspecting the same ten percent, and we have  
3 seen here that higher power, the plants, we can be  
4 missing this in United States, because we are not  
5 looking for that, we are looking for thermal fatigue,  
6 and inspecting ten percent of the valves. Or this is  
7 something which will be lessons learned from this  
8 French situation.

9                   MEMBER HALNON:       But we also, the  
10 experience here shows that a small leak will occur.  
11 We won't get a catastrophic failure, so it's you will  
12 leak before break.

13                  MR. RUDLAND:   And this is Dave Rudland,  
14 let me also point out that the risk informed programs  
15 are designed such that the ones that they are looking  
16 at are the most susceptible locations, be it stress,  
17 or geometry, or whatever it happens to be. So, they  
18 are looking at the most susceptible.

19                  MEMBER HALNON:   One thing we do miss in  
20 this is the weld records. I was at the D.C. summer  
21 plant when the hot leg was found, and until you went  
22 back, and looked at the actual records of  
23 construction, you didn't realize that you had  
24 excessive grinding, and excessive rewelds on that root  
25 pass. And this 10 to 15 percent, it may be most

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 susceptible from a system condition perspective, but  
2 not necessarily the most susceptible from a rework  
3 perspective.

4 So, I don't know how you factor that in,  
5 but again, it's like the previous slide said, the most  
6 cases in the U.S. it's excessive grinding, and  
7 excessive rework, but that's not factored into the  
8 section 11, is it?

9 CHAIR BALLINGER: I feel compelled.

10 MEMBER HALNON: Go for it Ron.

11 CHAIR BALLINGER: My personal opinion is  
12 that stainless steel of this type is fundamentally  
13 unstable in 300 degrees C water. So, the material has  
14 to maintain that protective film. There are so many  
15 variables involved, everybody says there's too much  
16 grinding, there's too high stress, but this material  
17 will crack if you violate that film. And so, anything  
18 that violates that film will probably result in  
19 cracking.

20 The reason the difference is between PWRs,  
21 and BWRs is one operates as an oxygen over pressure,  
22 the other one operates as a hydrogen over pressure, so  
23 the potential is much lower, but they're still  
24 susceptible. So, that's one of the reasons why we're  
25 having this meeting, to kind of warn people that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 need -- 80 years is a long time. Thanks.

2 MEMBER MARCH-LEUBA: You came in on that,  
3 what film are you talking about, is this put in on the  
4 inside?

5 CHAIR BALLINGER: It's a Faustian bargain  
6 that we play. You've got a chromium oxide based film  
7 that's on the surface that isolates the material from  
8 the environment. But the material is fundamentally  
9 unstable, it wants to convert to an oxide. So, if you  
10 breach that film, then the underlying material is  
11 exposed. And if you do it in the right way, you  
12 crack.

13 So, in that respect, plain carbon steel  
14 would be better than 316 stainless steel because it  
15 doesn't stress corrosion crack.

16 MEMBER MARCH-LEUBA: I don't know anything  
17 about this, why I'm asking the question. Chromium  
18 oxide is generated when you put water inside --

19 CHAIR BALLINGER: Yeah, it's a film.

20 MEMBER MARCH-LEUBA: It's in itself  
21 something --

22 CHAIR BALLINGER: I'm being a little fast,  
23 and loose with the chromium oxide. It's an oxide  
24 based film that's tough, and adherent, and it is a  
25 strong function of the chromium content, which is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 reason why the higher nickel chrome, and higher chrome  
2 alloys, 690 for example, nickel based, that has 30  
3 percent chrome, that's much more stable. But this  
4 material is right at the limit where you need to be  
5 very careful about stress, and grinding, and all that  
6 kind of stuff.

7 MEMBER MARCH-LEUBA: But isn't that film  
8 self-generated, so grinding won't get rid of it, you  
9 will generate a new one?

10 CHAIR BALLINGER: Yeah, it reforms very  
11 quickly.

12 MEMBER MARCH-LEUBA: Anyway, you guys are  
13 the experts.

14 CHAIR BALLINGER: But you can create  
15 conditions in a crack which make the environment more  
16 aggressive. And if the stress is five millimeters  
17 deep, you're driving this crack through. So, again,  
18 we just need to be careful.

19 MEMBER MARCH-LEUBA: And would the stress  
20 be dependent, I mean if we have much more stress  
21 inside the pipe than outside?

22 CHAIR BALLINGER: For a single V weld,  
23 typically what happens is you have a tensile residual  
24 stress on the ID, but it goes compressive right away,  
25 which is what they see here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER MARCH-LEUBA: So, the probability  
2 of the crack growing more than a quarter of an inch is  
3 small?

4                   CHAIR BALLINGER: Low.

5                   MEMBER MARCH-LEUBA: Low.

6                   CHAIR BALLINGER: But again, the weld,  
7 you've heard the expression, is it a Friday weld, or  
8 is it a Monday weld? There are all kinds of things,  
9 parameters that affect welding. And these are -- look  
10 at the multi, these are like 20 pass welds. And the  
11 code allows regrinding. In other words you do an  
12 inspection part way through, and if you see a defect,  
13 the code requires you to grind it out.

14                   So, once you grind it out, you change the  
15 whole residual stress pattern, and everything. So,  
16 there are a lot of variables that can affect this, and  
17 you just have to be mindful of that.

18                   MEMBER MARCH-LEUBA: Would it be a good  
19 application for artificial intelligence to review all  
20 those records that we're talking about, and identify  
21 which of the records?

22                   MS. MOYER: Especially with a new NDE  
23 technique that's going to generate boatloads of data,  
24 an AI technique would be very --

25                   MEMBER MARCH-LEUBA: We have a separate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 subcommittee on artificial intelligence, and --

2 MS. MOYER: Machine learning is being  
3 looked at it for it.

4 MR. RUDLAND: The repairs haven't been  
5 documented, a lot of them haven't been well  
6 documented. And again, like Ron mentioned, the  
7 stresses are a function of the number of passes in the  
8 thickness, but also if there's any repairs, and the  
9 depth of those repairs on when this thing may go into  
10 compression. You have a large inter diameter repair,  
11 you can have even very high stresses through much of  
12 the wall because of that repair, so.

13 CHAIR BALLINGER: But the N4 reactors were  
14 the newer ones.

15 MR. RUDLAND: In reality the smaller the  
16 pipe, the harder it is to do an internal repair,  
17 right? So, for this size pipe, it's a lot less likely  
18 than it is for some of the hot legs, where they've had  
19 issues where they had to grind, and do welds.

20 MR. HOSLER: This is Ryan Hosler, just  
21 wanted to make a quick comment. Inspection coverage  
22 for these branch lines, the safety injection RHR  
23 lines, so as was mentioned, the risk informed  
24 inspection program looks at susceptibility, but also  
25 consequence. And obviously the non-iceable portion,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 which is what we're interested in, is going to have a  
2 higher consequence, and is going to get a focus of the  
3 inspections.

4 On top of that, as discussed previously,  
5 thermal fatigue is a big part of a potential issue in  
6 these non-iceable portions of the piping, and there's  
7 an MRP-146 inspection program that also looks there.  
8 So, there is focus at this particular branch  
9 connection, so you don't have to necessarily -- the  
10 specific condition isn't necessarily the entire class  
11 one, it's just the non-iceable portion of the piping.  
12 End of comment.

13 CHAIR BALLINGER: Just one, or two more.

14 MS. MOYER: Just one, or two slides more,  
15 yes. I know we are on time. Okay, as Ryan just  
16 mentioned, there is MRP-146 guidance document, I  
17 guess, what do you call it, white paper? That  
18 enhances owner's voluntary programs of inspection to  
19 look specifically for cracking in these lines. That's  
20 enough of that. Okay, class one pipes are examined  
21 using multiple ultrasonic angles, or scanning  
22 directions.

23 So, these are well inspected in U.S.  
24 plants, in any of the plants there are class one  
25 pipes. Personnel procedures, and equipment used on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 piping welds must pass rigorous performance  
2 demonstration testing under ASME code section 11  
3 appendix 8. The examinations in the U.S. are  
4 optimized for thermal fatigue flaws also, but are  
5 capable of detecting stress corrosion cracking.

6 And the UT examinations have a current  
7 ability to detect cracks 5 to 15 percent through wall  
8 with a very good probability of detecting larger  
9 cracks. Challenges, there are the same metallurgical  
10 challenges of metal grain structure, geometric  
11 features like counterbore, and weld crowns, and the  
12 well geometry itself that complicate the inspection  
13 procedure, and the interpretation of the inspection  
14 data.

15 But NRC continues also to do research on  
16 both SCC initiation, and growth, and NDE capabilities.  
17 Okay, so ASM has concluded that stresses caused by  
18 thermal stratification were one of the major  
19 contributors to the root cause of this IGSCC. The  
20 older French reactors appear to be less affected,  
21 possibly due to design. So, we talked earlier about  
22 this is a developing kind of degradation.

23 This is a time dependent degradation, so  
24 one might deduce then that the older plants would be  
25 more susceptible than newer plants, that's why this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 was a bit puzzling at first. And so we think that  
2 design had a bigger effect than age in this case.  
3 After the inspections have been completed on all the  
4 reactors, there's a periodic inspection program that  
5 will be defined, and implemented across the French  
6 fleet.

7 The U.S. fleet configured similarly to the  
8 older French plants, continues its regular  
9 inspections, no similar degradation has been observed  
10 in the U.S. plants. So, due to the past U.S.  
11 operational experience, the continued robust ASME  
12 section 11 exams in these locations, and the follow up  
13 by the U.S. industry, the staff concludes that there  
14 is no immediate concern for a similar issue in the  
15 U.S. fleet.

16 MEMBER HALNON: Is that taking into  
17 consideration comparable position, and places on the  
18 pipe? I know we did 10 to 15 percent for the NDE, but  
19 was there a concerted effort to go look at this  
20 specific line? I guess this is the high pressure  
21 injection, or low pressure injection line, what line  
22 is this comparable to the U.S. line, do you know Ron?

23 CHAIR BALLINGER: High pressure injection.

24 MEMBER HALNON: So, we had the high  
25 pressure injection.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 (Simultaneous speaking)

2 MEMBER HALNON: So, we have the high  
3 pressure injection nozzle issues, and some valve  
4 issues, but have we specifically checked to make sure  
5 our records are giving us what you said, that there's  
6 been nothing found at the U.S. plants? Is that  
7 because we haven't seen anything in our general  
8 inspections, or is that because we've actually gone,  
9 and looked at these pipes?

10 MS. MOYER: We have not changed our  
11 inspection plans for U.S. plants in response to this  
12 observation. We are taking it into account as we do  
13 all operating experience, but we have not changed  
14 anything in the near term. I think we have another  
15 presentation that I would be stepping on if I injected  
16 about --

17 MEMBER HALNON: Okay, we can wait, thanks.

18 MEMBER DIMITRIJEVIC: This is Vesna  
19 Dimitrijevic, I work on the development of EPRI for my  
20 side, and we apply this to over 30 plants in the  
21 United States, so I have some experience with that,  
22 and I can really give you some previous ASME section  
23 11, which is using France's inspect 25 percent every  
24 10 years in class one, and that 25 percent is the same  
25 25 percent every 10 years.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 In United States, with the risk informed  
2 ISI, which is now applied almost in every plant, I  
3 think only maybe a couple don't have a risk informed  
4 ISI, actually that was changed at this location, 25  
5 percent were selected based on stress, temperatures,  
6 changes, and things like that. So, in the risk  
7 informed ISI what happens is the valves were spreading  
8 risk, high risk, medium risk, and low risk.

9 High risk corresponds to high  
10 consequences, and high degradation mechanism, and only  
11 one high probability of the pipe fail to degradation  
12 mechanism, and only flow oscillated corrosion is one  
13 of those mechanisms. All other degradation  
14 mechanisms, including IGSCC, and the thermal fatigue  
15 are considered medium failure probability degradation  
16 mechanism.

17 But when combined with high consequences,  
18 like once when somebody just said, the pipe cannot be  
19 insulated, they will come in the medium category,  
20 where they inspect ten percent. Those ten percent are  
21 selected based on presence of degradation mechanisms.  
22 Based on all this ISI data up to that moment, only  
23 degradation mechanism identified in about 20000  
24 inspections in the class one was thermal fatigue.

25 And therefore those ten percent are put in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 those thermal fatigue locations, and that's always the  
2 same ten percent. However, the risk informed ISI  
3 program has, if ever a different degradation mechanism  
4 has been discovered, then the program has to be  
5 reevaluated. So, the question is can the current  
6 inspection (audio interference) thermal fatigue, also  
7 identify IGSCC, I don't know.

8 But I bet if this information comes from  
9 some outside programs, we'll also require plants to  
10 look in their risk informed ISI programs, that would  
11 be my understanding of that. There is also ASME court  
12 cases covering, I think one just covering class one is  
13 N760, but I'm not sure, I forgot those numbers. So,  
14 covering risk informed inspections.

15 CHAIR BALLINGER: Okay, well thank you.  
16 Other questions from members? Okay, we have -- we're  
17 way ahead of scheduled, we're scheduled for a break at  
18 2:40, but I think we can probably just pick it up, and  
19 keep going. And so if there aren't any other  
20 questions, can we just pick it up? Your name tag has  
21 been changed twice already. You were an EPRI guy, and  
22 now you're a Framatome guy.

23 MR. HOSLER: Yeah, somebody is moving me  
24 around.

25 CHAIR BALLINGER: I don't know what's

1 going on here.

2 MR. HOSLER: I'm Framatome. So, yeah,  
3 someone is going to have to drive the presentation for  
4 me, I wasn't able to get my computer hooked up to  
5 Teams. So, all right, while he's getting it up, I'll  
6 introduce myself. I'm Ryan Hosler, I'm the materials,  
7 and fracture mechanics supervisor at Framatome, that's  
8 the U.S. part of Framatome, but still part of the  
9 mother company.

10 I'm also the technical lead of the focus  
11 group that is addressing this issue, or addressing the  
12 potential impact of this issue in the United States.  
13 That focus group is developed by the PWR Owners Group  
14 in collaboration with EPRI. This focus group is the  
15 auxiliary piping stress corrosion cracking operating  
16 experience, and -- there we go, coming up here.

17 So, this focus group includes experts from  
18 the industry, utility members, also the vendors, and  
19 also EPRI as well, including materials experts,  
20 welding experts, NDE experts. A quorum to come  
21 together to try to see how this may impact the United  
22 States. Actually the focus group is also looking at  
23 Owners Group members outside of the United States, but  
24 for this presentation we'll focus on the U.S.

25 One thing I want to briefly cover that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 not in my slides, I probably should have added, is  
2 just why is this stress corrosion cracking atypical,  
3 why are we sitting here? So, historically, stress  
4 corrosion cracking in PWRs has been found in isolated  
5 locations beyond the first isolation valve, or clearly  
6 stagnant conditions, or up in the control audit drive  
7 mechanisms.

8 Where especially for certain designs, with  
9 certain plants have a very large volume. So, when you  
10 start up you get a lot of oxygen up there during start  
11 up. So, you have those off chemistry conditions,  
12 you'd see stress corrosion cracking there. Also for  
13 cases of stress corrosion cases in PWRs, and well  
14 controlled water chemistry, it required heavy cold  
15 work. So, imagine pressurizer heaters that were  
16 assuaged, and not stress relieved afterwards.

17 We saw stress corrosion cracking in those,  
18 and some chemical volume control system heat exchanger  
19 tubes, thin wall tubes that were bent as part of the  
20 design. As high cold work, and cracking in those.  
21 Now, and so for the non-iceable portions of the branch  
22 connections, we haven't really seen stress corrosion  
23 cracking prior to this EDF OE. So, that's -- so,  
24 looking at this EDF OE, the first factor is it seems  
25 like that the weld stress is a primary contributor to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 initiation.

2 Meaning there's no evidence cold work, the  
3 destructive exams haven't shown any slip planes, or  
4 you wouldn't be able to grind the inside of these  
5 pipes anyway, it would not be normal practice to grind  
6 the inside, and the destructive exams, as mentioned  
7 earlier, shows that the weld crown is there, there is  
8 no -- at the root, I'm sorry, there is no grinding  
9 afterwards.

10 So, and also this is 316L, so you wouldn't  
11 expect sensitization, we haven't really seen any  
12 evidence of sensitization, and in destructive exams  
13 we've seen indications close to the flowing line, and  
14 also far from the flowing line. So, water chemistry  
15 does not seem to be a big factor in my opinion, from  
16 what I've seen. It seems like exceptionally high  
17 stress at the root is what's the primary driver.

18 And that's what makes this unique, is we  
19 have not seen that previously, typically it requires  
20 high cold work for this to happen. So, that's one  
21 piece, the other piece is the flaws have a large flaw  
22 aspect ratio. Meaning they're very shallow, and can  
23 be very long, which is again not typical of what we  
24 see with stress corrosion cracking. And that's, in my  
25 view, primarily driven by, as you discussed earlier,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the stress profile you typically see for weld residual  
2 stress.

3 A high ID weld residual stress, and then  
4 quickly becoming compressive. So, I just wanted to  
5 start off, the Japanese OE that was mentioned, one  
6 flaw has been found there, that appears very similar,  
7 has all those same characteristics. So, those being  
8 the cases that we're aware of, that have this atypical  
9 stress corrosion cracking. I just want to kind of  
10 give that as a lead in.

11 So, that comes to the agenda here, which  
12 is what are the industry actions to consider this  
13 operating experience, and how it may impact the U.S.  
14 fleet? So, first, as I said, it's a collaboration  
15 between the Owners Group, and EPRI. So, EPRI  
16 completed a white paper, which I'll talk a little bit  
17 about. We're in the process of revising MRP-236,  
18 revision one, which is among other things, a database  
19 of the PWR stress corrosion cracking operating  
20 experience.

21 So, that was last revised in 2017, so  
22 we're adding new operating experience to it to  
23 understand the new trends, and what they may mean.  
24 And then lastly I'll talk about the effort in the  
25 focus group itself, and the two main efforts are a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety assessment, and applicability assessment. Next  
2 slide please. Okay, so for the white paper, the MRP  
3 letter, and number is listed there if you'd like to  
4 take a look at it.

5 CHAIR BALLINGER: We have it.

6 MR. HOSLER: So, it was developed by  
7 experts in the field of stress corrosion cracking,  
8 Peter, and Jason, Peter Scott I believe. So, here are  
9 a few of the inclusions from the paper. The first is  
10 that the most important factors that accelerate stress  
11 corrosion cracking to higher levels than expected in  
12 PWR primary water are residual deformation from cold  
13 work, or welding stress.

14 And then stress from welding, and  
15 pressurization fit up, etcetera, and environment,  
16 oxidants, and contaminates in creviced areas. Also  
17 there's a good deal of discussion of a newly developed  
18 crack growth rate for stress corrosion cracking that's  
19 discussed, MRP-458, which is also available for  
20 review. And also last point being stress corrosion  
21 cracking, and stand still components exposed to  
22 flowing PWR primary water will continue to occur.

23 But there is no evidence of aging that  
24 accelerates stress corrosion cracking in raw stainless  
25 steels, and no sudden increase in stress corrosion

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 cracking initiation growth is expected after decades  
2 of operation. I'm happy to take questions on this  
3 paper, but I didn't write it, so I can only say so  
4 much.

5 CHAIR BALLINGER: That statement is almost  
6 self-contradictory. I mean you take up before the  
7 comma, and keep everything after that, everything is  
8 fine. If you take everything out after the comma, the  
9 meaning changes.

10 MR. HOSLER: So, you know, I know Peter,  
11 so I'll try to interpret what I believe it's saying.  
12 What I believe it's saying is stress corrosion  
13 cracking is going to happen. As you said earlier,  
14 it's hot water, and stainless steel, if you give  
15 enough time, it'll happen. If the three components,  
16 if they're minor enough, then it might not happen in  
17 the life of the plant.

18 But if one, or two of the components are  
19 severe enough, then it'll happen at some point. I  
20 think he's trying to hit that point, but he's saying  
21 there isn't a late blooming phase, or something,  
22 there's no sudden increase expected, I think is what  
23 he's saying.

24 CHAIR BALLINGER: Got it.

25 MR. WAX: Yeah Ryan, that point you made

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 at the very end is really what that statement's trying  
2 to imply there. And I'm Chris Wax from EPRI. That  
3 statement is saying there's no significant increase in  
4 propensity for stress corrosion cracking as you age  
5 these plants, it's there from day one, it'll be there  
6 in day infinity.

7 CHAIR BALLINGER: I rest my case.

8 MR. HOSLER: All right, next slide please.  
9 Okay, so this is going to discuss a little bit in the  
10 next couple slides, the preliminary results of the  
11 provisioned MRP-236. So, as I said earlier, this  
12 report contains information concerning stress  
13 corrosion cracking of primary circuit pressure  
14 boundary stainless steel, including an operating  
15 experience database.

16 The last revision was completed in 2017,  
17 which found no cases of stress corrosion cracking in  
18 the non-iceable portions of the branch piping. The  
19 new revision, which is in progress, is reviewing the  
20 operating experience since 2017. The only confirmed  
21 cases of stress corrosion cracking in the non-iceable  
22 portions of the branch piping have occurred in the EDF  
23 fleet, and the one case at the Japanese unit.

24 Also, we've also been reviewing the  
25 thermal fatigue OE database, and that's MRP-85, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MRP-468. And the reason for this is that in some  
2 cases you'll be looking for thermal fatigue, you'll  
3 inspect, you'll find the flaw, and then perform an  
4 overlay, and you'll never actually do a destructive  
5 exam, so you can't know with 100 percent certainty,  
6 it's just because you were looking for thermal fatigue  
7 that it was in fact stress corrosion cracking.

8 Like with EDF, they were looking for  
9 thermal fatigue, and then they ended up finding stress  
10 corrosion cracking. So, we reviewed that database for  
11 the purpose of seeing if we could find any potential  
12 cases of this atypical stress corrosion cracking that  
13 was believed to be thermal fatigue. And the way we  
14 went about doing that was first looking at the OE  
15 database, there's about 34 cases over the last several  
16 decades, and look for cases where they did not perform  
17 a destructive exam.

18 And in cases where there was a flaw with  
19 a large aspect ratio, meaning shallow, and quite long,  
20 similar to what we (audio interference) events in this  
21 category. And so, we went through our database, and  
22 identified 2 of the 34 cases where it met this  
23 criteria. Does that mean stress corrosion cracking?  
24 Can't say, because weld overlays were performed, but  
25 it does meet the criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, those will be summarized in the  
2 revision to this report. Next slide please. So, this  
3 is again, preliminary results, I'll try to walk  
4 through this figure here. So, this figure is showing  
5 at the bottom, X axis is number of events, stress  
6 corrosion cracking events for PWR stress corrosion  
7 cracking of stainless steel. And on the left side is  
8 the stress driver. Whether it be weld residual  
9 stress, cold work, cold work, and residual stress.

10           Just operating stresses, or depending on  
11 operating stresses, and so the blue represents  
12 stagnant conditions, and the red represents well  
13 controlled conditions. And I'll explain that in a  
14 little bit. And saying it might be better to look at  
15 it as the blue represents cases where we believe  
16 aggressive environment was a significant factor in the  
17 stress corrosion cracking.

18           And the red cases represent events where  
19 we believe the environment was not a primary  
20 contributing factor in the stress corrosion cracking.  
21 Okay, so that being said, as I mentioned earlier, so  
22 the top right there, you see the weld residual stress,  
23 the big blue block there that is being driven by  
24 residual stress. Again, CRD, and CED housings, and  
25 fuels, and valve drain lines in iceable piping is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 where we see the most issues.

2 And for cold work, in the cold work case,  
3 we do see there's some stagnant conditions, but the  
4 well controlled conditions, we also would see driven  
5 by cold work, I mentioned the pressurizer heaters, and  
6 also the vent heat exchanger tubes. What's new is  
7 that now there's well controlled water chemistry  
8 events that are driven by residual stress, that top  
9 right.

10 And those are the new events, that's the  
11 EDF OE, and the safety injection RHR piping, and also  
12 the one case in pressurizer spray piping at the  
13 Japanese plant. So, that's kind of a visual look at  
14 the outlier here, and why we're focusing on this, and  
15 how it may impact the U.S. fleet. All right, I think  
16 I hit that there. Next slide. Okay, so now I'm going  
17 to go over where we are currently with the PWR EPRI  
18 focus group addressing this issue.

19 So, first, I'll discuss the safety  
20 assessment, the purpose of the assessment is to assess  
21 the potential safety impact of this operating  
22 experience in the industry, and then the applicability  
23 assessment is to assess the applicability of this OE  
24 to the industry. Next slide. The safety assessment's  
25 in progress, so this is all preliminary, but the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 approach essentially, to determine safety impact is  
2 based on risk.

3 And risk is a function of likelihood, and  
4 consequence, so what is the likelihood of this type of  
5 stress corrosion cracking being present in the United  
6 States? And we're going to determine that by  
7 reviewing inspection data to determine if applicable  
8 locations are being inspected. Review the UT method  
9 to determine if these type of flaws would be  
10 identified.

11 And then also review the operating  
12 experience database, which I have been discussing, to  
13 determine if this type of stress corrosion cracking is  
14 occurring outside of EDF. Then we'll also look at the  
15 consequences of this type of stress corrosion  
16 cracking. So, we'll review the available flaw  
17 evaluations to determine if a flaw could reach a  
18 critical flaw size, and then also compare design basis  
19 analysis breaks to branch line breaks.

20 And then after all that's done, if  
21 appropriate, we'll issue recommendations. Next slide.  
22 All right, so this picture on the right here is an  
23 example of a branch line within EDF stress corrosion  
24 cracking -- I'm sorry, EDF safety injection piping  
25 from an N4 design plant. And the reason I'm showing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 this is in order to determine whether we're inspecting  
2 the right locations, we have to define what is the  
3 area of interest?

4 And so, looking at the EDF OE, all of it  
5 is in the safety injection RHR branch lines, non-  
6 iceable portions, and elbow welds, or heat affected  
7 zone adjacent to those elbow welds. And there was  
8 discussion of this earlier, but all these are large  
9 diameter pipes, 8 to 14 inches. The safety injection  
10 is passive, and the RHR is the big RHR suction,  
11 sometimes it's 14 inch diameter pipe.

12 And so, that's the main area of focus for  
13 the OE review, or I should say the inspection review  
14 I will cover in a moment. Next slide. Okay, so the  
15 preliminary results for the likelihood of stress  
16 corrosion cracking being present in the fleet. So,  
17 I've reviewed the inspection results for 56 units, and  
18 focusing on each unit's last inspection that occurred  
19 in the last ten year period.

20 And so going through each of these, the  
21 passive safety injection piping, large diameter, it  
22 was about 130 welds inspected with no reportable  
23 indications. Have the other SI piping, which is high  
24 pressure, smaller diameter pipe, could be one, and a  
25 half to maybe six inches in diameter. About 250 welds

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 have been inspected with no reportable indications.  
2 We'll go to the double asterisk there.

3 And I'll note that historically some  
4 indications have been identified, and attributed to  
5 thermal fatigue. But again, these results are the  
6 last time they inspected, and the thermal fatigue they  
7 observed was prior to that, and some repair  
8 replacement was performed. Then lastly, the  
9 pressurizer spray -- I'm sorry, the RHR piping, large  
10 diameter, we looked at 180 welds that were inspected  
11 with no reportable indications.

12 And also the pressurizer spray piping with  
13 60 welds inspected with no reportable indications.  
14 So, there's still 17 units in the U.S. I have not  
15 reviewed their data yet, we're still gathering. It's  
16 a big effort to gather all that information, to go  
17 through it. So, we're looking, and we're not seeing  
18 it, at least not in the last ten year period.

19 And we looked at the OE database, and  
20 we're not seeing -- before the last ten year period,  
21 the OE database goes up to 2017, we're not seeing  
22 stress corrosion cracking in these locations. We look  
23 to the thermal fatigue database, there might be two  
24 units that meets the criteria, but we're not sure,  
25 because there's an overlay. So, then the question

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 becomes well, are we using the appropriate UT method  
2 to see it?

3 So, talking with ND experts, UT experts at  
4 EPRI, and the vendors in the industry, the conclusion  
5 was that the UT methods employed were appropriate.  
6 Meaning that while the techniques used may not be  
7 specifically designed for IGSCC protection, they do  
8 provide reasonable assurance that if a significant  
9 cracking was present, it would be detected. So, there  
10 are new UT methods, and qualifications for personnel,  
11 and methodologies specific for identifying IGSCC.

12 They've been used for years in BWRs, and  
13 so we are considering those methods here potentially  
14 for the future. At least to some, maybe a one time,  
15 or maybe something else. It's part of what we're  
16 considering as far as the safety assessment.

17 MEMBER HALNON: So, what if we missed it,  
18 what happens?

19 MR. HOSLER: That gets to the consequence,  
20 which is the next slide here.

21 MEMBER HALNON: Okay, I knew that.

22 MR. HOSLER: All right, good lead in. All  
23 right, so for the consequence evaluation, this is a  
24 preliminary result, it's in process. A branch break  
25 line is bounded by a break, considered by design basis

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 analysis, that's no surprise. Design basis analysis  
2 consider large break LOCA, and those lines are clearly  
3 more limiting than a break in a branch line. So,  
4 considering could simultaneous breaks happen in  
5 multiple branch lines.

6 Given the paucity of this type of OE, and  
7 the extent of inspection coverage, simultaneous breaks  
8 in multiple branch lines is highly unlikely. We don't  
9 have the statistics to put a number on highly  
10 unlikely, but that's where we are right now.

11 MEMBER HALNON: Is a break in any line  
12 likely? Or, I mean less unlikely? In other words if  
13 this is left to crack, are we going to expect a  
14 catastrophic break?

15 MR. HOSLER: What makes this -- I talked  
16 about why this stress corrosion cracking is atypical,  
17 and part of the reason is the large flaw aspect ratio.  
18 Typically you would expect a flaw to be driven through  
19 a wall, and then leak, and so worse case it would  
20 leak, and you would identify it, because stainless  
21 steel is highly ductile, and flaw tolerant.

22 In this case it's less clear, because as  
23 EDF has observed, you can have a 360 degree flaw, that  
24 so far they've only seen them go the duct to the root  
25 pass wall, maybe 20 percent through a wall. EDF has

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 performed flaw evaluations under those criteria, and  
2 concluded that faulted events would not cause that to  
3 rupture. And as part of this focus group, we have not  
4 yet done an analysis like that.

5 MEMBER HALNON: Okay. Are the cracks  
6 arrested, or are they just growing slower, and slower  
7 because of less stress?

8 MR. HOSLER: The residual stress profile  
9 that is driving the flaw is highly tensile at the ID,  
10 and then drops off very quickly to become compressive.  
11 The stress intensity factor, the K driving the crack  
12 won't go to zero, it will flatten out to --

13 MEMBER HALNON: It'll continue to crack,  
14 but just maybe at a slower rate.

15 MR. HOSLER: Correct.

16 MEMBER HALNON: If it's going all the way  
17 around, that slow rate doesn't give me any comfort.

18 MR. HOSLER: Right. And ideally, that is  
19 correct.

20 CHAIR BALLINGER: I mean the good news is  
21 that the maximum amount of unidentified leakage would  
22 easily be detected before you got to a case before you  
23 had a real problem. The bad news is that at no time  
24 during the Davis-Besse event, did the leak rate ever  
25 exceed the unidentified leakage limit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           MEMBER HALNON:   And that's the same in  
2           D.C. Summer, we never, it was a third of a gallon a  
3           minute, which is less than the one -- we found it was  
4           400 pounds of boric acid crystals hanging from the hot  
5           leg. So, the boric acid is the key, keep boric acid  
6           in your system so you can find the leaks.

7           CHAIR BALLINGER:   That's part of my  
8           argument about the tactile business of walking through  
9           the plant.

10          MEMBER HALNON:   That's right.

11          MR. RUDLAND:   This is Dave Rudland, I have  
12          one comment about the stability of these types of  
13          flaws. And realize that we're talking about mainly  
14          just the membrane type of stresses. If the type was  
15          under just totally, membrane stress, you might get to  
16          a condition where you might get a crack that continues  
17          to grow evenly around the circumference even. But  
18          under bending, which a lot of these pipes have bending  
19          stresses on them.

20          Of course it's going to favor one side, or  
21          the other to wherever the bending tensile stress is.  
22          Which again would lead to a leakage behavior probably  
23          before it ruptured.

24          MR. HOSLER:   All right, next slide. Okay,  
25          so applicability assessment. This is also in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 progress, this is preliminary. But the approach being  
2 applied is identify, or consider the root causes to  
3 find for the EDF stress corrosion cracking operating  
4 experience. So, the primary is elevated stresses in  
5 the elbow weld region, and through a thermal  
6 stratification, I should say that it's identified as  
7 the primary by EDF.

8 And EDF has identified the secondary as  
9 weld residual stress. The IRSN has suggested that  
10 elevated dissolved oxygen due to dissolved oxygen in  
11 makeup water may be a contributing factor. EDF does  
12 not consider this to be one of the root causes, but it  
13 has been brought up by the IRSN. I can briefly give  
14 my thoughts on that. I agree with EDF on this.

15 Dissolved oxygen in the makeup water  
16 would, if that was a contributing factor, you would  
17 see stress corrosion cracking in the cold leg. Not  
18 only that, we're seeing stress corrosion cracking at  
19 the EDF branch lines near the flowing line, and down  
20 the branch line far from the flowing line. So, there  
21 doesn't seem to be -- oxygen doesn't seem to be a big  
22 driver in my view.

23 CHAIR BALLINGER: The question has been  
24 asked in another setting, with respect to the U.S.  
25 fleet, on makeup water tanks, some of them are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           inerted, some of them are not, is that true?

2                   MR. HOSLER: That's my understanding.

3                   CHAIR BALLINGER: And has somebody checked  
4           to see which ones are, and which ones aren't? If  
5           somebody claims that oxygen is an issue, would that be  
6           a discriminating?

7                   MR. HOSLER: If the applicability  
8           assessment concludes that oxygen is one of the main  
9           drivers, then that could be a way to focus inspections  
10          potentially. But we're not going that direction  
11          currently for the reasons we discussed. Oxygen can  
12          certainly aggravate stress corrosion cracking  
13          absolutely. Especially when the material is  
14          sensitized, and there's no evidence of sensitization.

15                  And again, we would expect to see cracking  
16          elsewhere if oxygen was really an issue. And beyond  
17          that, there's also been IGSCC found in the RHR branch  
18          line, which comes out of the hot leg, so clearly  
19          whatever makeup water you had after it's through  
20          before, it's gone. So, there's no oxygen you would  
21          expect in the RHR line.

22                  CHAIR BALLINGER: Got it.

23                  MR. HOSLER: All right. So, considering  
24          those root causes, assessed whether these conditions  
25          are present in the industry so we can consider the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 potential for thermal stratification in industry  
2 branch lines. This has been considered for quite a  
3 few years for concerns with thermal fatigue. And so  
4 MRP-146, which has NEI0308 guidelines for performing  
5 inspections specifically in these elbow welds, looking  
6 for thermal fatigue.

7 So, stratification is definitely something  
8 that's been a focus historically in the U.S. For the  
9 residual stress aspect, which as I said earlier is, in  
10 my view, the main driver, partially because of how the  
11 flaw is growing. I think as mentioned earlier, if the  
12 thermal stresses, or stratification is going to be  
13 preferential on the bottom of the pipe, so you would  
14 imagine the flaw would preferentially grow, and go  
15 through on that side.

16 But looking at the EDF OE I haven't seen  
17 that. So, that being said, for the applicability  
18 assessment, considering weld residual stress, it would  
19 be very beneficial to be able to review the weld  
20 procedures used, and weld records at the EDF units,  
21 and compare that to the U.S. fleet. That is easier  
22 said than done. You don't have access to the EDF  
23 records.

24 And also in the U.S. it's highly varied in  
25 how it was done, because it's done differently all

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 over the industry. The branch lines weren't welded by  
2 the OEM of the reactor, or the primary loop, or the  
3 steam generators, they were all done by other  
4 organizations. So, I can't go look at the Framatome,  
5 or the BMW fabricated plants, and pull those records,  
6 because the branch lines were done by other companies.

7 So, gathering those records is very  
8 difficult, so making that comparison is still being  
9 considered how feasible it is. Lastly, so we can --  
10 as we discussed, review common practices for makeup  
11 water control, and monitoring programs. If we do end  
12 up feeling the oxygen is a primary contributor, that's  
13 a path we're going to have to go down, but right now  
14 we're not going that direction.

15 Next slide please. All right, so been  
16 working on this for a little while, it's going a  
17 little slower than I like for two reasons. One is  
18 gathering all this inspection data for the fleet has  
19 taken some time. And also as mentioned earlier, it's  
20 very much an ongoing investigation in France,  
21 identifying where there are flaws, determining the  
22 extent of the condition.

23 And so, it's taken some time to gather up  
24 that information, and only so much is available to the  
25 U.S. And so at a point now where we've discussed in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the focus group, said okay, this is the information we  
2 have now, or do we take what we have, and write our  
3 safety assessment, and then revise it later if we get  
4 more information later? So, that was what we've  
5 decided to do.

6 So, now we're moving forward, going to put  
7 out the safety assessment in January, and if  
8 additional information comes out later, we'll just  
9 revise it, and update it. And then applicability,  
10 assessment sometime in the first quarter of next year.  
11 I'll leave that as my last slide there.

12 CHAIR BALLINGER: Questions from the  
13 members, or consultants? I apologize.

14 MEMBER PETTI: I just had a question given  
15 these French units, are there any designs similar to  
16 the French units in terms of the way the piping runs?

17 MR. HOSLER: So, the N4 design that seems  
18 to be most affected, the EDF type design, there are  
19 passive safety injection lines, large diameter safety  
20 injection lines, which for the vast majority of their  
21 flaws, are in those lines are in kind of a downward  
22 horizontal configuration, which is not true with the  
23 U.S. fleet. The U.S. fleet, pretty much all the  
24 passive safety injections are either up horizontal, or  
25 horizontal.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Thanks.

2 MEMBER BROWN: Is that good, or bad?

3 MR. HOSLER: If thermal stratification, as  
4 identified by OE, is a primary driver, then that would  
5 mean that the safety injection lines in the U.S. fleet  
6 are not affected by the issue.

7 MEMBER BROWN: Less susceptible.

8 MR. HOSLER: Correct.

9 CHAIR BALLINGER: So, then you tumbled to  
10 the idea that subtracting all that out, all that's  
11 left is residual stress, weld residual stress, and if  
12 that's the case, what's the difference between welding  
13 procedures in the U.S. versus France?

14 MR. HOSLER: Besides the operating  
15 experience -- besides seeing the types of flaws being  
16 observed at EDF, and not seeing those flaws in the  
17 U.S., that is the indirect comparison. The direct  
18 comparison would be actually reviewing the weld  
19 procedures, and weld records. And if those were made  
20 available, then that would be useful.

21 CHAIR BALLINGER: Because there's  
22 obviously a difference, one cracked, and one didn't.

23 MR. HOSLER: I believe, and maybe this is  
24 me talking, Ryan Hosler, and not representative of a  
25 consensus, but I definitely see a correlation between

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the branch line configuration, and the amount, the  
2 extent of stress corrosion cracking in the EDF fleet.  
3 Certainly the N4 design has the most indications, and  
4 it has the most stratification. So, there's a clear  
5 correlation there.

6 I'm not seeing the cause effect, but  
7 everything I've seen, much of what I've seen is  
8 similar to others, which is press reports, some  
9 PowerPoint presentations, not a full report. And  
10 maybe if I saw a full report, I'd say clearly, I see  
11 how they got from A to B. But right now I don't see  
12 how they got from A to B, I see a correlation, but not  
13 a cause effect right now.

14 MEMBER BROWN: Is there -- I was looking  
15 at the age of the plants. Our plants are older than  
16 theirs by not an insubstantial decade, or so.

17 MR. HOSLER: Yeah, the U.S. fleet is  
18 certainly older than the N4 design branch point.

19 MEMBER BROWN: Yeah, based on the  
20 statistics, you're talking 20 years, and these aren't  
21 cracking, and those are.

22 MR. HOSLER: Correct.

23 MEMBER BROWN: And their materials are  
24 still the same? Was it 316LN, or whatever the name  
25 was?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. HOSLER: Yeah, the materials vary in  
2 the U.S., but much of it is 316, sometimes 316L, for  
3 the larger diameter pipes, 316 seems more common. For  
4 the smaller diameter, 304 seems more common. But  
5 they're all stainless steels that are generally  
6 similar.

7 MEMBER BROWN: So, the U.S. plants have  
8 had more stress applied to them over a period of time  
9 you would think, just from normal operations.

10 MR. HOSLER: I wouldn't say -- the stress  
11 is imparted during fabrication, the weld residual  
12 stress. The thermal stratification --

13 MEMBER BROWN: I wasn't thinking about  
14 thermal stress, but just due to operations, and flow  
15 usage.

16 MR. HOSLER: Right. Yeah, I'd say the  
17 time is a factor, and temperature is a factor, but all  
18 other conditions being equal, higher temperature will  
19 make it occur more quickly, but temperatures are  
20 similar in both designs, U.S., and EDF. All other  
21 components being equal, then yeah, it's just a matter  
22 of time. So, clearly we're not seeing -- in the EDF  
23 fleet, their older plants, they're only seeing it in  
24 their newer plants.

25 MEMBER BROWN: The 900s.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. HOSLER: In the 900s they're not  
2 seeing, they had one that was really associated with  
3 a weld defect, doesn't seem to be part of this extent  
4 of condition. The extended condition at EDF, they  
5 defined it as the N4 plant safety injection RHR. And  
6 then for the P Prime4, which is new, but not their  
7 newest plants, they've seen stress corrosion cracking  
8 at one unit.

9 So, they've included the safety injection  
10 lines for those 12 units as well as part of their  
11 inspection destructive examination program. But yeah,  
12 generally the EDF, they've only seen it in their newer  
13 plants, and not their older plants.

14 MEMBER DIMITRIJEVIC: Yeah, but those are  
15 also coming up --

16 MEMBER BROWN: There's a benefit to being  
17 old.

18 MEMBER DIMITRIJEVIC: Those are higher  
19 power plants, over 1300 megawatts. So, I mean in  
20 United States, if we look at this, it would have to be  
21 in higher power plants. I don't think that aging is  
22 maybe such a big part. It's your opinion, the aging  
23 is an effect, or the power of the plant?

24 MR. HOSLER: I don't see a cause effect  
25 between the power of the plant, and susceptibility to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 stress corrosion cracking. It's certainly an aging  
2 effect question --

3 MEMBER DIMITRIJEVIC: No, not the  
4 progression, but the temperatures could affect thermal  
5 transfer, so.

6 CHAIR BALLINGER: Nobody really knows when  
7 initiation occurred, and these plants are 40, 30  
8 years.

9 MR. HOSLER: For the EDF fleet, they  
10 performed inspections ten years ago, and they didn't  
11 see anything, they performed inspections this time,  
12 and they did see something. Was it there ten years  
13 ago? It's possible it may have been to a small  
14 degree, and they just weren't able to detect it. But  
15 to them, it appears as though -- I mean it's their 20  
16 year life is when all these started popping up at the  
17 N4 design.

18 Which, now U.S. plants are hitting their  
19 50 years around this time, some of them are. And  
20 they're not seeing it, which indicates that clearly  
21 there is, in my view, a significant difference between  
22 the weld practices that were used at those two  
23 designs.

24 MR. RUDLAND: This is Dave Rudland, if I  
25 can make an observation, the NRC, and EPRI a few years

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 back did a very extensive weld residual stress  
2 validation program, where we made welds in plates in  
3 small diameter pipes, and very large diameter pipes,  
4 and looked at how these residual stresses are formed.  
5 And something that struck me when I first saw this,  
6 and looked at it was the micrographs that I saw  
7 definitely showed the root pass of the weld was very  
8 large compared to the fill passes.

9 And again, typically in these multi pass  
10 welds, the secondary, the second, and third passes  
11 kind of anneal the first pass a little bit, and reduce  
12 the stresses slightly. In the cases that we've seen  
13 the root passes are very large, indicating to me it's  
14 going to have very high residual stress because of how  
15 big that root pass is. And that evidence is further  
16 brought forward by how deep the crack went.

17 Which, the crack went to about the depth  
18 of the root pass, suggesting again that it's some weld  
19 procedure, or some issue with the residual stresses  
20 that come from that particular weld. And those were  
21 -- granted, we've only seen a very small sampling of  
22 the weld sections, but that was an observation that we  
23 had from those weld sections.

24 MR. HOSLER: And that was true for the EDF  
25 destructive exam results I've seen, and also the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Japanese one as well.

2 MEMBER HALNON: I wanted to ask Carol,  
3 given all this information, what are the plans for the  
4 NRC? Is it leveled effort with research to the SCC,  
5 and NDE research, or are you guys finding a generic  
6 communication, and you're working up towards that?  
7 What's the NRC engagement as they finish their safety  
8 assessment?

9 MS. MOYER: This is an emerging  
10 experience, and response. None of that has been  
11 decided for sure yet. I will restate that we had  
12 already research in place on SCC initiation, crack  
13 growth rate, NDE techniques, and their sensitivity,  
14 and their reliability, including some of these newer  
15 techniques that EDF is employing now. So, we will  
16 continue those works to better understand what tools  
17 we have, and what susceptibility we may be looking  
18 for.

19 I'm not aware of any plans for a generic  
20 communication. I'm looking at Dave because I don't  
21 know the answer to that one.

22 MR. RUDLAND: Yeah, so this is Dave  
23 Rudland. Just coincidentally this morning, the NRC  
24 management, and the industry management had a  
25 materials meeting, and this topic came up of course.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 And the status of the industry's focus, effort stuff  
2 came up. We asked that when they finish their effort,  
3 that we have another public meeting to kind of go over  
4 their final results.

5 And then I think any action we take will  
6 have to wait until after we hear their final results.

7 CHAIR BALLINGER: Yeah, that's good,  
8 thanks.

9 MR. RUDLAND: We suspect, and correct me  
10 if I'm wrong, but we suspect sometime this spring,  
11 early summer, we would have that meeting.

12 MEMBER KIRCHNER: Ron, this is Walt, may  
13 I ask a question?

14 CHAIR BALLINGER: Of course.

15 MEMBER KIRCHNER: Going back to the  
16 earlier presentation with that nice picture of the  
17 crack, so we have Carol, and David, and Ryan who are  
18 metallurgists, I'm not. I look at that kind of crack,  
19 and that doesn't look like stress corrosion cracking.  
20 I shouldn't have said that. How would you describe  
21 that crack from the picture, from the inner elbow  
22 picture from EDF.

23 MR. HOSLER: So, this is Ryan Hosler. The  
24 main indicators that it's stress corrosion cracking,  
25 and it's hard to see in that picture I agree, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 there's some better pictures where it's closer up, and  
2 it's etched, so you can see the grain boundaries, and  
3 you can clearly see that the flaw is following the  
4 grain boundaries. Also some other destructive exam  
5 results did in fact break open some of the flaws, and  
6 look at the fracture surface with an SEM.

7 And you can clearly see that the faceted  
8 type intra granular stress corrosion cracking  
9 indicative surface.

10 MR. RUDLAND: And this is Dave, one of the  
11 first questions I asked was were these things  
12 initiated by thermal fatigue, and then grown by SCC?  
13 Transitioned, and grown by SCC, and from what I've  
14 heard, and read through my counterparts in France,  
15 that the SCC is across the entire crack face. So,  
16 it's not something that was transitioned, it was  
17 purely stress corrosion cracking.

18 MEMBER KIRCHNER: So, how do you reconcile  
19 that with looking at root causes, and saying it's  
20 residual weld stress?

21 MR. HOSLER: Residual stress is  
22 historically primary driver for stress corrosion  
23 cracking. For the BWRs, all the issues they had in  
24 the 80s, they were all weld residual stress driven.

25 MEMBER KIRCHNER: Okay, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: I might add, there's  
2 kind of a rule of thumb, Vicker's hardness number for  
3 initiation, the Vicker's hardness number, if I recall,  
4 exceeded these numbers.

5 MR. HOSLER: They're very close to the ID,  
6 the hardness is quite high.

7 MR. RUDLAND: And just to be clear, stress  
8 corrosion cracking is a constant load mechanism crack.  
9 Fatigue is an alternating load, on, off. For stress  
10 corrosion cracking you need to have constant load, and  
11 so that's why residual stress is so detrimental to  
12 those that are susceptible to stress corrosion  
13 cracking.

14 MEMBER KIRCHNER: Great, thank you, thank  
15 you.

16 MEMBER BROWN: Earlier I asked a question,  
17 not being a metallurgist, where we're going now, it  
18 seems to me, the way I take away this is our ASME  
19 standards, and everything else in the weld  
20 requirements for Part 50, and Part 52, whatever we do  
21 to build plants seems to have put us in good stead.  
22 Is that a reasonable conclusion?

23 MR. HOSLER: I think what we've been doing  
24 has worked very well. Stainless steel generally has  
25 been -- stainless steel welds have been extremely well

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 performing.

2 MEMBER BROWN: Is anything changing with  
3 the Part 53 with risk informed stuff, does that get  
4 applied to welding? I know a wide variety of plants,  
5 and light water reactors could use Part 53 if they  
6 wanted to, I presume. Do we still have special --

7 MEMBER PETTI: It still pushes the section  
8 level.

9 MEMBER BROWN: Okay, I didn't remember  
10 that from our previous --

11 MEMBER PETTI: Yes, but again, in some  
12 cases they're not going to use stainless steel,  
13 they're going to use high end nickel alloy, it depends  
14 on the reactor.

15 MEMBER BROWN: Yeah, stuff of that nature.  
16 I just needed to make sure it was clear in my mind.

17 MEMBER PETTI: Yes, and the code, and such  
18 is actively evolving for some of these more advanced  
19 reactors, and the newer materials, and higher  
20 temperatures, so they're in the process of evolving to  
21 try to meet those needs.

22 MEMBER BROWN: Just worry about you don't  
23 want to see the standards not meet the tests, we've  
24 been building these things since the late 50s, and  
25 that's a long time to have some of the very, very

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 early plants, which have been decommissioned already,  
2 but it just seems to have put us in good stead, that's  
3 why I asked the questions.

4 CHAIR BALLINGER: Stainless steel has  
5 produced a number of bad hair days, and expenses, but  
6 it hasn't resulted in anything really bad.

7 MS. MOYER: As we've been saying, it is a  
8 resilient material, corrosion resistant, stainless,  
9 but corrosion resistant anyway. And between the  
10 design, and the inspection of section 11, leak before  
11 break has been maintained, and yes. So, if there are  
12 problems, typically they can be detected before they  
13 become big problems.

14 MEMBER BROWN: My point is inspection  
15 requirements, and things like that are costly, but  
16 they have at least been able to ensure that we're  
17 okay, which is the good news to me.

18 MS. MOYER: Fair enough.

19 MEMBER BROWN: I'm not criticizing anybody  
20 else, it's not the point, it's just a matter of  
21 whatever standards people have, and people complain  
22 about, they seem to have worked. Thank you.

23 MR. SCHULTZ: Carol, this is Steve  
24 Schultz. You mentioned that the inspection techniques  
25 that have been newly developed in France had the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 advantages of more rapid testing, and also other  
2 opportunities for testing, and you said that we were  
3 going to be looking further with that. I'm not sure  
4 if this is a question for you, or for the Owners  
5 Group. Is there --

6 MS. MOYER: That's not quite an accurate  
7 portrayal. I would say the techniques they're  
8 employing are very sensitive, and they find they're  
9 capable of detecting flaws, they're also capable of  
10 detecting geometry, they're capable of detecting grain  
11 structure, and weld micro structure. And the  
12 difficulty with a sensitive technique that is capable  
13 of detecting many things is it can be challenging in  
14 the interpretation of those results.

15 So, while EDF has selected an inspection  
16 technique that will give them a lot of information,  
17 turning that into actionable information will be a  
18 challenge for them. We are continuing to look at  
19 those inspection techniques, as I'm sure a lot of  
20 other people are. I mean there are systems available  
21 that you can buy, then take to your power plant of  
22 whatever sort, and employ that kind of an inspection.

23 But there are not ASME section 11 appendix  
24 8 qualified procedures that say if you do this, you  
25 will get that predictable result. You see what I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 mean? We're in that somewhat sort of grey area with  
2 these new techniques.

3 MR. SCHULTZ: I thought you mentioned that  
4 there would be a dose reduction off (audio  
5 interference) technique, did I miss that?

6 MS. MOYER: That's not true.

7 MR. SCHULTZ: Okay, thank you.

8 MR. WAX: This is Chris Wax from EPRI.  
9 From a inspection perspective, we do have the  
10 performance demonstration institute within our EPRI  
11 NDE Center of Excellence. So, we do require folks to  
12 come, and actually qualify on these procedures to  
13 prove that they can actually go find an indication in  
14 a plant. They get their qualifications there, they  
15 get their approval, they get the -- essentially the  
16 thumbs up that they can actually go perform these.

17 And following the IGSCC experience from  
18 the BWR plants, we have a pretty extensively well put  
19 together IGSCC procedure that has been utilized in the  
20 past to look for these types of indications. And like  
21 Ryan mentioned in our presentation, that's one of the  
22 things we're looking at for future inspection needs.  
23 Do we need to go to that route, to that level, and  
24 have this IGSCC procedure deployed on these  
25 inspections?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   And that's something that will come out of  
2                   our findings, and our discussion from our focus group.

3                   CHAIR BALLINGER: Thank you.

4                   MEMBER DIMITRIJEVIC: Do you mean, okay,  
5                   are you talking outside of the current ISI program,  
6                   outside of these ten years, ten percent? You mean  
7                   additional inspection for IGSCC, is that your meaning?

8                   MR. WAX: I mean we have the thermal  
9                   fatigue programs that we have required the thermal  
10                  fatigue procedures to be utilized on in the past, and  
11                  we're looking at some of those inspections, and the  
12                  periodicity that they are utilized on. And  
13                  potentially providing input that we propose the use of  
14                  the IGSCC procedures. Again, that's in conversation,  
15                  it's not formal yet, but that's just a thought we're  
16                  having.

17                  MS. MOYER: And I would want to reiterate  
18                  that the newer techniques that I mentioned earlier,  
19                  I'm not going to say the letters, because I'll say it  
20                  wrong, but you can look back at the slide that  
21                  mentions these matrix type things. They are very  
22                  challenging to deploy in a real power plant at this  
23                  time. They require a transducer that is very large.  
24                  And so, a large transducer on a small diameter pipe  
25                  means you don't always get very good sound connection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 between the transducer, and the pipe.

2 So, unless they can shrink the size of the  
3 transducer with additional technology development, I  
4 mean trying to get something that's three inches  
5 square to meet against a pipe, and give you a  
6 predictable sonification of that volume is just hard.  
7 It also produces, as I said earlier, vast quantities  
8 of data that will be an interpretation challenge. So,  
9 this is why we've chosen not to go this direction just  
10 yet.

11 CHAIR BALLINGER: Are there questions from  
12 members, or consultants? Well, that's the end of your  
13 presentation, right?

14 MR. HOSLER: Correct.

15 CHAIR BALLINGER: So, I'm sure the other  
16 members would thank you very much for the  
17 presentation, it's been very informative. We are  
18 hopefully going to get more presentations as this  
19 evolves. This was for information only, and I think  
20 you provided us with as much as you can by way of  
21 information that we can -- to give us a perspective on  
22 the issue, which is really important for us.

23 So, if there aren't any -- I have to go  
24 out -- excuse me. Now we can ask, are there any  
25 members of the public that would like to make a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 comment? If there are members of the public out there  
2 that would like to make a comment, please state your  
3 name, and then make your comment. Hearing none,  
4 again, I'd like to thank you guys very much for  
5 coming, and talking with us. And this meeting is  
6 adjourned.

7 (Whereupon, the above-entitled matter went  
8 off the record at 3:05 p.m.)

9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

# Stress Corrosion Cracking in French PWRs: Operating Experience Discussion

Carol Moyer, Sr. Materials Engineer, NRR/DNRL/NVIB

David Rudland, Sr. Technical Advisor, NRR/DNRL

November 16, 2022

# French Operating Fleet

- 56 reactors in operation, all Pressurized Water Reactors (PWRs)
- Built during 1970s – 1990s
- 3 main styles
  - 32 are 900 MW (CP0 and CPY types)
  - 20 are 1300 MW (P4 and P'4 types)
  - 4 are 1450+ MW (N4 type)
- Based on Westinghouse design, modified for French grid




Figure courtesy of ASN


# Timeline of Cracking Detected in French NPPs in Fall 2021

---

- Flaw indications were detected near welds in safety injection (ECCS) lines during scheduled decennial safety inspections
  - 10/2021 – Civaux-1 (N4)
  - 11/2021 – Civaux-2 (N4) and Penly-1 (P4)
  - 12/2021 – Chooz-B1 and Chooz-B2 (N4)
- Indications found in safety injection (SI) lines and residual heat removal (RHR) lines
- Laboratory analyses of Civaux-1 cracks identified intergranular stress corrosion cracking (IGSCC)
- Regulator (ASN) decided to expand inspections and reevaluate prior NDE data





# Affected Piping Loops



- 4 separate loops, connected to the cold leg of the primary circuit
- Stainless steel piping
  - Diameter: 25 to 30 cm
  - Thickness: 2.85 cm
- Design modifications increased the length of piping runs in the safety injection circuits to reduce inspector dose.

# Cracking Locations in Safety Injection Piping



Nominal pipe sizes are 8" – 14" diameter, 1" wall thickness

Figures courtesy of ASN. <https://french-nuclear-safety.fr/asn-informs/news-releases/stress-corrosion-phenomenon-detected-on-reactors>

# Additional Indications of SCC in Spring 2022

---

- EDF accelerated plans to inspect safety injection piping for similar degradation in Spring 2022
- The regulator (ASN) requested additional information from EDF to assess the degradation and its extent – whether a generic issue.
- Summer 2022 – EDF deployed new NDE method to detect & size flaws
- SCC indications were mostly in 1300 MW and 1450 MW type (newer) reactors, not in 900 MW (older) plants
- SCC indications have been reported at these reactors:
  - Civaux-1 & -2 (1561 MW)
  - Chooz-B1 & -B2 (1560 MW)
  - Penly-1 (1382 MW)
  - Cattenom-3 (1362 MW)
  - Flamanville-2 (1382 MW) (unconfirmed)
  - Golfech-1 (1363 MW) (unconfirmed)

# Characterizing the Crack-like Indications

---

- Indications were at pipe inner diameter, located at elbows.
- Through destructive examination, the cracks were confirmed and attributed to intergranular stress corrosion cracking (IGSCC).
  - In the base metal (AISI 316L) and heat affected zone (HAZ) adjacent to welds
  - Crack depth varies
  - Crack extension can reach 360° (the full circumference)
- Thermal fatigue cracks had been anticipated.
  - Stagnant or intermittent flow is expected in affected lines.
  - Thermal stratification in affected lines is postulated.





# Destructive Examination

---

- Over 100 welds have been examined with either penetrant test or destructive examination.
- Cracked elbows were removed and sent to EDF hot laboratory for assessment. Cracks were confirmed, attributed to intergranular stress corrosion cracking (IGSCC).
  - In the base metal (AISI 316L) and heat affected zone (HAZ)
  - Max. depth confirmed ~1/4 through-wall depth
- High hardness detected in the vicinity of the weld root pass
- Unusual weld geometry (height of the weld root pass) or weld repairs detected in some cross-sections
- No evidence of chemical contamination

# Destructive Examination of Civaux-1 Crack



*"Susceptibility to IGSCC of cold work austenitic stainless steels in non-polluted primary PWR environment," T. Couvant et al., EDF, Fontevraud 10, Sept. 2022*

- Non-sensitized 316LN
- Non-polluted hydrogenated primary water at  $\sim 300^{\circ}\text{C}$
- 20 years in service
- Elevated hardness ( $\sim 270$  HV) at ID surface
- Fully IGSCC

## Non-Destructive Examination (NDE) (1/2)

---

- Cracks were detected by manual ultrasonic testing (UT)
  - Procedure used 45° shear wave at 2.25 MHz
  - Manual scanning has worker dose implications
- The UT procedure was designed to detect thermal fatigue (TF) cracks. It was not optimized to detect or size SCC cracks.
- Destructive exams have confirmed intergranular SCC cracks, with depths up to 6 mm (0.25”), up to 360° circumference.
- EDF has reanalyzed prior NDE data to look for missed calls, data characterized as “non-relevant indications.”
- Re-inspection of plant ECCS piping is using an advanced NDE procedure and accelerated schedule.

## Non-Destructive Examination (NDE) (2/2)

---

- Safety injection lines are being inspected by remote penetrant test or by ultrasonic test (UT)
- Total Focusing Method/Full Matrix Capture (TFM/FMC ) Plane Wave Imaging (TFM/PWI)
  - Scanning is still manual but encoded for location
  - EDF claims flaw depth sensitivity is +/- 1mm
  - TFM/FMC is a research technique, not qualified – will pursue RSE-M
  - Why a qualified phased array UT (PA-UT) technique was not selected is unclear.




## Root Cause Analysis (1/2)

---

- IGSCC degradation was not expected, not in accordance with the international operating experience. No SCC on the French 900 MW plant series after 30 years.
- No evidence of contamination was observed
- Weld repairs and deviations from normal weld procedures may have influenced cracking.
- EDF has performed a welding simulation to estimate hardening and residual stresses in the areas where IGSCC is observed.
  - An area of limited depth on the inner side of the weld is subject to tensile stress.
  - A compression zone exists within the bulk of the weld. This compression zone could significantly slow down the propagation of the cracks.
  - Destructive exams confirmed hardening near pipe inner diameter

## Root Cause Analysis (2/2)

- Weld repairs may contribute to SCC susceptibility
  - Residual stress changes and localized hardening may occur
  - Regulator asked for all repaired welds to be re-inspected
- Oxygenated water may contribute to SCC susceptibility
  - Oxygen ingress in reactor coolant system might come from non-deaerated fluids (core make-up tanks, boric acid tank) or  $H_2O_2$  injected at shutdown.
- Thermal stratification is expected to impose cyclic loading on the pipes
  - Increased in N4-type reactors, associated with longer horizontal runs for inspectability
  - Modeling by IRSN shows more stratification than previously expected



## Mitigation Plans - France

---

- Cracked piping sections have been removed and replaced.
- From September 2022 through 2025, EDF intends to carry out a complete examination program on all operating reactors, on the areas that might be affected by IGSCC.
  - Advanced UT procedure optimized for IGSCC detection
    - Technique is based on Phased Array Ultrasonic Testing (PAUT) combined with the Total Focusing Method (TFM)
    - EDF plans to seek qualification of the technique in 2023
  - All reactors considered as most sensitive (N4 type, reactors with indications that may have been considered as non relevant) have been stopped to carry out inspection and repairs where needed.
- A periodic inspection program will be defined, with a periodicity based on the sensitivity of the NDE, the growth rate of IGSCC, and mechanical elastic-plastic fracture mechanics analyses.

## Status of the French Fleet

---

- Currently 26 reactors are shut down: 15 for stress corrosion problems and 11 for maintenance.
  - Repair work was completed at 6 reactors
  - Repairs are underway at 4 reactors
- EDF performed FEA stress analysis and proposed flaw evaluation criteria for continued operation.
  - For Cattenom Unit 1, EDF requested continued operation for 8 months without repair of cracks (4mm and 6mm).
  - On advice of IRSN, ASN denied a re-start authorization due to uncertainties in crack sizing and pipe stresses.

## Similar Operating Experience

---

- A similar crack was found in Japanese Ohi Nuclear Power Station Unit 3 pressurizer spray weld in August 2020, which was attributed to hardening from high weld stress on the inside diameter (ID) surface.
  - Unusual heat input at the weld
  - Restriction of weld deformation (constraint)
  - Residual stress would be expected
- Operating experience in U.S. PWRs has shown that stress corrosion cracking of 316 stainless steel is unlikely without significant abnormal conditions, e.g., cold working, grinding, contamination, oxygenated water conditions.

# USA Operating Experience

---

- The use of ASME Code Section XI is mandated by 10 CFR 50.55a with most U.S. plants using an NRC-approved risk-informed inservice inspection (RI-ISI) plan as an alternative to Section XI.
- U.S. plants examine  $\approx$ 10-15% of the ASME Class 1 SI and RHR piping welds under their RI-ISI programs.
- No SCC has been found in analogous welds in U.S. PWRs.
- Welds are susceptible to thermal fatigue cracking.
- There have been ten incidents of thermal fatigue cracking since 2013, with seven found through UT examination and three by leakage.
- EPRI updated MRP-146 in 2018 to enhance the owner's voluntary programs of inspections to detect thermal fatigue cracking.

## More on U.S. NDE Examinations

---

- Class 1 stainless steel pipes are examined using multiple ultrasonic angles from four directions.
- The personnel, procedures, and equipment used on piping welds must pass rigorous performance demonstration testing under ASME Code Section XI, Appendix VIII.
- The examinations in the U.S. are optimized for thermal fatigue flaws but are capable of detecting stress corrosion cracking.
- The UT examinations have a current ability to detect cracks of 5-15% through-wall depth and a good probability of detecting larger cracks.
- Challenges include the metal grain structure and geometric features of the pipes and welds.
- NRC continues to conduct research on SCC initiation and NDE capabilities

# Conclusions

---

- ASN concludes that the stresses caused by thermal stratification are likely the most significant factor in the root cause of the IGSCC.
- Older French reactors appear less affected, possibly due to design.
- French fleet inspections will be carried out with advanced UT.
- After inspections have been completed on all reactors, a periodic inspection program will be defined, with a periodicity based on the sensitivity of the NDT, the expected growth rate of IGSCC, and elastic-plastic fracture mechanics analyses.
- The US fleet, configured similarly to the older French plants, continues regular inspections. No similar degradation has been observed.





**PWROG**  
PWR Owners Group



**Global Expertise • One Voice**

**Ryan Hosler – Auxiliary Piping SCC OE Focus Group Update**  
**ACRS Meeting 11/16/22**

# Agenda

## Industry actions to consider EDF OE

- EPRI white paper (complete)
- Revision to MRP-236R1 (in progress)
- PWROG Focus Group (in progress)
  - Safety Assessment
  - Applicability Assessment


# EPRI White Paper (MRP Letter 2022-018)

- Developed by experts in the field of SCC in LWRs
- Conclusions:
  - The most important factors that accelerate SCC to higher levels than expected in PWR primary water are residual deformation (from cold work or welding), stress (from welding, pressurization, fit up, etc.) and environment (oxidants and contaminants in creviced areas)
  - There is a newly developed empirically-based SCC CGR equation (MRP-458)
  - SCC in stainless steel components exposed to flowing PWR primary water will continue to occur, but there is no evidence of aging that accelerates SCC in wrought stainless steels, and no sudden increase in SCC initiation and growth is expected after decades of operation

# Revision to MRP-236R1 (1/2)

- MRP-236 contains information concerning SCC of primary circuit pressure boundary stainless steel, including an OE database
- Last revision was completed in 2017, which found no cases of SCC in the non-isolable portions of branch piping
- New revision (in progress) is reviewing OE since 2017
  - Only confirmed cases of SCC in non-isolable portions of branch piping have occurred in the EDF fleet and one case at a Japanese unit
  - Revision will also include a review of the thermal fatigue OE database (MRP-85R2/MRP-468) for cases that have the potential to be EDF-like SCC
    - Focused on flaws with large aspect ratios and where a destructive exam to confirm mechanism was not performed
      - Two units have presumed thermal fatigue in RHR piping with these characteristics

# Revision to MRP-236R1 (2/2)



**EDF OE (SI and RHR piping)**  
**Japan OE (one case in PZR spray piping)**

EDF/Japan OE is atypical because

- given well-controlled water chemistry, WRS alone is sufficient for SCC
- Located in non-isolable portion of branch piping
  - Previous OE indicated that only thermal fatigue occurred in this piping (MRP-85R2/MRP-468), which is addressed by an inspection program (MRP-146R2)

**CRDM/CEDM housings/seals**  
**Valve drain lines**  
**Isolable piping**

**Bent CVCS HX tubes**  
**PZR heaters (non-stress relieved)**

# PWROG/EPRI Focus Group

- Coordinating efforts between PWROG and EPRI
- Safety Assessment
  - Purpose: Assess potential safety impact of EDF OE on the industry
- Applicability Assessment
  - Purpose: Assess applicability of EDF OE to the industry



# Safety Assessment (1/4)

## Approach

- Safety is based on risk, which is a function of likelihood and consequence
  - Likelihood of SCC
    - Review inspection data to determine if applicable locations are being inspected
    - Review UT method to determine if EDF-type flaws would be identified
    - Review SCC OE database to determine if EDF-type SCC has occurred elsewhere
  - Consequence of SCC
    - Review available flaw evaluations to determine if a flaw could reach critical flaw size
    - Compare design basis analysis breaks to branch line breaks


**Issue Recommendations (as appropriate)**

# Safety Assessment (2/4)

Areas of interest per EDF/Japan SCC OE

- Red highlighted welds indicate weld HAZ locations of interest (i.e., elbow welds)

Example branch line  
(EDF SI piping)





# Safety Assessment (3/4)

## Preliminary Results for Likelihood of SCC

- Inspection results reviewed for 56 units\*
  - Passive SI Piping (large diameter): ~130 elbow welds inspected with no reportable indications
  - Other SI Piping (small diameter): ~250 elbow welds inspected with no reportable indications\*\*
  - RHR Piping (large diameter): ~180 elbow welds inspected with no reportable indications\*\*
  - PZR Spray Piping: ~60 elbow welds inspected with no reportable indications
- Gathering of inspection results continues (17 units remain for US fleet)
- UT methods employed were appropriate
  - While the techniques used may not be specifically designed for IGSCC detection, they do provide reasonable assurance that if significant cracking was present, it would be detected
- UT methods specific to IGSCC are being considered

\*Results from last inspections performed during most recent 10-year interval

\*\*Historically, some indications have been identified and attributed to thermal fatigue

# Safety Assessment (4/4)

## Preliminary Results for Consequence of SCC

- A break in a branch line is bounded by breaks considered by design basis analyses
- Given the paucity of this type of OE and the extent of inspection coverage, simultaneous breaks in multiple branch lines is highly unlikely



# Applicability Assessment

## Approach

- Consider root causes defined for EDF SCC OE
  - Primary: Elevated stresses in the elbow weld regions due to thermal stratification
  - Secondary: Weld residual stress
  - Suggested by IRSN: Elevated dissolved oxygen due to dissolved oxygen in makeup water\*
- Assess whether these conditions are present in the industry
  - Consider potential for thermal stratification in industry branch piping
    - This is a primary focus for existing thermal fatigue inspection requirements (MRP-146R2)
  - Compare weld procedures
  - Review common practices for makeup water control and monitoring programs

**\*EDF does not consider O2 to be a root cause**

# Schedule

Report	Projected Completion
Safety Assessment	January 2023*
Applicability Assessment	March 2023

**\*Safety Assessment may need to be updated in the future as more information becomes available**

# Questions?

Full Name	Timestamp
Court Reporter1	11/16/22, 12:45:20 PM
Russell Cipolla Intertek	11/16/22, 12:45:20 PM
Larry Burkhart	11/16/22, 12:45:20 PM
Thomas Dashiell	11/16/22, 12:45:20 PM
Michael Snodderly (DFO, ACRS)	11/16/22, 12:45:20 PM
Christopher Brown	11/16/22, 12:45:20 PM
Carol Moyer (NRR)	11/16/22, 12:50:09 PM
DUBOIS Olivier	11/16/22, 12:51:21 PM
Carol Nove	11/16/22, 12:52:31 PM
Beth Kehler Haluska (Services - 6)	11/16/22, 12:52:52 PM
Vesna Dimitrijevic (Guest)	11/16/22, 12:54:12 PM
PETIT Marc	11/16/22, 12:54:18 PM
Timothy Wyant (Guest)	11/16/22, 12:55:05 PM
Dan Widrevitz	11/16/22, 12:55:50 PM
On Yee	11/16/22, 12:56:05 PM
Sandra Walker	11/16/22, 12:56:16 PM
Matt Sunseri	11/16/22, 12:57:12 PM
ALEXANDER STANISLAV CHAPMAN	11/16/22, 12:58:12 PM
Bengt (Guest)	11/16/22, 12:58:14 PM
LOUET Guillaume	11/16/22, 12:58:16 PM
Bushmire, Anthony J.	11/16/22, 12:58:17 PM
Udyawar, Anees	11/16/22, 1:00:57 PM
Emma Haywood	11/16/22, 12:59:16 PM
Seppänen Tommi	11/16/22, 12:59:42 PM
DE CURIERES Ian	11/16/22, 12:59:48 PM
Edwin Lyman	11/16/22, 12:59:51 PM
Tammy Skov	11/16/22, 12:59:57 PM
Thierry SOLLIER IRSN (Guest)	11/16/22, 1:00:44 PM
Ness (Guest)	11/16/22, 1:00:45 PM
Dariana LLANES VEGA	11/16/22, 1:01:11 PM
Walt Kirchner	11/16/22, 1:02:13 PM
Marlette, Steve E	11/16/22, 1:02:23 PM
Enes ARACI	11/16/22, 1:02:42 PM
Gregory Halnon	11/16/22, 1:02:55 PM
Zhai, Ziqing	11/16/22, 1:04:26 PM
Steven Wessels	11/16/22, 1:04:36 PM
Mycele Schneider	11/16/22, 1:05:03 PM
Andy Morley (Guest)	11/16/22, 1:05:15 PM
Wilson, Bryan M.	11/16/22, 1:06:51 PM
Adrien THIBAUT (ASN) (Guest)	11/16/22, 1:07:21 PM
Dennis Bley (Guest)	11/16/22, 1:09:16 PM
Matthew Mitchell	11/16/22, 1:10:12 PM
FRANKLIN BARNABAS NOMBO	11/16/22, 1:11:26 PM
Shim, DJ	11/16/22, 1:11:32 PM
Fajar KURNIA (Guest)	11/16/22, 1:15:45 PM
R (Guest)	11/16/22, 1:16:40 PM
Christina Antonescu	11/16/22, 1:21:43 PM
Zena Abdullahi	11/16/22, 1:23:01 PM

CATTIAUX Gerard (Guest)	11/16/22, 1:33:46 PM
Cory Parker	11/16/22, 1:42:39 PM
GARCIA HERAS MARIA LUISA	11/16/22, 1:44:05 PM
Tim Watkins (Guest)	11/16/22, 1:59:20 PM
Ryan Hosler (Framatome)	
David Rudland (NRR)	
Chris Wax (EPRI)	