


UFSAR Revision 31.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29.0
Chapter: 14
Sheet: 1 of 1



UFSAR Figure: 14.2.5-1

Unit: 2

Title: Variation of Reactivity with Core Temperature at 1050 psia for the End of Life Rodded Core with One Control Rod Assembly Stuck (Assumes Zero Power)

UFSAR Revision 31.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29.0
Chapter: 14
Sheet: 1 of 1




Figure 14.2.5-2: Doppler Power Feedback for Steamline Break

UFSAR Figure: 14.2.5-2

Unit: 2

Title: **Doppler Power Feedback for Steam Line Break**





Figure 14.2.5-3 Safety Injection Flow Supplied by One Charging Pump

UFSAR Revision 31.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29.0
Chapter: 14
Sheet: 1 of 1



UFSAR Figure: 14.2.5-4

Unit: 2


Title: **Steam Line Break DER Inside Containment with Power Nuclear Power and Core Heat Flux Versus Time**

UFSAR Revision 31.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29.0
Chapter: 14
Sheet: 1 of 1



UFSAR Figure: 14.2.5-5


Unit: 2

Title: Steam Line Break DER Inside Containment with Power Core Average Temperature, RCS Pressure, and Pressurizer Water Volume Versus Time



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29.0
Chapter: 14
Sheet: 1 of 1



UFSAR Figure: 14.2.5-6

Unit: 2

Title: Steam Line Break DER Inside Containment with Power Reactivity and Core Boron Concentration Versus Time




Figure 14.2.6-1 Rod Ejection
Nuclear Power and Fuel Clad Temperature Versus Time for Hot
Full Power at Beginning of Life




Figure 14.2.6-2 Rod Ejection
Nuclear Power and Fuel and Clad Temperatures Versus Time for
Hot Zero Power at Beginning of Life





Figure 14.2.8-1 Feedline Break with Power
Nuclear Power and Core Heat Flux Versus Time

UFSAR Revision 31.0




Figure 14.2.8-2 Feedline Break with Power
Pressurizer Pressure and Pressurizer Water Volume Versus Time





Figure 14.2.8-3 Feedline Break with Power
Faulted and Non-Faulted Loop Temperatures Versus Time




Figure 14.2.8-4 Feedline Break with Power
Steam Generator Mass and Steam Generator Pressure Versus
Time




Figure 14.2.8-5 Feedline Break without Power
Nuclear Power and Core Heat Flux Versus Time

UFSAR Revision 31.0




Figure 14.2.8-6 Feedline Break without Power
Pressurizer Pressure and Pressurizer Water Volume Versus Time





Figure 14.2.8-7 Feedline Break without Power
Faulted and Non-Faulted Loop Temperatures Versus Time




Figure 14.2.8-8 Feedline Break without Power
Steam Generator Mass and Steam Generator Pressure Versus Time