

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

January 25, 2023

10 CFR 50.55a

Attn: Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Serial No.: 23-003  
NRA/GDM: R0  
Docket Nos.: 50-280/281  
License No.: DPR-32/37

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNITS 1 AND 2**  
**NOTIFICATION OF FIFTH 10-YEAR INSERVICE TESTING INTERVAL EXTENSION**

The purpose of this letter is to notify the U.S. Nuclear Regulatory Commission (NRC) that Virginia Electric and Power Company (Dominion Energy Virginia) is extending the end date for the fifth 10-year Inservice Testing (IST) interval for Surry Power Station (SPS) Units 1 and 2. The fifth 10-year IST interval for SPS is currently scheduled to end on May 9, 2024.

The SPS Units 1 and 2 IST program code of record is the American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code), 2004 Edition through 2006 addenda. Section ISTA-3120, *Inservice Test Interval*, paragraph (d), of the ASME OM Code states:

- (d) *Each of the inservice test intervals may be extended or decreased by as much as 1 year. Adjustments shall not cause successive intervals to be altered by more than 1 year from the original pattern of intervals.*

As allowed by Section ISTA-3120, paragraph (d), SPS is extending the fifth 10-year IST interval end date for Units 1 and 2 by three months to August 9, 2024, to accommodate a scheduled spring refueling outage in 2024. Based on the new interval end date for the fifth 10-year IST interval, the sixth 10-year IST interval will now begin on August 10, 2024, and end on August 9, 2034. The new 10-year IST interval beginning and end dates of August 10 and August 9, respectively, will continue going forward to avoid future refueling outage conflicts. This adjustment does not cause successive intervals to be altered by more than one year from the original pattern of intervals.

Should you have any questions, please contact Mr. Gary D. Miller at (804) 273-2771.

Respectfully,



James Holloway  
Vice President – Nuclear Engineering and Fleet Support

Commitments made in this letter: None.

cc: U.S. Nuclear Regulatory Commission, Region II  
Marquis One Tower  
245 Peachtree Center Avenue, NE  
Suite 1200  
Atlanta, Georgia 30303-1257

Mr. L. John Klos - Surry  
NRC Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 09 E-3  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. G. Edward Miller  
NRC Senior Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 09 E-3  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

NRC Senior Resident Inspector  
Surry Power Station