


N-853-1 Proposed Revision

Travis Olson, Framatome
NRC/EPRI Technical Exchange
Meeting
March 7, 2023

Purpose of N-853

- ▶ B&W and some CE NSSS primary piping contain branch connections
 - ▶ Contained in both the hot and cold legs
 - ▶ Some locations mitigated through piping replacement during SGRs
 - ▶ Locations not replaced remained susceptible to PWSCC
- ▶ Rules were needed for repair and mitigation as well as NDE
- ▶ PWROG funded a project to design and analyze a repair and mitigation approach
- ▶ Project supported technical basis for N-853 for Branch Connection Weld Metal Buildup (BCWMB)


Typical Branch Connection Configuration




Status of N-853

- ▶ N-853 was approved June 2016
 - ▶ Endorsed as Acceptable Code Case by RG 1.147 R19
- ▶ N-853-1 was approved November, 2020
 - ▶ Not yet endorsed by RG 1.147
 - ▶ Incorporated reference to N-888 or IWA-4600 for procedure qualifications of temperbead welding
- ▶ Proposed N-853-2
 - ▶ Draft presented to ASME TG-TBW and WG-W&SRP August and November 2022 meetings
 - ▶ Currently incorporating comments and feedback from meetings

Typical Branch Connection Repair Configuration




Implementation Steps



Existing Configuration

► Fabrication Examinations:

- Surface exam prior to welding
- Surface exam and UT of BCWMB (prior to hole drilling)
- Surface exam of bore & J-prep
- Progressive PT of new J-groove weld
- Bare metal visual PSI



Drill Bore & J-Prep and Install New Nozzle

Proposed Changes


▶ Technical Changes

- ▶ All technical changes are associated with UT volumetric examination requirements
 - ▶ Section 3 - Fabrication Examination
 - ▶ Figure 6 - Surface and Volumetric Acceptance Examination for BCWMB Prior to Nozzle Welding
- ▶ Intent of revision is to allow use of ASME Section XI acceptance criteria and bring N-853 into alignment with other ASME C&S
 - ▶ Distinguish volumetric exam requirements for structural versus non-structural
 - ▶ Brings into alignment with other ASME C&S:
 - ▶ Non-Mandatory Appendix Q
 - ▶ N-740-3 (Draft)
 - ▶ N-894 (Draft)

▶ Editorial

- ▶ Delete Mandatory Appendix I - should have been deleted as part of N-853-1 revision
- ▶ Minor editorial changes throughout

N-853 and N-853-1 Figure 6



Proposed N-853-2 Figure 6

Proposed Changes

▶ Section 3 - Fabrication Examination



▶ UT Qualification and Acceptance Criteria

- ▶ Current revisions require qualification to Section V and acceptance criteria of NB-5330
- ▶ Proposed revision would permit qualification to Section XI Mandatory App. VIII, Supplement 11, using IWB-3514 pre-service acceptance criteria

▶ Volumetric Examination Volume

- ▶ Current revisions require essentially 100% of the BCWMB to be volumetrically examined for planar flaws (volume A-H-J-K-C-B)
- ▶ Proposed revision would require structural portion of BCWMB (volume B-J-L-K-C-D) to be examined for planar flaws. Non-structural portion (volumes A-B-D-E and H-J-L-M) would only be examined for laminar flaws for reduction in UT coverage (not to exceed 10%) of the structural portion of the BCWMB only

N-853 and N-853-1 Figure 6



Proposed N-853-2 Figure 6

Precedence and Moving Forward

▶ Precedence

- ▶ Oconee RR RA-20-0334
 - ▶ NRC SER ML21124A170
- ▶ UT in lieu of RT CC N-831-1
- ▶ Majority of Section XI design specific ambient temperature temperbead code cases utilize Section XI qualifications and acceptance criteria

▶ Moving Forward

- ▶ Incorporate comments to draft N-853-2
 - ▶ Present to May TG-TBW, WG-W&SRP, SG-RRA
 - ▶ August/November - WG-PQ&VE, SG-NDE
- ▶ Support technical basis for N-888 revision
 - ▶ ASME Record 22-954, Revise N-888 to allow Section XI acceptance criteria
 - ▶ Establish position on subsequent UT monitoring of flaws