

PRIMARY COOLANT FISSION AND CORROSION PRODUCT ACTIVITIES

| <u>Isotope</u> | Design Activity (1% Failed Fuel) (Microcuries/ Cubic Centimeter) | Design Inventory (Curies) |
|----------------|---|------------------------------|
| H-3 | 2.80 | 860 |
| Br-84 | 4.66×10^{-2} | 13.4 |
| Kr-85(m) | 1.50 | 432 |
| Kr-85 | 2.34 | 674 |
| Kr-87 | 0.81 | 233 |
| Kr-88 | 2.48 | 714 |
| Rb-88 | 2.44 | 702 |
| Rb-89 | 6.10×10^{-2} | 0.18 |
| Sr-89 | 5.33×10^{-3} | 1.53 |
| Sr-90 | 1.50×10^{-4} | 4.3×10^{-2} |
| Y-90 | 5.77×10^{-4} | 0.17 |
| Sr-91 | 3.70×10^{-3} | 1.06 |
| Y-91(m) | 0.24 | 68.4 |
| Mo-99 | 2.26 | 649 |
| Te-129 | 2.72×10^{-2} | 7.84 |
| I-129 | 5.66×10^{-8} | 1.63×10^{-5} |
| I-131 | 4.40 | 1,266 |
| Te-132 | 0.36 | 102 |

PRIMARY COOLANT FISSION AND CORROSION PRODUCT ACTIVITIES

| <u>Isotope</u> | <u>Design Activity (1% Failed Fuel) (Microcuries/ Cubic Centimeter)</u> | <u>Design Inventory (Curies)</u> |
|----------------|---|--------------------------------------|
| I-132 | 1.13 | 324 |
| I-133 | 6.38 | 1,830 |
| Xe-133 | 255 | 6.47×10^4 |
| Cs-134 | 1.42 | 725 |
| Te-134 | 2.63×10^{-2} | 7.55 |
| I-134 | 0.64 | 184 |
| I-135 | 2.78 | 801 |
| Xe-135 | 6.75 | 1,943 |
| Cs-136 | 0.15 | 43.4 |
| Cs-137 | 10.6 | 3,064 |
| Xe-138 | 0.36 | 103 |
| Cs-138 | 0.69 | 198 |
| Ba-140 | 6.78×10^{-3} | 1.95 |
| La-140 | 6.52×10^{-3} | 1.88 |
| Co-60 | 1.1×10^{-3} | 0.37 |
| Fe-59 | 7.7×10^{-6} | 2.6×10^{-3} |
| Co-58 | 7.9×10^{-3} | 2.67 |
| Mn-56 | 2.3×10^{-2} | 7.77 |

PRIMARY COOLANT FISSION AND CORROSION PRODUCT ACTIVITIES

| <u>Isotope</u> | Design Activity (1% Failed Fuel) (Microcuries/ <u>Cubic Centimeter</u>) | Design Inventory <u>(Curies)</u> |
|----------------|---|--|
| Mn-54 | 2.0×10^{-5} | 6.8×10^{-3} |
| Cr-51 | 2.4×10^{-3} | 0.81 |
| Zr-95 | <u>1.9×10^{-5}</u> | <u>6.4×10^{-3}</u> |
| Total | 275.7 | 79,663 |

RADIOACTIVE WASTE QUANTITIES OF SIGNIFICANT ACTIVITY

| <u>Liquid Waste Sources</u> | <u>Gallons</u> | <u>Assumptions</u> |
|--|----------------|--|
| Chemical and Volume Control System | 2,200 | Cold shutdown Day 240 |
| Primary System Drain Tank | 64,900 | Drain primary system for maintenance at Day 240 |
| Equipment Drain Tank | 7,000 | Spent fuel pool overflow |
| | 3,900 | Spent resin tank overflow from resin flushing - 260 ft ³ /year of resin replacement at 2 ft ³ /ft ³ resin |
| | 1,900 | Demineralizers drain from resin charging - 260 ft ³ /year of resin replacement at 1 ft ³ /ft ³ resin |
| Total | <u>12,800</u> | |
| Radiochemistry Lab Drain Tank | 11,000 | 12 samples per day at 2.5 gallons per sample |
| Total Liquid Waste of Significant Activity | <u>90,900</u> | |

| <u>Gaseous Waste Sources</u> | <u>Quantity/Year-ft³</u> | <u>Assumptions</u> |
|--|-------------------------------------|--------------------|
| Off-Gas Liquid Drained for Maintenance and Miscellaneous | 243 | |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

1. CLEAN WASTE RECEIVER TANKS (T-64A, B, C, D)

| | |
|--------------------|-------------------------------------|
| Number | 4 |
| Material | Type 304 Stainless Steel |
| Capacity (Each) | 50,000 gal (7,000 ft ³) |
| Design Pressure | 5 psig (Vapor Space) |
| Design Temperature | 103°F |
| Code | API 620 |

2. PRIMARY SYSTEM DRAIN TANK (T-74)

| | |
|--------------------|---|
| Number | 1 |
| Material | Type 304 Stainless Steel |
| Capacity | 900 gal |
| Design Pressure | 50 psig |
| Design Temperature | 250°F |
| Code | ASME B&PV Code, Section III, Class C |

3. EQUIPMENT DRAIN TANK (T-80)

| | |
|--------------------|------------------------------|
| Number | 1 |
| Material | Type 304 Stainless Steel |
| Capacity | 550 gal |
| Design Pressure | 50 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section VIII |

4. SPENT RESIN STORAGE TANK (T-69)

| | |
|--------------------|---|
| Number | 1 |
| Material | Type 304 Stainless Steel |
| Capacity | 3,000 gal (400 ft ³) |
| Design Pressure | 125 psig |
| Design Temperature | 200°F |
| Code | ASME B&PV Code, Section III, Class C |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

5. CONTROLLED CHEM LAB DRAIN TANK (T-76)

| | |
|--------------------|-------------------------------|
| Number | 1 Divided Into 2 Compartments |
| Material | Type 304 Stainless Steel |
| Capacity | 900 gal (Total) |
| Design Pressure | 50 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section VII |

6. TREATED WASTE MONITOR TANKS (T-66A, B)

| | |
|--------------------|------------------------------|
| Number | 2 |
| Material | Carbon Steel |
| Internal Coating | Baked Phenolic, 6-8 Mils |
| Capacity | 5,500 gal |
| Design Pressure | 10 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section VIII |

7. DIRTY WASTE DRAIN TANK (T-60)

| | |
|--------------------|--|
| Number | 1 Divided Into 2 Compartments |
| Material | Carbon Steel |
| Capacity | 3,800 gal |
| Design Pressure | 10 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section VIII Requirements |

8. FILTERED WATER MONITORING TANKS (T-63)

| | |
|--------------------|------------------------------|
| Number | 1 With 2 Compartments |
| Material | Carbon Steel |
| Internal Coating | Baked Phenolic, 6-8 Mils |
| Capacity | 5,500 gal |
| Design Pressure | 10 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section VIII |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

9. WASTE GAS SURGE TANK (T-67)

| | |
|--------------------|---|
| Number | 1 |
| Material | Carbon Steel |
| Capacity | 550 gal (80 ft ³) |
| Design Pressure | 20 psig |
| Design Temperature | 150°F |
| Code | ASME B&PV Code, Section III, Class C |

10. WASTE GAS DECAY TANKS (T-68A, B, C)

| | |
|--------------------|---|
| Number | 3 |
| Material | Carbon Steel |
| Capacity | 800 gal (100 ft ³) |
| Design Pressure | 120 psig |
| Design Temperature | 550°F |
| Code | ASME B&PV Code, Section III, Class C |

11. LAUNDRY DRAIN TANK (T-70)

| | |
|--------------------|-------------------------------|
| Number | 1 Divided Into 2 Compartments |
| Material | Carbon Steel |
| Capacity | 1,000 gal (Total) |
| Design Pressure | 15 psig |
| Design Temperature | 150°F |
| Code | ASME P&PV Code, Section VIII |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

12. VACUUM DEGASIFIER

a. Tank (T-57)

| | |
|--------------------|--|
| Number | 1 |
| Performance | Handle Solution With 0-50 Std cm ³ H ₂ (kg of Liquid Waste. Reduced H ₂ Concentration to 1/40 of Influent Concentration) |
| Design Flow | 0-160 gpm |
| Design Pressure | 75 psig & 30" Hg |
| Design Temperature | 200°F |
| Material | Stainless steel |
| Code | ASME B&PV Code, Section III, Class C |

b. Vacuum Pumps (C-51A, B)

| | |
|----------|--|
| Number | 2 |
| Capacity | 28 scfm @ 28" Hg |
| Type | Rotary, Water-Sealed, Water-Lubricated with Closed Cooling Loop |
| Motor | 3 hp |
| Material | Stainless steel |

13. RADWASTE DEMINERALIZER

a. Demineralizer Tanks (T-55A, B, C)

| | |
|-----------------------------|--|
| Number | 3 |
| Material of Tank | Stainless Steel |
| Flow Rate (Each) | 48 gpm (Rated), 100 gpm (Max) |
| Unit Flow Rate (at Ratings) | 5.0 gpm/ft ² |
| Resin Volume (Each) | 32 ft ³ |
| Resin Type | Equivalent Capacity Mixture of Nuclear Grade Cation and Anion |
| Design Pressure | 125 psig |
| Design Temperature | 160°F |
| Code | ASME B&PV Code, Section III, Class C and ASME B&PV Code, Section VIII, Para UW-2 (a) |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

b. Clean Resin Transfer Tank (T-61)

| | |
|--------------------|------------------------------|
| Number | 1 |
| Material | PVC Lined Carbon Steel |
| Capacity | 32 ft ³ |
| Design Pressure | 125 psig |
| Design Temperature | 125°F |
| Code | ASME B&PV Code, Section VIII |

14. CLEAN WASTE FILTERS (F-57A, B, C)

| | |
|------------------------|--|
| Type | Cartridge Type With Replaceable Elements |
| Number | 3 |
| Material, Container | Stainless Steel |
| Material, Filter Media | Polypropylene |
| Filter Media Rating | 150 Micron |
| Flow Rate | 100 gpm |
| Design Pressure | 125 psig |
| Design Temperature | 160°F |
| Code | ASME B&PV Code, Section III, Class C and ASME B&PV Code, Section VIII, Para UW-2 (a) |

15. EQUIPMENT DRAIN FILTER (F-56)

| | |
|------------------------|--|
| Number | Cartridge Type with Replaceable Elements |
| Material, Container | Stainless Steel |
| Material, Filter Media | Polypropylene |
| Filter Media Rating | 25 Microns |
| Design Pressure | 125 psig |
| Design Temperature | 212°F |
| Code | ASME B&PV Code, Section III, Class C and ASME B&PV Code, Section VIII, Para UW-2 (a) |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

16. DIRTY WASTE FILTER (F-53)

| | |
|------------------------|--|
| Type | Cartridge Type With Replaceable Elements |
| Number | 1 |
| Material, Container | Stainless Steel |
| Material, Filter Media | Polypropylene |
| Filter Media Rating | 200 Microns |
| Flow Rate | 75 gpm |
| Design Pressure | 100 psig |
| Design Temperature | 160°F |
| Code | ASME B&PV Code, Section III, Class C and ASME B&PV Code, Section VIII, Para UW-2 (a) |

17. LAUNDRY DRAIN FILTER (F-55)

| | |
|------------------------|--|
| Type | Cartridge Type With Replaceable Elements |
| Number | 1 |
| Material, Container | Stainless Steel |
| Material, Filter Media | Polypropylene |
| Filter Media Rating | 25 Microns |
| Flow Rate | 20 gpm |
| Design Pressure | 100 psig |
| Design Temperature | 160°F |
| Code | ASME B&PV Code, Section III, Class C and ASME B&PV Code, Section VIII, Para UW-2 (a) |

18. PRIMARY SYSTEM DRAIN TANKS PUMPS (T-71A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 75 gpm |
| Head | 80 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 5 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

19. DEGASIFIER PUMPS (P-68A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 160 gpm |
| Head | 190 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 20 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

20. EQUIPMENT DRAIN TANK PUMPS (P-75A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 100 gpm |
| Head | 266 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 25 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

21. CONTROLLED CHEM LAB DRAIN PUMPS (P-61A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 10 gpm |
| Head | 158 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 7.5 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

22. RECEIVER TANK (CWRT) PUMPS (P-69A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 100 gpm |
| Head | 200 ft TDH |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

| | |
|--|--|
| Material | Type 316 Stainless Steel |
| Motor | 15 hp, 3 Phase, 60 Hertz, 460 Volt |
| 23. RECEIVER TANK (CWRT) CIRCULATING PUMP (P-70) | |
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 1 |
| Capacity (Each) | 250 gpm |
| Head | 121 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 15 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |
| 24. TREATED WASTE MONITOR PUMPS (P-58A, B) | |
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 150 gpm |
| Head | 140 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 15 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |
| 25. SAFETY INJECTION ROOM SUMP PUMPS (P-72A, B AND P-73A, B) | |
| Type | Vertical Centrifugal |
| Number | 4 (2 Sets With 2 Pumps per Set) |
| Capacity (Each) | 25 gpm |
| Head | 35 ft TDH |
| Material | Stainless Steel |
| Motor | 1 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA, |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

26. DIRTY WASTE DRAIN TANK PUMPS (P-60A, B)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 2 |
| Capacity (Each) | 75 gpm |
| Head | 160 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 10 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

FILTERED WASTE MONITOR PUMP (P-63)

| | |
|-----------------|--|
| Type | Horizontal Centrifugal With Mechanical Seals |
| Number | 1 |
| Capacity (Each) | 75 gpm |
| Head | 150 ft TDH |
| Material | Type 316 Stainless Steel |
| Motor | 10 hp, 3 Phase, 60 Hertz, 460 Volt |
| Codes | Motor NEMA; Pump, Standards of Hydraulic Institute |

28. WASTE GAS COMPRESSORS (C-50A, B)

a. Compressor

| | |
|--------------------|---|
| Number | 2 |
| Type | Single Head, Single Stage Diaphragm Type |
| Capacity (Each) | 2.35 scfm at 14.7 psia Suction, 0.44 scfm at 7.5 psia Suction |
| Discharge Pressure | 100 psig at Maximum Delivery |
| Material | Stainless Steel |
| Motor | 2 hp, 3 Phase, 60 Hertz, 460 Volt, TEFC |

b. Aftercoolers

| | |
|----------|---|
| Number | 2 |
| Type | Shell and Tube With Moisture Separator and Drain Trap |
| Material | Tube Side (Gas) Stainless Steel, Shell |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

Side (Water) Carbon Steel

29. WASTE GAS COMPRESSOR (C-54)

a. Compressor

| | |
|--------------------|--|
| Number | 1 |
| Type | Diaphragm Type |
| Capacity (Each) | 5 scfm Avg Between Suction Pressures of 7.5 and 15.0 psia |
| Discharge Pressure | 100 psig |
| Material | |
| Motor | 7.5 |

b. Aftercoolers

| | |
|--------|---|
| Number | 1 |
|--------|---|

30. PIPING, FITTING AND VALVES

a. Liquid Systems

| | |
|-----------------------|--|
| Material | Stainless Steel |
| Design Pressure | Floor Drains - Atmosphere, Process - 50 psig |
| Joints, 2" and Larger | Butt Weld |
| 1-1/2" and Smaller | 2,000 lb SW |
| Valves, 2" and Larger | Stainless Steel, Butt Weld Ends, 150 lb |
| 1-1/2" and Smaller | Stainless Steel, 2,000 lb SW Ends, 150 lb |
| Butterfly Valves | Stainless Steel, Flangeless, 150 lb |
| Plug Vales | Stainless steel, FF Flanged, 150 lb |
| Code | ASA B31.1, Code for Pressure Piping, Including Applicable Nuclear Code Cases, ASA B16.5 |
| Radiography | All Butt Weld in Nuclear Service Systems Rated for Higher Than 50 psig and 212°F Are Radiographed 100. All Butt Welds in Nuclear Systems Rated for Less Than 50 psig and 212°F Are Radiographed 10% |

EQUIPMENT RATINGS AND CONSTRUCTION CODES - ORIGINAL EQUIPMENT

b. Gaseous Systems

| | |
|-----------------------|---|
| Material | Carbon Steel |
| Design Pressure | 100 psig |
| Joints, 2" and Larger | Butt Weld |
| 1-1/2" and Smaller | 3,000 lb SW |
| Valves, 2" and Larger | Carbon Steel, 150 lb BW |
| 1-1/2" and Smaller | Carbon Steel, 600 lb, 3,000 lb SW |
| Butterfly | Carbon Steel, 150 lb, FF Flanged |
| Plug | Ductile Iron, 150 lb, FF Flanged |
| Code | ASA B31.1, Code for Pressure Piping, Including Applicable Nuclear Code Cases, ASA B16.5 |
| Radiography | All Welds Are 100% Radiographed |

**EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973**

1. CLEAN WASTE HOLDUP TANK (T-85)

| | |
|--------------------|---|
| Number | 1 |
| Material of Tank | SA240 Type 304 SS |
| Capacity | 5,000 gal |
| Design Pressure | Atm |
| Design Temperature | 212°F |
| Code | API-620, 1970 Exam ASME B&PV Code, Section III, 1971 |

2. CLEAN WASTE TRANSFER PUMP (P-94)

| | |
|----------|--|
| Type | Gould 3196 |
| Number | 1 |
| Capacity | 80 gpm |
| Head | 85 ft |
| Material | Stainless Steel |
| Motor | 5 hp |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

3. CLEAN AND DIRTY WASTE EVAPORATORS (M-59A, B)

a. Evaporator Vessel

| | |
|--------------------|--|
| Number | 2 |
| Material | 316 SS |
| Capacity | 1,600 gal |
| Design Pressure | 15 psig |
| Design Temperature | 200°F |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

b. Recirculation Pump

| | |
|----------|--|
| Type | Gould 3196 - 3 x 4-13 |
| Number | 4 |
| Capacity | 200 gpm |
| Head | 30 ft |
| Material | 316 SS |
| Motor | 5 hp, 3 Phase, 60 Hertz, 460 Volt |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

**EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973**

c. Distillate Pump

| | |
|----------|--|
| Type | Gould 3196 - 1 x 1-1/2-6 |
| Number | 4 |
| Capacity | 25 gpm |
| Head | 130 ft |
| Material | 316 SS |
| Motor | 5 hp |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

d. Concentrate Pump

| | |
|----------|--|
| Type | Gould 3196 - 1 x 1-1/2-6 |
| Number | 4 |
| Capacity | 25 gpm |
| Head | 100 ft |
| Material | 316 SS |
| Motor | 3 hp |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

e. Vacuum Pump

| | |
|----------|---------------------|
| Type | Nash |
| Number | 4 |
| Capacity | 48 cfm @ 20" vacuum |
| Head | 2 psig |
| Material | 316 SS |
| Motor | 3 hp |
| Code | N/A |

4. CLEAN WASTE DISTILLATE TANK (T-86)

| | |
|--------------------|---|
| Number | 1 |
| Material | SA240 Type 304 SS |
| Capacity | 5,000 gal |
| Design Pressure | Atm |
| Design Temperature | 212°F |
| Code | API-650, 1970 Exam ASME B&PV Code, Section III, 1971 |

EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973

5. CLEAN WASTE DISTILLATE PUMP (P-97A, B)

| | |
|----------|--|
| Type | Gould 3196 |
| Number | 2 |
| Capacity | 80 gpm |
| Head | 85 ft |
| Material | 316 SS |
| Motor | 5 hp - Pacemaker |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

6. CLEAN (MISCELLANEOUS) WASTE CONCENTRATE TANKS (T-94, T-95)

| | |
|--------------------|---|
| Number | 2 |
| Material | SA240 Type 304 SS |
| Capacity | 1,500 gal |
| Design Pressure | Atm |
| Design Temperature | 212°F |
| Code | API-650, 1970 Exam ASME B&PV Code, Section III, 1971 |

7. MISCELLANEOUS WASTE FILTER (F-59)

| | |
|------------------------|--|
| Type | Cartridge Type With Replaceable Elements |
| Number | 1 |
| Material, Container | 304 SS |
| Material, Filter Media | Epoxy Impregnated Cellulose |
| Filter Media Rating | 150 Micron* |
| Flow Rate | 30 gpm |
| Design Pressure | 50 psig |
| Design Temperature | 212°F |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

*May be in service with element removed.

8. CLEAN (MISCELLANEOUS) WASTE CONCENTRATE PUMPS (P-95A, B)

| | |
|----------|--|
| Type | Gould 3196, 1 x 2-8 |
| Number | 2 |
| Capacity | 30 gpm |
| Head | 75 ft |
| Material | 316 SS |
| Motor | 3 hp - Pacemaker |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973

9. POLISHING (MISCELLANEOUS WASTE) DEMINERALIZERS (T-88, T-89A, B)

| | |
|-------------------------|--|
| Number | 3 |
| Material of Tank | 304 SS |
| Flow Rate | 50 gpm (Rated), 100 gpm (Max) |
| Unit Flow Rate (At Max) | 10 gpm/ft ² |
| Resin Volume | 32 ft ³ |
| Resin Type | Equivalent Capacity Mixture of Nuclear Grade Cation and Anion |

10. MISCELLANEOUS WASTE HOLDUP TANKS (T-92A, B, C)

| | |
|--------------------|---|
| Number | 3 |
| Material | SA240 Type 304 SS |
| Capacity | 20,000 gal |
| Design Pressure | Atm |
| Design Temperature | 212°F |
| Code | API-620, 1970 Exam ASME B&PV Code, Section III, 1971 |

11. MISCELLANEOUS WASTE TRANSFER PUMPS (P-92A, B)

| | |
|----------|--|
| Type | Gould 3196, 2 x 3-13 |
| Number | 2 |
| Capacity | 80 gpm |
| Head | 120 ft |
| Material | 316 SS |
| Motor | 10 hp - Pacemaker |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

12. MISCELLANEOUS WASTE DISTILLATE TANK (T-87)

| | |
|--------------------|---|
| Number | 1 |
| Material | SA240 Type 304 SS |
| Capacity | 8,000 gal |
| Design Pressure | Atm |
| Design Temperature | 212°F |
| Code | API-650, 1970 Exam ASME B&PV Code, Section III, 1971 |

EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973

13. MISCELLANEOUS WASTE DISTILLATE PUMPS (P-89A, B)

| | |
|----------|--|
| Type | Gould 3196, 1-1/2 x 3-6 |
| Number | 2 |
| Material | 316 SS |
| Capacity | 80 gpm |
| Head | 110 ft |
| Motor | 7-1/2 hp - Pacemaker |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

14. RADWASTE SPENT RESIN STORAGE TANK (T-100)

| | |
|--------------------|--|
| Number | 1 |
| Material | 304 SS |
| Capacity | 200 ft ³ |
| Design Pressure | 125 psig |
| Design Temperature | 200°F |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

15. WASTE GAS DECAY TANKS (T-101A, B, C)

| | |
|--------------------|--|
| Number | 3 |
| Material | Carbon Steel |
| Capacity | 225 ft ³ |
| Design Pressure | 120 psig |
| Design Temperature | 550°F |
| Code | ASME B&PV Code, Section III, Class 3, 1971 |

**EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973**

16. PIPING, FITTINGS AND VALVES

a. Liquid Radwaste System (Process)

| | |
|--------------------|---|
| Material | Stainless Steel |
| Design Pressure | 125 psig and 150 psig |
| Fittings | |
| 2-1/2" and Larger | 150 lb Thickness To Match Pipe Butt Weld Ends |
| 2-1/2" and Smaller | 3,000 lb Socket Weld |
| Valves | |
| 2-1/2" and Larger | 150 lb Butt Weld Ends |
| 2" and Smaller | 150 lb Socket Weld Ends |
| Joints | |
| 2-1/2" and Larger | Butt Weld Ends |
| 2" and Smaller | Socket Weld Ends |
| Code | ASME B&PV Code, Section III, Nuclear Power Plant Components, Nuclear Class 3, 1971, per AEC Safety Guide 26, March 27, 1972 |

b. Atmospheric Radwaste Drainage Piping

| | |
|-----------------|----------------------------------|
| Material | Stainless Steel |
| Design Pressure | Atmospheric |
| Fittings | |
| 8" and Smaller | Butt Weld Ends |
| Joints | |
| 8" and Smaller | Butt Weld |
| Code | ANSI B31.1.0 - 1967 Power Piping |

c. Gaseous Radwaste System (Process)

| | |
|-------------------|---|
| Material | Carbon Steel |
| Design Pressure | 150 psig |
| Fittings | |
| 2-1/2" and Larger | 150 lb Thickness To Match Pipe Butt Weld Ends |
| 2" and Smaller | 3,000 lb Socket Weld Ends |
| Valves | |
| 2-1/2" and Larger | 150 lb Butt Weld Ends |
| 2" and Smaller | 600 lb Socket Weld Ends |
| Joints | |
| 2-1/2" and Larger | Butt Weld Ends |
| 2" and Smaller | Socket Weld |
| Code | ASME B&PV Code, Section III, Nuclear Power Plant Components, Nuclear Class 3, 1971, per AEC Safety Guide 26, March 23, 1972 |

**EQUIPMENT RATINGS AND CONSTRUCTION CODES -
ADDITIONAL EQUIPMENT INSTALLED 1971-1973**

17. PRIMARY SYSTEM MAKEUP STORAGE TANK (T-90)

| | |
|-----------------|---------------|
| Number | 1 |
| Material | Carbon Steel |
| Capacity | 200,000 gal |
| Design Pressure | Atmospheric |
| Code | API-650, 1970 |

18. UTILITY WATER STORAGE TANK (T-91)

| | |
|-----------------|---------------|
| Number | 1 |
| Material | Carbon Steel |
| Capacity | 75,000 gal |
| Design Pressure | Atmospheric |
| Code | API-650, 1970 |

PRIMARY SYSTEM DRAIN TANK

Letdown and Regenerative HX Drain
Shutdown Cooling Header Relief
SI Tanks Leakage
PCS Loop Drains
Quench Tank Drains
Flange Leak Detector Drain
Controlled Bleed-Off Relief
PCS Pump Seal Leakage *PCS Pump Seal Leakage can be
aligned to Primary System Drain Tank, but normal system
alignment is to containment sump

EQUIPMENT DRAIN TANK

Spent Resin Storage Tanks
Primary Coolant Sample Drain
Clean Resin Transfer Tank
Radwaste Demineralizer Drains
Fuel Pool Overflow
Fuel Pool HX Drains
Fuel Pool Demineralizer Drains
Fuel Pool Filter Drains
Blowdown Drain Tank
HPI Header Relief
SIRW Tank Overflow Drain
SIRW Tank HX Drain
SI Tank Sample Flush
Waste Gas Surge Tank Drain
Chemical Addition Tank Drain
Charging Pump Relief and Drains
VCT Drain
Purification Filters Drain

DIRTY WASTE DRAIN TANK

Radwaste Addition Area Sample Sink Drains
Clean Resin Transfer Tank Drains
Pump Leak-Offs
Auxiliary Building Floor Drains
Decontamination Pit Drains
Cask Washdown Area Drains
Controlled Chemical Laboratory Drain Tank Drains
Component Cooling Surge Tank Drain
Boric Acid Batching Tank Drain
Boric Acid Filter Drains
Treated Waste Monitor Tanks
VCT Relief
Vacuum Degasifier Relief
Turbine Building Sump Pump Discharge
Containment Sump Drains
Shutdown Cooling HX Drains
Spent Resin Storage Tank (T-100)
Primary System Makeup and Utility Water Tanks Overflow
Laundry Drain Tank Drains
Auxiliary Building Sump Pumps

LIQUID RADWASTE

| | | Clean Liquid Waste Activities (μCi/cm ³)* | | | | | Dirty Liquid Waste Activities (μCi/cm ³)* | | |
|--------------------|-----------------------------|---|-------------------------|--|--|--|---|--|--------------------------------|
| Isotope | Half-Life Demineralizers | As Received in Receiver Tanks | After 30 Days' Decay | After Processing Through Two Demineralizers | After Processing Through Evaporator | After Processing Through Polishing Demineralizer | As Received in Drain Tank | After Processing Through Evaporator | After Processing Through |
| Fission Products | | | | | | | | | |
| Br-84 | 32m | 1.25 x 10 ⁻² | (a) | (a) | (a) | (a) | 4.66 x 10 ⁻⁴ | 4.66 x 10 ⁻⁸ | (a) |
| Rb-88 | 18m | 6.61 x 10 ⁻¹ | (a) | (a) | (a) | (a) | 2.44 x 10 ⁻² | 2.44 x 10 ⁻⁶ | 2.44 x 10 ⁻⁸ |
| Rb-89 | 15m | 1.66 x 10 ⁻² | (a) | (a) | (a) | (a) | 6.10 x 10 ⁻⁴ | 6.10 x 10 ⁻⁸ | (a) |
| SR-89 | 54d | 1.44 x 10 ⁻³ | 9.80 x 10 ⁻⁴ | 9.80 x 10 ⁻⁶ | (a) | (a) | 5.33 x 10 ⁻⁵ | (a) | (a) |
| Sr-90 | 28y | 4.00 x 10 ⁻⁵ | 4.00 x 10 ⁻⁵ | 4.00 x 10 ⁻⁷ | (a) | (a) | 1.50 x 10 ⁻⁶ | (a) | (a) |
| Y-90 | 64h | 1.55 x 10 ⁻⁴ | 6.51 x 10 ⁻⁸ | (a) | (a) | (a) | 5.77 x 10 ⁻⁶ | (a) | (a) |
| Sr-91 | 9.7h | 1.00 x 10 ⁻³ | (a) | (a) | (a) | (a) | 3.70 x 10 ⁻⁵ | (a) | (a) |
| Y-91 | 58d | 6.50 x 10 ⁻² | 4.53 x 10 ⁻² | 4.53 x 10 ⁻⁴ | 4.53 x 10 ⁻⁸ | (a) | 2.40 x 10 ⁻³ | 2.40 x 10 ⁻⁷ | (a) |
| Mo-99 | 67h | 6.12 x 10 ⁻¹ | 3.67 x 10 ⁻⁴ | 3.67 x 10 ⁻⁶ | (a) | (a) | 2.26 x 10 ⁻² | 2.26 x 10 ⁻⁶ | 2.26 x 10 ⁻⁸ |
| Te-129 | 33d | 7.36 x 10 ⁻³ | 3.93 x 10 ⁻³ | 3.93 x 10 ⁻⁵ | (a) | (a) | 2.72 x 10 ⁻⁴ | 2.72 x 10 ⁻⁸ | (a) |
| I-129 | 1.7 x 10 ⁷ y | 1.52 x 10 ⁻⁸ | 1.52 x 10 ⁻⁸ | (a) | (a) | (a) | (a) | (a) | (a) |
| I-131 | 8.0d | 1.18 | 8.87 x 10 ⁻² | 8.87 x 10 ⁻⁴ | 8.87 x 10 ⁻⁷ | 8.87 x 10 ⁻⁸ | 4.40 x 10 ⁻² | 4.40 x 10 ⁻⁵ | 4.40 x 10 ⁻⁷ |
| Te-132 | 77h | 9.75 x 10 ⁻² | 1.46 x 10 ⁻⁴ | 1.46 x 10 ⁻⁶ | (a) | (a) | 3.60 x 10 ⁻³ | 3.60 x 10 ⁻⁷ | (a) |
| I-132 | 2.3h | 3.05 x 10 ⁻¹ | (a) | (a) | (a) | (a) | 1.13 x 10 ⁻² | 1.13 x 10 ⁻⁵ | 1.13 x 10 ⁻⁷ |
| I-133 | 21h | 1.73 | (a) | (a) | (a) | (a) | 6.38 x 10 ⁻² | 6.38 x 10 ⁻⁵ | 6.38 x 10 ⁻⁷ |
| Cs-134 | 2.3y | 3.84 x 10 ⁻¹ | 3.78 x 10 ⁻¹ | 3.70 x 10 ⁻³ | 3.78 x 10 ⁻⁷ | 3.78 x 10 ⁻⁸ | 1.42 x 10 ⁻² | 1.42 x 10 ⁻⁶ | 1.42 x 10 ⁻⁸ |
| Te-134 | 44m | 7.12 x 10 ⁻³ | (a) | (a) | (a) | (a) | 2.63 x 10 ⁻⁴ | 2.63 x 10 ⁻⁸ | (a) |
| I-134 | 52m | 1.73 x 10 ⁻¹ | (a) | (a) | (a) | (a) | 6.40 x 10 ⁻³ | 6.40 x 10 ⁻⁵ | 6.40 x 10 ⁻⁷ |
| I-135 | 6.7h | 7.53 x 10 ⁻¹ | (a) | (a) | (a) | (a) | 2.78 x 10 ⁻² | 2.78 x 10 ⁻⁶ | 2.78 x 10 ⁻⁸ |
| Cs-136 | 13d | 4.06 x 10 ⁻² | 8.20 x 10 ⁻³ | 8.20 x 10 ⁻⁵ | (a) | (a) | 1.50 x 10 ⁻³ | 1.50 x 10 ⁻⁷ | (a) |
| Cs-137 | 30y | 2.87 | 2.87 | 2.87 x 10 ⁻² | 2.87 x 10 ⁻⁶ | 2.87 x 10 ⁻⁷ | 1.06 x 10 ⁻¹ | 1.06 x 10 ⁻⁵ | 1.06 x 10 ⁻⁷ |
| Cs-138 | 32m | 1.87 x 10 ⁻¹ | (a) | (a) | (a) | (a) | 6.90 x 10 ⁻³ | 6.90 x 10 ⁻⁷ | (a) |
| Ba-140 | 12.8d | 1.84 x 10 ⁻³ | 3.65 x 10 ⁻⁴ | 3.65 x 10 ⁻⁶ | (a) | (a) | 6.78 x 10 ⁻⁵ | (a) | (a) |
| La-140 | 40.2h | 1.27 x 10 ⁻³ | (a) | (a) | (a) | (a) | 6.52 x 10 ⁻⁵ | (a) | (a) |
| Corrosion Products | | | | | | | | | |
| Cr-51 | 27d | 6.50 x 10 ⁻⁴ | 3.02 x 10 ⁻⁴ | 3.02 x 10 ⁻⁶ | (a) | (a) | 2.4 x 10 ⁻⁵ | (a) | (a) |
| Mn-54 | 300d | 5.22 x 10 ⁻⁶ | 4.87 x 10 ⁻⁶ | 4.87 x 10 ⁻⁸ | (a) | (a) | 2.0 x 10 ⁻⁷ | (a) | (a) |
| Mn-56 | 2.58h | 6.00 x 10 ⁻³ | (a) | (a) | (a) | (a) | 2.3 x 10 ⁻⁴ | 2.3 x 10 ⁻⁸ | (a) |
| Co-58 | 71d | 2.07 x 10 ⁻³ | 1.55 x 10 ⁻³ | 1.55 x 10 ⁻⁵ | (a) | (a) | 7.9 x 10 ⁻⁵ | (a) | (a) |
| Fe-59 | 45d | 2.02 x 10 ⁻⁶ | 1.27 x 10 ⁻⁶ | 1.27 x 10 ⁻⁸ | (a) | (a) | 7.7 x 10 ⁻⁸ | (a) | (a) |
| Co-60 | 5.2y | 2.98 x 10 ⁻⁴ | 2.95 x 10 ⁻⁴ | 2.95 x 10 ⁻⁶ | (a) | (a) | 1.1 x 10 ⁻⁵ | (a) | (a) |
| Zr-95 | 65d | 4.96 x 10 ⁻⁶ | 3.61 x 10 ⁻⁶ | 3.61 x 10 ⁻⁸ | (a) | (a) | 1.9 x 10 ⁻⁷ | (a) | (a) |

(a) Less Than 10^{-8}

LIQUID RADWASTE

Assumptions:

Factor of 10 reduction in each demineralizer for all isotopes except tritium.

10^3 reduction for iodine in evaporator.

10^4 reduction for all other isotopes except tritium.

19% of clean waste is direct from primary system.

81% of clean waste is from Chemical and Volume J Control System and passes through one ion exchanger prior to entering clean waste receiver tanks.

No holdup period assumed in Miscellaneous Waste Holdup Tank.

1% defective fuel.

Dirty waste activity is 1% of primary coolant activity.

*The above information pertaining to isotopic activities are based on decontamination factors (DF) which were provided as part of the initial safety analysis or added as changes to the systems were made. Operating experience has demonstrated that the reactor coolant activity levels are much lower than the activity levels assumed in the radwaste system design. The ODCM provides information pertaining to the monitoring of waste streams and ensures the resultant offsite doses are in compliance with current regulatory requirements. The above information is considered historical.

**MAXIMUM CALCULATED TRITIUM RELEASE DUE TO EVAPORATION
FROM REFUELING CAVITY AND SPENT FUEL POOL**

| <u>Yr of Oper</u> | <u>Conc in Contain Bldg (Ci/cm³)</u> | <u>Release From Contain Bldg (Ci/Yr)</u> | <u>Conc in Spent Fuel Bldg (Ci/cm³)</u> | <u>Release From Spent Fuel Bldg (Ci/Yr)</u> | <u>Total Release (Ci/Yr)</u> |
|-----------------------|---|--|--|---|--------------------------------------|
| 5 | 1.1 x 10 ⁻¹³ | 18 | 8.5 x 10 ⁻¹⁴ | 13 | 31 |
| 10 | 2.1 x 10 ⁻¹³ | 35 | 2.2 x 10 ⁻¹³ | 33 | 68 |
| 15 | 3.0 x 10 ⁻¹³ | 50 | 3.6 x 10 ⁻¹³ | 53 | 103 |
| 20 | 3.8 x 10 ⁻¹³ | 63 | 4.9 x 10 ⁻¹³ | 72 | 135 |
| 25 | 4.5 x 10 ⁻¹³ | 75 | 6.1 x 10 ⁻¹³ | 90 | 165 |
| 30 | 5.1 x 10 ⁻¹³ | 85 | 7.1 x 10 ⁻¹³ | 105 | 190 |
| 35 | 5.6 x 10 ⁻¹³ | 93 | 8.0 x 10 ⁻¹³ | 118 | 211 |
| 40 | 6.0 x 10 ⁻¹³ | 100 | 8.6 x 10 ⁻¹³ | 127 | 227 |

LADTAP INPUT DATA AND RESULTS
MAXIMUM INDIVIDUAL DOSE CALCULATIONS

| <u>Exposure Pathway</u> | <u>Dilution Factor</u> | <u>Transit Time (h)</u> | <u>Usage Rates (kg/yr or h/yr)</u> | | | |
|-------------------------|------------------------|-------------------------|------------------------------------|-------------|--------------|---------------|
| | | | <u>Adult</u> | <u>Teen</u> | <u>Child</u> | <u>Infant</u> |
| Fish Ingestion | 15 | 12 | 21.0 | 16.0 | 6.9 | 0.0 |
| Water Ingestion | 1,000 | 24 | 730.0 | 510.0 | 510.0 | 510.0 |
| Shoreline Use | 1 | 0 | 12.0 | 67.0 | 14.0 | 0.0 |
| Swimming | 1 | 0 | 12.0 | 67.0 | 14.0 | 0.0 |
| Boating | 15 | 0 | 52.0 | 52.0 | 29.0 | 0.0 |

Dose Results (mrem/yr)(a)

| <u>Exposure Pathway</u> | <u>Adults</u> | | | <u>Teenager</u> | | |
|-------------------------|---------------|--------------|-------------|-----------------|--------------|-------------|
| | <u>T Body</u> | <u>Liver</u> | <u>Skin</u> | <u>T Body</u> | <u>Liver</u> | <u>Skin</u> |
| Fish Ingestion | 5.25(-1)(b) | 6.96(-1) | - | 2.97(-1) | 6.91(-1) | - |
| Water Ingestion | 5.66(-4) | 6.13(-4) | - | 3.10(-4) | 4.06(-4) | - |
| Shoreline Use | 7.96(-3) | 7.96(-3) | 9.3(-3) | 4.45(-2) | 4.45(-2) | 5.19(-2) |
| Swimming | 8.24(-5) | 8.24(-5) | - | 4.6 (-4) | 4.6 (-4) | - |
| Boating | 1.19(-5) | 1.19(-5) | - | 1.19(-5) | 1.19(-5) | - |
| Totals | 5.34(-1) | 7.04(-1) | 9.3(-3) | 3.43(-1) | 7.36(-1) | 5.19(-2) |

(a) Doses to other individuals and organs are smaller than those presented.

(b) $5.25(-1) = 5.25 \times 10^{-1}$

ACTIVITY IN GASEOUS WASTE

| <u>Isotope</u> | <u>Half-Life</u> | <u>Activity in Surge Tank</u> <u>μCi/cm³ H₂</u> | | <u>10 CFR 20</u> <u>μCi/cm³</u> | <u>Fraction of 10 CFR 20</u> <u>Limit at Boundary</u> | |
|----------------|------------------|--|--------------------|---|--|--------------------|
| | | <u>As Received</u> | <u>60-Day Hold</u> | | <u>No Hold</u> | <u>60-Day Hold</u> |
| Kr-85(m) | 4.4h | 42.9 | (a) | 1×10^{-7} | .0065 | (a) |
| Kr-85 | 10.4y | 66.9 | 65.6 | 3×10^{-7} | .0034 | .0034 |
| Kr-87 | 78m | 23.1 | (a) | 2×10^{-8} | .017 | (a) |
| Kr-88 | 2.8h | 70.9 | (a) | (b) | (b) | (b) |
| Xe-133 | 5.27d | 6,430 | 2.48 | 3×10^{-7} | 0.32 | .00012 |
| Xe-135 | 9.2h | 193 | (a) | 1×10^{-7} | .029 | (a) |
| Xe-138 | 17m | 10.3 | (a) | (b) | (b) | (b) |

(a) Less than 10^{-8}

(b) Unlisted in 10 CFR 20

SPECIAL LOCATION GASPAR INPUT DATA

| <u>Number</u> | <u>Distance (Miles)</u> | <u>Direction</u> | <u>Description</u> | <u>Normal X/Q(s/m³)</u> | <u>Depleted X/Q(s/m³)</u> | <u>Deposition D/Q(1/m²)</u> |
|---------------|-----------------------------|------------------|--------------------|--|--|--|
| 1 | 0.63 | S | Residence | 5.56(-6) | 4.66(-6) | 3.08(-8) |
| 2 | 0.88 | ENE | Garden | 2.06(-6) | 1.67(-6) | 2.31(-8) |
| 3 | 1.00 | ESE | Meat Animal | 2.13(-6) | 1.69(-6) | 1.49(-8) |
| 4 | 2.50 | NE | Goat Milk | 2.60(-7) | 1.85(-7) | 8.14(-10) |
| 5 | 2.75 | ENE | Milk Cow | 1.81(-7) | 1.26(-7) | 1.59(-9) |

| <u>Parameter</u> | <u>Value for Appropriate Locations</u> |
|---|--|
| Fraction fresh leafy vegetables grown locally | 1.0 |
| Fraction of year cows, cattle, goats on pasture | 0.5 |
| Fraction of vegetable intake grown in garden | 0.76 |
| Fraction of feed from pasture while on pasture | 1.0 |
| Air water content, g/m ³ | 8.0 |

DOSE RESULTS FOR SPECIAL LOCATIONS
MAXIMUM INDIVIDUAL DOSES BY AGE GROUP AND ORGAN
mrem/yr(a)

| <u>Location(a)</u> | <u>Description</u> | <u>Adults</u> | | | <u>Teenagers</u> | | | <u>Children</u> | | | <u>Infants</u> | | |
|--------------------|--------------------|---------------|-------------|----------------|------------------|-------------|----------------|-----------------|-------------|----------------|----------------|-------------|----------------|
| | | <u>T Body</u> | <u>Skin</u> | <u>Thyroid</u> | <u>T Body</u> | <u>Skin</u> | <u>Thyroid</u> | <u>T Body</u> | <u>Skin</u> | <u>Thyroid</u> | <u>T Body</u> | <u>Skin</u> | <u>Thyroid</u> |
| 1 | Plume | 1.13(-1) | 3.38(-1) | 1.13(-1) | 1.13(-1) | 3.38(-1) | 1.13(-1) | 1.13(-1) | 3.38(-1) | 1.13(-1) | 1.13(-1) | 3.38(-1) | 1.13(-1) |
| | Ground | 1.43(-1) | 1.68(-2) | 1.43(-2) | 1.43(-2) | 1.68(-2) | 1.43(-2) | 1.43(-2) | 1.60(-2) | 1.43(-2) | 1.43(-2) | 1.68(-2) | 1.43(-2) |
| | Inhalation | 9.25(-2) | 9.20(-2) | 3.40(-1) | 5.13(-2) | 5.09(-2) | 2.58(-1) | 5.22(-2) | 5.16(-2) | 3.25(-1) | 5.57(-2) | 5.49(-2) | 5.23(-1) |
| 2 | Garden | 2.05(-1) | 1.99(-1) | 1.71(0) | 2.43(-1) | 2.37(-1) | 1.43(0) | 5.02(-1) | 4.95(-1) | 2.30(0) | - | - | - |
| 3 | Meat | 5.09(-2) | 5.06(-2) | 1.10(-1) | 3.52(-2) | 3.50(-2) | 7.62(-2) | 6.16(-2) | 6.14(-2) | 1.24(-2) | - | - | - |
| 4 | Goat Milk | 1.45(-2) | 1.36(-2) | 2.58(-1) | 1.84(-2) | 1.72(-2) | 3.84(-1) | 3.66(-2) | 3.46(-2) | 7.60(-1) | 6.84(-2) | 6.49(-2) | 1.81(0) |
| 5 | Cow Milk | 6.79(-3) | 6.33(-3) | 1.84(-1) | 9.47(-3) | 8.77(-3) | 2.76(-1) | 2.03(-2) | 1.90(-2) | 5.48(-1) | 3.89(-2) | 3.74(-2) | 1.31(0) |

(a) See Table 11-12 for location data

PROCESS RADIATION SERVICE AND EQUIPMENT

| Process Radiation Monitoring Systems | Detection Equipment/ Sampling Equipment | Readout Equipment | Sensitivity | Alarm and Control |
|---|--|--|--|---|
| Service Water, RE0833 | Scintillation detector/detector well in service water line to discharge structure. | Digital indicator 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure. |
| Steam Generator Blowdown, RE0707 | Scintillation detector/external to blowdown tank, drain to P98A/B suction. | Digital rate meter 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation signal; isolates blowdown tank. |
| Radwaste Liquid Discharge, RE1049 | Scintillation detector on radwaste liquid line to discharge structure. | Digital rate meter 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure. Isolates radwaste release. |
| Component Cooling Water, RE0915 | Scintillation detector/piping, valves, and detector housing. CC pump dP for flow. | Digital indicator 10-10 ⁷ CPM. | 5 x 10 ⁻⁵ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure; isolates component cooling water surge tank vent. |
| Circ Water Discharge, RE1323 | Scintillation detector/piping, valves, sample pump and detector housing; circulating from mixing basin prior to discharge. | Digital indicator 10-10 ⁷ CPM. | 4 x 10 ⁻⁶ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure. |

PROCESS RADIATION SERVICE AND EQUIPMENT

| Process Radiation Monitoring Systems | Detection Equipment/ Sampling Equipment | Readout Equipment | Sensitivity | Alarm and Control |
|---|--|---|--|--|
| Off-Gas Monitoring, RE0631 | Scintillation detector/piping, valves and detector housing; main condenser steam jet air ejector noncondensibles to stack. | Digital rate meter analyzer 10-10 ⁷ CPM. | 1 x 10 ⁻⁵ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation and circuit failure. |
| Radwaste Area Ventilation, RE1809 | Geiger-Mueller tube/piping, valves, sample pump and detector housing; air monitoring prior to discharge to stack. | Linear rate meter 0-10 ⁶ CPM. | 4 x 10 ⁻⁵ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation and circuit failure; isolates radwaste vent system. |
| Engineered Safeguards Pump Rooms Vent, RE1810, 1811 | Geiger-Mueller tube; piping, valves, sample pump and detector housing; to stack, 2 systems, East and West rooms. | Digital rate meter 10-10 ⁷ CPM. | 1 x 10 ⁻⁴ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation and circuit failure; isolates pump room vent supply and exhausts. |
| Waste Gas Radiation, RE1113 | Geiger-Mueller tube/piping, valves and detector housing; from the waste gas surge tank and waste gas decay tanks to stack. | Digital rate meter 10-10 ⁷ CPM. | 1 x 10 ⁻⁴ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation and circuit failure; isolation waste gas surge tank and decay tanks. |

PROCESS RADIATION SERVICE AND EQUIPMENT

| Process Radiation Monitoring Systems | Detection Equipment/ Sampling Equipment | Readout Equipment | Sensitivity | Alarm and Control |
|--|--|--|--|--|
| Containment Building Gas Monitoring System, RE1817 | Geiger-Mueller tube/piping solenoid valves and detector housing; from 5 sample locations on (4) cooler fan discharges. | Linear rate meter 10-10 ⁷ CPM. | 1 x 10 ⁻⁴ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation and circuit failure. |
| Failed Fuel, RE0202 | Scintillation detector/detector housing in letdown line. | Linear rate meter, 0-10 ⁶ CPM, local. | N/A | Alarm on high radiation, circuit failure. |
| Steam Generator Blowdown Vent, RE2320 | Scintillation detector/in well on blowdown vent line. | Digital rate meter, 10-10 ⁷ CPM. | 2 x 10 ⁻⁵ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure. |
| Turbine Building Sump, RE5211 | Scintillation detector/piping, valves, and detector housing, sump pump discharge to drain. | Digital rate meter, 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Cs-137 equivalent. | Alarm on high radiation, circuit failure. |
| Radwaste Addition Vent, RE5711 | Beta scintillation/dP across roughing filter used for flow. | Digital rate meter, 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation circuit failure; high radiation isolates radwaste addition vent. |
| Fuel Building Addition Vent, RE5712 | Beta scintillation/dP across roughing filter used for flow. | Digital rate meter, 10-10 ⁷ CPM. | 5 x 10 ⁻⁶ µCi/cm ³ of Xe-133 equivalent. | Alarm on high radiation circuit failure; high |

PROCESS RADIATION SERVICE AND EQUIPMENT

| Process Radiation Monitoring Systems | Detection Equipment/ Sampling Equipment | Readout Equipment | Sensitivity | Alarm and Control |
|--------------------------------------|--|--|---|--|
| | | | | radiation isolates fuel building vent. |
| RGEMS 2327 | Scintillation detectors for beta, gamma, ionization chamber/piping, valves, filters, sample collection bottle; discharge to stack inlet. | Log count rate meter, recorded; stack flow, recorded; sample flow recorded; 10-10 ⁶ CPM beta (log), 10-10 ⁷ CPM (log), gamma 1-10 ⁷ mr/h (ion chamber) or 4 x 10 ⁶ Ci/s digital. | 1 x 10 ⁻⁶ µCi/cm ³ of Xe-133 equivalent. | Alarm, set recorder speed, isolate samples on alert level. Alarm transfer flow to upper range on high radiation. |
| RGEMS RE2325, RE2326 | Scintillation detectors for beta, gamma, ionization chamber/piping, valves, filters, sample collection bottle; discharge to stack inlet. | Digital rate meter RIA-2325: 10-10 ⁶ CPM RIA-2326: 10-10 ⁷ CPM | 3.9 x 10 ⁻⁷ µCi/cm ³ of Xe-133 equivalent. | Alarm, set recorder speed, isolate samples on alert level. Alarm transfer flow to upper range on high radiation. |
| Main Steam, RE2323, 2324 | Geiger-Mueller tube/in lead collimator adjacent to main steam lines. | Digital rate meter 10-10 ⁷ CPM. | 5 x 10 ⁻² µCi/cm ³ of dose equivalent I-131 | Alarm on high radiation. |

AREA RADIATION DETECTORS

| <u>Instrument(a), (b)</u> | <u>Range</u> |
|---|---------------------------|
| Containment 590' Elev NW Side (b) | 10^{-2} - 10^4 Rem/hr |
| Containment 590' Elev SW Side (b) | 10^{-2} - 10^4 Rem/hr |
| Containment 590' Elev NE Side (b) | 10^{-2} - 10^4 Rem/hr |
| Containment 590' Elev SE Side (b) | 10^{-2} - 10^4 Rem/hr |
| East Engineering Safeguards Room | 0.1 - 10^7 mrem/hr |
| Radwaste Service Corridor | 0.1 - 10^7 mRem/hr |
| Radwaste Control Area (C-40 Panel) | 0.1 - 10^7 mrem/hr |
| 2.4 kV Switchgear Room (1C) | 0.1 - 10^7 mRem/hr |
| Control Lab Corridor | 0.1 - 10^7 mrem/hr |
| Access Control Station | 0.1 - 10^7 mrem/hr |
| Outside Cont Personnel Air Lock 607' Elev | 0.1 - 10^7 mrem/hr |
| Containment Purge Unit Room-North | 0.1 - 10^7 mrem/hr |
| Radwaste Demineralizer Room Roof | 0.1 - 10^7 mrem/hr |
| Control Room/Turbine Bldg Corridor | 0.1 - 10^7 mrem/hr |
| Control Room Entrance | 0.1 - 10^7 mrem/hr |
| Turbine Floor East Side | 0.1 - 10^7 mrem/hr |
| Health Physics Offices | 0.1 - 10^7 mrem/hr |
| Spent Fuel Pool-South | 0.1 - 10^7 mrem/hr |
| Air Room 590' Elev | 0.1 - 10^7 mrem/hr |
| Inside of Cont Personnel Air Lock | 1.0 - 10^7 mrem/hr |
| Containment 649' Elev Rx Cavity | 1.0 - 10^7 mRem/hr |
| Containment 649' Elev Rx Cavity | 1.0 - 10^7 mRem/hr |
| Containment Hi range-left channel | 1 - 10^7 Rem/hr |
| Containment Hi range-right channel | 1 - 10^7 Rem/hr |
| Decontamination Room | 0.1 - 10^7 mrem/hr |
| Evaporator "A" | 0.1 - 10^7 mrem/hr |

- (a) Sensitivity for all instruments except containment detectors has energy dependence of $\pm 20\%$ of the actual radiation intensity over a photon energy spectrum of 100 keV to 2.5 MeV
- (b) Sensitivity for containment detector instruments has an energy dependence of $\pm 15\%$ of actual radiation intensity over a photon energy spectrum of 100 keV to 2.5 MeV.
- (c) Sensitivity for the radwaste monitor is $\pm 30\%$ of the actual intensity over a photon energy spectrum from 80 keV to 1.33 MeV.

AREA RADIATION DETECTORS

| | |
|--------------------------------------|-----------------------------|
| Evaporator "B" | 0.1-10 ⁷ mrem/hr |
| Evaporator Control Panel C-105 | 0.1-10 ⁷ mrem/hr |
| Waste Gas Decay Tank T-101, A, B & C | 0.1-10 ⁷ mrem/hr |
| Environmental Lab Entrance | 0.1-10 ⁷ mrem/hr |
| Radwaste Packaging Area-East | 0.1-10 ⁷ mrem/hr |
| Radwaste Packaging Area-West | 0.1-10 ⁷ mrem/hr |
| Radwaste Demineralizer 649' Elev | 0.1-10 ⁷ mrem/hr |
| Steam Dumps Area | 0.1-10 ⁷ mrem/hr |

Radwaste Monitors (c) Local Readout

| | |
|--|-----------------------------|
| East Processing Building | 1.0-10 ⁵ mRem/hr |
| East Storage Building | 1.0-10 ⁵ mRem/hr |
| South Storage Building | 1.0-10 ⁵ mRem/hr |
| (Not Used for Radwaste Storage at this time) | |

- (a) Sensitivity for all instruments except containment detectors has energy dependence of $\pm 20\%$ of the actual radiation intensity over a photon energy spectrum of 100 keV to 2.5 MeV
- (b) Sensitivity for containment detector instruments has an energy dependence of $\pm 15\%$ of actual radiation intensity over a photon energy spectrum of 100 keV to 2.5 MeV.
- (c) Sensitivity for the radwaste monitor is $\pm 30\%$ of the actual intensity over a photon energy spectrum from 80 keV to 1.33 MeV.

**Primary Coolant Fission and Corrosion Product Activities
for AST Dose Analyses**

| Nuclide | Activity* (μCi/g) | Nuclide | Activity* (μCi/g) |
|----------------|---|----------------|---|
| Co-58 | 7.0E-03 | Np-239 | - |
| Co-60 | 8.0E-04 | Pu-238 | - |
| Cr-51 | 4.7E-03 | Pu-239 | - |
| Fe-55 | 1.8E-03 | Pu-240 | - |
| Fe-59 | 4.5E-04 | Pu-241 | - |
| Mn-54 | 2.4E-03 | Am-241 | - |
| Kr-85 | 5.3E-01 | Cm-242 | - |
| Kr-85m | 1.2E+00 | Cm-244 | - |
| Kr-87 | 7.5E-01 | I-130 | 1.1E-01 |
| Kr-88 | 2.2E+00 | Kr-83m | 3.2E-01 |
| Rb-86 | 1.5E-02 | Xe-138 | 4.7E-01 |
| Sr-89 | 5.4E-03 | Xe-131m | 4.5E-01 |
| Sr-90 | 4.9E-04 | Xe-133m | 1.7E+00 |
| Sr-91 | 1.5E-03 | Xe-135m | 4.8E-01 |
| Sr-92 | 5.9E-04 | Cs-138 | 7.0E-01 |
| Y-90 | 6.4E-04 | Cs-134m | 4.6E-02 |
| Y-91 | 1.8E-02 | Rb-88 | 2.3E+00 |
| Y-92 | 7.2E-04 | Rb-89 | 5.8E-02 |
| Y-93 | 4.4E-04 | Sb-124 | 1.1E-03 |
| Zr-95 | 1.2E-03 | Sb-125 | 9.2E-03 |
| Zr-97 | 4.9E-04 | Sb-126 | 6.2E-04 |
| Nb-95 | 1.2E-03 | Te-131 | 1.5E-02 |
| Mo-99 | 4.2E+00 | Te-133 | 6.1E-03 |
| Tc-99m | 3.2E+00 | Te-134 | 2.1E-02 |
| Ru-103 | 1.2E-03 | Te-125m | 2.0E-03 |
| Ru-105 | 1.4E-04 | Te-133m | 1.2E-02 |
| Ru-106 | 5.3E-04 | Ba-141 | 9.1E-05 |
| Rh-105 | 5.5E-04 | Ba-137m | 2.5E+01 |
| Sb-127 | 4.3E-02 | Pd-109 | - |
| Sb-129 | 2.4E-02 | Rh-106 | 5.3E-04 |
| Te-127 | 4.6E-02 | Rh-103m | 1.2E-03 |
| Te-127m | 7.2E-03 | Tc-101 | 1.5E-02 |
| Te-129 | 3.8E-02 | Eu-154 | - |
| Te-129m | 2.2E-02 | Eu-155 | - |
| Te-131m | 3.7E-02 | Eu-156 | - |

**Primary Coolant Fission and Corrosion Product Activities
for AST Dose Analyses**

| Nuclide | Activity* (μCi/g) | Nuclide | Activity* (μCi/g) |
|----------------|---|----------------|---|
| Te-132 | 4.8E-01 | La-143 | 1.1E-05 |
| I-131 | 5.2E+00 | Nb-97 | 8.1E-05 |
| I-132 | 1.2E+00 | Nb-95m | 8.5E-06 |
| I-133 | 5.4E+00 | Pm-147 | 1.2E-04 |
| I-134 | 4.7E-01 | Pm-148 | 1.7E-04 |
| I-135 | 2.3E+00 | Pm-149 | 3.0E-04 |
| Xe-133 | 7.0E+01 | Pm-151 | 8.3E-05 |
| Xe-135 | 7.4E+00 | Pm-148m | 2.6E-05 |
| Cs-134 | 4.9E+01 | Pr-144 | 9.3E-04 |
| Cs-136 | 4.3E+00 | Pr-144m | 1.6E-05 |
| Cs-137 | 2.6E+01 | Sm-153 | - |
| Ba-139 | 4.3E-04 | Y-94 | 1.4E-05 |
| Ba-140 | 7.1E-03 | Y-95 | 8.6E-06 |
| La-140 | 3.4E-03 | Y-91m | 8.9E-04 |
| La-141 | 2.4E-04 | Br-82 | 2.5E-02 |
| La-142 | 6.8E-05 | Br-83 | 6.6E-02 |
| Ce-141 | 1.1E-03 | Br-84 | 2.7E-02 |
| Ce-143 | 6.3E-04 | Am-242 | - |
| Ce-144 | 9.3E-04 | Np-238 | - |
| Pr-143 | 1.0E-03 | Pu-243 | - |
| Nd-147 | 4.3E-04 | | |

*Activities based on 1% failed fuel. Listed activities are adjusted to Technical Specification limits for performance of AST dose calculations.