

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Kairos Power Licensing Subcommittee

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, April 4, 2023

Work Order No.: NRC-2343

Pages 1-190

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
1716 14th Street, N.W.  
Washington, D.C. 20009  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

KAIROS POWER LICENSING SUBCOMMITTEE

+ + + + +

TUESDAY

APRIL 4, 2023

+ + + + +

The Subcommittee met via hybrid in-person and Video Teleconference, at 8:30 a.m. EDT, David Petti, Chairman, presiding.

COMMITTEE MEMBERS:

- DAVID PETTI, Chair
- RONALD G. BALLINGER, Member
- CHARLES H. BROWN, JR., Member
- VICKI BIER, Member
- VESNA DIMITRIJEVIC, Member
- GREGORY HALNON, Member
- WALT KIRCHNER, Member
- JOSE MARCH-LEUBA, Member
- JOY L. REMPE, Member
- MATTHEW SUNSERI, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 ACRS CONSULTANT:

2 DENNIS BLEY

3 STEPHEN SCHULTZ

4 DESIGNATED FEDERAL OFFICIAL:

5 WEIDONG WANG

6 ALSO PRESENT:

7 JOSEPH ASHCRAFT, NRR

8 BENJAMIN BEASLEY, NRR

9 NORBERT CARTE, NRR

10 CALVIN CHEUNG, NRR

11 ALEXANDER CHERESKIN, NRR

12 ANTHONIE CILLIERS, Kairos Power

13 AUSTIN CLARK, Kairos Power

14 DARRELL GARDNER, Kairos Power

15 VIJAY GOEL, NRR

16 MICHELLE HART, NRR

17 EDWARD HELVENSTON, NRR

18 MATT HISER, NRR

19 ANDREW LINGENFELTER, Kairos Power

20 AUGUSTUS MERWIN, Kairos Power

21 DREW PEEBLES, Kairos Power

22 SHEILA RAY, NRR

23 JEFFREY SCHMIDT, NRR

24 NICOLAS ZWEIBAUM, Kairos Power

25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR PETTI: Good morning, everyone. The meeting will now come to order.

This is a meeting of the Kairos Power Licensing Subcommittee of the Advisory Committee on Reactor Safeguards. I'm David Petti, Chairman of today's subcommittee meeting.

ACRS members in attendance are Jose March-Leuba, Joy Rempe, Matthew Sunseri, Ron Ballinger, Walt Kirchner, and Greg Halnon. We anticipate Charlie Brown will arrive once traffic subsides a little. And Vesna Dimitrijevic and Vicki Bier may join us virtually.

MEMBER DIMITRIJEVIC: Yes, (audio interference).

CHAIR PETTI: Okay. Great. You're both there. Great. Thank you.

Consultants Dennis Bley and Steve Schultz are also online.

Weidong Wang of the ACRS staff is the designated federal official of this meeting.

During today's meeting the subcommittee will continue its review of the staff's safety evaluation on Kairos Power Hermes Non-Power Reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 preliminary safety analysis.

2 The subcommittee will presentations by and  
3 hold discussions with the NRC staff, Kairos Power  
4 representatives, and other interested persons  
5 regarding this matter.

6 Parts of the presentation by the applicant  
7 and the NRC staff may be closed in order to discuss  
8 information that is proprietary to the licensee and  
9 its contractors pursuant to 5 USC 552b(c)(4).  
10 Attendance at the meeting that deals with such  
11 information will be limited to the NRC staff and its  
12 consultants, Kairos Power, and those individuals and  
13 organizations who have entered into an appropriate  
14 confidentiality agreement with them. Consequently we  
15 need to confirm that we have only eligible observers  
16 and participants in the closed part of the meeting.

17 The rules for participation in all ACRS  
18 meetings including today's were announced in the  
19 Federal Register on June 13th, 2019. The ACRS section  
20 of the U.S. NRC public website provides our charter,  
21 bylaws, agendas, letter reports, and full transcripts  
22 of all full and subcommittee meetings including slides  
23 presented there. The meeting notice and the agenda  
24 for this meeting were posted there.

25 We have received no written statements or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 requests to make an oral statement from the public.

2 The subcommittee will gather information,  
3 analyze relevant issues and facts and formulate  
4 proposed positions and actions as appropriate for  
5 deliberation by the full committee.

6 A transcript of the meeting is being kept  
7 and will be made available.

8 Today's meeting is being held in person  
9 and over Microsoft Teams by ACRS staff and members,  
10 NRC staff, and the applicant. There's also a  
11 telephone bridge line and a Microsoft Teams link  
12 allowing participation of the public.

13 When addressing the subcommittee the  
14 participants should identify themselves and speak with  
15 sufficient clarity and volume so that they may be  
16 readily heard. When not speaking we request that  
17 participants mute their computer microphone or their  
18 phones by pressing \*6.

19 We can now proceed with the meeting and  
20 we'll call upon Kairos to begin.

21 Kairos?

22 MR. PEEBLES: Thank you, Mr. Chairman.  
23 This is Drew Peebles. I'm a senior licensing manager  
24 at Kairos Power. I'd like to thank the subcommittee  
25 for the opportunity to continue to provide an overview

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of the Hermes PSAR. I think we had some good  
2 discussion at the past few meetings and look forward  
3 to more of that.

4 First up is Chapter 5, so I'm going to  
5 hand it over to the responsible director, Nico  
6 Zweibaum.

7 MR. ZWEIBAUM: Good morning, everyone.  
8 Rapid sound check just making sure that everyone can  
9 hear me correctly.

10 CHAIR PETTI: You're fine. Go ahead.

11 MR. ZWEIBAUM: Thank you very much.

12 So as Drew Peebles mentioned, my name is  
13 Nico Zweibaum. I'm the Director of Salt Systems  
14 Design of Kairos Power and today I will be presenting  
15 on Chapter of the Hermes preliminary safety analysis  
16 report on heat transport system.

17 Next slide, please? So first for a  
18 description of the primary heat transport system,  
19 which is provided in Section 5.1 of the PSAR, the  
20 PHTS, the primary heat transport system, is  
21 responsible for transporting heat from the reactor to  
22 the ultimate heat sink which is environmental air  
23 during power operation and during normal shutdown. Of  
24 note the PHTS operates near atmospheric pressure and  
25 it does not provide a safety-related heat removal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 function.

2 The members of ACRS may remember the  
3 presentation on Chapter 6 a couple weeks ago that  
4 mentioned the decay heat removal system, or safety-  
5 related system, but the PHTS in contrast does not  
6 provide a safety-related heat removal function.

7 In particular there is no driving force thanks  
8 to the near-atmospheric pressure operation for  
9 energetic releases during a pipe break. Again, the  
10 PHTS is a non-safety-related system.

11 There are a number of parameters that are  
12 shown here to further describe that system. It is  
13 sized for a thermal duty of the reactor of 35  
14 megawatts thermal. It is equipped with one heat  
15 rejection radiator, or HRR. This is the heat  
16 exchanger between the FLiBe salts and air. There is  
17 one hot leg and two cold legs returning to the reactor  
18 vessel. The nominal size for the piping in the PHTS  
19 will be between 8 and 12 inches. The temperature of  
20 the coolant entering the heat rejection radiator will  
21 be somewhere between 600 and 650 degrees Celsius  
22 depending on operating mode. The cold leg coolant  
23 temperature will be 550 Celsius.

24 Nominal flow rate of the coolant in the  
25 primary heat transport system will be 210 kilograms

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 per second and the design pressure here is (audio  
2 interference).

3 MEMBER HALNON: So just a question for  
4 clarification, make sure I have it in -- pictured my  
5 in mind. So the hot leg let's say comes into the top  
6 of the heat exchanger and out the bottom comes two  
7 cold legs?

8 MR. ZWEIBAUM: The split for the two cold  
9 legs happens closer to the reactor vessel. There's a  
10 very simple notional diagram I believe on the next  
11 slide, but that's --

12 MEMBER HALNON: Okay.

13 MR. ZWEIBAUM: -- probably not going to be  
14 sufficient. But, yes, it happens -- yes, you can see  
15 it here. It's obviously very notional, but yes, it  
16 would happen closer to the vessel.

17 MEMBER HALNON: Okay.

18 MEMBER MARCH-LEUBA: And this is Jose.  
19 Can you remind me, on the top of your head do you know  
20 what the freezing temperature is of FLiBe?

21 MR. ZWEIBAUM: Yes, it's around 460  
22 degrees Celsius.

23 MEMBER MARCH-LEUBA: Sixteen?

24 MR. ZWEIBAUM: Four-six-zero. Sixty.

25 MEMBER MARCH-LEUBA: Oh, 60? So we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 like a little less than 100 degrees C to freezing?

2 MR. ZWEIBAUM: That's correct.

3 MEMBER MARCH-LEUBA: All right. Okay.  
4 Thank you.

5 MR. ZWEIBAUM: Okay. Continuing on the  
6 description of that system. Here the major subsystems  
7 are listed starting with primary loop piping. That  
8 piping transports reactor coolant which is FLiBe salt  
9 between the reactor vessel and the heat rejection  
10 radiator. This is a non-safety-related portion of the  
11 reactor cooling boundary.

12 The primary salt pump, or PSP, is a  
13 variable-speed cartridge-style pump which is located  
14 on the head of the reactor vessel. Its inlet extends  
15 downwards through the reactor coolant-free surface.  
16 It has an anti-siphon function on the hot leg which is  
17 performed by the geometric features of that downward-  
18 facing inlet of the PSP. There is no safety-related  
19 function for the PSP itself as a subsystem, however  
20 there is a safety-related trip of that pump should a  
21 leak occur on the hot leg to maintain reactor coolant  
22 inventory level.

23 The heat rejection subsystem provides for  
24 heat transfer from the reactor coolant to  
25 environmental air, which is the ultimate heat sink.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 It consists of a heat rejection radiator, heat  
2 rejection blower, and associated ducting and thermal  
3 management. There is no safety-related function for  
4 the heat rejection system, however there is a safety-  
5 related blower trip upon tube failure to minimize  
6 forced air ingress into the PHTS.

7 And finally, we do have a primary loop  
8 thermal management function to provide non-nuclear  
9 heating and insulation to the PHTS as needed for  
10 various operations which again has not safety-related  
11 function.

12 MEMBER HALNON: Just a quick question.  
13 This is Greg. The environmental air reject for the  
14 heat, is that -- do you have dimensions on the stack?  
15 Is it high or it surface level? What is the release  
16 there?

17 MR. ZWEIBAUM: So we'll provide more  
18 details with the operating license application. The  
19 factors that will get into that is not only for  
20 thermal management and kind of heat balance, but  
21 there's also considerations associated with tritium  
22 and dilution and source term. So there is a  
23 combination of factors that leads -- or will lead to  
24 the specifics provided for that stack height.

25 MEMBER HALNON: Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER MARCH-LEUBA:   And this is Jose.  
2                   Can you explain to us -- you have a safety-related  
3                   function to prevent air going into the system.  What  
4                   will be the safety significance of air getting into  
5                   the system?

6                   MR. ZWEIBAUM:   So there's really -- and  
7                   actually there was a request for additional  
8                   information by the NRC specifically on oxidation of  
9                   reactor internals.  There's really two regimes:  
10                  During normal operation there is a technical  
11                  specification around the quantity of air that could be  
12                  ingested into the primary heat transport system to  
13                  limit oxidation.  During an accident that includes a  
14                  break in the heat rejection radiator the trip is  
15                  intended to limit forced air ingress.  And then the  
16                  natural convection that would result in some amount of  
17                  air introduced into the system and causing oxidation  
18                  of reactor internals would be bounded by what we'll be  
19                  testing based on our materials qualification topical  
20                  report.  So this is all related to oxidation and  
21                  bounded by acceptable values up to seven days during  
22                  any postulated event.

23                  MEMBER MARCH-LEUBA:   So summarizing, is  
24                  more of a chemical reaction of the oxygen, not flow  
25                  blockage or prevention of circulation or change of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 flow factors, things like that?

2 MR. ZWEIBAUM: That is correct.

3 MEMBER MARCH-LEUBA: Nothing --

4 MR. ZWEIBAUM: That's correct. The  
5 natural circulation that we are relying upon for decay  
6 heat removal happens strictly within the reactor  
7 vessel, so the PHTS which is described in Chapter 5 is  
8 not involved in that function.

9 MEMBER MARCH-LEUBA: Thanks.

10 MR. ZWEIBAUM: Next slide? Our reactor  
11 coolant, although part of the functional containment  
12 function that was described in Chapter 6 is also  
13 architecturally a part of a heat transport system, so  
14 this is why it's also described in Section 5.1. This  
15 is FLiBe, the liquid fluoride salt coolant that's been  
16 described multiple times. Of note is its negative  
17 temperature coefficient of reactivity as well as the  
18 fact that it acts as a secondary barrier to fission  
19 product release.

20 For thermal physical properties there is  
21 a topical report, Reactor Coolant for the Kairos Power  
22 Fluoride Salt Cooled High-Temperature Reactor, KP-TR-  
23 005, that provides all of the thermophysical  
24 properties. And another important aspect here is the  
25 high heat capacity of the coolant, which from a safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 perspective provides large thermal inertia for  
2 transients so that any transient don't result in any  
3 kind of rapid evolution of temperature.

4 MEMBER KIRCHNER: This Walt Kirchner.  
5 Could you tell us what we're looking at in the picture  
6 on the right?

7 MR. ZWEIBAUM: Yes, so this picture I  
8 believe was the first time that we did some static  
9 exposure of a metallic coupon in FLiBe in our own salt  
10 lab in Alameda, California. So we're looking at a  
11 small trinket if you will that contains liquid FLiBe.  
12 The red glow is because of the temperature that we  
13 have to heat up the system to for melting of the salt  
14 and then introduce that little machined Kairos Power  
15 logo made of 3/16th stainless steel into the salt  
16 there.

17 MEMBER KIRCHNER: Could you tell us what  
18 happens with FLiBe sitting in -- exposed to air,  
19 whether it's dry air or humid air, or water?

20 MR. ZWEIBAUM: In what context? With  
21 materials and materials oxidation or just the chemical  
22 reaction between FLiBe and other chemicals?

23 MEMBER KIRCHNER: Well, if you have a  
24 break in this primary heat transport system what  
25 happens with the FLiBe being exposed to air?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ZWEIBAUM: Yes, so this is something  
2 that we'll be continuing to investigate and bound from  
3 I guess a reaction perspective. There's a number of  
4 factors here, the main thing being the corrosion of  
5 the materials exposed to the combination of FLiBe and  
6 oxygen. And this is what we'll be testing for and  
7 bounding from what we've committed to in our materials  
8 topical report that's been submitted and approved by  
9 the NRC.

10 MEMBER KIRCHNER: So what happens in if  
11 you have a spill of FLiBe?

12 MR. ZWEIBAUM: Also (audio  
13 interference) --

14 MEMBER KIRCHNER: You don't have a  
15 confinement, so just talk through what issues you have  
16 with FLiBe exposed to air.

17 MR. ZWEIBAUM: Well, I guess the main  
18 thing would be the release of radionuclides or  
19 aerosols that would be contained in the FLiBe. And  
20 this is something that we are also bounding in our  
21 analysis, and it's part of our Chapter 13 analysis.  
22 I think we have our manager of salt chemistry Gus  
23 Merwin on the line if you have more questions related  
24 to chemistry specifically.

25 MEMBER KIRCHNER: Well, is it toxic? Do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 you have an occupational hazard if it's spilled?

2 MR. MERWIN: This is Gus Merwin, manager  
3 of Salt Chemistry here at Kairos. I'd say the  
4 chemical toxicity is sort of out of scope of the PSAR.  
5 There's a -- so the beryllium hazards are assessed  
6 separately into different regulatory domain.

7 I would note that there is no chemical  
8 reaction between oxygen and FLiBe itself, so a pool of  
9 FLiBe does not chemically react with oxygen. There is  
10 the corrosion concerns that Nico Zweibaum mentioned,  
11 and those are assessed as part of the materials  
12 topical program.

13 For a salt spill scenario there is the  
14 potential for radiological releases from circulating  
15 activity which is handled as part of our postulated  
16 event analysis.

17 MEMBER MARCH-LEUBA: And in that line of  
18 questioning what happens to hot FLiBe falling onto a  
19 concrete floor? Does it interact with the concrete?  
20 Releases gases?

21 MR. MERWIN: The chemical reactions  
22 between FLiBe and concrete are precluded by design.  
23 There is a safety-related drip tray that precludes  
24 chemical reactions between FLiBe and concrete.

25 MEMBER MARCH-LEUBA: Oh, so you have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 metal barrier? But if it were to fail, is it really  
2 bad? I mean, all this gas it goes -- it fizzes and  
3 produces lot of gases.

4 CHAIR PETTI: I don't think it's a good  
5 day.

6 Yes, I was -- on the trays -- I know you  
7 -- I don't see any slides -- I mean are they basically  
8 like below all the welds? Is that where they're  
9 putting -- or is it really the whole reactor  
10 compartment in under a big steel tray above the --

11 MR. MERWIN: This is Gus Merwin again.  
12 We've not specified where the trays will be or their  
13 geometric configuration, but the general bulk chemical  
14 reactions are precluded by design. But I will note  
15 that for Kairos' internal learnings and investment  
16 protections we have done experiments reacting FLiBe  
17 with concrete as part of test program to develop  
18 prototype systems and those reactions are extremely,  
19 extremely slow. We're talking about functionally  
20 chemically inert. The FLiBe does not want to form  
21 oxides. It's the same reason there's no driver for  
22 FLiBe reactions with air. So the reactions are over  
23 the course of many hours and we probably freeze the  
24 system before you get any bulk degradation of the  
25 concrete.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER BALLINGER: This is Ron Ballinger.  
2                   I guess I understand that part, but I've had some  
3                   experience when you drop something very hot on  
4                   concrete it's not the reaction with the concrete  
5                   that's the issue. It's the literally explosion of air  
6                   bubbles in the concrete that blows the concrete  
7                   surface away. Have you looked at that?

8                   MR. MERWIN: That is a primary motivator  
9                   for why we precluded this by design.

10                  MEMBER BALLINGER: Thank you.

11                  CHAIR PETTI: Okay. Keep going. No more  
12                  questions here.

13                  MR. ZWEIBAUM: Okay. This is --

14                  MEMBER REMPE: I guess I'm just kind of  
15                  wondering a little bit more about this tray. So you  
16                  plan to specify the thickness of the -- and the  
17                  material of the metallic tray as well as -- do you  
18                  need to have a lip to contain a certain amount of  
19                  FLiBe? I mean all of those things will be determined  
20                  based on some estimated release amount by the time of  
21                  the operating license. I haven't looked for that  
22                  specific detail anywhere, but that's the plan?

23                  MR. MERWIN: Yes, that is correct.

24                  MEMBER REMPE: And is that in Appendix A  
25                  also as something that you're expecting to get from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       them?

2                   MR. SCHMIDT:   This is Jeff Schmidt from  
3       Reactor Systems.  I don't think it's specifically in  
4       Appendix A that I remember other than it's precluded  
5       by design and we just don't have the design details of  
6       it.

7                   MEMBER REMPE:   But that's something a  
8       level of detail you'll expect to iron out?

9                   MR. SCHMIDT:   Yes, I mean there's a -- as  
10      they pointed out there's a Chapter 13 event, a salt  
11      spill.  So obviously we'll be looking at that and  
12      where the salt goes from that salt spill.  And they've  
13      committed to looking at a variety of locations for  
14      break sizes through the primary system.

15                  MEMBER REMPE:   You'll have to --

16                  MR. SCHMIDT:   Yes.

17                  MEMBER REMPE:   -- think hard about does it  
18      flow and spread out or does it -- I mean (audio  
19      interference) --

20                  MR. SCHMIDT:   Yes.  No.

21                  MEMBER REMPE:   -- concrete interaction  
22      concerns (audio interference) --

23                  MR. SCHMIDT:   No, right.  Right.

24                  MEMBER REMPE:   -- severe accident stuff in  
25      the past.  And I'll be looking at Chapter 13 a little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 bit more carefully on those kind of --

2 MR. SCHMIDT: Yes, it is -- as they  
3 pointed out it's precluded by design, by the design  
4 details are not available.

5 MR. ZWEIBAUM: This is Nico Zweibaum  
6 again, Director of Salt Systems Design. I would like  
7 to note that by OLA we'll also have more definition of  
8 plant layout including the specific routing of any  
9 salt-containing system. So that will allow for a lot  
10 better definition on location and sizes and geometry  
11 of those drip trays. And this will all be part of the  
12 operating license application.

13 MEMBER KIRCHNER: Yes, in particular; this  
14 is Walt Kirchner, you point out in your own Chapter 6  
15 that FLiBe is an external hazard for your decay heat  
16 removal system.

17 MR. ZWEIBAUM: What we did point out in  
18 Chapter 6 is that we are precluding water and FLiBe  
19 interactions by design. And since the major system  
20 containing water in the plant is our safety-related  
21 DHRS, that system does include a leak barrier so that  
22 should there be a leak in the primary barrier of that  
23 water-containing system that the water is still  
24 contained and not introduced into the reactor cavity  
25 where it could come into contact with FLiBe. If that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 makes sense.

2 CHAIR PETTI: Okay. Keep going.

3 MR. ZWEIBAUM: Shall we proceed? Okay.

4 So on the design basis for the PHTS the  
5 structure systems components that are part of the  
6 reactor cooling boundary will be designed to ASME  
7 B31.3 and Boiler Pressure Vessel Code Section 8, Codes  
8 and Standards.

9 Consistent with PDC 2 failure of the non-  
10 safety-related PHTS components during seismic events  
11 will not affect the performance of nearby safety-  
12 related SSEs.

13 Consistent with PDC 10 adequate coolant  
14 flow will be maintained to assure SARRDLs will not be  
15 exceeded under any condition of normal operation.

16 Consistent with PDC 12 the PHTS is  
17 designed with features that ensure power oscillations  
18 cannot result in conditions exceeding SARRDLs.

19 Consistent with PDC 16 and 60 the reactor  
20 coolant provides control of the release of radioactive  
21 materials during normal operations and postulated  
22 events through the accumulation of radionuclides.

23 Consistent with PDC 33 the casing for the  
24 primary salt pump, PSP, is designed with geometric  
25 features to prevent reactor coolant from being

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 siphoned below the pump casing inlet elevation to  
2 maintain reactor coolant inventory in the event of a  
3 break in an external portion of the PHTS.

4 Consistent with PDCs 33 and 70 the PHTS is  
5 designed with features that support maintaining  
6 reactor coolant inventory and maintaining reactor  
7 coolant purity by eliminating air ingress.

8 The PHTS will be designed according to 10  
9 CFR 20.1406 to the extent practicable to minimize  
10 contamination and support eventual decommissioning.

11 CHAIR PETTI: This is their last slide,  
12 members, Chapters 5. Any questions?

13 (No audible response.)

14 CHAIR PETTI: If not, we'll turn to staff.

15 M R . H I S E R :

16 Thank you. My name is Matt Hiser. I am  
17 a senior project manager in the NRR's Division of  
18 Advanced Reactors and Non-Power Production and  
19 Utilization Facilities. I've been one of four project  
20 managers focused on Hermes and I'd like just to offer  
21 a few introductory slides sort of for all the  
22 presentations today hopefully to make it a little more  
23 efficient, a little less repetitive on the material  
24 that we're going to cover and the regulatory basis.

25 So the four chapters that we're going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 cover today are Chapter 5, as Kairos has already  
2 jumped into; Chapter 7 on Instrumentation and Control;  
3 Chapter 8 on Electrical Power Systems; and then  
4 Chapter 11 on Radiation Protection and Radioactive  
5 Waste Management. And towards the bottom of this  
6 slide I just have sort of included a rough common  
7 agenda for each chapter, so we'll sort of have a brief  
8 overview in more than a slide or two of the PSAR  
9 information and the relevant principal design criteria  
10 for that chapter. Then if there are some topical  
11 reports that are referenced for that chapter, those  
12 will be noted. And then the bulk of each chapter  
13 we'll discuss the staff's technical evaluation and  
14 then wrap up with findings and conclusions.

15 Next slide? And so just to cover sort of  
16 the common regulatory basis; and you guys saw these  
17 slides in about every chapter a couple weeks ago, so  
18 we thought we'd boil it down to one slide up front.  
19 These are the relevant regulations: 50.34a, which  
20 describes what expected in a preliminary safety  
21 analysis report, or PSAR; 50.35, the expectations for  
22 the agency, the findings that need to be made for  
23 issuance of a construction permit; and then the common  
24 standards in 50.40; and finally, the guidance, NUREG-  
25 1537, Part 2, the SRP and acceptance criteria. Those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 are all applicable guidance and regulations. And  
2 we'll have noted for each chapter if there are other  
3 regulations or guidance or PDCs that are applicable to  
4 that chapter.

5 So with that I'll happily turn it over to  
6 Alex Chereskin to cover Chapter 5.

7 MR. CHERESKIN: Good morning. This is  
8 Alex Chereskin from the NRC staff. Can everyone hear  
9 me?

10 (No audible response.)

11 MR. CHERESKIN: Okay. Thanks.

12 I'll be covering the NRC staff's review of  
13 Chapter 5 for the primary heat transport system.

14 Next slide, please? This slide covers the  
15 overview of the staff's review of Chapter 5. And to  
16 start off the primary heat transport system is a non-  
17 safety-related system. A general overview, not to  
18 repeat too much of what Kairos just said, but it  
19 includes the primary salt pump, heat rejection  
20 subsystem and the associated piping. And the purpose  
21 is to transport heat from the reactor core to the  
22 ultimate heat sink through the heat rejection  
23 radiator. It's also meant to manage thermal changes  
24 and provide normal heat removal. And the design will  
25 provide for potential in-service inspection,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 maintenance, and replacement activities.

2           Next slide, please?    These are the  
3 principal design criteria that are applicable to  
4 Chapter 5. I will get into more detail on the next  
5 couple of slides for each of these PDCs, but in  
6 general they cover -- PDC 2 discusses the requirement  
7 for safety-related systems, structures, and components  
8 to be protected against the effects of natural  
9 phenomena; PDC 10 requiring that specified acceptable  
10 system radionuclide design limits are not exceeded;  
11 PDC 12 for ensuring power oscillations aren't possible  
12 or can be reliably readily detected; PDC 16 and 60  
13 which deal with controlling the release of radioactive  
14 materials to the environment; PDC 33 requiring a  
15 system to maintain coolant inventory; and also PDC 70  
16 which deals with reactor coolant purity based on  
17 design limits that I will get into on a subsequent  
18 slide.

19           Next slide, please?    So this slide just  
20 covers a list of applicable topical reports to this  
21 section. And as they come up in the subsequent slides  
22 we can add more detail, but I don't have much to say  
23 on this specific slide.

24           So next slide, please?    This slides  
25 contains the staff evaluation of PDC 2, which as I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 mentioned requires safety-related systems, structures,  
2 and components be protected against the effects of  
3 natural phenomena. And so information in the PSAR  
4 notes that the PHTS piping and supports are designed  
5 in accordance with ASME Code B31.3 and the heat  
6 exchanger is designed in accordance with ASME Code --  
7 Section 8 standards. And the design of the non-  
8 safety-related primary heat transport system will be  
9 such that a failure of that system would not affect  
10 the performance of safety-related SSCs due to  
11 something like a design-basis earthquake. In the PSAR  
12 it notes that the sufficiently small pipe thickness  
13 will be used so that the failure of these pipes would  
14 not impact the vessel nozzles and the staff had found  
15 that the preliminary design information provided for  
16 the primary heat transport system is consistent with  
17 PDC 2.

18 Next slide, please?

19 MEMBER MARCH-LEUBA: Can we --

20 MR. CHERESKIN: Yes. Sorry.

21 MEMBER MARCH-LEUBA: -- go to the previous  
22 slide with the topical reports?

23 MR. CHERESKIN: Yes.

24 MEMBER MARCH-LEUBA: Yes, notice that the  
25 last two, 13 14 are not approved yet or reviewed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 That's correct, right?

2 MR. CHERESKIN: Those were recently  
3 issued, I think maybe last month.

4 MEMBER MARCH-LEUBA: And there's an SE out  
5 on them?

6 MR. CHERESKIN: Yes.

7 MEMBER MARCH-LEUBA: That's what I -- but  
8 it doesn't say A.

9 CHAIR PETTI: This slide is a little old.

10 MR. CHERESKIN: Yes, that was --

11 CHAIR PETTI: At the time they did the  
12 review it was not A, but today it's A.

13 MR. CHERESKIN: That is correct. They're  
14 A today. It was just a matter of timing.

15 MEMBER MARCH-LEUBA: I was just going to  
16 comment that the issue of going between CP and OL,  
17 we're kind of pushing things to next year and we need  
18 to keep a mental picture of what's missing. And if  
19 something were to change what would effect on our  
20 conclusions?

21 MR. CHERESKIN: It's understood.

22 MEMBER MARCH-LEUBA: But fix the slides,  
23 what is says, and that way it won't make a problem.

24 MR. CHERESKIN: I think we covered this  
25 slide. I think I went through my notes here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   Next slide, please? All right. So this  
2                   is the staff evaluation of PDC 10 which requires that  
3                   the SARRDLs aren't exceeded during normal operations  
4                   or unplanned transients. And the staff had found that  
5                   the preliminary information in the PSAR is consistent  
6                   with PDC 10. As Kairos noted, the coolant properties  
7                   are found in the cited topical report on this slide.  
8                   Additionally there's a chemistry control system that  
9                   can maintain FLiBe composition. There's also a  
10                  proposed technical specification to maintain the  
11                  coolant within allowable limits.

12                  And this all rolls up to the coolant  
13                  being resistant to thermal hydraulic instabilities due  
14                  to its high heat capacity. And I would note that the  
15                  actual evaluations of thermal hydraulics to  
16                  demonstrate consistency with this PDC are found in  
17                  Chapter 4 of the staff SE. And then Chapter 6 of the  
18                  staff SE actually evaluates the decay heat removal  
19                  capabilities of the system.

20                  Next slide, please? So this is the staff  
21                  evaluation of PDC 12 requiring coolant systems to  
22                  ensure power oscillations that could result in  
23                  exceeding SARRDLs aren't possible or can be reliably  
24                  and readily detected and suppressed. And the staff  
25                  had found that the preliminary information in Chapter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 5 is consistent with PDC 12 as the primary heat  
2 transport system can limit and suppress inlet  
3 temperature and mass fluoride oscillations and limited  
4 train gas in the coolant, maintain coolant  
5 specifications.

6 And as I mentioned on the previous slide,  
7 the resistance of the coolant to thermal hydraulic  
8 instabilities. And also similar to the last slide,  
9 other sections of the staff's safety evaluation  
10 contain the full evaluations of consistency with PDC  
11 12, Chapter 4 for the nuclear design and Chapter 7 for  
12 the required instrumentation and controls.

13 Next slide, please? Okay. So this slide  
14 combines the evaluation for PDCs 16 and 60 as they are  
15 pretty similar. And the function of the FLiBe to be  
16 consistent with these is also very similar. PDC 16,  
17 which requires a functional containment to control  
18 release of radioactivity and PDC 60 requiring the  
19 plant design to control the release of radioactive  
20 materials including during postulated events in the  
21 PSAR.

22 In Chapter 5 it describes the ability of  
23 FLiBe to retain fission products that may escape from  
24 the fuel and credits FLiBe as a radionuclide barrier  
25 in the safety analysis. And the staff had found that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the preliminary information in the PSAR is consistent  
2 with these PDCs as the ability of FLiBe to retain  
3 radionuclides was previously evaluated by the staff in  
4 the cited topical report here, the Mechanistic Source  
5 Term Topical Report, which contains the methodology  
6 for evaluating the ability of FLiBe to retain fission  
7 products with a KP-FHR design. Additionally Chapter  
8 14 in the PSAR contained a proposed tech spec to limit  
9 circulating activity which also supports assumptions  
10 made in that topical report.

11 Next slide, please? This slides contains  
12 the staff's evaluation of PDC 33 which requires a  
13 system to maintain coolant inventory to protect  
14 against small breaks in the safety-related portion of  
15 the coolant boundary. And so on this slide we have a  
16 discussion of the anti-siphon features for when the  
17 loss of the reactor coolant.

18 And so just to expand on that a little bit  
19 because I know we've had some discussions a couple  
20 weeks ago on this topic, there are a couple different  
21 anti-siphon features, and I think Kairos was talking  
22 about some of them during their presentation starting  
23 with the pump -- the primary salt pump suction inlet  
24 being above the required coolant level. So when the  
25 coolant drops below that it would help to break the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 siphon in the hot leg.

2 And additionally for the cold legs if  
3 there is a break in the primary heat transport system,  
4 gas flowing out of the covered gas system would also  
5 help to break the siphon from the cold leg as the  
6 argon gas could flow out of the cold leg as the  
7 coolant level decreases breaking the siphon. And  
8 that's facilitated by the cutout features in the core  
9 barrel which is mentioned in Section 4.3.

10 And so the information on these design  
11 features is -- the preliminary information is  
12 consistent with PDC 33. It's also consistent with the  
13 guidance given in NUREG-1537. And I think that's  
14 actually all I had on that slide. Sorry about that.

15 Next slide, please? Okay. So this slide  
16 contains the staff evaluation of PDC 70. PDC 70  
17 requires a system to maintain purity of the reactor  
18 coolant based on design limits that consider chemical  
19 attack, fouling and plugging passages, radionuclide  
20 concentrations, and air or moisture ingress due to  
21 leaks. And the preliminary information in the PSAR  
22 and also the RAI response that Kairos mentioned  
23 describes how the primary heat transport system is  
24 designed to either withstand or mitigate fouling, air  
25 ingress, chemical attack, and also manage radionuclide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 concentrations.

2           The staff had found this preliminary  
3 information is consistent with PDC 70 as there is  
4 coolant purity control and temperature monitoring that  
5 can detect the fouling or plugging of passages, the  
6 previously discussed ability of FLiBe to retain  
7 radionuclides combined with the circulating activity  
8 limits, and the ability to also remove those  
9 radionuclides from FLiBe. As discussed previously  
10 there are the Material Qualification Topical Reports  
11 which assess chemical attack and FLiBe.

12           And the last bullet here that I wanted to  
13 cover is the ability of the primary heat transport  
14 system to limit forced air ingress due to the design  
15 features that Kairos described during their  
16 presentation in order to remain within bounds of  
17 qualification testing, and as described in Chapter 13  
18 of the PSAR, the availability of compensatory measures  
19 after I believe the seven days that Kairos described.

20           Next slide, please? I think this is one  
21 of the last slides here covering testing and  
22 inspection. And the PSAR states that the design of  
23 the PHTS allows for inspection, maintenance, or  
24 replacement activities and it states that any testing  
25 or inspection will be submitted with the OL

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 application. And so this is a future review item for  
2 the NRC staff to look at these programs at the time of  
3 the operating license application.

4 This might be my last slide.

5 Next slide, Ed? Oh, sorry.

6 And so this slide is just the technical  
7 findings in conclusion here that the preliminary  
8 design information in the PSAR is consistent with the  
9 applicable criteria in NUREG-1537 and the PDCs  
10 discussed on the previous slides and that the  
11 information in Section 5 of the PSAR is sufficient for  
12 issuance of a CP in accordance with 10 CFR 50.35 and  
13 50.40 with the rest of the reviews being left for the  
14 operating license application.

15 Next slide, please? All right. And that  
16 was the last slide. Are there further questions?

17 MEMBER HALNON: Yes, Alex, this is Greg.  
18 Given the unique nature and I guess first-of-a-kind-  
19 type reactor this is, can you -- are you going to  
20 handle technical specifications in the same way that  
21 you would normally do it? In other words, I'm looking  
22 at PDC 70, to maintain reactor coolant purity. I  
23 mean, clearly there were tech specs proposed for  
24 radionuclide inventory of the FLiBe. Are you going to  
25 go deeper than that to make sure that in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 situation the secondary systems that are supporting  
2 those types of attributes of the PDC will be  
3 maintained in spec? I guess what I'm thinking about  
4 is there going to be the auxiliary systems that we  
5 talked about in Chapter 9 that may have tech specs  
6 requirements, non-safety systems, but tech spec  
7 requirements?

8 MR. CHERESKIN: So I think I'll answer  
9 that in two parts.

10 And, Ed, I might ask you to chime in  
11 because I believe you did the full review of Chapter  
12 14 here.

13 But given that these are only proposed  
14 tech specs at this time obviously there's no final  
15 proposed -- no final technical specifications or a  
16 final staff finding on it. But I would note that even  
17 in the proposed tech specs in Section 3.3 there are  
18 some of the proposed tech specs, for example, for  
19 inner gas system pressure. And so I mean there's at  
20 least something in here in the preliminary information  
21 that indicates that could be a possibility. But  
22 again, the final determination of that would obviously  
23 be made with the operating license.

24 MEMBER HALNON: Okay. So there wouldn't  
25 be tighter controls placed on a first-of-a-kind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 through tech specs? It would be through other means?  
2 Or do you think that those discussions -- I mean, they  
3 have to be had, I understand that, but I'm curious how  
4 deep we're going to go with that.

5 I realize that there were a lot proposed  
6 high-level tech specs, but some of these things --  
7 when we talk about maintain reactor coolant purity,  
8 chemical attack, fouling and plugging -- so those  
9 radionuclide concentrations, those just beg of limits  
10 being put somewhere, being monitored consistently and  
11 inspectable, if you will, from the standpoint of  
12 normal operations.

13 So I guess it's -- again we're going to  
14 start from pretty much scratch looking at the PSAR  
15 going to the FSAR, but I was just curious how deep  
16 we're going to go with the tech specs and requirements  
17 being the first-of-a-kind. Is it going to be more  
18 stringent than you think down the road when all these  
19 things are proven? That's probably more of a  
20 statement than a question. You don't have to answer.

21 MR. HELVENSTON: Yes, this is Ed  
22 Helvenston from the staff. I'll just clarify that in  
23 PSAR Chapter 14 Kairos did list a number of the  
24 probable subjects of what the tech specs are going to  
25 be. There were some things related to coolant purity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and other items, but it's understood that perhaps that  
2 list could be considered to cover some of the most  
3 significant items, but we certainly, at least from the  
4 staff's standpoint, don't consider that to be a  
5 comprehensive list.

6 We will do a much more detailed review of  
7 the tech specs at the operating license application  
8 and we'll certainly consider the level of importance  
9 to safety of various systems in those tech specs. And  
10 I think just because something is not necessarily  
11 safety-related, that doesn't automatically preclude it  
12 not having a tech spec limit on it if necessary.

13 MEMBER HALNON: As these progress I'm just  
14 interested in how those support systems will be  
15 controlled, the cooling systems in the same way. So  
16 like I said, more to be talked about later. Thanks.

17 MR. HISER: And this is Matt Hiser. I  
18 just wanted to offer one -- I think Alex was trying to  
19 mention this. There is an indication in their PSAR of  
20 inert gas system pressure, argon purity in the covered  
21 gas. So that's a non-safety-related system, but  
22 they've indicated they probably will have tech specs  
23 associated with those items. And to Ed's point and  
24 Alex' point, there may be more as they finalize the  
25 design. And then as we go through the review process,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 they may find that additional tech specs on non-  
2 safety-related aspects of the design are needed to  
3 ensure safety. If that's helpful.

4 MEMBER HALNON: Yes, it is. Are all the  
5 attributes of PDC 70 sort of like -- I mean, this is  
6 probably an easy one to look at, like moisture ingress  
7 and air moisture, measurement of that in the gases and  
8 whatnot. Are each one of those items going to kind of  
9 filter down into some limits somewhere in tech specs  
10 or is it too early to really go through that  
11 discussion?

12 MR. CHERESKIN: It might be a little early  
13 to determine if it would end up in somewhere like tech  
14 specs because there are also things like chemistry  
15 control programs which might not be explicit in the  
16 tech specs. And so I think it's a little premature to  
17 say exactly where they would end up, but I think the  
18 design criterion is pretty clear that purity limits  
19 need to be based on those factors. And so I think  
20 they would be somewhere.

21 MEMBER HALNON: Okay. Yes, it's like  
22 fouling and plugging. I mean, how do you measure it?  
23 How do you make sure that PDC 70 is being met from a  
24 fouling perspective? I know in light water reactors  
25 we do eddy currents and we do heat transfer and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 whatnot. We have plugging limits and all those types  
2 of things. Are those types of things going to be part  
3 of this as well? Again, you have to get the actual  
4 heat exchanger design in front of you to be able to  
5 talk about that. So, I got it. Thanks.

6 CHAIR PETTI: I had a question, but it may  
7 be more for Kairos. A chemistry control system, does  
8 it actually remove stuff from the coolant? I  
9 understand the whole keeping the composition correct,  
10 but there's going to be fission products in it. What  
11 I'm really worried about is the uranium. When you get  
12 beryllium you get uranium with it. And that's going  
13 to see the neutron field and could produce a mixed  
14 hazardous waste. It may make it difficult. It  
15 depends on the numbers. I've not run the numbers, but  
16 the presence of uranium in beryllium has historically  
17 been a problem with the disposal. This is more solid  
18 beryllium, blocks for instance, that are used in some  
19 reactors.

20 And so if the chemistry system can clean  
21 up some of that, they may be helping themselves in  
22 terms of at the end of the day with the way -- with  
23 what -- how to disposition the FLiBe. I just -- I  
24 don't know what functionalities that system has.

25 MR. MERWIN: This is Gus Merwin, Manager

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of Salt Chemistry. Appreciate the question. As  
2 stated in the PSAR and mainly in Chapter 9, the  
3 chemistry control system is only credited for ensuring  
4 the salt is within those tech specs that were just  
5 discussed. The circulating activity tech spec as part  
6 of -- I believe in the environmental report, is stated  
7 that the FLiBe will be ensured to be low-level  
8 radiological waste. And so we are aware of those  
9 effects. They're monitored. And we will ensure the  
10 FLiBe has a disposal path.

11 CHAIR PETTI: But saying that it's low-  
12 level waste, doesn't the presence of beryllium -- make  
13 it a RCRA mixed waste? I'm not an expert in this  
14 area. I always thought it was the combination of the  
15 two that did it.

16 MR. MERWIN: Yes, as part of our ER we did  
17 ensure that there was a disposal path in partner with  
18 a vendor for disposal of radiological materials. And  
19 they specifically were aware of the chemical form and  
20 the chemical composition of the waste.

21 CHAIR PETTI: Okay.

22 MEMBER KIRCHNER: You know there are  
23 pointers to control -- this is Walt Kirchner -- I  
24 think it's Chapter 9 has pointers to controlling  
25 chemistry. You also have to be concerned about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 transmutation products accumulating. So it suggests  
2 to me that the system will have the ability to strip  
3 out impurities.

4 CHAIR PETTI: Yes, if the system can take  
5 out some of that stuff that helps a lot. Again, not  
6 credited per se, but what is it actually going to do?

7 MEMBER KIRCHNER: Well, there's two ways  
8 to look at this. What's credited in terms of an  
9 accident scenario?

10 CHAIR PETTI: Right.

11 MEMBER KIRCHNER: And then what do you  
12 need to do to maintain the system?

13 CHAIR PETTI: Yes, I mean the other thing  
14 -- I mean I'm sure they're doing this, but the  
15 assumptions on how much fission products gets out is  
16 very high compared to what I think they're going to  
17 see. You want to make sure you design the system to  
18 see what you're going to see, not just what the safety  
19 limit is. Otherwise, what good is your system?

20 Any other questions?

21 (No audible response.)

22 CHAIR PETTI: Okay. Let's --

23 MR. HISER: I just want to make one  
24 clarification on the discussion earlier about topical  
25 reports and dash A. So typically the way it works is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 NRC issues the final safety evaluation and then the  
2 vendor develops a dash A version, it may be a month or  
3 two after, that incorporates the SE. I just want to  
4 be clear, we don't have a dash A yet, but we have a  
5 final SE out. So they're approved --

6 MEMBER MARCH-LEUBA: I wouldn't worry  
7 whether a revision 4 was in the future. You're  
8 revision 4 is in the past.

9 MR. HISER: Right. Yes. Correct. I just  
10 want to make clear for the record what -- we don't  
11 have a dash A today, but we will certainly by the time  
12 this CP is issued or down the line.

13 MEMBER MARCH-LEUBA: All they do is  
14 prepend the SER --

15 MR. HISER: Right.

16 MEMBER MARCH-LEUBA: -- and topical report  
17 and make the conforming changes to the --

18 MR. HISER: And stick dash A in the tape.  
19 Just wanted to make sure that was 100 percent clear.

20 MEMBER MARCH-LEUBA: Revision 4 is in the  
21 past. That's important.

22 MR. HISER: Yes, yes.

23 CHAIR PETTI: Okay. Then let's now talk  
24 about the memo.

25 Walt?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER KIRCHNER:    Okay.    While we're  
2 bringing the memo up I think the good thing here is  
3 that Kairos is building a prototype to demonstrate  
4 some of the key features of their design approach.

5                   So I'm not going to read my memo to you.  
6 Basically I would be repeating what Kairos and the  
7 staff have already presented.    So let me get to the  
8 bottom line.

9                   CHAIR PETTI:    Oh, yes.    Hold on, Walt.  
10 Just so that the court reporter doesn't have to record  
11 this part of the memo reading discussion.    Thank you.

12                   (Whereupon, the above-entitled matter went  
13 off the record at 9:20 a.m. and resumed at 9:36 a.m.)

14                   MR. CILLIERS:    Good morning, everyone.  
15 This is Anthonie Cilliers.    I'm the Director of  
16 Instrumentation, Controls & Electrical.    And I thank  
17 you for the opportunity to be able to present this  
18 Chapter 7 of the PSAR on instrumentation and control  
19 systems to you.    Next slide.

20                   So the chapter consists of a couple of  
21 systems, the first system notably being the reactor  
22 protection system.    It's a safety related system that  
23 provides protective, protection for reactor operations  
24 by initiating signals to mitigate the consequences of  
25 postulated events and ensure a safe shutdown.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The second one, the plant control system,  
2           is a non-safety related system.       And that's  
3           responsible for controlling the plant parameters  
4           during normal operations and providing data to the  
5           main control room control consoles.

6           The main control room provides means for  
7           the operators to monitor the behavior of the plant and  
8           control room performance of the plant.   The remote  
9           onsite shutdown panel provides a separate means to  
10          shut down the plant and to monitor plant parameters in  
11          response to postulated event conditions.

12          Of course, the system receives its inputs  
13          from various sensors throughout the system that are  
14          used to provide information about the plant parameters  
15          as inputs to the plant control system as well as the  
16          reactor protection system as safety related inputs  
17          into that system.

18          Sensors that are provided into the RPS are  
19          safety related as I've said.   And the plant control  
20          system receives its inputs from non-safety related  
21          sensors, as well as has access to the safety related  
22          sensor data through safety related isolation device or  
23          data diode.   Next slide.

24          I want to start off with taking you  
25          through the architectural system.   Since we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 presented this work to the committee previously, we  
2 have made a couple of changes in form of change  
3 packages, not fundamental design changes, but as  
4 details developed in the development of our reactor  
5 protection system we've added that information.

6 Notably, you will find that you'll see on  
7 the right-hand side the red box where the reactor  
8 protection system is. And I apologize. This is  
9 really small. But I believe you've got a printout,  
10 larger printout that you could be looking at.

11 So, on the right-hand side of the reactor  
12 protection system, we've moved the data diode into the  
13 reactor protection system itself. So you'll see the  
14 data diode there. And the reason for that is it is  
15 built into the architecture of the HIPS platform that  
16 we are using as our reactor protection system.

17 The reactor protection system is an FPGA  
18 based system. The HIPS platform I think you're all  
19 aware of the HIPS platform architecture. And it's  
20 both in hardwired, one-way communication. So we've  
21 moved that data diode, instead of being a separate  
22 device, to being part of the architecture.

23 You will also note that we have added the  
24 thermal management systems as systems on the little  
25 (audio interference).

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER SUNSERI: We're getting a bit of  
2 feedback. If participants could mute themselves, we  
3 could keep moving. Thank you.

4                   MR. CILLIERS: Thank you. You will also  
5 note that in the previous version of the architecture  
6 we had four non-safety related systems that were  
7 tripped. But we added the thermal management systems  
8 of both the reactive thermal management system as well  
9 as the primary loop thermal management system trips to  
10 that as well. And that makes logical sense, because  
11 those are heaters, and when we trip the system, we do  
12 not want to add heat while we are trying to remove  
13 heat at the same time.

14                   So those are the big changes to the  
15 system.

16                   Jumping back to the reactor protection  
17 system on the right-hand side, it receives four inputs  
18 from safety related instrumentation. And you'll find  
19 those four inputs are directly related to protecting  
20 the safety systems of the reactor.

21                   So that would be the temperature of the  
22 coolant in the reactor, the level of the coolant in  
23 the reactor, as well as the flux that's being created  
24 inside the reactor during operations. And for that  
25 flux monitoring, we do have a maximum flux trip, as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 well as a rate of change trip.

2 In addition, you'll see the PHSS bubble  
3 there. And that has been defined the inert gas  
4 pressure sensor that will be tripping on, as stated in  
5 previous chapters as well, to trip the reactor on any  
6 break in the inert gas system to prevent air increase  
7 or limit air increase into the system.

8 I think it's key to note that the  
9 separation between the reactor protection system and  
10 the plant control system is absolute. The only link  
11 between the two systems is through the physical  
12 operation of the plant itself. And that is  
13 specifically to prevent any adverse effects of the  
14 plant control system to affect the reactor protection  
15 system's safety functions.

16 So, basically, the reactor protection  
17 system removes power from the safety related relays,  
18 which will then remove electricity from all of the  
19 active systems. Notably, it will trip the shutdown  
20 elements into the core. It will trip the primary salt  
21 pump. It will prevent heaters from heating up the  
22 plant and a number of other systems that stop  
23 functioning until the reactor protection system finds  
24 that the parameters have returned back to normal.

25 I think we can move to the next slide, or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 if there's any questions.

2 MEMBER BROWN: Yes, let me ask one. Can  
3 you go back to that again?

4 MR. CILLIERS: Yeah, sure.

5 MEMBER BROWN: And I'm looking at your --  
6 I think you've got another slide where you show the  
7 RPS trip logic. Is that --

8 MR. CILLIERS: That's correct --

9 MEMBER BROWN: Okay. I'll save my one  
10 comment for that.

11 We've got a safety related system for the  
12 RPS, do all the right things on the relays. But  
13 there's no safety related power supply. Is it not --  
14 I couldn't tell from Chapter 8 whether that was a dual  
15 redundant power supply fed from separate somethings.

16 Whether it's safety related, it's not --  
17 but there's no dual power supply anywhere. It's a  
18 single power supply. That was the implication I got  
19 from the other diagrams in Chapter 8.

20 So I guess that's a question that's  
21 hanging out there that I guess should be addressed at  
22 some point.

23 MR. CILLIERS: I think it's very important  
24 to note that we do not create any electrical supply  
25 for safety functions. In fact, we remove electrical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 supply for the activation of safety functions.

2 So the reactor protection system actively  
3 keeps the system alive while in operation and removes  
4 the voltage from those relays to shut the reactor  
5 down. The same would happen in the event of a loss of  
6 power. We would automatically shut down.

7 That being said, we do have, and we'll  
8 talk about it in Chapter 8, but we do have a backup  
9 power supply system, because clearly as an investment  
10 protection system we would not want to lose  
11 electricity supply to our systems. We would rather  
12 take it away with the reactor protection system. Also  
13 -- yep.

14 MEMBER BROWN: I understand that point.  
15 The backup system, though, is just another set of  
16 generators that replaces the grid.

17 What I was talking about was the UPS power  
18 supply that you have feeding the RPS. And what  
19 you're, from a safety standpoint, you're saying it  
20 doesn't, you're just setting yourself up for a plant  
21 shutdown in case you lose the UPS.

22 MR. CILLIERS: That is correct --

23 MEMBER BROWN: And that's okay. I got it.  
24 I got it. I just, it was just a matter of  
25 reliability. I'm not questioning the duality that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you've got in the RPS at this point. Okay?

2 MR. CILLIERS: Correct.

3 MEMBER BROWN: And you're willing to  
4 accept that is all I'm saying.

5 MR. CILLIERS: Yes, we do.

6 MEMBER BROWN: Okay. All right. Go on  
7 then.

8 MEMBER HALNON: Yeah, this is Greg. A  
9 real quick question on the reactor trip or vessel  
10 level monitoring. Is that perceived to be straight  
11 vessel level, or is that going to be triggered off of  
12 the inventory management system type parameters, such  
13 as when the PSP gets tripped based on leakage  
14 detection or something to that effect? I guess the  
15 question is, is it going to be an indirect or is it  
16 just vessel level? So --

17 MR. CILLIERS: It is a safety related,  
18 direct indication of the vessel level inside the core.  
19 So we have a vessel level indication directly from the  
20 core itself.

21 MEMBER HALNON: Okay. So, if the PSP gets  
22 tripped because the inventory management system  
23 determines that there's a leak, how will the reactor  
24 get tripped?

25 MR. CILLIERS: The reactor will be tripped

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 through the same systems that, the inputs that's  
2 coming into the reactor protection system. So it's  
3 very important to note that, as I said, there's a  
4 separation of operations between the reactor  
5 protection system and the plant control system.

6 All parameters that would trip the reactor  
7 is when any parameters move outside of the boundary  
8 that may challenge the safety systems of the reactor,  
9 in other words, if the temperature goes higher than a  
10 specific set point, if the level goes lower than a  
11 specific set point, or the neutrons or the pressure in  
12 the system. If any of those does not happen, the  
13 safety systems are not being challenged and the plant  
14 will continue basically operation in normal until that  
15 happens.

16 I have to add to that, if anything happens  
17 on the plant control system side where the pump is  
18 tripped or any of those systems are tripped, the plant  
19 control systems also maintain full functionality until  
20 you're able to shut down the reactor itself or shut  
21 down various systems around that, although those will  
22 not be deemed as safety functions because it's not  
23 within the scope of challenging any of the safety  
24 systems that we're protecting with the reactor  
25 protection system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Okay. So the reactor  
2 trips will protect from safety limits or whatever --

3 MR. CILLIERS: Correct.

4 MEMBER HALNON: -- whatever margin, and  
5 the plant control system may also trip the reactor  
6 based on parameters going so far out that, even though  
7 they haven't challenged the reactor safety limits,  
8 they are not a good place to be operating. Is that  
9 correct?

10 MR. CILLIERS: That is correct. That is  
11 absolutely correct.

12 So any of the trips, like you mentioned,  
13 the primary salt pump trip would result in a sequence  
14 of events all coming from the reactor, the plant  
15 control system while in operation.

16 MEMBER HALNON: Okay. So there will be a  
17 distinction between non-safety trips and safety trips  
18 in other words.

19 MR. CILLIERS: Correct.

20 MEMBER HALNON: Okay. Thanks.

21 MEMBER BROWN: Okay. I have one other --  
22 are you done?

23 MEMBER HALNON: Yes.

24 MEMBER BROWN: Okay. I have one other  
25 question, this is Charlie Brown again, relative to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 power supply routine.

2 I understand the backup goes away. Right  
3 now you show in Chapter 8 a UPS for that. And then  
4 you show in the Chapter 8 discussion, as well as the  
5 figure, that it can maintain itself for 72 hours on a  
6 UPS performance basis.

7 So, even though you lose the grid and you,  
8 if your other backup power supply doesn't come on,  
9 you've still got RPS systems in place for any other  
10 things that happen in the reactor to take care of at  
11 least for a three-day period while you're taking other  
12 actions. Is that -- I'm just trying to connect the  
13 dots between Chapter 8 UPSs and the concept.

14 I have no problem with the idea that if  
15 you lose power you shut down the reactor, that the UPS  
16 does shut down the reactor. And that's a reliability  
17 issue. And that's, if you accept that, that's okay.  
18 But is the 72 hours accurate?

19 MR. CILLIERS: I believe so, yes. I  
20 believe --

21 MEMBER BROWN: All right. That's fine.  
22 I just wanted to make sure. There's little subscripts  
23 under the UPS in the figure. So thank you.

24 MR. CILLIERS: Yeah, I know it's very  
25 small.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           The purpose of that 72 hours is, of  
2 course, we would like to have power during any event.  
3 Although we do not rely on it, it's better to have it  
4 and to be able to monitor the system continuously.  
5 But it doesn't provide any safety functions.

6           MEMBER BROWN: I got that. I'm not  
7 questioning that issue.

8           MR. CILLIERS: All right.

9           MEMBER BROWN: Thank you. Okay. Go  
10 ahead.

11          MR. CILLIERS: Okay. Next slide.

12           So the plant control system consists of  
13 three larger systems. The one is the reactor control  
14 systems. We perform the functions associated with the  
15 reactivity control and power level adjustments.  
16 Members --

17          MEMBER BROWN: Oh, can --

18          MR. CILLIERS: Sorry?

19          MEMBER BROWN: Can I interrupt you again  
20 for --

21                   (Simultaneous speaking.)

22          MEMBER BROWN: Don't flip slides. I just  
23 noticed on the RPS slide that's in Rev. 2, as opposed  
24 to Rev. 0, there is a new acronym called HRCS, but  
25 it's not listed in the acronym table. And I keyworded

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it for all of Rev. 2, and it's not listed anywhere.  
2 So I have no idea what HRCS is as a --

3 MR. CILLIERS: That's the heat rejection  
4 control system.

5 MEMBER BROWN: Oh, okay. Well, you might  
6 mention it in the text somewhere, because it --

7 MR. CILLIERS: Thank you for that. That  
8 was a system that was added a little later.

9 MEMBER BROWN: Okay. Thank you. Sorry to  
10 interrupt.

11 MR. CILLIERS: Thank you. So the three  
12 systems in the plant control system, this is a non-  
13 safety system. So this is during normal operations.  
14 The plant control system will be operating the reactor  
15 itself, including its reactivity control and power  
16 level adjustments, as well as monitoring the core  
17 neutronics in the pebble handling and storage systems.

18 The reactor coolant auxiliary control  
19 system performs functions associated with chemistry  
20 control, inventory management system control, the  
21 inert gas system control, and the tritium management  
22 system and monitoring control.

23 And then we've got the primary heat  
24 transport control system, which perform the functions  
25 associated with control of the flow rate through the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 primary heat transport system, the primary heat  
2 transport system's thermal management, as well as the  
3 control of the heat rejection system that we've just  
4 been talking about, and the primary loop draining,  
5 filling, and piping monitoring.

6 The plant control system receives input  
7 from non-safety related sensor inputs as well as  
8 safety related sensors from the reactor protection  
9 system through the data diode, as described  
10 previously. And it's electronically and functionally  
11 isolated from the safety related RPS using a safety  
12 related isolation device or data diode.

13 The plant control system generates control  
14 outputs based on sensor inputs and set points provided  
15 by the control system. And these set points are  
16 adjusted automatically based on the plant operating  
17 mode or in some cases by operators via the main  
18 control room console. So the operators do have  
19 control over this system, while it is not changing any  
20 safety systems before reactor protection system takes  
21 over. Next slide.

22 Moving on to the reactor protection  
23 system, this is the safety related system that is  
24 created for tripping the reactor system and initiating  
25 protective --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER BROWN: Can I interrupt again?

2 MR. CILLIERS: Yes.

3 MEMBER BROWN: Please. This is Charlie  
4 Brown again. Can you go back to the previous slide?  
5 Oh, no, go all -- now that you're on the plant control  
6 system, can you go back to the overall figure? That's  
7 it. That can't be. Does everybody have a bigger  
8 picture of this?

9 MR. CILLIERS: Yes, right here.

10 MEMBER BROWN: Okay. I'll just bring this  
11 up now from a single failure standpoint. All the data  
12 from the plant control system goes up into a  
13 distributed, as you all -- let me see it to make sure  
14 I get the -- it's a microprocessor based distributed  
15 control system --

16 MR. CILLIERS: Correct.

17 MEMBER BROWN: -- individually controls  
18 plant systems using inputs. That's the -- but all  
19 that data goes up into a gateway. Then it goes to the  
20 supervisory controller, then up into this redundant  
21 dual -- I can't read the rest of it. I've got to get  
22 the right chart here. Real-time data highway, and  
23 then through another gateway and up into the main  
24 control room.

25 So those are all, that's a single line of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 everything. If that bus fails or the gateways fail,  
2 there's no data going to the main control room. That  
3 seems to be not a particularly useful design approach  
4 to maintain your overall visibility of what's going on  
5 in the plant.

6 In addition, now the gateway up in the  
7 main control room connects to, as you all noted,  
8 TCPI/IP modems and/or fiber optic modems, however they  
9 want to phrase them, which effectively sounds to me  
10 like connections to the outside world, and doesn't  
11 mention -- it says, I'm not talking cyber security at  
12 this point. It's just control of access to this bus,  
13 which seems to be totally open to the universe the way  
14 it's designed.

15 So I don't know what your all's thought  
16 process is. That just seems to be a weakness in terms  
17 of control of access from whatever external source is  
18 to the main control room and other, and the local  
19 systems are. But it also sets you up for a major  
20 cyber security issue.

21 Now, you talk about using IEC, whatever it  
22 is. I've forgotten the numbers for that. That means  
23 you're embedding cyber, you know, malicious code  
24 detection stuff enveloped in all the software that  
25 you've got to manage, all the data going up in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 managing the plant. Just bringing that up as a point.

2 That's, a single failure is one point, and  
3 then the control of access is another point that I --  
4 so I'm just mentioning that so you will be aware, from  
5 my thought process. That's my thought process, not  
6 the committee's. You can go back and finish the rest  
7 of the slides now. This was just --

8 MR. CILLIERS: Thank you. Can I respond?

9 MEMBER BROWN: Of course.

10 MR. CILLIERS: Yeah, I'd like to respond  
11 to it. Thank you very much for that. That is  
12 something that from this architecture we did not  
13 include or show any of the redundancy systems.

14 In our subsequent development, and I did  
15 not feel that it's necessary to put that in the piece  
16 or at this stage, but in further developments of the  
17 architecture we do indicate redundant, both redundant  
18 controllers on the plant control system side. So we  
19 have two controllers. So, if there's a fail, it moves  
20 over to the other controller, as well as redundant  
21 highways. So thank you very much for that. We've  
22 also included that into our design that will be  
23 presented in the OLA phase.

24 The connection to that cloud, the TCPI/IP  
25 connection, we've also built (audio interference) into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that part of the design since we've spoke about this  
2 previously. It's very important to note that that  
3 internet connection or that TCP/IP connection to the  
4 outside world, although --

5 (Simultaneous speaking.)

6 MEMBER BROWN: Excuse me. Can I interrupt  
7 you a second? We're losing you. You're fading in and  
8 out. I don't know what -- and it's reverberating.

9 MEMBER MARCH-LEUBA: Yeah. Can you speak  
10 closer to the mic?

11 MEMBER BROWN: Yeah, stay closer to the  
12 mic.

13 MR. CILLIERS: I'm moving the microphone.  
14 Is that better?

15 MEMBER BROWN: Yeah, we just --

16 MEMBER MARCH-LEUBA: Yeah, speak slowly,  
17 because you're going a little garbled, but keep going  
18 --

19 MR. CILLIERS: Okay. I'll speak slowly.  
20 So the connection to the outside world, in our  
21 development of that system, we use a specific control  
22 protocol. And we only provide read-only connections  
23 to the outside world. So there's no routes of control  
24 or any sort of communication path back into the  
25 control system using that connection. So that's a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 very specific one-way communication. Other than that,  
2 it's for monitoring of plant parameters from remote  
3 locations such as headquarters or remote support  
4 safeway where the engineers will be supporting from --

5 MEMBER BROWN: Okay. Can I interrupt  
6 again for a second? Okay. I got that. That's fine.  
7 Not a problem with that, if it's a one-way. But is it  
8 a one-way, how do I phrase this, a hardware based one-  
9 way not configured by software, or is it a fancy-dancy  
10 bidirectional transmission device which is configured  
11 by software to make it one-way?

12 It's just something to consider in your,  
13 in the longer term when we see the final operating  
14 license design, as you say, you're working on for the  
15 subsequent submittals. I just wanted to bring that  
16 point up, is how that one-way is configured does make  
17 a difference.

18 MR. CILLIERS: Yeah, thank you very much.

19 MEMBER BROWN: Okay? Thank you.

20 MEMBER MARCH-LEUBA: Yeah, let me say it  
21 in a different language with the same concept. On the  
22 top left of that blue box on the control room, you  
23 have a cloud connection via TCPI/IP encrypted --

24 MEMBER BROWN: Yeah, that's what I was  
25 talking about.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER MARCH-LEUBA:  -- I assume it's a  
2                   VPN.  If you totally intend it to be unidirectional,  
3                   yes, or monitoring and no action can be taken from the  
4                   outside, it would be best if you put the diode in  
5                   there so that it is enforced.

6                   MEMBER BROWN:  Thank you.  That's two out  
7                   of two.

8                   MEMBER MARCH-LEUBA:  Yeah, I mean, the  
9                   diode on the red box on the right side into the  
10                  protection system, that's fantastic.

11                  MEMBER BROWN:  Yeah, that's excellent.  
12                  That's a --

13                  MEMBER MARCH-LEUBA:  Yeah.

14                  MEMBER BROWN:  Love to see that when  
15                  you're doing your RPS setup.

16                  MEMBER MARCH-LEUBA:  If you truly intend  
17                  to have a functional diode on the control room box  
18                  going into the cloud, put a real one.  And then you  
19                  don't have to worry about it.

20                  MEMBER BROWN:  It makes it easy when you  
21                  submit it also.  Thank you.

22                  MR. CILLIERS:  Well, thank you for that.

23                  MEMBER BROWN:  You can go on.  I'm sorry.

24                  MR. CILLIERS:  No, this is good.  Thank  
25                  you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           So, back to the reactor protection system,  
2           it's a safety related system created for tripping the  
3           reactor and initiating protective functions. It gets  
4           its inputs, as I've described, from specific safety  
5           related inputs.

6           It also allows for manual initiation of a  
7           trip from the main control room or the onsite shutdown  
8           panel, although this is not created as safety  
9           functions in the system, but it allows the operators  
10          to trip the system in the event of noticing that  
11          something is going in a specific direction.

12          It will also trip the reactor on loss of  
13          power with a small time delay to allow for backup  
14          systems to come on. And that is discussed more in  
15          Chapter 8.

16          It's got three predictive functions that  
17          result from the RPS actuation. It inserts the control  
18          rod and shutdown elements into the core. It inhibits  
19          actions from the plant control systems, and I've  
20          already mentioned a couple of them that could  
21          interfere with the reactor protection system. So it  
22          really puts the plant into a passive state where we  
23          rely on the decay heat removal system to remove the  
24          heat.

25          And the RPS is built on a logic-based

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 platform that utilizes discrete components and field  
2 programmable gate array technology.

3 I may add, and we've already discussed  
4 that in a previous chapter, that the reactor  
5 protection system also activates the DHRS system once  
6 the DHRS system is a required safety functions, in  
7 other words, when enough fission products has been  
8 accumulated in the system to have sufficient decay  
9 heat that needs to be removed by the DHRSs.

10 So it will activate that system and remove  
11 all manual deactivation capability from the operators  
12 and only hand that back once, after a shutdown and  
13 then once temperature has reduced sufficiently as to  
14 not challenge any of our safety related systems. Next  
15 slide.

16 So I'll go a little bit into the reactor  
17 protection system trip logic schematic. You will  
18 notice that we've got the inputs at the bottom in,  
19 multiplied by four. So there's four inputs from all  
20 the safety related inputs.

21 The reason for the four is we use two out  
22 of four voting logic. And it allows for one of these  
23 planes to be removed for maintenance purposes, and  
24 then we will move to two out of three voting logic in  
25 the system. So it allows for maintenance channel as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 well.

2 As the signals go in, the signals are  
3 conditioned, and it is determined if a trip should  
4 take place from each of these signals. And once those  
5 signals, if there's a trip determination coming in  
6 from any of those signals, it goes into the voting and  
7 actuation system, which then votes on the two out of  
8 four or two out of three voting system. And it then  
9 decides on which part of the systems need to be  
10 activated.

11 And you will see, you've got safety  
12 related relays from both of these trains that get shut  
13 down to remove power from the various non-safety  
14 related systems.

15 And you'll see that we've subsequently  
16 added two more systems to this list, which is not in  
17 this figure. We've got a change package in place to  
18 cover for that just for consistency's sake. And in  
19 addition, you'll also see the DHRS system, which is  
20 basically toggled on/off by this system itself.

21 MEMBER MARCH-LEUBA: This is Jose again.  
22 Can you --

23 MR. CILLIERS: Yes.

24 MEMBER MARCH-LEUBA: -- the difference in  
25 the actuation logic for the blue boxes, the non-safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 related trips versus the DHRS, the safety related one?  
2 I see that the switches are in series of the non-  
3 safety related line parallel for the safety related.

4 MR. CILLIERS: Yeah, so any of the  
5 priority logic systems could activate the DHRS system.  
6 And it ultimately happens the same to activate the  
7 other two, the other systems as well. If any of them  
8 should activate -- well, sorry, both of them should be  
9 activated to shut down the system itself. But the  
10 DHRS system, any of the two priority logic systems  
11 will allow the DHRS to be activated.

12 It's important to note that the DHRS  
13 systems are not activated on trip, although if it has  
14 been necessary, it can be done. But that is activated  
15 prior to any of the events based on the collection of  
16 data from the safety related sensors, and as I've said  
17 before, the activation of the --

18 MEMBER MARCH-LEUBA: Maybe I don't, I'm  
19 not reading correctly your diagram. But what you're  
20 saying is that DHRS, if either priority logic 1 or  
21 priority logic 2, only one --

22 MR. CILLIERS: Correct.

23 MEMBER MARCH-LEUBA: -- of the two is  
24 activated, DHRS will activate, just the blue boxes,  
25 HRCS, PSP, and so on. It requires both of them to be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 activated, both of them have to --

2 MEMBER KIRCHNER: It's cutting power to  
3 them. It's cutting power to the --

4 MEMBER MARCH-LEUBA: I know.

5 MEMBER KIRCHNER: -- to the boxes.

6 (Simultaneous speaking.)

7 MEMBER MARCH-LEUBA: The way I read this  
8 is the blues trip if only one of the logics are  
9 tripped, but DHRS requires both.

10 MEMBER BROWN: It turns on with either  
11 one.

12 MEMBER MARCH-LEUBA: It's the same thing  
13 --

14 MEMBER BROWN: Either one of the priority  
15 logics will actuate --

16 MEMBER HALNON: You're saying this in its  
17 activated state.

18 MEMBER BROWN: Say again.

19 MEMBER HALNON: You're saying this in its  
20 activated state. So --

21 (Simultaneous speaking.)

22 MEMBER BROWN: -- in its deactivated  
23 state, only one to activate.

24 MEMBER HALNON: Well, I mean, I'm talking  
25 about the RPS is actuated in this state.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: I think it's --

2 (Simultaneous speaking.)

3 MEMBER HALNON: So you're turning, either  
4 one can turn off the non-safety system or either one  
5 can turn on. So, if you follow just electrons through  
6 the wires --

7 MEMBER MARCH-LEUBA: Okay, okay. So the  
8 blue trips, you turn them off --

9 MEMBER HALNON: Right.

10 MEMBER MARCH-LEUBA: -- when you trip.  
11 And DHRS on --

12 MEMBER BROWN: Yeah.

13 MEMBER HALNON: Correct.

14 MEMBER MARCH-LEUBA: Okay.

15 MEMBER BROWN: They tried to show that on  
16 the other diagrams as well.

17 MR. BLEY: This is Dennis Bley. I've got  
18 a related question. Over in Chapter 8, it says if you  
19 do get an activation of DHRS, RPS then removes 24 volt  
20 power so that operators can't inadvertently disable  
21 DHRS. Is that done through the same area, or is that  
22 different, handled somewhere else in RPS?

23 MR. CILLIERS: Yeah, that is actually done  
24 in the same area, but it's not shown on this picture.  
25 So --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. BLEY: And there's --

2 MR. CILLIERS: It's opening up the manual  
3 control so that there's no more path from manual  
4 controls to deactivate the DHRS system.

5 MR. BLEY: Okay. And it's done in the  
6 same kind of logic that's been used for everything  
7 else. It's not done through relays or something like  
8 that.

9 MR. CILLIERS: No, it's done through the  
10 same logic. When the DHRS system is activated by the  
11 RPS, it also removes the path for manual actuation by  
12 the operator.

13 MR. BLEY: Okay. I'm just -- when you do  
14 something like that, I always wonder if there's some  
15 way that can get you into trouble. But I'm not, I  
16 can't think of it, if there is. Okay. Thanks.

17 MEMBER HALNON: So what is the input from  
18 the pebble handling system. I can't remember. Was  
19 that in the PSAR or was it --

20 MR. CILLIERS: Oh, I mentioned it earlier.  
21 That is an inert gas pressure sensor. You're talking  
22 about the PHSS at the bottom?

23 MEMBER HALNON: Yeah, yeah --

24 MR. CILLIERS: Yes.

25 MEMBER HALNON: So that's the inert gas

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 system feeding into that?

2 MR. CILLIERS: Yeah, so the inert gas  
3 system is a larger system that maintains inert gas  
4 slightly above ambient pressure on the system, as well  
5 as within the pebble handling system. And should a  
6 break be detected other than the pebble handling  
7 system or anywhere in the inert gas system, that input  
8 will be triggered --

9 MEMBER HALNON: Okay. So it's more of an  
10 inert gas input than the PHSS. Sorry. I missed that  
11 earlier.

12 MEMBER BROWN: You done, Greg?

13 MEMBER HALNON: Yes.

14 MEMBER BROWN: I have one other question  
15 on this. Is there a reason the two manual trip  
16 switches only go to priority logic 2, priority logic  
17 1 is ignored?

18 MR. CILLIERS: There's no specific reason  
19 why it would go to only one. It could go to two as  
20 well, because it's not a safety related input. We  
21 just added it as an input to priority logic 2.

22 MEMBER BROWN: So it's got to go somewhere  
23 to trip the plant, right, if you --

24 MR. CILLIERS: Right.

25 MEMBER BROWN: And if you look back at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 your big overall diagram, those two switches go into  
2 a single box, which says priority logic 1 and 2. It  
3 says priority logic times two. It's just an  
4 inconsistency in how you represent the operation of  
5 the manual trip switches. I would think you'd go to  
6 both of them. That's my, again, that's a personal  
7 thought. It's kind of a wiring diagram issue, not a  
8 --

9 MR. BLEY: I don't know, Charlie. It's --  
10 if you're going to have two switches, why not run them  
11 -- it doesn't cost you anything different. Why not  
12 run them through both so you get a little better  
13 reliability?

14 MEMBER BROWN: I agree with you. The  
15 words, the figures imply one thing in one figure.  
16 That's the overall diagram. And when you get to the  
17 details, it's only one of them. It's an --

18 MR. BLEY: And there's a difference  
19 between something you have to do and something that  
20 just common sense says you probably ought to do.

21 MEMBER BROWN: Yeah. Anyway, you can put  
22 that on your plate for what you do with this figure  
23 the next time.

24 MR. CILLIERS: Right. Thank you.

25 MEMBER REMPE: So I have a question. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 thought I heard you say somewhere during this  
2 discussion that you're in the process of submitting a  
3 change package to this. Could you elaborate what's  
4 being changed and what impact that will have on what  
5 we're hearing today and have in our documentation and  
6 the staff's SC?

7 MR. CILLIERS: Yeah, thank you for that.  
8 So it was -- I basically picked up that in our main  
9 diagram we have, we've added the two thermal  
10 management systems, the reactor thermal management  
11 system as well as the primary coolant loop thermal  
12 management system as a trip, as one of the non-safety  
13 related boxes.

14 So there's four boxes in the one figure.  
15 In this one, we only have -- there's six boxes, non-  
16 safety related ones, in the third figure. There's  
17 only four in this one. So it's just for consistency  
18 that we're adding those two to this figure as well.

19 MEMBER REMPE: So the PSAR is changing?

20 MEMBER BROWN: If you look at Rev. 0,  
21 they've --

22 MEMBER REMPE: So is it in Rev. 2?

23 MEMBER BROWN: Yes, they're in Rev. 2 --

24 MEMBER REMPE: Okay.

25 MEMBER BROWN: -- but they're not in Rev.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 1, not in Rev. 0, which is --

2 MEMBER REMPE: That's fine. But he said

3 --

4 MEMBER BROWN: I went back and looked at  
5 Rev. 2 when we got that just to see for consistency.

6 MEMBER REMPE: So Rev. 2 has what we are,  
7 is the current version.

8 MEMBER BROWN: Yes. That's the one,  
9 that's the -- we got this one --

10 MEMBER REMPE: Okay. Yeah, I know we have  
11 it in Rev. 2. But it sounded like you're submitting  
12 something beyond Rev. 2. And that's not the case,  
13 right?

14 MR. PEEBLES: This is Drew Peebles, the  
15 senior licensing manager. It is an inconsistency that  
16 we're updating now. And --

17 MEMBER REMPE: So Rev. 2 is changing.

18 MR. PEEBLES: Right.

19 MEMBER BROWN: But that's, you're saying  
20 Rev. 2 did not pick up everything.

21 MR. PEEBLES: Correct. And again, this is  
22 just a change to make the figures consistent. The  
23 text is still correct.

24 MEMBER REMPE: Okay. And the staff is  
25 aware of this, and their SC, even though it's dated a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 while back, will not change.

2 MEMBER BROWN: Yeah, the main figure for  
3 the overall plant stuff made a couple of what it turns  
4 out to be fairly significant changes relative to the  
5 data diodes and where they'd be and how they're fed,  
6 through gateways or not through gateways. And they've  
7 now taken them out of the gateway operation.

8 MEMBER REMPE: But the staff's SC is not  
9 going to change from these corrections. Thank you.

10 MEMBER BROWN: I'm done. You can go. I'm  
11 sorry about that.

12 MR. CILLIERS: Thank you. The main  
13 control room remote onsite shutdown panel, it contains  
14 a capability related to the normal operations of the  
15 plant, including operator and supervisor workstation  
16 terminals, which provides alarms, annunciations, and  
17 personnel and equipment interlocks.

18 And it provides information from both the  
19 plant control system, as well as the reactor  
20 protection system, a manual trip switch that  
21 propagates through the gateway and into the safety  
22 related isolation to allow operators to initiate a  
23 plant trip, and the central alarm panel for the fire  
24 protection system to monitor the status of fire  
25 protection equipment in the reactor building and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 controlling the ventilation and extinguishing systems  
2 related to the fire response.

3 The remote onsite shutdown panel provides  
4 a human system interface for the plant staff to  
5 monitor indications from the reactor protection  
6 system, including the operating status of the reactor  
7 trip system and the decay heat removal system in the  
8 event that the main control room could become  
9 inaccessible or uninhabitable.

10 The remote onsite shutdown panel features  
11 one-way communication with the RPS and the ability to  
12 initiate a manual trip signal that actuates the RPS.  
13 And I will note that that is also not a safety related  
14 function. It's just an additional function that we've  
15 discussed before. Next slide.

16 The design basis for these, the RPS and  
17 safety related sensors are designed using relevant  
18 industry codes and standards such as the IEEE 603-2018  
19 and the quality assurance program to be included PDC  
20 1.

21 The RPS and safety related sensors are  
22 designed to extend and to be able to perform these  
23 safety related functions during adverse natural  
24 phenomena, PDC 2.

25 The RPS and safety related sensors are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 designed and located to minimize the probability and  
2 effects of fires and explosions, PDC 3.

3 The RPS is designed for the environmental  
4 conditions associated with normal operations,  
5 maintenance and testing and postulated events, PDC 4.

6 The RPS provides an active trip and decay  
7 heat removal actuations that ensure radionuclide  
8 release design limits are not exceeded during normal  
9 operations as a result of postulated events and upon  
10 reactor trip actuation, including in the event of a  
11 single failure of the reactivity control systems.  
12 These are PDCs 10, 20, and 25.

13 The reactor protection system as well as  
14 the plant control system and safety related sensors  
15 are designed to monitor plant parameters over the  
16 anticipated ranges of normal operations and postulated  
17 event conditions, PDC 13.

18 The design of the main control room allows  
19 actions to be taken to operate the reactor on a normal  
20 operating and postulated event conditions. It  
21 provides radiation protection allowing access and  
22 occupancy during postulated event conditions with  
23 occupants not receiving radiation exposures in excess  
24 of 5 rem TEDE for the duration of the event and  
25 maintains habitability, allowing access and occupancy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 during normal operations and postulated event  
2 conditions.

3 The remote onsite shutdown panel is  
4 located outside of the main control room and provides  
5 the capability to promptly shut down the reactor and  
6 monitor the unit during shutdown and provide  
7 capability for subsequent safe shutdown of the reactor  
8 through use of suitable procedures. That's PDC 19.

9 The reactor protection system and safety  
10 related sensors are designed with sufficient  
11 redundancy and independence to ensure no single  
12 failure results in a loss of protection functions, PDC  
13 21.

14 The result of natural phenomena and of  
15 normal operating maintenance, testing, and postulated  
16 event conditions do not result in loss of protection  
17 function of the RPS, all safety related sensors, PDC  
18 22.

19 The RPS fails to a safe state upon loss of  
20 electrical power or detection of adverse environmental  
21 conditions, that's PDC 23.

22 The RPS and safety related sensors are  
23 functioning independent from non-safety related  
24 control systems, that's PDC 24.

25 The RPS safe points are designed to limit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the potential amount and rate of reactivity to ensure  
2 sufficient protection from postulated events involving  
3 reactivity transients, PDC 28.

4 The RPS and safety related sensors are  
5 designed to be redundant to show that there's a high  
6 probability of accomplishing the safety related  
7 functions of the RPS in postulated events.

8 And I think most of those should be clear  
9 from this discussion we've had on the design itself.  
10 Next slide.

11 That's it. Any further questions?

12 MEMBER BROWN: Yes. You didn't show --  
13 going back to the big diagram, this is a small  
14 question, the overall --

15 MR. CILLIERS: The architecture?

16 MEMBER BROWN: Yeah, the big architecture  
17 picture.

18 MR. CILLIERS: That one, yes.

19 MEMBER BROWN: In the main control room,  
20 you show, you know, two operator workstations and a  
21 supervisor workstation. And in your comments relative  
22 to the single bus sending all that data, you said  
23 that's, you just didn't show the redundancy you intend  
24 to incorporate.

25 Do those workstations both, is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 intention to feed those workstations with both of the  
2 redundant, independent busses bringing all that plant  
3 control system data up to the main control room so  
4 that you can select them. You don't want them to  
5 interfere. But I presume you can select one bus or  
6 the other to maintain continuity.

7 MR. CILLIERS: Yeah, we haven't made a  
8 final decision on how we will be using the redundant  
9 systems. So I will not comment on that right now.

10 MEMBER BROWN: Okay. That's fine. Thank  
11 you. The question will come up. You know that.

12 MR. CILLIERS: Yeah.

13 MEMBER BIER: Hi. Question from Vicki  
14 Bier. On the discussion of control room habitability  
15 basically, that it provides adequate radiation  
16 protection to be usable during an emergency, have you  
17 also looked at habitability due to emergencies at  
18 other nearby facilities, whether chemical or  
19 radiological?

20 MR. CLARK: Hi, this is Austin Clark with  
21 the licensing team at Kairos Power. So we do, in the  
22 environmental report, go through an analysis of the  
23 impacts of events at nearby facilities, as well as  
24 nearby transportation routes. As far as the details  
25 of that analysis, you're welcome to review them in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 environmental report.

2 We did go through that analysis in Chapter  
3 2 a couple weeks ago. The big one I think is there is  
4 a potential for chemical spills on Highway Tennessee  
5 58 to potentially drift to the control room. But the  
6 dispersion over that distance is not anticipated to  
7 cause a major impact.

8 MEMBER BIER: Okay. Thank you.

9 CHAIR PETTI: Okay. I'm hearing no  
10 questions.

11 We're a little ahead of schedule. So  
12 let's take a -- I'm trying to do the math in my head.  
13 Okay. Let's just come back at 10:40. That's what the  
14 agenda said. We'll take a break. Thank you.

15 (Whereupon, the above-entitled matter went  
16 off the record at 10:23 a.m. and resumed at 10:40  
17 a.m.)

18 CHAIR PETTI: Okay, we're all back. It's  
19 time for the staff to talk about Chapter 7.

20 MR. ASHCRAFT: Hello, my name's Joe  
21 Ashcraft. I'm a -- hello, my name's Joe Ashcraft.  
22 I'm a NRR DEX electrical and control branch, and I'm  
23 a technical reviewer.

24 And myself and Calvin Cheung, we're the  
25 I&C reviewers for Chapter 7.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 Next slide. Who's running the slides?

2 Okay, oh, they took out my agenda so let's  
3 just go to this slide. You've seen it. I know some  
4 of our initial interfaces with Kairos, there was  
5 discussion about the diode for protection system.

6 They also had the displays up on the  
7 remote shutdown, you know, for safety related.

8 So, there was some discussions. We didn't  
9 really highlight or discuss too much, the non-safety  
10 side because our review is really supposed to be  
11 focused on safety.

12 But we did look at it. We had some  
13 comments.

14 As far as what you saw down at the bottom,  
15 I guess Joy asked a question. So there was a  
16 supplement that was issued, and that's where they  
17 introduced the RTMS, and the other one.

18 That supplement didn't update that back  
19 figure, so that's why you know, it's just an editorial  
20 concern.

21 But anyway, I was, figure we would spend  
22 a lot of questions here, but I think, I think Charlie,  
23 you done asked them all.

24 But if there's any additional questions,  
25 it's basically you know, the architecture is designed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 in four pieces.

2 You've got your safety related RPS; your  
3 PCS, which you know, they tend to control just about  
4 everything; and then main control room; and, remote  
5 shutdown.

6 And I think everything, we're going to get  
7 into the HRS, or at least what I think's going to  
8 happen.

9 You know, they mention they're using a  
10 HIPS now, but in the SAR that we have right now,  
11 that's not part of it.

12 So we didn't review it thinking that, but  
13 that last --

14 (Simultaneous speaking.)

15 MEMBER BROWN: Well but in the PSAR, they  
16 did, that's what you're talking about? It talked  
17 about a FPGA type system, which implied.

18 MR. ASHCRAFT: Yes, but it could be --

19 (Simultaneous speaking.)

20 MEMBER BROWN: It could be another one?

21 MR. ASHCRAFT: Right.

22 MEMBER BROWN: So you're saying it didn't  
23 explicitly call out --

24 (Simultaneous speaking.)

25 MR. ASHCRAFT: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: -- that? I noticed that.  
2 I just didn't say anything.

3 MR. ASHCRAFT: And at some point, you know,  
4 they made the comment so I'm assuming they'll either  
5 come in with the IBR and the topical report, and it's  
6 already been reviewed.

7 And at that time, which makes life a lot  
8 easier because it's been approved, and then we just  
9 have to focus on the ASAIs.

10 And even some of those, they might not  
11 apply to them but they'll have to at least discuss  
12 that.

13 So that makes, you know, the OL portion a  
14 lot easier.

15 But there's other areas that still need to  
16 be addressed. And I think it was brought up before.  
17 There's an Appendix A and we put you know, a lot of  
18 bullets.

19 One of them was the I&C platform, you  
20 know, that stuff. So there's areas --

21 (Simultaneous speaking.)

22 PARTICIPANT: Excuse me, could you lean  
23 into the mic? The people on the line are having  
24 trouble hearing.

25 MR. ASHCRAFT: Okay, sorry.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 PARTICIPANT: Thanks.

2 MR. ASHCRAFT: Sorry about that. I'll  
3 lean. Do I need to repeat all that, or are we good?

4 (No audible response.)

5 MR. ASHCRAFT: Okay, so if there's no  
6 additional questions --

7 (Simultaneous speaking.)

8 MEMBER HALNON: Just one other question.  
9 There will be another system, I mean some kind of  
10 input for the other systems, like chilled water or  
11 plant water systems?

12 I mean they're going to need some kind of  
13 control room interface, cooling water to the RB HVAC  
14 system. Cooling water to some of these pumps and  
15 stuff.

16 I mean it will be something in there,  
17 right? So there will be another block somewhere else  
18 that?

19 MR. ASHCRAFT: Well, not necessarily in  
20 Chapter 7. I mean those I&C type stuff is really  
21 dealt with the chapters.

22 But now as far as the you know, if you  
23 took a dive into the control panels and stuff, that  
24 you know, all that would be there. But that's not  
25 something we review in Chapter 7.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Okay, because like the  
2 treated water system interfaces with decay heat  
3 removed. There's some, something there.

4 MR. ASHCRAFT: Well, when you say in the  
5 descriptions, or it definitely will be in the logics.  
6 We'll see you know, schematics in the OL that will  
7 show all those ties to the various things.

8 MEMBER HALNON: Yes, that's what I'm  
9 saying, so there's going to be something else?

10 MR. ASHCRAFT: Oh, yes, yes.

11 MEMBER HALNON: As far as this?

12 MR. ASHCRAFT: Yes, I've been chomping at  
13 the bit. You know, as I look at, so right now the  
14 architecture's really just kind of a skeleton.

15 MEMBER HALNON: Right.

16 MR. ASHCRAFT: We don't know you know, the  
17 logic and stuff. And you know, so when I see, when I  
18 hear the discussion about the HRS, you know, I've  
19 already, I'm doing the you know, creating the logic in  
20 my mind.

21 But you know I'm not designing it. So,  
22 but I do have a sort of a different take on what I  
23 thought I heard when we did Chapter 6 on the VHRS.  
24 But let's go on.

25 So, but basically, and I'll just describe.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 So when you have your safety sensors, I can't read  
2 them but it's temperature, power and level, and the  
3 PHSS, if that trips the RPS or provides sufficient,  
4 then what happens is it'll cut power to the rod  
5 control.

6 So the control rods and shutdown elements,  
7 not rods, will go down. Then they talk about the DHRS  
8 is already the thimbles are full of water when they're  
9 operating, so it's not like it says it actuates the  
10 DHRS.

11 I believe what happens and what I've read  
12 in the description, it prevents them from shutting the  
13 water valves because that's that 7-day supply.

14 So that's effectively what that actuation  
15 from the RPS is doing. It's just keeping them from  
16 closing those valves.

17 And then you know, whether there's six  
18 blue boxes or four, effectively and they describe  
19 their process, what they're trying to do there is they  
20 don't want to overcool you know, and have their Flibe  
21 go solid.

22 They don't want to add additional heat,  
23 and they don't want to be you know, pumping in more  
24 Flibe and TRISO fuel.

25 So really, you know, and as their design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 fully gets vetted, you know, maybe there might be  
2 another box, but I think what they've shown there is  
3 pretty much the final.

4 And once they update the other figure, you  
5 know, I don't anticipate you know, any significant  
6 changes.

7 Next slide.

8 MEMBER BROWN: Before you, no, before you  
9 flip, I just wanted to re, or not reiterate, but to  
10 clarify somewhat my comments on the bus and feeding  
11 outwards was really, it's really a control of access.

12 It has nothing, we're totally not  
13 interested in fighting the cybersecurity and the rest  
14 of the plants and all the other stuff. There are guns  
15 and guards, and we're just trying to get it back to  
16 control of access, the way we do all other type of  
17 control of access.

18 We don't want external electronic control  
19 of access to be compromised. That's fundamentally it.

20 So cyber, that's just the words they put  
21 in and you all had in your SE, that's why I used them,  
22 so that we would have the same words.

23 But it's really a control of access.  
24 That's the same thing we've emphasized in other  
25 designs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ASHCRAFT: Yes, and I don't want to  
2 start anything here, Charlie.

3 MEMBER BROWN: I, no, no, I just, I don't  
4 --

5 (Simultaneous speaking.)

6 MR. ASHCRAFT: No, I only wanted to say  
7 that you know --

8 MEMBER BROWN: That's all we're thinking  
9 about is control of access.

10 MR. ASHCRAFT: No, and I agree 100 percent.  
11 And any time we have any discussions with applicants  
12 coming in, we have that discussion.

13 MEMBER BROWN: Okay.

14 MR. ASHCRAFT: But.

15 MEMBER BROWN: I don't want to deal with  
16 the rest of the 5.71, all the other stuff that's going  
17 to get tied up in whatever else they're doing in the  
18 plant.

19 I don't care what they do with the  
20 telephones, and water fountains.

21 MR. ASHCRAFT: Okay.

22 All right, I was only going to say that  
23 though that is on the non-safety side, so I don't know  
24 that there's a specific criteria that, that forces  
25 them to do that. It's just good design, like you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 said.

2 All right, well if Charlie's happy with  
3 this, I'm definitely happy.

4 MEMBER BROWN: Well, with a diode I'd be  
5 really happy.

6 MR. ASHCRAFT: Well, and I think they took  
7 that down. I mean, you know.

8 MEMBER BROWN: Well, that's what they  
9 talked of. That's what they said they're doing, and  
10 they might as well do it the easy way.

11 MR. ASHCRAFT: Exactly, because you know,  
12 we'll be back here sometime in the future.

13 MEMBER BROWN: Yes.

14 MR. ASHCRAFT: Okay.

15 MEMBER BROWN: If I'm still alive.

16 MR. ASHCRAFT: All right, next slide.

17 Yes, I'm not even looking at my notes, but  
18 so here are all the PDCs for Chapter 7, and they're  
19 typical of what you would see at any I&C design.

20 I didn't evaluate them because I didn't  
21 have the design yet. So, but we did line them up with  
22 the various sections and they seemed to be  
23 appropriate.

24 And they will be, you know, when they come  
25 in with their OL, they will demonstrate meeting these,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and we will review it intensely.

2 I'll just point out, I don't think you  
3 mentioned it, but PDC 19 for the control room. I  
4 don't think they're taking any exceptions, since  
5 they're having a remote shutdown.

6 And I guess at this, you know, I know Matt  
7 talked about NUREG-1537. So in my sections with  
8 various areas, I pulled out what I thought were  
9 appropriate bullets that could be discussed, and a  
10 construction permit.

11 And also, I used the DSRS Chapter 7 for  
12 the I&C principles, and also the appendix on  
13 architecture. Not as a you know, an extensive review,  
14 but just to help me look at the architecture and focus  
15 on the areas.

16 So I did use that, and it's listed in the  
17 SC. And as I tell all the applicants, I'm going to be  
18 using that to look at their architecture. I want to  
19 see good architecture.

20 Next slide.

21 So, the plant control system. These are  
22 the areas that we looked at. It's all in the SC. I  
23 mean I don't have the SC here so I don't, you know, if  
24 there's any questions on any particular spot, I'd be  
25 happy to answer it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           There's a lot of it we didn't necessarily  
2           have that much information. Like I said, I kind of  
3           put in bullets where I thought maybe there would be  
4           something.

5           So we did make a, not a finding, but we  
6           did look at these areas and had a discussion of what  
7           we saw.

8           And like I said, we had that Appendix A so  
9           there's a lot more that will be coming in the OL.

10          So I mean, well, and I, maybe I will talk  
11          a little bit. One of the things that we look at when  
12          I look at the architecture, and when I look at non-  
13          safety systems, is how does it, could impact the you  
14          know, safety system.

15          So that bottom one failure modes, that was  
16          an important -- communication to load. Charlie got me  
17          on that one.

18          But at any rate, so that's our review.  
19          It's in the SC. If there's any questions, otherwise  
20          we go on.

21                           (No audible response.)

22                           Next.

23           The reactor protection system. Lot more,  
24           but keep in mind a lot of that stuff like safety  
25           settings, I so much wanted to talk about set points

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 today.

2 But there are no set points. There's a  
3 table I think it's Table 731, that has a lot of  
4 permissives and so forth.

5 And that, you know, we don't have values  
6 there, but I think a lot of those permissive is how  
7 the DHRS gets activated, et cetera. And deactivated,  
8 actually. It's in there, as well.

9 I&C platform. We don't have it now, but  
10 it should be coming since they talked about it.

11 So these are, you know, these are the  
12 areas that we focused on and did a write up. Like I  
13 say, nothing's conclusive because without the  
14 platform, most of everything's internal to the  
15 platform.

16 So, you know, we're still just kind of  
17 looking at architecture and what we read.

18 But codes and standards. Here's another  
19 thing. They're not required to follow IEEE 603, but  
20 they did say they are.

21 And knowing that the HIPS platform, if  
22 that indeed comes in, has been you know, reviewed and  
23 approved using 603.

24 So I feel confident that their I&C  
25 platform is going to be sufficient.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: They only use one point, 152  
2 in the main control room discussion. They didn't  
3 mention that anyplace else in their PSAR.

4 I mean that's --

5 (Simultaneous speaking.)

6 MR. ASHCRAFT: It's not required.

7 MEMBER BROWN: I guess but it like the  
8 DPSRS 603, it is an enunciation of some, a lot of the  
9 fundamentals that we talked about.

10 And they did mention a number of those,  
11 so.

12 MR. ASHCRAFT: Yes, I --

13 (Simultaneous speaking.)

14 MEMBER BROWN: Little surprised by its  
15 absence.

16 MR. ASHCRAFT: Well, so am I, and if you  
17 talked with Ed or Ben, you would, you know, I'm a  
18 power guy so I like to look for all that stuff.

19 But you know, this is different. You  
20 know, but the fact they're committing to 603 and you  
21 know, I think they're putting a good system together.

22 MEMBER BROWN: Okay, thank you.

23 MR. ASHCRAFT: Next slide.

24 You know, once again here are the bullet  
25 points.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: I presume it's 603 1991?

2 MR. ASHCRAFT: No, I believe they --

3 (Simultaneous speaking.)

4 MEMBER BROWN: They're using 2016, or 2008,  
5 or whatever?

6 (Simultaneous speaking.)

7 MR. ASHCRAFT: -- it's 98. 2018, oh geez,  
8 you know, what, I have no --

9 (Simultaneous speaking.)

10 MEMBER BROWN: Don't worry about it.  
11 There's a date in there, I remember seeing it in the  
12 PSAR.

13 MR. ASHCRAFT: Yes, I don't think it's --

14 (Simultaneous speaking.)

15 MEMBER BROWN: Don't sweat it, keep going.  
16 91 though. Keep going.

17 MR. ASHCRAFT: So the main control room  
18 remote shutdown. You know, we talk about you know,  
19 this is a passive design, so there is no 1E power.

20 Now when you get inside the RPS, that is  
21 considered 1E power. I mean just to make all the  
22 safety aspect of the platform work.

23 But it is provided, I mean supplied with  
24 non-1E and you'll probably hear more about Chapter 8.

25 You know, it's a reliability thing. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 know, you don't want your plant shutting down. Well,  
2 you want it as reliable as you can make it, and I'm  
3 sure they're thinking about that in their final  
4 design.

5 But at this point as you pointed out,  
6 that's not a aspect of power to the RPS.

7 At any rate, you know, control displays,  
8 alarms, you know, a lot of that's probably going to be  
9 looked at by HFE people.

10 We do evaluate it and we see power paths,  
11 and once again, we're looking for any you know,  
12 communication into the RPS. And that's shown to be  
13 independent.

14 So you know, using the dependents and  
15 redundancy, and diversity and stuff, I think we looked  
16 at all the different main control room, PCS and RPS,  
17 for you know, that sort of thing.

18 And it's not conclusive yet because  
19 there's a lot of communication that you know, you  
20 always maybe find when a operating license comes in.

21 But we'll be looking for that. Typically  
22 they would have a table or something, that would show  
23 all the ins and outs.

24 But once again, if they're used to HIPS  
25 platform, I don't think there's too many ways other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 than the shutdown switches, which I think despite the  
2 way the HIPS is laid out, it will go to both, both  
3 sides.

4 So, I think their drawing probably was as  
5 correct as it could have been.

6 Boy I got a lot of notes here, but I think  
7 they cover most of it Kairos.

8 MEMBER HALNON: Will you be looking for  
9 some hardwiring in the remote shutdown area, some  
10 hardwired switches?

11 I know it said a manual switch, is that a  
12 hardwired switch where it's I guess back to the analog  
13 days, where you can actually hear a click and  
14 something happens?

15 MR. ASHCRAFT: Well --

16 (Simultaneous speaking.)

17 MEMBER BROWN: That actually doesn't  
18 change. If you look at the earlier diagram, it showed  
19 those remote switches going through a gateway, which  
20 implies software and intermediary.

21 But then when they showed the last  
22 diagram, it appears to be a direct wired --

23 (Simultaneous speaking.)

24 MR. ASHCRAFT: Right.

25 MEMBER BROWN: -- switch now directly onto

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 the priority box.

2 MR. ASHCRAFT: Other --

3 MEMBER HALNON: That's what it looks like.

4 MEMBER BROWN: That was, I'm going to just  
5 springboard off of your question, thank you for  
6 asking.

7 MEMBER HALNON: Yes.

8 MEMBER BROWN: When you look at the final  
9 main control room, everything's coming out through the  
10 gateway.

11 I guess, and I'm of all the systems that  
12 you've got, are there any critical systems that when  
13 you turn a switch, you really want to make sure the  
14 motor starts, or the pump stops, or the whatever.

15 I'm big on having not three computers in  
16 the intermediate spaces between one turn of a switch,  
17 and something happening down at the pump level. Or  
18 valve level, or whatever it is.

19 I know you can't mandate it, I'm just  
20 saying that's something --

21 (Simultaneous speaking.)

22 MR. ASHCRAFT: Well, --

23 MEMBER BROWN: -- to question if we can.

24 If people indicate there's a couple of  
25 these systems that are very, very critical to make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 sure they actuate, then we ought to ensure that  
2 there's a very, very reliable means of making sure the  
3 thing starts, as opposed to, in other words, a  
4 separate hardwired like the spring switch.

5 MR. ASHCRAFT: Right, well you know, as far  
6 as critical making sure it starts, I mean all that  
7 sort of, well it is covered with HMP as far as you  
8 know, take the switch, turn the switch, get  
9 indication.

10 So we don't really review that in Chapter  
11 7, but we, you know, I would say that's maybe this is,  
12 that's standard you know, sort of stuff, main control  
13 room type stuff, that's a known, a known thing.

14 MEMBER BROWN: From what I understand,  
15 their people are looking at is the all glass, it would  
16 be their work station.

17 So, now it's click and all I can do is see  
18 click and a pump starts somewhere.

19 MR. ASHCRAFT: Well, right.

20 MEMBER BROWN: Or with a touch screen, or  
21 something like that.

22 MR. ASHCRAFT: When you think about other  
23 designs like say NuScale, that's essentially what they  
24 have.

25 But they had a mechanism from a HIP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 perspective of when they started a pump, or whatever,  
2 to ensure they got it.

3 MEMBER BROWN: Okay, I'm just saying we  
4 need to think about that on this design, so.

5 MEMBER HALNON: I was a little bit more  
6 simplistic. I was thinking common mode failure, you  
7 know, with a fire.

8 And even with the remote shutdown, there's  
9 no unless you can predict where the fire is going to  
10 be, you don't know what necessarily all the failure  
11 modes might be.

12 MR. ASHCRAFT: Well, those manual switches,  
13 they are hardwired. We get the supplement, and I'm  
14 not sure if it shows up in Chapter 3 or not, but it  
15 talks about the switch and the cabling, and then  
16 similar.

17 You know, and it goes in the HIPS as a  
18 hardwiring. But kind of --

19 (Simultaneous speaking.)

20 MEMBER HALNON: Okay.

21 So, part of your failure review on the  
22 operating license will include those types of cross-  
23 cutting looks at these?

24 In other words, you'll take a scenario  
25 like a fire and say is there any common modes, from a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Chapter 7 perspective?

2 MR. ASHCRAFT: Well, we kind of look at  
3 that, but that's not really our area. But as far as  
4 a shutdown switch you know, for fire or whatever,  
5 that's the last thing they do as they run out is hit  
6 the switch.

7 So, yes. I don't want to pin myself down  
8 in Chapter 7 for reviewing that stuff.

9 MEMBER HALNON: You'd be doing everything,  
10 you know? I got it. It is a cross-cutting issue from  
11 the standpoint you know, when the fire starts going  
12 across electrical chapters, safety --

13 (Simultaneous speaking.)

14 MR. ASHCRAFT: Well, I've sort of been  
15 involved with the smoke in the control room, and how  
16 that works. You know, so we're kind of involved, but  
17 that's not really in our SE portion.

18 Next slide, if there's no more questions.

19 (No audible response.)

20 MR. ASHCRAFT: Okay, since there's the  
21 little light here, now they provided a section for  
22 sensors but when you look at NUREG-1537, the sensors  
23 is actually part of the system.

24 So, when you talk about the sensors for  
25 PCS, they have to meet criteria for PCS. And for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 safety sensors, they really need to meet all the PDCs  
2 for the safety system.

3 So, we looked at them and I did put some  
4 you know, we don't have much for sensors right now.  
5 I mean they gave us a range for the temperature,  
6 normal and, and well, an accident.

7 So they have us two, safety, safety range  
8 and then a normal range. But that's about it. We  
9 don't have anything for the level.

10 They talked about what they were you know,  
11 thinking about. But once we get that and they fill  
12 out those tables and stuff, when we look at it and  
13 then start thinking of sub-points and everything else.

14 So it's you know, at this point it looked  
15 like they you know, the sensors are independent, and  
16 there's redundancy.

17 So you know, that's --

18 (Simultaneous speaking.)

19 MEMBER BROWN: Are there sensors available  
20 that will actually work? I mean this is, my brain's  
21 in --

22 (Simultaneous speaking.)

23 MR. ASHCRAFT: Well, you know --

24 MEMBER BROWN: -- the water world and now  
25 here, these are very, very high temperature. You've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 got a different interface for these things.

2 Do you have the little things you can  
3 stick a temperature sensor in, okay, a well? Can you  
4 measure levels with a differential pressure, or do you  
5 have to have something else, a radar detector that  
6 does it, or?

7 MR. ASHCRAFT: Well, so.

8 MEMBER BROWN: Do you have any idea what  
9 the sensors are going to be like? Joy is not here; I  
10 know she'd love to talk about sensors.

11 MR. ASHCRAFT: I know, that's how  
12 convenient.

13 MEMBER BROWN: I'm just trying to work on  
14 it.

15 MR. ASHCRAFT: Well.

16 MEMBER BROWN: Help out with the sensor  
17 part a little bit.

18 MR. ASHCRAFT: You know, back when all this  
19 started, in my mind it was you know, the sensors was  
20 going to be you know.

21 And I talked with Kairos I think in some  
22 of our pre-meetings. And they're going to maybe not  
23 the same as NuScale, but they're looking, they're  
24 trying to find sensors that's going to meet their  
25 needs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: Yes, but NuScale was water.

2 MR. ASHCRAFT: I understand, but you know,  
3 when you're talking temperature --

4 (Simultaneous speaking.)

5 MEMBER BROWN: And they did use an unusual.

6 MR. ASHCRAFT: But when you think about the  
7 level, I mean it could be a connectivity level, or it  
8 could be radar.

9 I mean I don't know what their thinking,  
10 or what they're considering.

11 MEMBER BROWN: Or flow.

12 CHAIR PETTI: So Charlie, I looked at level  
13 sensors and it's contradictory. There's a DOE  
14 presentation that says we don't have anything that  
15 works for these high temperature systems.

16 But there's a paper from India, saying  
17 that they have one that they're using in their fast  
18 reactor.

19 MEMBER BROWN: Oh.

20 CHAIR PETTI: Today. So, take that for  
21 what it's worth.

22 MEMBER BROWN: It's just, I mean this is  
23 way out from anything that we typically use. Are we  
24 measuring flow for everything in this thing? I've  
25 forgotten; I've got to look back at the diagram.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   There's an F in here, so I presume we're  
2 measuring flow of some kind.

3                   MR. ASHCRAFT: Well --

4                   (Simultaneous speaking.)

5                   MEMBER BROWN: And, I'm just kind of  
6 interested how we're going to measure flow rate, I  
7 guess. And you're right, this is light on sensors.  
8 It's one paragraph plus we'll do it later.

9                   MR. ASHCRAFT: Right, but in order, you  
10 know, what we look at anyway is you know, ranges. And  
11 you know, that sort of stuff.

12                   The fact that it works or not, that's, you  
13 know.

14                   MEMBER BROWN: That's not your issue, I  
15 understand that. But you've got to be thinking about  
16 that.

17                   MR. ASHCRAFT: Oh, yes, yes.

18                   MEMBER BROWN: I mean.

19                   MR. ASHCRAFT: Between set points and  
20 sensors, that's always on my mind, Charlie.

21                   MEMBER HALNON: They'll be subject to the  
22 environment qualification.

23                   MR. ASHCRAFT: Oh, yes, all the safety  
24 related sensors --

25                   (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER HALNON: Right.

2 MR. ASHCRAFT: -- will you know, PDC.

3 MEMBER HALNON: And, that will look at  
4 compatibility and longevity.

5 MR. ASHCRAFT: Yes, so it will have the  
6 pedigree, whatever they decide to end up using.

7 MR. HISER: This is Matt Hiser. I just  
8 wanted to on the sensor piece, I just wanted to point  
9 out that they did identify that as one of the research  
10 and development items in Chapter 1.

11 So, develop process sensor technology for  
12 key reactor process variables. So, it's something  
13 that they've acknowledged there's work to be done on.

14 And they don't expect to just pull  
15 something off the shelf.

16 MEMBER BROWN: I did one of those dumb  
17 things with Googling high temperature this, high  
18 temperature that level and got blanks.

19 You know, lot of people want to sell  
20 little things, but they were little piece part type  
21 stuff.

22 Oh yes, we'd have some of those. There  
23 was no definition of what they were, what their ranges  
24 were, or what they were even compatible with.

25 So, and there's a material compatibility

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 it seems to me is another issue relative to this line  
2 up. And, the interesting coolant that we're using.

3 MR. HISER: Yes, just wanted to fill in the  
4 licensing regulatory piece.

5 MEMBER BROWN: Yes, and I know they've got  
6 to make it work.

7 MR. HISER: Right.

8 MEMBER BROWN: I understand that. I'm not,  
9 you all don't have to make it work. They do.

10 CHAIR PETTI: Yes, and I think they have a,  
11 it's in our draft letter. Don't worry about it.

12 MEMBER BROWN: It is? Okay.

13 CHAIR PETTI: Yes, the whole list.

14 MEMBER BROWN: Okay, all right.

15 MR. ASHCRAFT: I think they're doing  
16 something similar to what NuScale is as far as  
17 evaluate and trying to determine, you know, that kind  
18 of process.

19 Next.

20 Okay, I think the end result is we, you  
21 know, feel that they're able to you know, construct a  
22 plant and meet, meet all their safety requirements at  
23 the OL.

24 So, that's effectively what this says.  
25 And you seen this in all the chapters, but pretty much

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 we feel that they can, we should issue them a CP.

2 MEMBER BROWN: The one question I had  
3 relative to the OL versus this, because I'm not used  
4 to doing it in this order.

5 Construction permit. That's what this is,  
6 right? That sounds like building something.

7 CHAIR PETTI: Well, it's a start.

8 MEMBER BROWN: And who's building -- huh?

9 CHAIR PETTI: It's an authorization to  
10 start.

11 MEMBER BROWN: Yes, that means, that means  
12 you got to build, you're starting to design and build  
13 systems. And the control systems, and the shutdown  
14 systems.

15 And now, and we've got this is sparse  
16 relative to, from any standpoint, whether it's I&C or  
17 whether it's something else, it's pretty sparse.

18 MR. ASHCRAFT: Well, you know --

19 (Simultaneous speaking.)

20 MEMBER BROWN: In detail.

21 MR. ASHCRAFT: -- I've been around for a  
22 while although I'm not aware of what, I mean all the  
23 existing plants were construction permits.

24 And they had you know, they had maybe more  
25 detail, maybe less. But at the end of the day,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 they're at risk because once they build it, they got  
2 to come in and get their operating license.

3 So that's why --

4 (Simultaneous speaking.)

5 MR. BLEY: This is Dennis Bley, and just a  
6 question on this. Yes, none of us were around back in  
7 the 60s when they really had to deal with this with  
8 novel designs, with not much experience.

9 We're getting a prototype here and they're  
10 going to collect data. And once they get the  
11 construction permit, they can build everything and  
12 they can put the sensors in and everything else.

13 Is there an expected path by the staff or  
14 the applicant during the construction process, to come  
15 back in to the staff and say hey, here's the kind of  
16 sensors we've picked, and here's why they think  
17 they're going to work.

18 To kind of get preliminary approval on  
19 things that will come up for the operating license?

20 MR. ASHCRAFT: Well, as the expert on this,  
21 I am going to turn it over to Ben or Ed, for the  
22 answers.

23 MR. HELVENSTON: Yes, this is Ed  
24 Helvenston, from the staff.

25 You know, as you may know, there is a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 construction inspection process in which you know,  
2 we'll have inspectors that will be on the site during  
3 construction, that looking at what they're doing, and  
4 making sure that it's conforming to the design bases  
5 that we're approving as part of our CP review.

6 But you know, just to clarify, we're not  
7 approving a final design as part of a construction  
8 permit approval.

9 We're essentially approving the design  
10 bases, and finding that there's reasonable assurance  
11 that Kairos will conform to those, you know, that  
12 Hermes can, the final design will conform to the  
13 design bases.

14 But the final design itself is still  
15 subject to change, and those details could still be  
16 worked out as they go through the construction  
17 process.

18 MR. BLEY: All right, I guess my question  
19 was orthogonal to your answer.

20 The question is, is there a way during  
21 this process, and maybe it's coming in with a topical  
22 report or something like that to get approval on, to  
23 as it becomes possible to clarify some of these areas  
24 with substantial uncertainty, to make sure the staff's  
25 onboard with the design as it evolves, before they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 come in for the operating license?

2 MR. HELVENSTON: That would certainly be if  
3 Kairos wanted to do something like a topical report.  
4 I mean they would certainly free to submit that to us.

5 But there isn't really a formal process  
6 where they would sort of confirm those things to us.  
7 I mean it's a responsibility of an applicant to the  
8 NRC, to comply with their licensing basis.

9 And you know, part of the licensing basis  
10 for the --

11 (Simultaneous speaking.)

12 MR. BLEY: Yes, of course.

13 (Simultaneous speaking.)

14 MR. HELVENSTON: -- part of the licensing  
15 basis for the construction permit is that you know,  
16 we've approved a certain, certain design basis that  
17 they described to us.

18 And if Kairos identifies a situation, you  
19 know, they have some flexibility in how they, how they  
20 meet that.

21 But if they identify a situation where  
22 they don't think that their design is going to be able  
23 to conform to what they told us in the CP, you know,  
24 that's, they may have to consider a process like an  
25 amendment to the construction permit, or something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 else.

2 MR. BEASLEY: And this is Ben Beasley with  
3 the staff as well. I'll chime in a little bit.

4 So, certainly Kairos is accepting this  
5 risk for the 2-step process, and they have  
6 acknowledged that. They understand it.

7 From a practical standpoint, they're  
8 looking at submitting their OL application about the  
9 same time that they begin construction. So, there  
10 will be opportunity for us to see the final design,  
11 you know, as they are building.

12 And so if you know, if there is some  
13 feedback that they gain from our review as we're doing  
14 the review and asking for additional information, you  
15 know, they can modify their design as they go.

16 But just from a practical standpoint,  
17 those will be somewhat running in parallel.

18 MR. BLEY: Yes, thanks, I guess I missed  
19 that part of the schedule, I'm glad to hear that.

20 MEMBER BROWN: Thanks, Dennis.

21 One of the things that's and I appreciate  
22 the input, that was good input from what you said.

23 My perception was they can now go off and  
24 design their entire architect, whatever they want to  
25 do, they can design an I&C system to do what they want

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to do, based on this PSAR.

2 And the one thing they talk about is  
3 they're going to have an FPGA system. Well, there was  
4 no mention of diversity in this entire, in this entire  
5 write up.

6 Okay, so now are we saying that's okay  
7 because we've, you're writing an SE. You're all  
8 putting the Betty Crocker Good Housekeeping seal of  
9 approval on this construction permit, and yet now  
10 we're saying that diversity is no longer a  
11 requirement?

12 You know, D3, defense in depth, diversity?  
13 And it doesn't have to be across the board, I'm just  
14 talking about in the fundamental area such as the  
15 reactor protection system, is the argument going to be  
16 if it doesn't work at all, it doesn't matter?

17 And if that's the case, seems to me that  
18 the NRC should be agreeing with that up front, as  
19 opposed to in arrears. That's my only point from that  
20 standpoint.

21 But all the rest of our protection systems  
22 and other systems, have been, and safeguards, have  
23 been based on you know, a defense in depth philosophy,  
24 as well as a you know, the independence, redundance,  
25 and all the other, and they've got that in the RPS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 design.

2 I'm not arguing about that, but the  
3 diversity aspect is not there.

4 MR. ASHCRAFT: Well, they haven't --

5 (Simultaneous speaking.)

6 MEMBER BROWN: You didn't address it in  
7 your SE. At least I don't think you did.

8 MR. ASHCRAFT: You didn't see it? Well,  
9 but I mean so I mean when you think about diversity,  
10 I mean there's sensors coming in, they're protecting  
11 --

12 (Simultaneous speaking.)

13 MEMBER BROWN: I'm talking about the FPGA  
14 reactor protection system. There has been diversity  
15 defined for that in other, in the one system we've  
16 approved on the FPGA basis.

17 MR. ASHCRAFT: Well --

18 (Simultaneous speaking.)

19 MEMBER BROWN: And we've approved that in  
20 what I would call the microprocessor based world, in  
21 terms of diversity for the other earlier, some of the  
22 earlier plants.

23 But there's no mention of it in this.

24 MR. ASHCRAFT: Well, as I said --

25 (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: And that's one of your old  
2 major standpoints relative to how you evaluate these  
3 protection systems, is from the diversity defense in  
4 depth standpoint, which seems to be not mentioned.

5 MR. ASHCRAFT: Well, so as of right now, we  
6 don't have the platform so it's hard to you know, to  
7 go into that depth.

8 MEMBER BROWN: But you didn't say anything  
9 in your SE about that was missing.

10 MR. ASHCRAFT: Because we had nothing in  
11 the SE to evaluate.

12 MEMBER BROWN: But that's something you  
13 normally insist on as part of the design.

14 MR. ASHCRAFT: Well --

15 (Simultaneous speaking.)

16 MEMBER BROWN: You demonstrate it at some  
17 point and if it's not part of the --

18 (Simultaneous speaking.)

19 MR. ASHCRAFT: And, it will. I mean once  
20 they establish the platform, which I think maybe they  
21 did in there, then a lot of your concerns will be  
22 taken care of.

23 But say they go with another platform.  
24 Once they come in with a topical for their platform,  
25 then all that will be evaluated on some merit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 So, I guess that's my answer there.

2 MEMBER HALNON: But and your review  
3 standards would drive you to that, right? I mean  
4 you're not just making this up.

5 You've got review standards, Reg Guides  
6 that they'll be using in this, the light that, the  
7 design?

8 MR. ASHCRAFT: Well, so we have NUREG-1537  
9 and I don't, I know it speaks to diversity at some  
10 part. But at this time, without the platform it's  
11 hard to you know.

12 MEMBER BROWN: But the concept doesn't  
13 depend on a platform though. The concept of diversity  
14 is part of the overall architecture fundamentals, that  
15 safeguard systems and reactor protection systems  
16 design.

17 It's not, and it's built in you know, to  
18 a number of the Reg Guides, as well as BTB 7-19 and et  
19 cetera, which is very extensive.

20 This is a different approach. It's more  
21 narrowly focused, but there is a protection system and  
22 it talks about a, what platform, two different  
23 platforms.

24 One for the plant control system where  
25 they're talking about they're going to have dual

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1       whatevers, and they've got independent things.

2               But all the data goes up in this big  
3       mishmash of how everything's done, just in  
4       presentation.

5               But the RPS is a separate little box that  
6       says, I can shut things down. We've got four  
7       channels, two channels for voting, fine.

8               But then they talk about an FPGA base, not  
9       a software base, so you've eliminated one possible  
10      compromise, but you still have the failure modes of  
11      particular FPGAs.

12              And others have used diverse FPGAs,  
13      whether they be volatile, non-volatile, whatever you  
14      have.

15              MR. ASHCRAFT: Well --

16                      (Simultaneous speaking.)

17              MEMBER BROWN: And there's no, nothing in  
18      the SE about that. That's all, it doesn't address, it  
19      does not address diversity at all.

20              MR. ASHCRAFT: And I agree, and the fact  
21      that potentially as they stated they're using HIPS,  
22      that a lot of that --

23                      (Simultaneous speaking.)

24              MEMBER BROWN: They didn't say HIPS. Did  
25      they say HIPS? Okay, maybe I.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: I don't think it was written.

2 MR. ASHCRAFT: No, it's not provided at  
3 this point, but they mention it.

4 MEMBER BROWN: I'm just saying, it's not in  
5 the PSAR.

6 MR. ASHCRAFT: No.

7 MEMBER BROWN: It's not in Rev 2. That's  
8 all I'm saying.

9 MR. ASHCRAFT: And the --

10 (Simultaneous speaking.)

11 MEMBER BROWN: It just says FPGA base, and  
12 which I agree with, I like. You know, because it  
13 eliminates some problems, okay.

14 MR. ASHCRAFT: Right.

15 MEMBER BROWN: Software wise.

16 MR. ASHCRAFT: But in the Appendix A, what  
17 that tells me is I'm waiting, I need to know what  
18 they're platform is so that I can look at all that.

19 Until I've gotten that.

20 MEMBER BROWN: Appendix A, I keep --

21 (Simultaneous speaking.)

22 MR. ASHCRAFT: Well, that just states --

23 (Simultaneous speaking.)

24 MEMBER BROWN: It says what?

25 MR. ASHCRAFT: That's just a list of things

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that we expect, and it's not all inclusive, but.

2 MEMBER BROWN: You're talking about  
3 Appendix A to part?

4 MR. ASHCRAFT: Of the SC.

5 MEMBER BROWN: Okay.

6 CHAIR PETTI: There is a punch list of the  
7 staff's items that they.

8 MEMBER BROWN: Yes, okay.

9 MR. ASHCRAFT: You know, because people  
10 keep saying what are we going to --

11 (Simultaneous speaking.)

12 MEMBER BROWN: Have we seen that yet?

13 MEMBER KIRCHNER: It's the Appendix to  
14 Chapter 1, right? Just to make this for the entire  
15 SE, yes.

16 MR. HISER: So I just want to be clear,  
17 Appendix A is things that the Kairos has identified to  
18 us either through the audit or in the PSAR, that they  
19 are planning to provide with the OL application.

20 It's not an all-inclusive list. It's also  
21 not --

22 (Simultaneous speaking.)

23 MEMBER BROWN: Where is it listed? Where  
24 is Appendix A? Is it a document?

25 MR. HISER: Yes, yes, it's Appendix A to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the SE. To the safety evaluation.

2 MEMBER BROWN: Oh, I was looking for that.

3 MEMBER HALNON: But we got it, we don't  
4 have it posted though.

5 MEMBER BROWN: Okay, I'll have to go find  
6 it.

7 MR. ASHCRAFT: We also had input to that.

8 MEMBER KIRCHNER: Charlie, can I raise one  
9 question?

10 MEMBER BROWN: Yes, go ahead. It's a free  
11 for all.

12 MEMBER KIRCHNER: This is more specific.  
13 It's probably more of a design options going forward  
14 for the OL.

15 I don't understand this, I guess the  
16 question should go to Kairos, not the staff, but that  
17 having the DHRS in the loop with the RPS, I don't get  
18 that.

19 The one simpler diagram where it shows  
20 it's just a lock, an interlock or whatever, makes much  
21 more sense than it being an active part of the, the  
22 RPS system.

23 Unless it blocks you from pulling rods or  
24 something, or it's just kind of just dangling out  
25 there in this RPS architecture.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: We had a discussion of that  
2 at one of the earlier chapters, a decay heat removal  
3 meeting.

4 MEMBER KIRCHNER: Right.

5 MEMBER BROWN: And there's not a  
6 consistent, there's, and what I heard today and you  
7 can correct me, was there's two different pieces.

8 There's one if the RPS trips, it makes  
9 sure the DHRS comes on. That's the way that diagram  
10 reads.

11 Then there's something else. There's  
12 another widget in there that operates a valve  
13 somewhere, which we don't show.

14 MEMBER KIRCHNER: Yes, but if they don't  
15 have a large decay heat inventory, they don't want it  
16 coming on because you could actually then freeze the  
17 fluid in the --

18 (Simultaneous speaking.)

19 MEMBER BROWN: Worry about overcooling.

20 MEMBER KIRCHNER: -- in the vessel, et  
21 cetera, et cetera.

22 And it goes back to Greg's point. What's  
23 missing I think right now, at least just notionally in  
24 this control system, is something about showing that  
25 before you go ahead and run at power, you've got a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 level indication that these tanks are filled.

2 And I mean this can be done I think  
3 through tech specs and just a manual interlock, as  
4 part of the operating instructions I suppose.

5 But anyway, me, I don't, I'm not getting  
6 why it's part of an active system unless you've got  
7 the actual instrumentation feeding in to tell you you  
8 have water level or something.

9 CHAIR PETTI: Turn on your mic, please.

10 MR. ASHCRAFT: All right, so I've gone  
11 through you know, and I've heard Chapter 6 and I heard  
12 today, and I've heard a lot. So here's, but we don't  
13 have the schematic so it's hard.

14 So, but what I heard is the thimbles are  
15 dry, that's part of your DHRS. And it does dissipate  
16 some heat, but not enough, at a lower power level.

17 So once you reach a certain power level,  
18 which is not defined yet, but it is in Table 731 as a  
19 permissive, that is going to open the valves to those  
20 tanks and put water into the thimbles. So now you got  
21 a fully operational DHRS.

22 So as you're going up in power and as  
23 you're operating, those thimbles are full.

24 MEMBER BROWN: 10 megawatts is where that  
25 trigger was in the Chapter 6.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. ASHCRAFT: Right, but it hasn't, right  
2 now in Chapter 7 it's just a permissive. And so  
3 you're up in power running. Thimbles are full,  
4 everything's fine.

5 Your tanks, you know, are being supplied  
6 from outside. And then you get to a trip. So what  
7 happens on the trip is, well first of all you drop the  
8 control elements.

9 They drop and you turn off all the non-  
10 safety stuff. But for the DHRS, it ensures that the  
11 DHRS stays activated by preventing you from closing  
12 the valves from that tank. So that you will have a  
13 water supply.

14 That's --

15 (Simultaneous speaking.)

16 MEMBER KIRCHNER: Yes, and I get all that.  
17 It just doesn't make sense in the schematics to me.  
18 I get the simpler schematic where it just shows  
19 something which may be an interlock, or a switch.

20 And then there's no indication that this  
21 is part of what the operators will see. So that's,  
22 I'm nitpicking the schematics.

23 MR. ASHCRAFT: Well --

24 (Simultaneous speaking.)

25 MEMBER KIRCHNER: It may be more of a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 question of U graphs than --

2 MEMBER BROWN: It would make more sense --

3 MEMBER KIRCHNER: -- than substance, but.

4 MEMBER BROWN: It would make more sense if  
5 somehow power tells this DHRS it's got to turn on.

6 This just says if it trips, it turns it  
7 on. But there's also an activation so if you get  
8 above 10 megawatts, it's supposed to come on.

9 That's not shown in this diagram.

10 MR. ASHCRAFT: No, it's not shown and a lot  
11 of this is in the details. You won't know until you  
12 get the schematics, and you get a table of displays  
13 and whatnot.

14 But even now, so your DHRS is fully  
15 functional when you reach that permissive.

16 MEMBER BROWN: The 10 megawatts it's  
17 supposed to come on.

18 MR. ASHCRAFT: Right.

19 MEMBER BROWN: But that means all the  
20 systems that support the DHRS, the tanks have got to  
21 be full.

22 MR. ASHCRAFT: Right.

23 MEMBER BROWN: Blah blah blah, whatever the  
24 other pieces are.

25 MR. ASHCRAFT: Exactly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: And that's where, where is  
2 the data, where is the signal that says my tanks are  
3 full, therefore, I can actuate?

4 MR. ASHCRAFT: Well, that --

5 (Simultaneous speaking.)

6 MEMBER BROWN: I didn't, there's no, the  
7 control of the DHRS, the integrated control and turn  
8 it on and off, is not present in a single schematic to  
9 show how these things work together.

10 We had that big discussion in Chapter 6,  
11 and I came and walked away very unsatisfied with the  
12 results.

13 MEMBER MARCH-LEUBA: I wasn't here for that  
14 discussion, but the DHRS tanks are sized for a 7-day  
15 operation. And they're supposed to be filled by tech  
16 specs, I assume.

17 So, you don't check levels before you open  
18 the valve.

19 MEMBER BROWN: No, that's fine that you've  
20 got to open a valve, but there's still not, what opens  
21 the valve? Is it?

22 MR. ASHCRAFT: Well, yes --

23 (Simultaneous speaking.)

24 MEMBER MARCH-LEUBA: Losing power to that.

25 MEMBER BROWN: That's losing, that's the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 power, that's when you shut down, you scram.

2 MEMBER MARCH-LEUBA: Uh huh.

3 MEMBER BROWN: Then you turn it on. But  
4 you also turn on DHRS when the power goes above 10  
5 megawatts.

6 MR. ASHCRAFT: All right, from my reading  
7 of Chapter 6 and Chapter 7, and all the chapters, is  
8 when you reach that 10 megawatt and those thimbles  
9 fill with water, and those valves from the tanks are  
10 open, it's fully operation.

11 MEMBER BROWN: Yes, but where does that  
12 come from? Does it come from the PCS?

13 MR. ASHCRAFT: Well, the PCS --

14 (Simultaneous speaking.)

15 MR. ASHCRAFT: -- well, the PCS are not,  
16 that tank is non-safety. But there are safety valves,  
17 I remember hearing that.

18 MEMBER BROWN: There is one of the valves  
19 in there that does something for the --

20 (Simultaneous speaking.)

21 MR. ASHCRAFT: Right.

22 MEMBER BROWN: -- hit the water.

23 MEMBER KIRCHNER: No, the tank is, the tank  
24 is safety.

25 (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 PARTICIPANT: The DHRS tanks is definitely  
2 safety related.

3 MR. ASHCRAFT: The system is safety  
4 related.

5 MEMBER BROWN: And the valve is safety  
6 related.

7 MR. ASHCRAFT: Right, but we don't have  
8 that detailed logic.

9 MEMBER KIRCHNER: I'm just saying Joe, it's  
10 not even showing up on the schematic. I mean in the  
11 core functions, I would have put DHRS in this, this  
12 box here, of the schematic.

13 For the people who are remote, I'm looking  
14 at the integrated --

15 (Simultaneous speaking.)

16 MEMBER BROWN: It's 7.1.1.

17 MEMBER KIRCHNER: Yes, diagram and the  
18 central box. There's no indication that you would  
19 feed the operators for example, the level in the  
20 tanks.

21 CHAIR PETTI: But it up above is DHRS  
22 status on the computer, little computer screen. Its  
23 own little computer.

24 Highly reliable display.

25 MEMBER BROWN: Yes, but that's a display,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 not a control function.

2 MEMBER KIRCHNER: Yes, that's a display.  
3 So there's nothing, I'm just saying there's no box  
4 down --

5 (Simultaneous speaking.)

6 CHAIR PETTI: Yes, yes, I understand what  
7 you're saying.

8 MEMBER BROWN: Somewhere a nuclear power  
9 signal has to go, activate, turn one of those switches  
10 or another switch somewhere, and turn on the DHRS.

11 MEMBER HALNON: I think you all --

12 (Simultaneous speaking.)

13 MEMBER BROWN: Then there's a valve.

14 MEMBER HALNON: I think you all need to  
15 make sure that you're not looking at this as the  
16 schematic. This is a presentation.

17 MEMBER BROWN: That is the architecture.

18 MEMBER HALNON: The schematic is behind --

19 (Simultaneous speaking.)

20 MR. ASHCRAFT: Yes.

21 MEMBER HALNON: -- the architecture, but it  
22 doesn't show the behind the scenes.

23 MEMBER BROWN: Like I said, there's a lot  
24 of other stuff.

25 MEMBER HALNON: Lot of communication going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 on.

2 CHAIR PETTI: Outside the pinkish color, is  
3 more notion.

4 MEMBER BROWN: A controlled diagram for the  
5 DHRS is not present.

6 MEMBER KIRCHNER: Correct.

7 MEMBER BROWN: In either Chapter 6 or  
8 Chapter 7.

9 MEMBER HALNON: Nor the other channels I  
10 was talking about with the treated water systems that  
11 I was --

12 (Simultaneous speaking.)

13 MEMBER BROWN: Well, but that, the treated  
14 water, that's down running the air conditioner. I  
15 agree with you, but those are so non, those are non-  
16 safety and non-safety.

17 MEMBER HALNON: But no, it interfaces and  
18 provides cooling water to the DHRS.

19 MEMBER BROWN: Then it ought to have  
20 something. There's a lot of incompleteness, that's  
21 all.

22 MEMBER HALNON: Yes, that's what I'm  
23 saying, but.

24 MR. ASHCRAFT: I was only going to point  
25 out on this diagram, that little toggle switch is when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 DHRS is supposed to be activated and remain activated,  
2 it prevents, that toggle switch from you turning it  
3 off.

4 Which means you cannot close the valve.  
5 So the water is going to keep coming down. And at  
6 such time that you no longer, as you know, as power  
7 comes down --

8 (Simultaneous speaking.)

9 MEMBER BROWN: Is that manually?

10 MR. ASHCRAFT: As power comes down and you  
11 don't need full DHRS, there is another permissive  
12 which is in that Table 731, which is going to allow  
13 them to switch that. And, I believe it is made.

14 And then the operator can turn it and  
15 close it off, because what you don't want is to have  
16 DHRS fully operational once you get back down to that  
17 10 megawatts.

18 MEMBER BROWN: Absolutely, we're not  
19 disagreeing with that point.

20 MR. ASHCRAFT: So, yes but all that's, no,  
21 all that's in the details that we don't have yet. And  
22 we won't have until we have detailed schematics that,  
23 and then we'll see what those levels are.

24 CHAIR PETTI: Okay, all right, we're  
25 running behind.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: All right, we've mouse  
2 milked this thing, we've mouse milked this good  
3 enough.

4 CHAIR PETTI: You're done, right, Joe?

5 MR. ASHCRAFT: Yes, I'm done.

6 MEMBER BROWN: Okay, thank you, Joe.

7 So let's get the memo out and court  
8 reporter, you're off again till we tell you you're  
9 back.

10 (Whereupon, the above-entitled matter went  
11 off the record at 11:30 a.m. and resumed at 1:02 p.m.)

12 CHAIR PETTI: We're back. We have most  
13 members. A couple are still coming in. But let's get  
14 going on Chapter 8.

15 Kairos?

16 MR. CILLIERS: Sound check. Can you hear  
17 me?

18 MEMBER BLEY: Excuse me. This is Dennis  
19 Bley. Before you get started, I wanted to pose  
20 something that I don't want you to answer now, but as  
21 you go through the discussion, I would appreciate it.

22 I have no problems with almost everybody  
23 here, except there is one area that we and the staff  
24 have raised with other applicants, and that is  
25 emergency lighting, communications, and monitoring.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Well, if everything works fine from the design basis  
2 events, you are golden. But if something goes wrong  
3 and you really need to do something in the plan, those  
4 are crucial.

5 And one of the previous applicants ended  
6 up making that equipment and their power supplies 1E.  
7 Another one came up with an approach that demonstrated  
8 essentially equivalent reliability to the 1E, and I  
9 guess it all hinges on the 72-hour UPSs that you have  
10 really being able to do their job for that length of  
11 time.

12 So when you go through, maybe you can  
13 raise this. I'm sure we will raise it toward the end.  
14 Go ahead.

15 MR. CILLIERS: Thank you very much. This  
16 is Anthony Cilliers again, Director of  
17 Instrumentation, Controls and Electrical, and I'll  
18 just jump straight into Chapter 8.

19 Next slide, please.

20 I'm going to start with the -- with the  
21 single -- the electrical power system drawing that we  
22 have here. It's -- I'll start at the top, and I hope  
23 you've got a bigger printout there, assignments that  
24 you've had with the other systems, if it's a little  
25 bit too small for you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 I'll just start by saying that primarily  
2 and this is a -- this is a key aspect here -- we do  
3 not rely on any electrical systems for any safety  
4 functions. There is no safety functions that requires  
5 electrical power. That being said, of course  
6 electrical power and the reliability of electrical  
7 power is extremely important to us.

8 And for that reason, you will see a lot of  
9 systems that's built in to support the reliability of  
10 these power systems. But it has to be said that they  
11 are known safety systems that depend on these  
12 electrical systems.

13 So starting at the top, the power -- the  
14 normal power supply would be coming from the -- from  
15 the utility and be stepped down through a stepdown  
16 transformer to 480 volts. We also have onsite backup  
17 generators with automatic transfer switch that allows  
18 switching between the normal power supply, should that  
19 go off, to the backup power supplies.

20 And there is roughly a 20-second switching  
21 time between the -- from the one to the other. So we  
22 are -- have accounted for that -- for that stoppage  
23 time as well.

24 In addition, there is also --

25 MEMBER BROWN: Could you repeat that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 again, please?

2 MR. CILLIERS: Okay.

3 MEMBER BROWN: I missed the point.

4 MR. CILLIERS: There is a roughly a 20  
5 second transfer time between the main -- from the main  
6 power going off to the diesel that -- not necessarily  
7 diesels --

8 MEMBER BROWN: Okay.

9 MR. CILLIERS: -- but the backup power to  
10

11 MEMBER BROWN: All right. That's the  
12 automatic transfer switch you're talking about.

13 MR. CILLIERS: Correct. Correct.

14 MEMBER BROWN: Okay. That's a typical  
15 transfer switch, not atypical transfer switch response  
16 after --

17 MR. CILLIERS: Yes.

18 MEMBER BROWN: -- transfer panel.

19 MEMBER BLEY: This is Dennis Bley. You're  
20 about to get to the portable generator connection. I  
21 just had a question. With that kind of connection,  
22 are you setting it up with the -- what is now the  
23 standard FLEX connectors, or are you doing your own  
24 and figuring you don't need any outside help?

25 MR. CILLIERS: That hasn't been defined

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 yet, how we will -- we are just indicating that  
2 connection at the moment for having a portable  
3 generator supply, if that were to be needed for an  
4 extended period of time. So --

5 MEMBER BLEY: Okay. And I guess the other  
6 applicants to this -- and I don't expect an answer  
7 right now, but I wonder if you've considered whether  
8 your customers would want to be involved in FLEX and  
9 in the SAFER system. And this is something for the  
10 Committee to think about later.

11 I don't know that the industry SAFER  
12 system has set up any options for people who don't  
13 need the full power of it. And some of these smaller  
14 plants, there might be something that would work  
15 really well for them. But I -- I don't expect you  
16 guys to answer that question.

17 Go ahead.

18 MR. CILLIERS: Thank you. Right. So  
19 we've covered the supply side of things. That goes on  
20 to a 480-volt bus bar, and in many cases a lot of our  
21 systems, I mean, you will see a lot of these little  
22 blocks all being supplied by that 480-volt. And if  
23 there is specific lower voltage requirements within  
24 that system, there is -- they will be stepped down as  
25 per -- as required within those various system blocks

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to take it to the required voltage.

2 MEMBER BLEY: May I ask you a kind of dumb  
3 question? This is Dennis again. UPS 120-volt that  
4 supplies the heat rejection control and double-  
5 handling systems, that stuff, so it's a 20-second  
6 duration capacity. Well, you don't buy one of those,  
7 but would you be designing this with very little  
8 capability or is that just a definition of what you  
9 think you'll need to support the rest of the fleet?

10 MR. CILLIERS: That's correct. Yeah. So  
11 you've asked the question, so maybe I'll just jump  
12 right into that. So for the reactor protection system  
13 and the plant control systems, we start off with  
14 having a 72-hour UPS supply system, so that we can  
15 supply those systems in the event of any power  
16 failure, so that we still have that capability of  
17 monitoring.

18 As I've said, this is really important to  
19 us, although it doesn't add -- doesn't have any safety  
20 functions. We want the monitoring there, and we want  
21 the systems to be available. So that is really a  
22 reliability function that we have built in.

23 The 20-second part is very much the  
24 systems that keep the relays going to supply power to  
25 the -- to the various systems that we need to shut

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 off.

2 Now, the reason we have specified 20  
3 seconds there is it should be 20 seconds or longer,  
4 but as short as possible, meaning that it should allow  
5 us to do the transfer between the main power supply  
6 and the backup power supply without a trip. We don't  
7 necessarily want the system to trip while we transfer  
8 power from the main to the backup power supply.

9 If that main -- that transfer between the  
10 main and the backup power supply does not happen  
11 within a specified period of time, and that would  
12 roughly be just over 20 seconds, that UPS would be  
13 drained and the system would then trip. And that's  
14 the reason why we say 20 seconds.

15 So it's roughly 20 seconds of what we will  
16 be needing, so it will just specify very small -- very  
17 small capacity supply there.

18 MEMBER BLEY: So ---

19 MR. CILLIERS: Yeah.

20 MEMBER BLEY: -- you are going to design  
21 this, and you can't count on the power running down,  
22 so you must be thinking of putting some kind of timing  
23 circuit in there to disconnect it?

24 MR. CILLIERS: It's designed specifically  
25 on the -- on the power requirements for the system, so

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 that it should run down. So it should be a very small  
2 many-hour battery supply for that system.

3 MEMBER BLEY: No kidding. Because that  
4 sounds -- something about that sounds dicey. I have  
5 never seen anybody design for a power to -- a battery  
6 to run out that quickly. And those batteries are  
7 wanted to do -- but somewhere along the line they  
8 might run out faster than you expect.

9 That was one, at least for me, I'm going  
10 to be thinking about when you come back with the  
11 operating license. This seems a little odd.

12 MR. CILLIERS: Right. Thank you.

13 MEMBER BROWN: Another question from  
14 Charlie Brown. Alongside Dennis' comment, that  
15 implies then that if your -- that main bus is totally  
16 deenergized because the automatic transfer switch  
17 didn't transfer, for whatever reason, that means all  
18 those four systems, you've lost them. They will stop.

19 I presume those are not necessary for any  
20 safety function as well. Is that correct?

21 MR. CILLIERS: That is correct.

22 MEMBER BROWN: Okay.

23 MR. CILLIERS: So I think it came from  
24 Chapter 7 as well. All our systems are designed to be  
25 passive, and we really want to shut them down to put

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the system in a safe state. So one of the systems of  
2 course is our reactor shutdown system, which inserts  
3 the rods into the system. So if that power fails, it  
4 drops in there.

5 Now, of course a reactor protection system  
6 can initiate that as well. But if there is a loss of  
7 power, that will -- that will drop the systems in.  
8 And the same as what we had in our diagram in Chapter  
9 7. All the other systems we -- we actually want to  
10 shut down and --

11 MEMBER BLEY: Okay.

12 MR. CILLIERS: So it fails to safety on  
13 loss of power. That's the --

14 MEMBER BROWN: All right. I'm just  
15 confirming that I heard -- heard it all correctly.  
16 Thank you.

17 MEMBER HALNON: Are you going to explain  
18 the safety-related isolation down in the bottom right  
19 of the --

20 MR. CILLIERS: Yeah. So this is -- this  
21 is very much a repeat of what we have seen in the  
22 other diagrams in Chapter 7 as well. Although those  
23 are safety-related relays, the power supply going  
24 through them are not safety-related. So the only  
25 safety-related part is the relay itself that should

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 fail open in all cases. So that makes it a safety-  
2 related component.

3 Also, the power supply that keeps it  
4 closed is not a safety-related power supply. So if  
5 that power should fail, it should fail open and the  
6 power is shut off to it.

7 So the isolating device is the same  
8 devices that you will see in the -- in the Chapter 7  
9 figures. If there is a power loss to those relays,  
10 either through the signal that keeps it closed that  
11 comes from the RPS, or the power itself that goes  
12 through the system, those systems basically lose power  
13 and they shut off.

14 MEMBER HALNON: Okay. And you're not  
15 going to rely on that for any safety-related function,  
16 right? I mean, you're not going to rely on loss of  
17 power to open the relay.

18 MR. CILLIERS: No. We don't rely on the  
19 loss of power to open the relay. We shut the power  
20 off, the signal to it, from the RPS. We rely on that  
21 part, that the RPS would send that signal. But also,  
22 loss of power would result in the same outcome as what  
23 would come from the RPS. Does that make sense?

24 MEMBER HALNON: Yeah. I guess my point  
25 was, I mean, you're showing one relay there. But if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 you're going to rely on it as a tripped RPS, you would  
2 have a redundant relay there.

3 MR. CILLIERS: Yeah. I think that's  
4 implied in the -- in the statement, that it's a  
5 safety-related system.

6 MEMBER HALNON: Right.

7 MR. CILLIERS: In Chapter 7, it says times  
8 four as well. So there is four of them.

9 MEMBER HALNON: Okay. That makes sense.

10 MR. CILLIERS: That's not indicated in  
11 this, yeah.

12 MEMBER DIMITRIJEVIC: This is Vesna  
13 Dimitrijevic. I have one question. So you said that  
14 the loss of power, all of those systems fail in the  
15 same position, right? So there is shut down or, you  
16 know, the RPS is tripping, things like that, right?

17 MR. CILLIERS: Correct.

18 MEMBER DIMITRIJEVIC: Okay. Now the  
19 question is, so all of the -- before you boot in 20  
20 seconds, right, this all happened in 20 seconds after  
21 you get the power back from the diesel generators. So  
22 all of those trips will occur within those 20 seconds,  
23 right?

24 MR. CILLIERS: It's important to note that  
25 the DHRS -- or, sorry, that RCSS system is supplied

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 through -- where is the supply coming from? I believe  
2 that's supplied by -- or it's not.

3 Yeah. It's got 20 seconds while it will  
4 stay on. And if the power doesn't switch over, then  
5 it will -- it will shut off.

6 MEMBER DIMITRIJEVIC: Run this again by  
7 me. I didn't hear you well.

8 MR. CILLIERS: Sorry. Should I --

9 MEMBER DIMITRIJEVIC: I didn't hear you  
10 well, if you can --

11 MR. CILLIERS: Yeah.

12 MEMBER DIMITRIJEVIC: -- just repeat what  
13 you just said.

14 MR. CILLIERS: So we've got 20 seconds for  
15 the transfer to happen from the main power to the  
16 backup power.

17 MEMBER DIMITRIJEVIC: Right.

18 MR. CILLIERS: If the power does not  
19 transfer, then all those systems shuts down.

20 MEMBER DIMITRIJEVIC: But I think the  
21 power transfers, they will stay on diesel generator.  
22 Is that what you're saying? If the power stays, would  
23 all those systems stay -- be supplied from the diesel  
24 generator?

25 MR. CILLIERS: That's correct. Yes. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 idea is that they can -- they can keep running, and  
2 then we could shut them down if we realized we're not  
3 going to get the main power supply back within a  
4 specified period of time.

5 MEMBER DIMITRIJEVIC: All right. Thanks.

6 MEMBER BROWN: This is Charlie Brown  
7 again. I had one other question relative to Vesna's  
8 question sort of, or related. So once they shut down,  
9 you lose all that power, so those four systems shut  
10 down, and then the power comes back, do they restart  
11 or do they have to be manually restarted?

12 MR. CILLIERS: They should continue  
13 running. They should --

14 MEMBER BROWN: Nope. That's not what I  
15 asked. That's not what I asked.

16 MR. CILLIERS: They should restart.

17 MEMBER BROWN: You've lost power. They've  
18 gone off. ATS didn't transfer --

19 MR. CILLIERS: Oh, okay. Sorry.

20 MEMBER BROWN: -- put everything -- there  
21 is no electrical power on that 480 bus. Now, all of  
22 a sudden, a minute, two minutes, three minutes later,  
23 the power comes back. Those didn't shut down. Now,  
24 do they automatically restart?

25 MR. CILLIERS: Okay. Got it. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 understand your question now. No, they do not --

2 MEMBER BROWN: Thank you.

3 MR. CILLIERS: -- automatically restart.

4 There is a manual reset to all of these systems that  
5 will have to be reset before you can start them back  
6 up again.

7 MEMBER BROWN: Okay. Thank you.

8 MR. CILLIERS: Next slide?

9 MEMBER BLEY: On Charlie's question, but  
10 that UPS that is designed to fail in something just  
11 over 20 seconds, it will start recharging itself once  
12 you get power back. True?

13 MR. CILLIERS: Yeah. I would say so. But  
14 the reactor protection system would have opened the  
15 relay. So the reactor system has to be reset.

16 MEMBER BLEY: Okay.

17 MR. CILLIERS: So from the normal power  
18 system, the normal power system does not perform any  
19 circulated functions and is not credited for the  
20 mitigation of any postulated events.

21 AC power is distributed to the plant  
22 electrical loads during startup and shutdown, normal  
23 operation, and off-normal conditions.

24 The DC power supply is limited to the I&C  
25 functions that require the 24-volt DC for operations,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 and that is the signals that is supplied to those  
2 relays.

3 The passive design features do not rely on  
4 electrical power for safety-related SSCs to perform  
5 the safety function. During postulated events PDC 17  
6 and 18, the normal power system is designed so that  
7 the differential displacements do not preclude a  
8 safety-related SSC from performing its safety  
9 function. That's PDC 2. And the normal power system  
10 is designed in accordance with the National Fire  
11 Protection Association, NFPA 70, or the National  
12 Electric Code.

13 Next slide?

14 Now going to the backup power system, the  
15 backup power system does not perform any safety-  
16 related functions and is not credited for the  
17 mitigation of postulated events. The backup power  
18 system provides AC electrical power to essential loads  
19 when normal power is not available.

20 The backup power system includes the  
21 backup generators, which will automatically start in  
22 the event of offsite power with one redundant  
23 generator and built in by design. It includes the  
24 interruptible power supplies, a highly reliable and  
25 continuous AC electrical supply.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1           And, again, this is really for -- because  
2 we want to have electrical -- reliable electrical  
3 supply, electrical equipment to connect the backup  
4 generators to the low voltage AC electrical power  
5 distribution system and space for a plug-in connection  
6 for reportable 480-volt AC generator.

7           Next slide?

8           So the backup power system design basis,  
9 to ensure fail to safety in the event of a complete  
10 loss of AC electrical power system, the reactivity  
11 control and shutdown system and the primary sump pump  
12 relays require on 24-volt DC to remain closed.

13           On a loss of power, the RCS relay opens,  
14 and the shutdown elements drop into the reactor by  
15 gravity. On loss of power, the PSP relays open to  
16 prevent inadvertent pump and blower restart on power  
17 restoration. And this includes all other systems that  
18 we would like to shut off during such an event,  
19 similar to what a trip would be.

20           On activation of the decay heat removal  
21 system, the reactor protection system will remove the  
22 24-volt DC from the activation circuit relay to  
23 prevent inadvertent shutdown of the DHRS by operator  
24 error. So there is a relay that opens as well, which  
25 I believe wasn't in the -- in the pictures before, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 that is there.

2 Equipment for monitoring the reactor  
3 status will be supplied by UPS until the normal power  
4 supply or backup generators are restored.

5 Passive design features do not rely on  
6 electrical power for safety-related SSCs to perform  
7 the safety functions. During postulated events --  
8 that's PDCs 17 and 18 -- the backup power system is  
9 designed so that differential displacement do not  
10 preclude safety-related SSCs from performing its  
11 safety function. That's PDC 2. And the backup power  
12 system is also designed according to the National  
13 Electrical Code.

14 And if there is any more questions, I'm  
15 happy to answer them.

16 MEMBER BLEY: Well, this is Dennis Bley  
17 again, and I guess one comment -- I think everything  
18 is fine for the construction permit. But the things  
19 I mentioned earlier, the emergency lighting  
20 communications and monitoring, are really essential if  
21 things don't go the way we expect them to go. And I  
22 know you are putting in what you consider to be very  
23 reliable 72-hour UPSs.

24 But for the staff, you know, in the past  
25 people were eventually persuaded to go 1E on these or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 to have some kind of justification that they were  
2 equivalent. And I think we need at least some kind of  
3 treatment and pedigree requirements for those things,  
4 because they are very important.

5 I don't know if the Committee would want  
6 to say anything about that in their reports or not.

7 And the other one is that 20-second UPS  
8 capacity is just kind of gnawing at me. I've been  
9 involved in testing batteries in powerplants, and,  
10 yeah, they almost always last a lot longer than  
11 predicted, which is usually great. Here you're  
12 counting on them to fail in a certain amount of time,  
13 and I don't recall anybody who has designed batteries  
14 to do that.

15 And I think you've got to be careful with  
16 that. You might need some additional circuitry to  
17 make sure it does what you want it to do. And I don't  
18 think it's a killer for now, but I think it is --  
19 needs to be addressed by operating license time.

20 That's the only comments from me.

21 MR. CILLIERS: Thank you very much. We've  
22 got some -- some systems in the works for that, so,  
23 yeah, we will definitely consider that for OLA.

24 CHAIR PETTI: Any other questions,  
25 members? Go ahead, Charlie.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MEMBER BROWN: Just a minute. I've got to  
2 find it. Problem with the computers. I've got to  
3 make the page bigger.

4 In Section 8.3.1.1 under your backup  
5 generators, in the last paragraph, it talks about the  
6 backup generator coming on, start up automatic  
7 transfer switch, a load-shedding scheme is employed to  
8 ensure that only essential loads are supplied.

9 So that implies to me that the backup  
10 diesel generator cannot support the load of everything  
11 in its normal configuration at the time you lose the  
12 main grid power source. Is that correct? That's what  
13

14 MR. CILLIERS: Yeah. That would be  
15 correct. But the specific scheme of what systems we  
16 want to remain on and what systems we do not, what is  
17 deemed as non-essential supplies that we will just  
18 simply not have on the backup power supply, that has  
19 not been defined yet.

20 So all systems really related to the  
21 reactor operations will be on the generator system.  
22 We just didn't want to leave it open so that we have  
23 the entire plant running off the -- off the  
24 generators.

25 MEMBER BROWN: Yeah. I saw the list about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 not going to be supplied, but I also didn't see any  
2 load, even an approximate load analysis that you would  
3 need to be drawing on from the grid anyway that would  
4 size that. It just --

5 MEMBER HALNON: Well, you need to get  
6 equipment specs.

7 MEMBER BROWN: No, I understand. Exactly.  
8 But shedding the load when the backup generator comes  
9 on is not a real, real good idea, although it can be  
10 done. So --

11 MEMBER HALNON: It's all right as long as  
12 you do it, so you don't get an overstated trip.

13 MEMBER BROWN: Exactly.

14 MEMBER HALNON: I mean, that's pretty  
15 common and, you know, load shed, load schemes are  
16 pretty --

17 MEMBER BROWN: Well, you've got everything  
18 trying to restart. So some start -- some things won't  
19 restart and others will.

20 All right. You answered my question. I  
21 just -- just kind of hanging that one out to dry.  
22 Thank you.

23 MEMBER BLEY: Charlie?

24 MEMBER BROWN: Yeah.

25 MEMBER BLEY: And I guess for these guys.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 You probably have some kind of load sequence or  
2 something that you didn't describe at this early  
3 stage. Is that what you expect?

4 MR. CILLIERS: That's correct. We do not  
5 have the information on what those loads would look  
6 like at the time of issuance. But, yes, the simple  
7 answer is the -- all essential loads, which will  
8 include an exhaustive list of systems, will run from  
9 the backup power supply.

10 We do not want to leave the impression  
11 that the entire plant, with all -- with all systems  
12 and offices and everything else will be running off  
13 that. But that specific list of what is -- what is  
14 deemed as essential would be operations and doing safe  
15 shutdown will be included in the OLA.

16 MEMBER BROWN: Okay. You answered my  
17 question. I'll leave it up to Dennis to deal with the  
18 other side. Thank you.

19 MEMBER BLEY: And that's for later. Yeah.

20 MEMBER BROWN: Okay.

21 CHAIR PETTI: Okay. Then let's move to  
22 the staff slides.

23 PARTICIPANT: I'll turn it over to Sheila  
24 Ray, who will present the staff's review of Chapter 8.

25 MS. RAY: Good afternoon. My name is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Sheila Ray. I'm currently a senior electrical  
2 engineer in the Electrical Engineering Branch. I'm  
3 also a licensed professional engineer in the State of  
4 Maryland.

5 The review of the electrical power systems  
6 was completed by myself and Vijay Goel. He's an  
7 electrical engineer, and he is participating  
8 virtually.

9 Next slide.

10 So we have had an overview from Kairos  
11 that talked about the non-Class 1E normal and backup  
12 power system. Due to the passive design of Hermes,  
13 safety-related structures, systems, and components do  
14 not require electric power to perform safety-related  
15 functions for a minimum of 72 hours following a design  
16 basis event.

17 As such, AC and DC power are not required  
18 to mitigate a design basis event and the power --

19 MEMBER BROWN: Can I interrupt you?

20 MS. RAY: Yes. Always.

21 MEMBER BROWN: You said that they have  
22 determined that they -- they didn't need these systems  
23 to operate -- how did you phrase that? It was how you  
24 phrased it that triggered my thought process.

25 No, it wasn't -- you don't need them on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 more than 72 hours under -- you said something. How  
2 did you --

3 MS. RAY: So I said they do not require  
4 safety -- SSCs do not require electric power to  
5 perform safety-related functions for a minimum of 72  
6 hours.

7 MEMBER BROWN: They don't need them for  
8 the minimum of 72 hours.

9 MS. RAY: Correct.

10 MEMBER BROWN: In other words, they don't  
11 need them at all.

12 MS. RAY: Correct.

13 MEMBER BROWN: Okay. That's the -- that's  
14 not the way I heard it. Thank you.

15 MS. RAY: Okay. You said it right. I was  
16 just -- my ears were behind.

17 MEMBER MARCH-LEUBA: Yeah. It's the same  
18 for ESFs, not only protection systems. Anything else

19

20 MEMBER BROWN: Yes, right. Nothing used  
21 anything.

22 MEMBER MARCH-LEUBA: They just deenergize  
23 POMs on the drops, and there you go. It's a good  
24 design.

25 MS. RAY: So the slide also provides the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 principle design criteria as listed here, PDC 17 and  
2 18.

3 Next slide, please.

4 So we had the AC and DC system provided by  
5 an offsite source, and we heard that the normal power  
6 system is designed in accordance with the National  
7 Electrical Code.

8 The staff conducted an audit, and during  
9 the audit the staff confirmed that no electrical  
10 systems were required for performing any safety-  
11 related function for safe shutdown of the plant or to  
12 keep the plant in safe shutdown condition.

13 Next slide.

14 MEMBER MARCH-LEUBA: Just one back. In  
15 the previous slide, you mentioned one power -- offsite  
16 power supply. But they are going to have two, right?

17 MS. RAY: I believe it's one.

18 MEMBER MARCH-LEUBA: I mean, you have  
19 Kingston and Bull Run powerplants within five miles.  
20 Yeah. Anyway, I will have to -- even if I don't need  
21 emergency power, I will be more comfortable.

22 MS. RAY: I understand.

23 MEMBER MARCH-LEUBA: For the record, I was  
24 involved in -- I used to be at Oak Ridge, and I was  
25 involved in the design of a reactor in Oak Ridge

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 National Laboratory. And we were making a case to DOE  
2 that Oak Ridge has the lowest incidence of tornado  
3 hits in the United States. And we were succeeding,  
4 and that weekend a tornado hit our office and broke it  
5 down.

6 (Laughter.)

7 MEMBER MARCH-LEUBA: I mean, it destroyed  
8 all the computers in the office. So, anyway --

9 MEMBER BLEY: But their design says one  
10 line coming in.

11 MEMBER MARCH-LEUBA: It's all they need  
12 for sure, but let's hope it's a high reliable --  
13 highly reliable line.

14 MS. RAY: The normal power system is not  
15 credited for postulated events or safe shutdown, and  
16 it is classified as non-Class 1E or non-safety, and no  
17 technical specifications for the normal power system  
18 are required.

19 Staff concluded that the PDCs 17 and 18  
20 are not applicable, since there are no Class 1E  
21 electric power systems, and non-safety power is  
22 available for non-safety functions not credited for  
23 DBE.

24 Next slide.

25 We heard about the backup power system,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 which provides AC electrical power to the essential  
2 facility loads when the normal AC power supply is not  
3 available.

4           Once again, the backup power system is  
5 designed in accordance with the National Electric  
6 Code.

7           Next slide.

8           As the backup power system does not  
9 perform any safety-related functions, is not credited  
10 for the mitigation of postulated events, and is not  
11 credited with performing safe shutdown functions, the  
12 non-safety classification is appropriate. The staff  
13 finds that the PDC 17 are not applicable. There are  
14 no Class 1E electric power systems, and non-safety-  
15 related power is available for non-safety functions,  
16 not credited for DBE.

17           Next slide.

18           So, once again, the staff finds that the  
19 PDC 17 and 18 are not applicable, since there are no  
20 safety-related electrical power systems. Non-safety-  
21 related power is available for non-safety functions  
22 not credited for DBE, and the staff finds that the  
23 design of the Hermes normal power system and backup  
24 power system are sufficient and meet the applicable  
25 regulatory requirements and guidance for the issuance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 of a CP, construction permit, in accordance with Title  
2 10, CFR 50.35 and 50.40.

3 That concludes my presentation.

4 MEMBER BLEY: What -- I'm sorry. Go  
5 ahead.

6 MEMBER KIRCHNER: Go ahead, Dennis.

7 MEMBER BLEY: Yeah. This is Dennis Bley.  
8 The same thing I was talking to them about, both  
9 questions deal with UPSs. I think you'll remember  
10 there were a couple of places where we had systems  
11 that for design basis didn't need electric power and  
12 didn't have 1E power. But in the two cases I'm  
13 remembering, eventually they agreed to some sort of  
14 requirements on what here would be the 72-hour UPS, to  
15 make sure its pedigree and the required treatment of  
16 it gets the sort of reliability we really want for  
17 systems that we need to monitor and see things around  
18 the plant and communicate.

19 You didn't say anything about that in the  
20 SE. What are your thoughts about that?

21 MS. RAY: So in our Regulatory Guide  
22 1.232, we do have the PDC 17 state that if electric  
23 power is not needed for AOOs or postulated accidents,  
24 the design shall demonstrate that power for safety  
25 significant functions is provided.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           But when we wrote that, we intended to  
2 include items like emergency lighting, communications,  
3 et cetera. So the staff's position is that can be  
4 non-safety-related power.

5           MEMBER BROWN: And the communications in  
6 lighting are on a 72-hour UPS just once.

7           MEMBER BLEY: Yes, they are. And so is  
8 the monitoring step, so they are. I just remember  
9 those cases in the past where you kind of added some  
10 extra requirements to make sure that they were there.

11           Second question was about their UPS that  
12 is going to trip in 20 seconds. Are you guys aware of  
13 any designs that are guaranteed to trip in a required  
14 time period? Not trip, but lose power. I'm not.

15           MS. RAY: I'm not aware of any. I would  
16 have to go back and look.

17           MEMBER BLEY: There wasn't anything in the  
18 chapter that said that was important, but today they  
19 said, yeah, they really needed to lose power in 20  
20 seconds. I think that's something for later, but I  
21 just wanted to bring it to your attention.

22           MS. RAY: Thank you.

23           MEMBER KIRCHNER: This is not a question,  
24 Sheila, just an observation. And it -- and it's --  
25 and I was saving it for here. As an operator, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 always want to have electric power, so you can do  
2 things to mitigate things. We have seen now, you know  
3 -- I get it. When they say the system doesn't have a  
4 safety function that's not credited, okay, fine,  
5 that's more so you can bend things in terms of  
6 economics and other considerations.

7 But I keep stumbling over this not needed  
8 to mitigate anything, and yet we have a first-of-the-  
9 kind reactor and who knows what happens at the 73rd  
10 hour, like I don't know, all of a sudden you find you  
11 are losing primary coolant inventory. I would want my  
12 inventory management system which they are designing  
13 to be functional to help cope with that loss. I'm  
14 making up a rhetorical scenario. I haven't thought it  
15 through.

16 So I understand the rules of engagement,  
17 but the constant onslaught on all the viewgraphs, that  
18 none of this needed to mitigate anything, after a  
19 while cumulatively bothers me because that assumes now  
20 we have looked at the design basis -- we have a very  
21 thorough design, and we have looked at all of the  
22 events, and we have a PRA, and we have laid all these  
23 kind of rhetorical kind of challenges against the  
24 system which we haven't.

25 So I would just observe that we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 constantly saying we don't need electric power to  
2 mitigate anything, and I -- it just leaves me a little  
3 concerned. I know that's part of the regulatory  
4 engagement and game that is being played, but as a  
5 former operator, I'm thinking, oh boy, you know, if  
6 this goes wrong or that goes wrong, that's when you  
7 need electric power to try and --

8 MEMBER HALNON: Well, there are two backup  
9 generators and a portable connection. You can back a  
10 tractor up with a PTO to --

11 MEMBER KIRCHNER: Yeah. So it's -- so  
12 they do have the FLEX provision.

13 MEMBER HALNON: Yeah. So, you know, as an  
14 operator, I want to have no stone unturned on, you  
15 know, what is the next option.

16 MEMBER KIRCHNER: Yeah.

17 MEMBER HALNON: But it seems like --

18 MEMBER KIRCHNER: That's where I was  
19 going, Greg.

20 MEMBER HALNON: Yeah.

21 MEMBER KIRCHNER: It's just -- I'm not  
22 objecting. I'm not raising any major safety issues.  
23 Just --

24 MEMBER HALNON: Because when you get down  
25 to those accidents and other issues, operators don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 think safety-related/non-safety-related. They think  
2 electrons and volts.

3 MEMBER KIRCHNER: Right. That's where I  
4 was going. Just an observation.

5 CHAIR PETTI: And I'm sure we'll see this  
6 with other advanced reactor designs.

7 MEMBER KIRCHNER: What?

8 CHAIR PETTI: We'll see this with other  
9 advanced reactor designs.

10 MEMBER KIRCHNER: No. No, of course we  
11 will. Yeah.

12 CHAIR PETTI: This is characteristic and  
13

14 MEMBER BROWN: Let me -- my memory may  
15 have failed me, but when I read this chapter, I now  
16 vaguely remember -- this is very vague, an old brain  
17 that the figure that shows two backup generators was  
18 noted in the text to maybe only be one. I saw that  
19 somewhere, and I don't remember where it was. I know  
20 it's in here somewhere.

21 MEMBER HALNON: I don't remember that,  
22 Charlie, but could they -- the backup generator  
23 running doesn't mean there's not two backing up to the  
24

25 MEMBER BLEY: I don't remember either.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER BROWN: For some reason, don't ask,  
2 my mind is blowing right now. I probably just ought  
3 to be quiet.

4 MEMBER HALNON: We'll put a bookmark in it  
5 and come back later.

6 MEMBER BROWN: All right. Put a cork in  
7 me would be -- probably be a better approach. Plus,  
8 it does say generators, plural, in the text.  
9 Somewhere I saw something where I thought it said only  
10 one, or possibly only one. That's fine. Let's go on.

11 MEMBER MARCH-LEUBA: Charlie, the slide  
12 number 2 says backup supply (N minus 1 contingency).  
13 Is that what you are thinking about?

14 MEMBER BROWN: No. I saw that. That is --  
15 you have two of them, so they -- if one of them  
16 doesn't start, then the other one -- hopefully the  
17 other one will. So that -- that didn't bother me.  
18 That --

19 MEMBER MARCH-LEUBA: So they probably --

20 MEMBER BROWN: I'm wrong. Just --

21 MEMBER MARCH-LEUBA: They probably mean  
22 that only one is created, but it's a backup. Let's  
23 continue.

24 CHAIR PETTI: Okay. If there's no other  
25 questions, we can move to the memo.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   And the court reporter can stop  
2 transcribing. Thanks.

3                   (Whereupon, the above-entitled matter went  
4 off the record at 1:42 p.m. and resumed at 1:44 p.m.)

5                   CHAIR PETTI: Okay. Court reporter, we  
6 are back on.

7                   MR. CLARK: This is Austin Clark. I'm an  
8 engineer with the licensing team here at Kairos Power,  
9 and I am presenting on PSAR 11, Section 1, radiation  
10 protection.

11                   Chapter 11 of the Preliminary Safety  
12 Analysis Report addresses commitments regarding  
13 radiation protection and waste management for the  
14 Hermes non-power reactor. Radiation protection  
15 includes identifying radiation sources, describing the  
16 radiation protection program, the ALARA program, and  
17 the environmental monitoring program, and describing  
18 radiation monitoring and surveying, radiation exposure  
19 control, dosimetry, and contamination control.

20                   Radioactive waste management includes  
21 describing the radioactive waste management program,  
22 radioactive waste handling systems and controls,  
23 design bases, and disposal of the radioactive wastes.  
24 For the PSAR, these programs are designed at the  
25 commitment level only.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Next slide, please.

2 MEMBER MARCH-LEUBA: While you're changing  
3 the slides, we mentioned earlier this morning -- so we  
4 mentioned earlier -- this is Jose. Mentioned earlier  
5 this morning about the possibility of mixed waste  
6 where you have both chemical and radioactive disposal,  
7 especially during decommissioning.

8 Can you tell us anything more about that?  
9 Or you just stand by the comment earlier? So the  
10 question is you have -- we have beryllium, which is a  
11 chemical waste mixed with some degree of  
12 contamination, radioactive contamination, that has to  
13 be disposed of.

14 MR. CLARK: I think -- so as far as  
15 handling onsite, obviously, because it's radioactive  
16 waste we will have to have radiological protection  
17 programs in place.

18 As far as the mixed waste aspect of  
19 beryllium waste, that falls under OSHA and we intend  
20 to be compliant with all OSHA requirements. And then  
21 as far as disposal, as we mentioned this morning, we  
22 have already contacted a vendor and received a written  
23 letter from them that they will be able to handle fly  
24 as a mixed waste.

25 MEMBER MARCH-LEUBA: And we've heard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 rumors that the fly, because the lithium is going to  
2 be enriched, could be worth a significant amount of  
3 money. Are you considering reprocessing for future  
4 reactor, or this is beyond the scope for this  
5 analysis?

6 MR. CLARK: It's beyond the scope at this  
7 point.

8 MEMBER MARCH-LEUBA: Okay. Thank you.

9 MR. CLARK: Sources of radiation include  
10 fission products, decay products, fuel, and activation  
11 products, including tritium. Sources of airborne,  
12 liquid, and solid radiation identified for the  
13 facility are given in Table 11.1-1 of the PSAR.

14 The radiation protection program, as  
15 required by 10 CFR 20.1101, will implement the  
16 regulations in 10 CFR 19 and CFR 20 to ensure  
17 compliance with the requirements for radiation  
18 protection. The radiation protection program contents  
19 and implementation will be reviewed periodically.

20 The ALARA program, as required by 10 CFR  
21 20.1101, will include provisions for the facility to  
22 maintain worker and public doses and radiological  
23 releases as low as is reasonably achievable.

24 The ALARA program will be consistent with  
25 the guidance in Regulatory Guide 8.10, operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 philosophy for maintaining occupational and public  
2 radiation exposures as low as is reasonably  
3 achievable, Revision 2. And a description of the  
4 program will be provided with the application for an  
5 operating license.

6 Radiation monitoring and surveying will be  
7 conducted as required by 10 CFR 20 to identify and  
8 control potential sources of radiation exposure and  
9 release.

10 Next slide, please.

11 All facility effluents are monitored prior  
12 to release. SSCs in the facility are designed to  
13 limit effluent releases both to work areas and to the  
14 environment. A screening analysis of the long-term  
15 radioactive effluents from the facility was completed.  
16 That analysis used the NRC's XOQ/DOQ and Gas Power 2  
17 codes for dispersion and dose model calculations,  
18 respectively, site-specific validated meteorological  
19 data covering the five-year period of record, and a  
20 bounding tritium admissions rates set equal to the  
21 first year tritium generation rate.

22 The limits for airborne radioactive  
23 emissions and for all licensed operations are given in  
24 10 CFR 20.1101(d) and 10 CFR 20.1301(a)(1),  
25 respectively. All model doses are conservatively

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 bounded and are below the limits specified in 10 CFR  
2 20.

3 Next slide, please.

4 MR. SCHULTZ: Excuse me. This is Steve  
5 Schultz. A question on your last slide.

6 MR. CLARK: Mm-hmm.

7 MR. SCHULTZ: You have assumed a bounding  
8 tritium emission, as you have indicated, equal to the  
9 first year tritium generation rate. My question is  
10 really looking forward either -- to the OL information  
11 that will be presented. Do you intend to take credit  
12 for any plant retention associated with tritium? And  
13 the reason I'm mentioning this is that if you look at  
14 -- not you look, but looking into the literature  
15 associated with tritium emissions, which has a key  
16 focus in -- both in the industry and with respect to  
17 the public, the information generally looks at  
18 emissions from various types of powerplants.

19 And, in that regard, they take credit for  
20 plant retention in their evaluation of tritium  
21 emissions. Are you planning to do that in the future  
22 and have just done this bounding calculation for this  
23 -- for this permit evaluation, construction permit?

24 MR. PEEBLES: This is Drew Peebles, the  
25 senior licensing manager. We're not prepared to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 discuss the final analysis that will be in the FSAR,  
2 only that we'll meet the Part 20 regulations.

3 MR. SCHULTZ: Okay. My comment is really  
4 a suggestion for activities in the future. Thank you.

5 MR. PEEBLES: Understood. Thank you for  
6 your comment.

7 MEMBER MARCH-LEUBA: Yeah. And while  
8 we're bringing the tritium issue, the analysis assumed  
9 that all of the tritium generated in one year gets  
10 released today with an accident, because now tritium  
11 will be released over the year. It will be slowly  
12 released.

13 MR. CLARK: So the Chapter 11 analysis  
14 looks at long-term effluent releases. It looks at the  
15 first year tritium generation rate because for the  
16 reactor life that is the highest generation rate for  
17 tritium. But it assumes a continuous release.

18 MEMBER MARCH-LEUBA: So it's a chronic  
19 dose.

20 MR. CLARK: Chronic dose.

21 MEMBER MARCH-LEUBA: Okay.

22 CHAIR PETTI: I had a different question.  
23 Probably the answer is you don't know yet. But have  
24 you looked at all into concentrations of tritium in  
25 the reactor cell and in the building, and what sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 worker protections may be necessary? Will they need  
2 bubble suits? You know, will you be above the DAC,  
3 the derived airborne concentration? Or you just don't  
4 -- you're not there yet in terms of the detailed  
5 design?

6 MR. CLARK: Yeah. That's another one that  
7 will be -- those details will be available in the OLA  
8 phase.

9 CHAIR PETTI: So if I ask the same  
10 question about beryllium in NIOSH standards, it's the  
11 same answer?

12 MR. CLARK: Correct.

13 CHAIR PETTI: Don't -- you know, it put  
14 high on your list. Those numbers are incredibly low,  
15 particularly the beryllium numbers. And I think  
16 you're going to have to monitor. There are  
17 technologies. That's good. But the numbers are  
18 really tight.

19 MEMBER MARCH-LEUBA: The unfortunate  
20 thing, it is very easy to capture tritium. Hydrogen  
21 reacts with everything at low temperatures, at 600  
22 degrees.

23 CHAIR PETTI: I mean, that is -- I mean,  
24 tritium is going to be everywhere in this plant,  
25 because of the high temperature.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER MARCH-LEUBA: Yeah.

2 CHAIR PETTI: And, you know, go talk to  
3 the guys that are doing the TP baths and power  
4 reactors. That's a low temperature, and it's -- the  
5 tritium is in lots of places. So it's from a worker  
6 perspective. I'm not worried about public safety.  
7 This is all about workers, because we've never had a  
8 real high temperature tritium system like this.  
9 CANDUs are much lower temperature.

10 Thank you.

11 MR. CLARK: Thank you. Consistent with 10  
12 CFR 20.1406, SSCs that may contain or handle  
13 radiological materials include design considerations  
14 to limit leakage and to provide contamination control  
15 in support of eventual decommissioning of the  
16 facility.

17 Environmental radiological monitoring will  
18 be conducted as required by 10 CFR 20.1302 and under  
19 an operational radiation affluent monitoring program,  
20 or RAMP, which will consider the guidance provided in  
21 Regulatory Guide 4.1, radiological environmental  
22 monitoring for nuclear powerplants, Rev 2, and NUREG  
23 1301 offsite dose calculation manual guidance,  
24 standard radiological effluent controls for  
25 pressurized water reactors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           Due to the extensive environmental  
2           characterization of the brownfield site by the  
3           Department of Energy, the RAMP will be implemented  
4           coincident with the start of operation.

5           MEMBER HALNON:     But along with the  
6           characterization, do you have I guess what's  
7           equivalent of the 70 -- 10 CFR 50.75(g) records of the  
8           site you are building on right now? In other words,  
9           when you look at 20.1406, I assume that's mainly  
10          geared towards just preventing spills. That may have  
11          to be cleaned up at a -- can't be totally cleaned up  
12          during operations, may have to be cleaned up during  
13          decommissioning. Is that consistent with your  
14          thinking?

15          MR. CLARK: This is another thing that we  
16          will have more details at the FSAR.

17          MEMBER HALNON: Okay. Well, you should  
18          know from the last statement that you say it's well  
19          characterized by the -- by the DOE. Do you have the  
20          records of what's left on the brownfield? Because,  
21          obviously, greenfield would be below, you know, a  
22          certain millirem into the soil, but if it's a  
23          brownfield, do you understand how that may affect your  
24          ultimate decommissioning?

25          MR. GARDNER: Okay. So this is Darryl

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 Gardner, senior director of licensing. All good  
2 questions. We have the site release from DOE. We  
3 have -- there's lots and lots of data about this site  
4 that's addressed as part of our environmental report.

5 As we mentioned, we will be discussing the  
6 environmental monitoring plan as we move into the OL  
7 stage, including decommissioning. That's just  
8 information we're not prepared to discuss for the  
9 PSAR.

10 MEMBER HALNON: All right. Thanks.

11 MR. LINGENFELTER: All right. Hi,  
12 everyone. I'm Andrew Lingenfelter, lead engineer of  
13 Engineering Integration. I will be talking today  
14 about Section 11.2, radioactive waste management.

15 But, first, we'll go through a  
16 description. Radioactive waste management systems are  
17 provided in the Hermes design for the collection,  
18 packaging, storing, and dispositioning of low level  
19 liquid and solid radioactive waste.

20 The systems' functions include  
21 decontamination capability for components and  
22 materials, vents and drains for collection of liquid  
23 rad waste, liquid rad waste handling, and solid rad  
24 waste handling.

25 These systems are not credited to perform

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 any safety-related functions, and the design bases  
2 include the following. In accordance with PDC 2, they  
3 are designed so that seismic-induced failure does not  
4 impact the safety-related -- impact any safety-related  
5 SSCs. In accordance with PDC 60, the design is such  
6 that releases of radioactive material to the  
7 environment do not exceed the limits of 10 CFR 20.

8 In accordance with PDC 63, they are  
9 equipped with a radiation monitoring system to monitor  
10 effluent radiation levels. And in accordance with 10  
11 CFR 20.1406, they are designed to the extent  
12 practicable to minimize contamination of the facility  
13 and the environment, and facilitate eventual  
14 decommissioning.

15 Additional system description information  
16 will be provided with the OLA.

17 We will talk about the program side here.  
18 The low level radioactive waste, including all solid  
19 and some liquid radioactive waste, is expected to be  
20 packaged and disposed using a licensed and qualified  
21 low level radioactive waste disposal vendor.

22 Gaseous radioactive effluents are filtered  
23 as practicable and monitored prior to release. Rad  
24 waste will be managed as described by the radioactive  
25 waste management plan, and we will be providing more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 details on this program in the OLA.

2 CHAIR PETTI: Members, questions?

3 MEMBER KIRCHNER: Just one point that you  
4 raised, Dave. This is Walt Kirchner. How does  
5 beryllium handling -- obviously, beryllium is  
6 regulated under OSHA in terms of occupational  
7 exposures and such. But you've got -- even if we  
8 don't -- you don't have a mixed waste stream of  
9 beryllium and their radioactive effluents, you've got  
10 to deal with beryllium detection, at least at an  
11 occupational level. What are the general constraints  
12 that beryllium introduces to your Chapter 11  
13 considerations?

14 MR. CLARK: So as was pointed out,  
15 beryllium is handled under OSHA and under NIOSH. So  
16 as far as Chapter 11, there won't be much more  
17 specifically on beryllium handling and even in the  
18 operating license application. But it will be  
19 something that is addressed, because compliance with  
20 OSHA and NIOSH is required.

21 MEMBER KIRCHNER: No. I'm just thinking  
22 aloud with you. What complications does it present in  
23 terms of your -- does it become more dominant than  
24 your -- for example, your tritium management  
25 requirements?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MR. GARDNER: So this is Darryl Gardner  
2 again, director of licensing. Again, these are  
3 interesting questions. I think it's just important to  
4 point out you are talking about chemical hazards,  
5 which are not within the scope of what we need to  
6 address for the PSAR, and so we have not.

7 It's not to suggest that we aren't  
8 addressing those, as Austin mentioned that we are.  
9 I'm just not sure this is the forum for us to get into  
10 those details when the complete plant hasn't been  
11 designed yet.

12 MEMBER KIRCHNER: No. I understand that.  
13 Where I'm going with this is, does the beryllium  
14 management wind up being more of a constraint on  
15 things like your ventilation systems, et cetera, than  
16 the tritium or other concerns?

17 MR. GARDNER: That's a fair question. I'm  
18 not sure we -- I don't want to say prepared to answer.  
19 I'm not sure we have enough information to tell you  
20 which one would be which. But suffice it to say, I  
21 mean, it certainly is a factor in the ventilation and  
22 confinement design, the non-safety-related portion of  
23 the building design.

24 CHAIR PETTI: So the concern that I have,  
25 you know, this is fairly unique. There are rules on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 chemical hazards. There are rules on radiation  
2 hazards. But if all -- if there is beryllium  
3 particulate, which there will be because of the  
4 dendritic deposition of fluoride and cold spots like  
5 on pump stem or something, if MSRE is any indication.  
6 There could also be some tritium absorbed onto that  
7 material.

8 So the material could both be chemically  
9 hazardous and radioactive, and the rules don't even  
10 address that. That co-hazard if you will, you know

11

12 MEMBER KIRCHNER: But it's called a mixed  
13 waste.

14 CHAIR PETTI: Well, that's from a waste  
15 perspective. I'm talking about from an operational  
16 perspective. I have not thought that -- what does  
17 that mean? Does that imply anything? I don't know.  
18 So, because the rules never envisioned it coming  
19 together, right? There were different types of  
20 facilities, so each --

21 MEMBER MARCH-LEUBA: You are talking about  
22 worker protection.

23 MEMBER KIRCHNER: Worker protection.

24 CHAIR PETTI: Yeah. Worker protections.

25 MEMBER KIRCHNER: The extreme that I would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 just be concerned about -- and, again, this is more  
2 having dealt with beryllium in the past, you've got --  
3 that was in the metal form, solid metal form.

4 So less of a hazard until you start  
5 machining, for example, then dealing with a liquid,  
6 but not -- never done in the context of also having to  
7 worry about radioactivity separate.

8 MEMBER MARCH-LEUBA: I'm not --

9 MEMBER KIRCHNER: What I'm concerned with  
10 is, does the beryllium -- for example, you don't have  
11 a confinement system per se for the reactor where the  
12 beryllium issues drive you to a more restrictive  
13 airflow in that cavity, et cetera, et cetera. Those  
14 are the kind of concerns I would have that -- when you  
15 have the two -- you have regulations concerning the  
16 beryllium, and then you have regulations concerning  
17 Chapter 11, 10 CFR 20 to be specific.

18 CHAIR PETTI: Well, the other --

19 MEMBER KIRCHNER: That was my question.

20 CHAIR PETTI: The other question, I mean,  
21 again, it's way outside our scope, but you need a good  
22 health physicist. And all the limits that we have,  
23 assume everything is independent, is the -- is the  
24 burden on the individual different when it's mixed?  
25 I don't know what the answer is to that. You know, is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 it a synergistic effect between a worker picking up  
2 some beryllium and some tritium?

3 MEMBER MARCH-LEUBA: Clearly, it can be  
4 because the absorption in the body is completely  
5 different depending on the chemical form. Hopefully,  
6 they won't be close to limits; they will be very far  
7 away from limits. All this is academic, but we need  
8 to know what you guys will have. I'm pointing at the  
9 staff. At the OL's stage, you have to make sure that  
10 that is the case. Wishful thinking is really not --  
11 for other people, not for us.

12 CHAIR PETTI: Okay. Let's move on.  
13 Staff?

14 MS. HART: Good afternoon. My name is  
15 Michelle Hart. I'm a senior reactor engineer in the  
16 Office of Nuclear Reactor Regulation, and I'm here to  
17 talk about my review of PSAR Chapter 11. This is the  
18 radiation protection and radioactive waste management  
19 sections of the PSAR.

20 Next slide, please.

21 So in our review of Chapter 11, as I said,  
22 there was preliminary information on the design and  
23 programs. You just heard from Kairos the level of  
24 information, and there were commitments to develop  
25 more detailed information in the operating license

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 application.

2           When we went through this review, there is  
3 a lot of discussion about how they will meet Part 20.  
4 They do not need to meet Part 20 for the construction  
5 permit, because there is no special nuclear material  
6 onsite. So we -- when we did the review, we looked at  
7 how they would be able to accomplish that in the  
8 future. Did they describe the systems and programs  
9 such that they would be able to do that during  
10 operation? And also, did they identify appropriate  
11 general design criteria?

12           Next slide, please.

13           So these are the topics in each of the  
14 sections. I won't go through them. You can read them  
15 for yourself.

16           Next slide, please.

17           Radioactive waste management for these  
18 particular topics. Okay?

19           So next slide, please.

20           So I wanted to talk a little bit more  
21 about radiation protection. We had questions about  
22 the PSAR information that we included in the general  
23 audit for this particular topic, radiation sources.  
24 The staff audit confirmed that Kairos did develop  
25 preliminary isotopic values for fuel and five

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 radiation sources for use in preliminary shielding  
2 design to support the information that's in the PSAR.

3 As Kairos has discussed several times, and  
4 we have discussed several times, there will be more  
5 detailed information in the FSAR for the operating  
6 license application.

7 We also audited their conservative  
8 screening analysis of the gaseous tritium emissions  
9 that was described in Section 11.1.5, and we noted  
10 that it was a conservative assumption for the tritium  
11 release rate, was equal to the generation rate for the  
12 year. It does not account for retention in the  
13 reaction, as was your question.

14 The release rate for other gaseous  
15 radionuclides was taken from the Clinch River ESP  
16 environmental report as kind of a representative set  
17 of information that may be released from a reactor.  
18 We thought it was a reasonable assumption for a  
19 preliminary analysis considering the relative power  
20 levels and the design differences between the  
21 reactors.

22 They did not model a liquid effluent  
23 release directly to the environment, and it was not  
24 expected based on the preliminary design, and we agree  
25 with that. So --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 CHAIR PETTI: Michelle, just a couple of  
2 questions. Do you happen to recall what the release  
3 rate was in curies per year?

4 MS. HART: I do not. I think --

5 CHAIR PETTI: Even an order of magnitude?

6 MS. HART: I didn't put it in the SE? I  
7 guess I didn't put it in the SE.

8 CHAIR PETTI: I wasn't sure if it's -- I  
9 can't believe that number would be proprietary, but  
10

11 MS. HART: Yeah. It was over --

12 CHAIR PETTI: I mean, microcurie,  
13 millicurie, curie.

14 MS. HART: It was curies.

15 CHAIR PETTI: It was curies per --

16 MS. HART: I think so. Does Kairos have  
17 that information and would like to provide it?

18 MR. GARDNER: It is in the PSAR, in the  
19 non-proprietary version of the PSAR. I don't recall  
20 it at the moment, but it's in large curies.

21 CHAIR PETTI: Okay. Good. My other  
22 question is on the whole thing -- okay, the liquid  
23 effluents. I know there is no liquid waste as well.  
24 Somebody gets contaminated in the plant, and you've  
25 got to scram down. What do you do with that water?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 It's now contaminated. I mean, is the plan to collect  
2 any water and solidify it? Is that the -- I mean,  
3 eventually, hopefully, you know, in a waterborne plant  
4 that would go, you know, off effluent treatment, et  
5 cetera, et cetera.

6 MS. HART: So they do describe collection  
7 of liquid wastes and packaging of that. I don't know  
8 that they've made a final determination --

9 CHAIR PETTI: But it may --

10 MS. HART: -- what they would --

11 CHAIR PETTI: -- solidify it. That would  
12 make -- that would make sense to me.

13 MS. HART: Correct.

14 MEMBER MARCH-LEUBA: Yeah. But the most  
15 source will be washing clothes. You will have  
16 overalls that are -- clothes that are contaminated,  
17 and you are not going to throw them all --

18 MEMBER HALNON: Right. I know that --

19 MEMBER MARCH-LEUBA: -- that is possible.

20 MEMBER HALNON: -- when we had to take  
21 water from TMI recently, we just dropped it off and  
22 disposed of it, big tanker truck. So, I mean, there's

23

24 MEMBER MARCH-LEUBA: Yeah. That's so not  
25 -- equal waste.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1                   MEMBER HALNON: Part 61, yeah. There's  
2 options to be able to --

3                   MS. HART: And of course they do commit to  
4 all of the waste regulations and shipping regulations  
5 and whatever is necessary for that.

6                   In looking at their screening calculation,  
7 we did look at the actual output from the XOQ/DOQ  
8 modules, so we were able to verify their description  
9 of it that they have in the PSAR.

10                  And we had several questions about the  
11 information in the PSAR, but we were able to have  
12 discussions with them about why they made those  
13 choices, like for the stack elevations. We did this  
14 in concert with the environmental review, so both the  
15 environmental reviewers and the safety reviewers  
16 looked at the information on the screening  
17 calculation, because it was used in both areas of  
18 review.

19                  Next slide, please.

20                  So for the remainder of topics in PSAR  
21 Section 11.1, radiation protection, we did not need  
22 additional information. In the audit, we did find  
23 that the PSAR describes the applicable regulatory  
24 requirements and guidance and provides preliminary  
25 information on the programs, practices, and design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 features, and that Kairos' commitments provide  
2 reasonable assurance that the Hermes design will  
3 comply with applicable requirements.

4 Next slide, please.

5 So now to move on to PSAR Section 11.2,  
6 the radioactive waste management. Staff did audit one  
7 topic area, the radioactive waste handling systems and  
8 controls. And this was, as I described before, just  
9 got done talking about we did look at the preliminary  
10 effluent calculation.

11 The PSAR describes the applicable  
12 regulatory requirements, preliminary design criteria  
13 and guidance, and provides preliminary design  
14 information on the systems that we have used for  
15 radioactive waste handling. And those PDCs are PDCs  
16 2, 60, and 63. And we did find that Kairos'  
17 commitments provide reasonable assurance that the  
18 Hermes design will comply with the applicable  
19 requirements.

20 I did also want to note that in addition  
21 to the information in the PSAR we did take some  
22 information from the environmental report on fly  
23 storage to help us make this determination.

24 Next slide, please.

25 There should be one more slide. There we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 go.

2 So in total for Chapter 11, the staff did  
3 find that preliminary information and design criteria  
4 for these radiation protection and waste management  
5 programs and provisions meet the applicable acceptance  
6 criteria in the NUREG-1537, and the provide reasonable  
7 assurance the final design will conform to the design  
8 bases and meet the applicable regulatory requirements  
9 and provides an acceptable basis for the development  
10 of the radiation protection programs and radioactive  
11 waste management.

12 And there is reasonable assurance that  
13 Kairos will comply with the regulations in 10 CFR  
14 Part 20 during facility operation, and, therefore, the  
15 staff concludes the information in Chapter 11 is  
16 sufficient to support issuance of construction permit.

17 Are there any questions?

18 MEMBER HALNON: Yeah. Michelle, did you  
19 in looking at 1537 Part 2, and I -- I go back on  
20 this a lot, that it's an old, you know, 20-plus-year,  
21 25 years old, did you see any areas that you were  
22 concerned about in the operating license of -- for the  
23 operating license, if it would not be adequate review  
24 criteria for you?

25 MS. HART: I --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309



1 MEMBER HALNON: I mean, this is a first-  
2 of-a-kind and type of reactor, and it wasn't  
3 anticipated back in 1997 when issued.

4 MS. HART: Right. So we have heard the  
5 concerns, and we have some similar concerns about, you  
6 know, the treatment of tritium and how it's going to  
7 be handled and how worker protection will be handled  
8 for that. I mean, I think a lot of it is to be  
9 determined when we get the actual final design detail.

10 MEMBER HALNON: Okay. So keep your eyes  
11 open, keep your ears --

12 MS. HART: Yeah.

13 MEMBER HALNON: -- open type of thing.

14 MS. HART: Yeah. I'm very interested in  
15 the analysis and all of that.

16 MEMBER HALNON: So this will be strict --  
17 it's not on 1537.

18 MS. HART: No. I was not planning to do  
19 that, assuming I would be --

20 MEMBER HALNON: Okay.

21 MS. HART: -- the reviewer.

22 CHAIR PETTI: So just something -- I did  
23 find the number. It's 62,500 curies per year.

24 MS. HART: It's several curies.

25 CHAIR PETTI: That's 6.2 grams per year

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 being released, so it is a significant number. It  
2 would be interesting to know what the CANDUs release.  
3 I used to know these numbers, but I've forgotten them.

4 The other question I had was I had asked  
5 the staff for an answer to a question, reminding me of  
6 one in the previous meeting. I'm used to, you know,  
7 in other reactor systems that deal with tritium, it  
8 comes through the heat exchanger. There's a secondary  
9 side, sometimes water, and there's a leak. And that  
10 tritium and that water has to meet the drinking water  
11 standard.

12 You know, in the DOE facilities they are  
13 doing interesting things with tritium. There is a  
14 water pathway. There is also an airborne pathway, but  
15 most of the issues are the waterborne pathway.

16 When you do it all like this and put it  
17 all airborne, does the fact that it could end up in  
18 the -- in the drinking water, is that considered in  
19 the whole chain of calculations?

20 MS. HART: So I will say, you know, the  
21 guidance that we have -- of course, it was for power  
22 reactors. It's Reg Guide 1.109 that talks about how  
23 you do these effluent calculations. It does consider  
24 airborne effluents separately from waterborne  
25 effluent.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1           And there is not right now -- I'm not  
2 aware of any capability in the codes to actually do  
3 that conversion from the airborne into the water and  
4 then transport it further. We don't have a direct  
5 regulatory requirement that they meet the drinking  
6 water standard, like --

7           CHAIR PETTI: Because they don't --

8           MS. HART: -- 10 CFR Part 20 --

9           CHAIR PETTI: -- have a liquid pathway,  
10 right?

11          MS. HART: Right.

12          CHAIR PETTI: Basically.

13          MS. HART: And Part 20 doesn't refer  
14 directly to the drinking water standards. Of course,  
15 any applicant is required to comply with any  
16 applicable regulation that applies to them, whether  
17 it's NRC or not.

18          MEMBER MARCH-LEUBA: Yeah. My guess,  
19 whatever gets into the air, it will be -- in chemical  
20 form will be HDO?

21          CHAIR PETTI: HTO, yeah. And eventually  
22 it gets --

23          MEMBER MARCH-LEUBA: HDO?

24          CHAIR PETTI: -- it will get into --

25          MEMBER MARCH-LEUBA: I mean, will most

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 likely be absorbed by the gas around the plant.

2 CHAIR PETTI: Correct. Correct.

3 MEMBER MARCH-LEUBA: And, I mean, soil

4 CHAIR PETTI: So the fusion program was  
5 very, very worried about this back in the -- before I  
6 was involved with the program -- '80s. They did  
7 experiments to look at dispersion, and they had codes,  
8 really complicated dose codes, that modeled all  
9 pathways.

10 It was really quite sophisticated, because  
11 of the public sensitivity of tritium, which as we know  
12 is -- is well in excess of the regulations I guess is  
13 a fair way to put it.

14 MS. HART: So Part 20 does have an  
15 environmental release level that is related to the  
16 ALARA requirement in, what is it, 10 CFR 11.01(d).  
17 And so there are those in the Appendix B to Part 20.  
18 There are concentration criteria, and that's at the  
19 release point.

20 It would -- if you took in that amount of  
21 tritium for the entire year, there is both an air and  
22 a water concentration. That would result in 50  
23 millirem.

24 CHAIR PETTI: Okay. So that's still  
25 pretty reasonable.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 MS. HART: Yeah. And then there's an  
2 additional constraint in 20.11.01(e) that would  
3 require them from all pathways, all sources, to be  
4 less than 10 millirem per year in their design. So if  
5 they used that ALARA constraint to help them with  
6 their design, it would reduce that even further.

7 MEMBER MARCH-LEUBA: I don't think the  
8 problem is safety of the public, but somebody is going  
9 to start sampling the Clinch River water a mile  
10 downstream. And if you start being able to detect it  
11

12 CHAIR PETTI: Look what's going on at this  
13 plant in Minnesota.

14 MEMBER MARCH-LEUBA: Yeah.

15 CHAIR PETTI: Right? I mean, Brookhaven.  
16 It shut down that reactor for numbers way, way below  
17 drinking water standards. It's just -- you know, it's  
18 a disproportionate --

19 MEMBER MARCH-LEUBA: The Clinch River, by  
20 that location, is a big fault. And if you dilute two  
21 grams in a year, you are going to see it. But you may  
22 be able to detect it, so that's --

23 CHAIR PETTI: Okay.

24 MEMBER MARCH-LEUBA: Kairos, do be careful  
25 and don't -- don't leak as much as you -- as you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 assuming in your --

2 CHAIR PETTI: I mean, the problem is, you  
3 know, in a high temperature system, once it goes past  
4 that heat exchange, it's gone. Even if you had a  
5 second basis --

6 MEMBER MARCH-LEUBA: I'm more worried  
7 about, if the plant is going to be in the old K25  
8 enrichment facility, and when you walk into K25, you  
9 have to wear suits everywhere or you are picking up  
10 tech-99 everywhere you touch.

11 I'm wonder if, Kairos, you have to wear  
12 the same thing because you're picking tritium from  
13 every place you touch.

14 MEMBER HALNON: When you talk to tritium  
15 in groundwater versus drinking water, there is a --  
16 there is a huge difference. So be careful. Drinking  
17 water well at 20,000 I guess picocuries, that's huge.  
18 But you'll hear values coming out of these plants of  
19 30, 40, 50,0000. That's groundwater. That's not  
20 drinking water. So you've got to be careful on doing  
21 that. The deposition of tritium HDO, whatever, in the  
22 ground, you would have to have unbelievable amount to  
23 affect the drinking water.

24 MEMBER MARCH-LEUBA: There are no wells  
25 out there. There's so much surface water that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 don't need to pick --

2 MEMBER HALNON: The surface water is not  
3 drinking water. So, anyway, I just wanted to make  
4 that distinction. It's a real --

5 MEMBER MARCH-LEUBA: It's not a safety  
6 issue.

7 MEMBER HALNON: No. But it is definitely  
8 a public relations issue.

9 MEMBER MARCH-LEUBA: Yes.

10 MEMBER HALNON: Which we are finding now  
11 at the operating reactors.

12 MS. HART: Any questions?

13 MR. SCHULTZ: Michelle, this is -- this is  
14 Steve Schultz.

15 MS. HART: Yes.

16 MR. SCHULTZ: You mentioned in the audit  
17 you reviewed the dose calculations at the side  
18 boundary, specifically for tritium. Did -- what did  
19 that entail in terms of your review? You didn't do  
20 any -- any qualifying calculations yourself. They  
21 were using some NRC-related codes.

22 So you reviewed input, output. Is that  
23 the extent of the -- of the review?

24 MS. HART: Yes. We did not do any kind of  
25 scoping or confirmatory calculations. They did use

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1716 14th STREET, N.W., SUITE 200  
WASHINGTON, D.C. 20009-4309

1 the NRC dose 3 code, GASPAR, and XOQ/DOQ. We did see  
2 the output file from that run that they did. And so  
3 and we were able to ask them questions about it as  
4 well.

5 MR. SCHULTZ: Okay. Thank you.

6 CHAIR PETTI: Okay. If there are no more  
7 questions, let's bring the memo up.

8 (Whereupon, the above-entitled matter went  
9 off the record at 2:22 p.m. and resumed at 2:23 p.m.)

10 CHAIR PETTI: So we are back on the record  
11 for public comment. Anyone has a comment from the  
12 public, please state your name and your comment.

13 Okay. Not hearing any, now we're off the  
14 record. Thank you.

15 (Whereupon, the above-entitled matter went  
16 off the record at 2:23 p.m.)

17

18

19

20

21

22

23

24



**Enclosure 1**  
**Presentation Slides for the April 4, 2023**  
**ACRS Kairos Power Subcommittee Meeting**  
**(Non-Proprietary)**



# Kairos Power

## Hermes PSAR Chapter 5 Heat Transport System

---

NICOLAS ZWEIBAUM – DIRECTOR, SALT SYSTEMS DESIGN

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 4, 2023

# 5.1 Primary Heat Transport System: Description


---

- The PHTS is responsible for transporting heat from the reactor to the ultimate heat sink (environmental air) during power operation and during normal shutdown
- The PHTS operates near atmospheric pressure and does not provide a safety-related heat removal function
  - No driving force for energetic releases during a pipe break
- The PHTS is a non-safety-related system

Parameter	Value
Thermal duty	35 MWth
Number of HRRs	1
Number of hot legs	1
Number of cold legs	2
Primary loop line size	8-12 in nominal pipe size
HRR inlet coolant temperature	600-650°C
HRR outlet coolant temperature	550°C
Nominal flow rate	210 kg/s
PHTS design pressure	525 kPa(g)

# 5.1 Primary Heat Transport System: Description (cont.)

- Primary Loop Piping
  - Transports reactor coolant between Reactor Vessel and Heat Rejection Radiator
  - Not a safety-related portion of the reactor coolant boundary
- Primary Salt Pump (PSP)
  - Variable speed, cartridge style pump located on the Reactor Vessel head
  - Inlet extends downwards through the Reactor Coolant free surface
  - Hot leg anti-siphon function performed by geometric features of the PSP's downward-facing inlet
  - No safety-related function for the PSP but safety-related trip to maintain Reactor Coolant inventory level
- Heat Rejection Subsystem (HRS)
  - Provides for heat transfer from the Reactor Coolant to the ultimate heat sink (environmental air)
  - Consists of a Heat Rejection Radiator, Heat Rejection Blower, and associated ducting and thermal management
  - No safety-related function for the HRS but safety-related blower trip upon tube failure minimizes forced air ingress
- Primary Loop Thermal Management
  - Provides non-nuclear heating and insulation to the PHTS as needed for various operations
  - No safety-related function



# 5.1 Primary Heat Transport System: Reactor Coolant

---

- Flibe ( $2\text{LiF}-\text{BeF}_2$ ) – Liquid Fluoride Salt Coolant
- Negative temperature coefficient of reactivity
- Secondary barrier to fission product release
- Thermophysical properties
  - Topical report approved by NRC, "Reactor Coolant for the Kairos Power Fluoride Salt-Cooled High Temperature Reactor" (KP-TR-005)
  - High heat capacity provides large thermal inertia for transients



# 5.1 Primary Heat Transport System: Design Basis

---

- The PHTS SSCs that are a part of the reactor coolant boundary will be designed to ASME B31.3 and BPVC Section VIII codes and standards
- Failure of the non-safety-related PHTS components during seismic events does not affect the performance of nearby safety-related SSCs (PDC 2)
- Adequate coolant flow is maintained to assure SARRDLs will not be exceeded under any condition of normal operation (PDC 10)
- The PHTS is designed with features that ensure power oscillations cannot result in conditions exceeding SARRDLs (PDC 12)
- The reactor coolant provides control of the release of radioactive materials during normal operations and postulated events through the accumulation of radionuclides (PDCs 16, 60)
- The PSP casing is designed with geometric features to prevent reactor coolant from being siphoned below the pump casing inlet elevation to maintain reactor coolant inventory in the event of a break in an external portion of the PHTS (PDC 33)
- The PHTS is designed with features that support maintaining reactor coolant inventory and maintaining reactor coolant purity by limiting air ingress (PDCs 33, 70)
- The PHTS will be designed according to 10 CFR 20.1406, to the extent practicable, to minimize contamination and support eventual decommissioning



# Kairos Power

## Hermes PSAR Chapter 7 Instrumentation and Controls Systems

---

ANTHONIE CILLIERS – DIRECTOR, I&C AND ELECTRICAL

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 4, 2023

# 7.1 Instrumentation & Controls Systems: Overview


---

The Instrumentation and Controls (I&C) Systems include:

- The Reactor Protection System (RPS) is a safety-related system that provides protection for reactor operations by initiating signals to mitigate the consequences of postulated events and ensure safe shutdown.
- The Plant Control System (PCS) is a non-safety related system responsible for controlling plant parameters during normal operations and providing data to the Main Control Room control consoles.
- The Main Control Room (MCR) provides a means for operators to monitor the behavior of the plant and control performance of the plant. The Remote Onsite Shutdown Panel (ROSP) provides a separate means to shut down the plant and to monitor plant parameters in response to postulated event conditions.
- Sensors are used to provide information about plant parameters as inputs to the PCS and RPS. Sensors that provide input to the RPS are safety-related. The PCS receives inputs from non-safety-related sensors, as well as safety-related sensors through safety-related isolation device.



# Instrumentation & Controls Systems Architecture



## 7.2 Plant Control System

---


- The PCS implements its monitoring and control functions through a series of subsystems:
  - The Reactor Control System performs functions associated with reactivity control and power level adjustments, monitoring of core neutronics, pebble handling and storage, and monitoring and controlling temperature in the reactor.
  - The Reactor Coolant Auxiliary Control System performs functions associated with chemistry control, inventory management system control, inert gas system control, and tritium management system monitoring and control.
  - The Primary Heat Transport Control System performs functions associated with control of the flow rate through the Primary Heat Transport System (PHTS), PHTS thermal management, control of the heat rejection system, and primary loop draining, filling, and piping monitoring.
- The PCS receives inputs from non-safety-related sensor inputs, as well as safety-related sensor inputs. The PCS is electronically and functionally isolated from the safety-related RPS using a safety-related isolation device.
- The PCS generates control outputs based on sensor inputs and setpoints provided by the control system. The setpoints are adjusted automatically based on plant operating mode, or in some cases by operators via the main control room consoles. Plant Operators do not directly control PCS outputs.

## 7.3 Reactor Protection System

---

- The RPS is the safety-related system credited with tripping the reactor and initiating protective functions upon receipt of signals in response to out-of-normal plant conditions. There are three possible sources that can cause the RPS to actuate:
  - Process variables reach or exceed specified setpoints as measured by safety-related RPS sensors that monitor core temperature, reactor coolant level, neutron flux, and the condition of the PHSS extraction line
  - Manual initiation from the main control room or remote onsite shutdown panel
  - Loss of plant electrical power (with a time delay)
- Three protective functions result from RPS actuation:
  - Actuate the RCSS to insert control and shutdown elements into the reactor core
  - Inhibit actions from the PCS so that it does not interfere with the functioning of the RPS, including RCSS element withdrawal, stopping the primary salt pump and heat rejection blower, stopping the pebble handling and storage system, and preventing the actuation of the reactor thermal management system
  - Ensure the actuation of the Decay Heat Removal System
- The RPS is built on a logic-based platform that utilizes discrete components and field programmable gate array technology
- The RPS is isolated from non-safety related I&C Systems using safety-related isolation hardware

# Reactor Protection System Trip Logic Schematic



# 7.4 Main Control Room and Remote Onsite Shutdown Panel

---

- The MCR contains equipment related to normal operation of the plant including:
  - Operator and supervisor workstation terminals, which provide alarm, annunciation, personnel and equipment interlocks, and process information from the PCS and RPS
  - A manual trip switch that propagates through a gateway and safety-related isolation to allow operators to initiate a plant trip
  - Central alarm panel for the fire protection system to monitor status of fire protection equipment in the Reactor Building and controlling the ventilation and extinguishing systems related for fire response
- The Remote Onsite Shutdown Panel (ROSP) provides a human/system interface for plant staff to monitor indications from the RPS including the operating status of the reactor trip system and the decay heat removal system in the event the MCR becomes inaccessible or uninhabitable. The ROSP features one-way (read only) communication with the RPS and the ability to initiate a manual trip signal that actuates the RPS.

# Instrumentation and Controls Systems: Design Basis

---

- The RPS and safety-related sensors are designed using relevant industry codes and standards such as IEEE 603-2018 and the quality assurance program (PDC 1)
- The RPS and safety-related sensors are designed to withstand and be able to perform their safety-related functions during adverse natural phenomena (PDC 2)
- The RPS and safety-related sensors are designed and located to minimize the probability and effects of fires and explosions (PDC 3)
- The RPS is designed for the environmental conditions associated with normal operation, maintenance, testing and postulated events (PDC 4)
- The RPS provides reactor trip and decay heat removal actuations that ensure radionuclide release design limits are not exceeded during normal operations, as a result of postulated events, and upon reactor trip actuation, including in the event of a single failure of the reactivity control system (PDCs 10, 20, 25)
- The RPS, PCS, and safety-related sensors are designed to monitor plant parameters over the anticipated ranges of normal operation and postulated event conditions (PDC 13)
- The design of the MCR (1) allows actions to be taken to operate the reactor under normal operating and postulated event conditions, (2) provides radiation protection allowing access and occupancy during postulated event conditions without personnel receiving radiation exposures in excess of 5 rem TEDE for the duration of the event, and (3) maintains habitability, allowing access and occupancy during normal operations and postulated event conditions. The ROSEP is located outside of the MCR and (1) provides the capability to promptly shutdown the reactor and monitor the unit during shutdown and (2) provides capability for subsequent safe shutdown of the reactor through use of suitable procedures (PDC 19)

# Instrumentation and Controls Systems: Design Basis

---

- The RPS and safety-related sensors are designed with sufficient redundancy and independence to assure no single failure results in a loss of protection function (PDC 21)
- The results of natural phenomena, and of normal operating, maintenance, testing, and postulated event conditions do not result in loss of protection function of the RPS or safety-related sensors (PDC 22)
- The RPS fails to a safe state upon loss of electrical power or detection of adverse environmental conditions (PDC 23)
- The RPS and safety-related sensors are functionally independent from the non-safety related control systems (PDC 24)
- The RPS setpoints are designed to limit the potential amount and rate of reactivity to ensure sufficient protection from postulated events involving reactivity transients (PDC 28)
- RPS and safety-related sensors are designed to be redundant to assure there is a high probability of accomplishing the safety-related functions of the RPS in postulated events (PDC 29)



# Kairos Power

## Hermes PSAR 8 Electrical Design

---


ANTHONIE CILLIERS – DIRECTOR, I&C

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 4, 2023



# 8.1 Electrical Power System



## 8.2 Normal Power System

---

- The normal power system does not perform any safety-related functions and is not credited for the mitigation of postulated events
- AC power is distributed to the plant electrical loads during startup and shutdown, normal operation, and off-normal conditions
- DC power supply is limited to I&C functions that require 24VDC for operations
- The passive design features do not rely on electrical power for safety-related SSCs to perform their safety functions during postulated events (PDCs 17, 18)
- The normal power system is designed so that differential displacements do not preclude a safety-related SSC from performing its safety function (PDC 2)
- The normal power system is designed in accordance with National Fire Protection Association (NFPA) 70, “National Electrical Code”

## 8.3 Backup Power System

---

- The backup power system (BPS) does not perform any safety-related functions and is not credited for the mitigation of postulated events
- The BPS provides AC electrical power to essential loads when normal power is not available
- The BPS includes:
  - Backup generators
    - Automatically start in the event of offsite power
    - One redundant generator by design
  - Uninterruptible power supplies (UPS)
    - Highly reliable and continuous AC electrical supply
  - Electrical equipment to connect the backup generators to the low voltage AC electrical power distribution
  - Plug-in connection for a portable 480 VAC generator

## 8.3 Backup Power System: Design Basis

---

- To ensure fail-to-safety in the event of a complete loss of AC electrical power, the reactivity control and shutdown system (RCSS) and the primary salt pump (PSP) relays require 24 VDC to remain closed
  - On a loss of power, the RCSS relay opens, and the shutdown elements drop into the reactor by gravity
  - On a loss of power, the PSP relays open to prevent inadvertent pump and blower restart on power restoration
- On activation of the decay heat removal system, the reactor protection system will remove 24 VDC from the activation circuit relay to prevent inadvertent shut down of the DHRS by operator error
- Equipment for monitoring reactor status will be supplied by UPS until the normal power supply or backup generators are restored
- The passive design features do not rely on electrical power for safety-related SSCs to perform their safety functions during postulated events (PDCs 17, 18)
- The BPS is designed so that differential displacements do not preclude a safety-related SSC from performing its safety function (PDC 2)
- The BPS is designed in accordance with National Fire Protection Association (NFPA) 70, “National Electrical Code”



# Kairos Power

## Hermes PSAR 11 Radiation Protection and Waste Management

---

AUSTIN CLARK - ENGINEER III, LICENSING

ANDREW LINGENFELTER - LEAD ENGINEER, ENGINEERING INTEGRATION

ACRS KAIROS POWER SUBCOMMITTEE MEETING

APRIL 4, 2023

# 11 Radiation Protection and Waste Management

---

- This chapter defines the elements of the radiation protection program and the radioactive waste management program and systems
  - Radiation Protection
    - Includes identification of radiation sources, description of radiation protection program, description of ALARA program, radiation monitoring and surveying, radiation exposure control and dosimetry, contamination control, and environmental monitoring program
  - Radioactive Waste Management
    - Includes a description of the radioactive waste management program, and a description of radioactive waste handling systems and controls, design bases, and disposal of radioactive waste
- For the PSAR, these programs are described at the commitment level. The PSAR commits to provide additional details at the operating license application stage, consistent with 10 CFR 50.34(b).

# 11.1 Radiation Protection

---

- Radiation Sources
  - Sources of radiation that present a potential hazard to workers and the public include fission products, decay products, fuel, and neutron activation products, including tritium
- Radiation Protection Program
  - The radiation protection program implemented for Hermes will comply with the regulatory requirements in 10 CFR 19 and 10 CFR 20, and will be developed, documented, and implemented commensurate with the scope and extent of licensed activities for a test reactor facility
  - Program content and implementation will be reviewed periodically
- ALARA Program
  - A program to ensure occupational doses and doses to members of the public are as low as is reasonably achievable will be implemented as required by 10 CFR 20.1101
  - The ALARA program will be consistent with the guidance in Regulatory Guide 8.10 and the program description will be provided with the application for the operating license
- Radiation Monitoring and Surveying
  - Conducted as required by 10 CFR 20 to detect releases of radioactive material from facility equipment and operations
  - Operational environmental monitoring is controlled by a radiological environmental monitoring program (REMP)

# 11.1 Radiation Protection

---

- Radiation Exposure Control and Dosimetry
  - Facility effluents are monitored for radioactivity during normal operations and postulated events
  - Structures, systems, and components are designed to limit uncontrolled liquid or gaseous effluent releases to work areas or the environment
  - A screening analysis of radioactive emissions from the facility employed:
    - the NRC's XOQDOQ and GASPAR II codes for dispersion and dose model calculations respectively
    - site-specific, validated meteorological data covering a 5-year period of record
    - a bounding tritium emissions rate set equal to the first-year tritium generation rate
  - Total body effective dose equivalents from gaseous effluents were calculated for the plant site boundary, the location of the maximally exposed individual (MEI) in an unrestricted area, and an analytical nearest resident
    - All modeled doses are below the limits specified in 10 CFR 20



# 11.1 Radiation Protection

---

- Contamination Control
  - SSCs with the potential to contain/handle radiological materials include design considerations to limit leakage and control the spread of contamination and to facilitate eventual decommissioning consistent with the requirements in with 10 CFR 20.1406
- Environmental Monitoring
  - Radiation monitoring and surveys of radiation levels in unrestricted areas and radioactive materials in effluents will be conducted as required by 10 CFR 20.1302
  - An operational radiation effluent monitoring program (REMP) will be implemented considering the guidance in RG 4.1, Rev 2 and NUREG-1301
  - A description of the program will be provided with the application for an operating license
  - The REMP will be implemented coincident with start of operation
    - The existing site is already well characterized by Department of Energy to establish a baseline prior to Hermes operation

# 11.2 Radioactive Waste Management - Description

---

- Radioactive waste management systems (RWMSs) are provided in the Hermes design for the collection, packaging, storing, and dispositioning of low-level liquid and solid radioactive waste (LLRW)
- RWMSs functions include:
  - Decontamination capability for components and materials
  - Vents and drains for the collection of liquid radioactive wastes
  - Liquid radioactive waste handling
  - Solid radioactive waste handling

# 11.2 Radioactive Waste Management – Design Bases

---

- The RWMSs are not credited to perform any safety-related functions
- The design bases for the RWMSs include:
  - The RWMSs are designed so that seismic-induced failure does not impact the safety related SSCs (PDC 2)
  - The RWMSs are designed such that releases of radioactive materials to the environment do not exceed the limits of 10 CFR 20 (PDC 60)
  - The RWMSs are equipped with a radiation monitoring system to monitor effluent radiation levels (PDC 63)
  - The RWMSs are designed, to the extent practicable, to minimize contamination of the facility and the environment and facilitate eventual decommissioning consistent with 10 CFR 20.1406
- Additional system description information will be provided with the application for an Operating License, consistent with 10 CFR 50.34(b)

## 11.2 Radioactive Waste Management - Program

---

- Low-level radioactive waste (including all solid and some liquid radioactive waste) is expected to be packaged and disposed using a licensed and qualified LLRW disposal vendor
- Gaseous radioactive effluents are filtered as practicable and monitored prior to release
- Radioactive waste will be managed as prescribed by the radioactive waste management plan
- Additional description of the radioactive waste management program will be provided with the application for an Operating License, consistent with 10 CFR 50.34(b)

# **NRC Staff Review for PSAR Chapters 5, 7, 8, and 11**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 4, 2023**

Office of Nuclear Reactor Regulation

# Agenda

- PSAR Chapter 5, “Primary Heat Transport System”
- PSAR Chapter 7, “Instrumentation and Control Systems” (I&C)
- PSAR Chapter 8, “Electrical Power Systems”
- PSAR Chapter 11, “Radiation Protection and Radioactive Waste Management”
- Common Agenda for Each Chapter
  - Overview of PSAR Chapter and Principal Design Criteria (PDC)
  - Referenced topical reports (if applicable)
  - Staff technical evaluation
  - Findings and Conclusions

# Common Regulatory Basis

- 10 CFR 50.34(a), “Preliminary safety analysis report.”
- 10 CFR 50.35, “Issuance of construction permits.”
- 10 CFR 50.40, “Common standards.”
- **Guidance:** NUREG-1537, “Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors,” Part 2, “Standard Review Plan and Acceptance Criteria.”

# **NRC Staff Review for PSAR Chapter 5 Primary Heat Transport System**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 4, 2023**

By the Division of Advanced Reactors and Non-Power Production and  
Utilization Facilities,  
Office of Nuclear Reactor Regulation



# PSAR Chapter 5 Primary Heat Transport System (PHTS) Overview

- Non-safety related system
- Includes primary salt pump, heat rejection subsystem, and associated piping
  - Circulates reactor coolant through the core and the heat rejection subsystem
- Transports heat from reactor core to ultimate heat sink
- Manages thermal changes and provides normal residual heat removal
- Provides for in-service inspection, maintenance, and replacement activities

# Chapter 5 Principal Design Criteria

- PDC 2 – “Design bases for protection against natural phenomena”
- PDC 10 – “Reactor design”
- PDC 12 – “Suppression of reactor power oscillations”
- PDC 16 – “Containment design”
- PDC 33 – “Reactor coolant inventory maintenance”
- PDC 60 – “Control of releases of radioactive materials to the environment”
- PDC 70 – “Reactor coolant purity control”

# Referenced Topical Reports

- KP-TR-003-NP-A, Revision 1, “Principal Design Criteria for the Kairos Power Fluoride Salt-Cooled, High Temperature Reactor”
- KP-TR-005-NP-A, Revision 1, “Reactor Coolant for the Kairos Power Fluoride-Salt Cooled High Temperature Reactor”
- KP-TR-012-NP-A, Revision 1, “Mechanistic Source Term Methodology for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor”
- KP-TR-013-NP, Revision 4, “Metallic Materials Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor,”
- KP-TR-014-NP, Revision 4, “Graphite Material Qualification for the Kairos Power Fluoride Salt-Cooled High-Temperature Reactor”

# Staff Evaluation – PDC 2

PDC 2, “Design bases for protection against natural phenomena”

- PHTS piping and supports are designed in accordance with ASME B31.3.
- The primary heat exchanger is designed in accordance with ASME Boiler and Pressure Vessel Code (BPVC) Section VIII standards.
- The design of the non safety-related PHTS SSCs is such that a failure of PHTS SSCs would not affect the performance of safety-related SSCs due to a design basis earthquake.

The staff finds the preliminary design of the PHTS is consistent with PDC 2.

# Staff Evaluation – PDC 10

- PDC 10 requires the core be designed to ensure specified acceptable system radionuclide release design limits (SARRDLs) are not exceeded
- The NRC staff finds the preliminary information on the PHTS design is consistent with PDC 10
  - Coolant composition and properties of Flibe in KP-TR-005-NP-A
  - Chemistry control system can maintain composition
  - Proposed technical specification to maintain reactor coolant within allowable limits to maintain Flibe properties
  - Reactor coolant is resistant to thermal hydraulic instabilities
  - Sections 4.3 and 4.6 of staff SE evaluate thermal hydraulics
  - Section 6.3 of staff SE evaluates heat removal when the normal PHTS heat removal path is unavailable

# Staff Evaluation – PDC 12

- PDC 12 requires the core be designed to ensure power oscillations that result in conditions exceeding SARRDLs are not possible or can be reliably detected and suppressed
- The NRC staff finds the preliminary information on the PHTS design is consistent with PDC 12
  - PHTS can limit and suppress inlet temperature and mass flow rate oscillations, limit entrained gas in the coolant, and maintain coolant specifications
  - Reactor coolant is resistant to thermal hydraulic instabilities
  - Section 4.5 of staff SE evaluates nuclear design
  - Chapter 7 of staff SE evaluates instrumentation and controls

# Staff Evaluation – PDCs 16 and 60

- PDC definitions
  - PDC 16 requires a functional containment to control the release of radioactivity to the environment
  - PDC 60 requires the plant design to control the release of radioactive materials, including during postulated events
- PSAR Section 5.1.3 describes the ability of Flibe to retain fission products that may escape the fuel
  - Flibe credited in safety analyses as a radionuclide barrier
- The NRC staff finds that the preliminary information is consistent with PDCs 16 and 60 because:
  - Flibe's ability to retain radionuclides as evaluated in KP-TR-012-NP-A, Revision 1
  - A proposed TS Limiting Condition for Operation to limit circulating activity, which supports the assumptions in KP-TR-012-NP-A, Revision 1

# Staff Evaluation – PDC 33

## PDC 33 – “Reactor coolant inventory maintenance”

- Anti-siphon features to limit loss of reactor coolant if there is a break in the PHTS cold leg.
- Reactor coolant inventory is maintained by anti-siphon design features on the hot and cold legs.
- The design’s ability to remove residual heat following a failure in the PHTS is consistent with the guidance given in NUREG-1537.
- The staff finds that the preliminary information of the PHTS design is consistent with PDC 33.



# Staff Evaluation – PDC 70

- PDC 70 requires systems to maintain reactor coolant purity including chemical attack, fouling/plugging, radionuclide concentrations, and air/moisture ingress
- PSAR Section 5.1.3 and RAI responses describe how the PHTS is designed to withstand and/or mitigate fouling, air ingress, chemical attack, and manage radionuclide concentrations
- The NRC staff finds the preliminary information is consistent with PDC 70 because
  - Coolant purity control and temperature monitoring to detect fouling or plugging of passages
  - Ability of Flibe to retain radionuclides, circulating activity limits, and ability to remove radionuclides from Flibe
  - Material qualification topical reports assess chemical attack in Flibe and the chemistry control system (CCS) can purify the coolant as well
  - PHTS designed to limit forced air ingress, remain within bounds of qualification testing for air ingress, and availability of compensatory measures

# Testing and Inspection

- PSAR states design of PHTS allows for inspection, maintenance, and replacement activities
- PSAR states any testing and inspection of PHTS will be submitted with the OL application
  - Staff will review these programs at that time

# Technical Findings and Regulatory Conclusion

- NRC staff finds the preliminary design information is consistent with the applicable criteria in NUREG-1537 and the applicable PDC
- The staff concludes information in Hermes PSAR Section 5 is sufficient for the issuance of a CP in accordance with 10 CFR 50.35 and 50.40 and further information can be reasonably left for the OL application

# Questions?

# **NRC Staff Review for PSAR Chapter 7 Instrumentation and Control Systems**


---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 4, 2023**

By the Division of Engineering and External Hazards,  
Office of Nuclear Reactor Regulation

# PSAR Chapter 7, I&C Architecture



# Chapter 7 Principal Design Criteria

- PDC 1 – “Quality standards and records”
- PDC 2 – “Design bases for protection against natural phenomena”
- PDC 3 – “Fire Protection”
- PDC 4 – “Environmental and dynamic effects design bases”
- PDC 10 – “Reactor design”
- PDC 13 – “Instrumentation and control”
- PDC 15 – “Reactor coolant system design”
- PDC 19 – “Control room”
- PDC 20 – “Protection system functions”
- PDC 21 – “Protection system reliability and testability”
- PDC 22 – “Protection system independence”
- PDC 23 – “Protection system failure modes”
- PDC 24 – “Separation of protection and control systems”
- PDC 25 – “Protection system requirements for reactivity control malfunctions”
- PDC 28 – “Reactivity limits”
- PDC 29 – “Protection against anticipated operation occurrences”

# Staff Evaluation – Plant Control System

- Architecture
- Communications
- Codes and Standards
- Technical Specifications
- Logic, Display, and Alarms
- Failure Modes



# Staff Evaluation – Reactor Protection System

- Architecture
- Protective Functions
- Communications
- Codes and Standards
- Logic and Schematics
- Trip Functions
- Accident Mitigation
- Safety Settings
- Response Time
- Technical Specifications
- I&C Platform
- Single Failure

# Staff Evaluation – Main Control Room and Remote Onsite Shutdown Panel

- Architecture
- Communications
- Codes and Standards
- Controls, Displays, and Alarms
- Technical Specifications

# Staff Evaluation – Sensors

- Architecture
- Codes and Standards
- Sensors

# Technical Findings and Regulatory Conclusions

Kairos has described the proposed facility design criteria for the I&C systems, including, but not limited to, the PDC, and has identified the major features or components incorporated therein for the protection of the health and safety of the public.

Further technical or design information as may be required to complete the safety analysis of the I&C systems can reasonably be left for later consideration in the FSAR.

The staff concludes the information in Hermes PSAR Chapter 7 is sufficient and meets the applicable guidance and regulatory requirements identified in this section for the issuance of a construction permit in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application.

# Questions?

# **NRC Staff Review for PSAR Chapter 8 Electrical Power Systems**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 4, 2023**

By the Division of Engineering and External Hazards,  
Office of Nuclear Reactor Regulation

# PSAR Chapter 8 Electrical Power Systems Overview

- Non-Class 1E normal power system
- Non-Class 1E backup power system
  
- Principal design criteria (PDC):
  - PDC 17 – “Electric power systems”
  - PDC 18 – “Inspection and testing of electric power systems”

# Staff Evaluation – Normal Power System

- Provides alternating current (AC) and direct current (DC) electrical power by an offsite power source
- Designed in accordance with National Fire Protection Association (NFPA) 70, “National Electrical Code 2020”
- During an audit, the applicant confirmed that no electrical systems were required for performing any safety-related function for safe shutdown of the plant or to keep the plant in the safe shutdown condition



# Staff Evaluation – Normal Power System

- The normal power system is not credited for postulated events or safe shutdown, is classified as non-Class 1E or non-safety, and no technical specifications for the normal power system are required
- Based on exceptions to PDCs noted in Section 3.1.1 of PSAR, PDCs 17 and 18 are not applicable since
  - there are no safety-related/Class 1E power systems required to perform any safety-related functions
  - Normal power system (non-Class 1E) is available for non-safety functions not credited for design basis events (e.g., for certain UPS loads)

# Staff Evaluation – Backup Power System

- Provides AC electrical power to the essential facility loads when the normal AC power supply is not available
- Includes backup generators and uninterruptible power supplies (UPS), as well as electrical equipment and circuits used to interconnect the backup generators to the low voltage AC electrical power distribution
- Plug-in connection available for use with a portable 480 VAC generator to provide power to essential loads in the event the backup generators are unavailable
- Designed according to NFPA 70, National Electric Code 2020

# Staff Evaluation – Backup Power System

- The PSAR addressed the classification and design attributes of the Backup Power System
- The Backup Power System does not perform any safety-related functions, is not credited for the mitigation of postulated events, and is not credited with performing safe shutdown functions.
- Based on exceptions to PDCs noted in Section 3.1.1 of PSAR, PDCs 17 and 18 are not applicable since
  - there are no safety-related/Class 1E power systems required to perform any safety-related functions
  - Backup Power System (non-Class 1E) is available for non-safety functions not credited for design basis events, (e.g., for certain UPS loads)

# Technical Findings and Regulatory Conclusion

- The staff finds that PDCs 17 and 18 are not applicable, since there are no Class 1E electrical power systems and non-Class 1E electrical power systems are available for non-safety functions not credited for DBE
- Staff finds that the design of the Hermes normal power system and backup power system are sufficient and meet the applicable regulatory requirements and guidance for the issuance of a construction permit in accordance with 10 CFR 50.35 and 50.40 and further information can be reasonably left for the OL application

# Questions?



# **NRC Staff Review for PSAR Chapter 11 Radiation Protection and Radioactive Waste Management**

---

**Briefing for the Advisory Committee on Reactor Safeguards**

**April 4, 2023**

By the Division of Advanced Reactors and  
Non-Power Production and Utilization Facilities,  
Office of Nuclear Reactor Regulation

# Overview of PSAR Chapter 11

- Radiation protection and radioactive waste management
  - Preliminary information on design and programs
  - Commitments to develop more detailed information in the OL application

# Overview of PSAR Section 11.1 “Radiation Protection”

- Radiation sources
- Radiation protection program and ALARA program
- Radiation monitoring and surveying
- Radiation exposure control and dosimetry
- Contamination control
- Environmental monitoring



# Overview of PSAR Section 11.2 “Radioactive Waste Management”

- Radioactive waste management program
- Radioactive waste handling systems and controls
- Release of radioactive waste

# Staff Evaluation – Radiation Sources

- Staff audit confirmed that Kairos developed preliminary isotopic values for fuel and Flibe radiation sources for use in preliminary shielding design
- Staff audit of conservative screening analysis of gaseous tritium emissions described in PSAR Section 11.1.5 noted:
  - Conservative assumption for tritium effluent release rate equal to the generation rate
    - Does not account for retention in the reactor
  - Release rate for other gaseous radionuclides taken from the Clinch River ESP Environmental Report
    - Reasonable assumption for a preliminary analysis considering relative power levels and design differences
  - Liquid effluent release direct to the environment was not modeled; not expected based on preliminary design

# Staff Evaluation – Radiation Protection

- Remainder of topics in PSAR Section 11.1
  - Did not need additional information in audit
  - PSAR describes the applicable regulatory requirements and guidance, and provides preliminary information on programs, practices, or design features
  - Kairos’s commitments provide reasonable assurance that the Hermes design will comply with applicable requirements

# Staff Evaluation – Radioactive Waste Handling Systems and Controls

- Preliminary effluent calculation in PSAR Section 11.1
- PSAR describes the applicable regulatory requirements, PDCs, and guidance and provides preliminary design information
  - PDC 2, “Design bases for protection against natural phenomena”
  - PDC 60, “Control of releases of radioactive materials to the environment”
  - PDC 63, “Monitoring of fuel and waste storage”
- Kairos’s commitments provide reasonable assurance that the Hermes design will comply with applicable requirements

# Staff Evaluation – Radioactive Waste Management

- Remainder of topics in PSAR Section 11.2
  - Did not need additional information in audit
  - PSAR describes applicable regulatory requirements and guidance and provides preliminary information on programs, practices, or design features
  - Kairos’s commitments provide reasonable assurance that the Hermes design will comply with applicable requirements

# Technical Findings and Regulatory Conclusion

- Staff finds that preliminary information and design criteria of the radiation protection and waste management programs and provisions
  - meets applicable acceptance criteria in NUREG-1537, Part 2
  - provides reasonable assurance that the final design will confirm to the design bases
  - meets applicable regulatory requirements
  - provides an acceptable basis for the development of the radiation protection programs and radioactive waste management, and there is reasonable assurance that Kairos will comply with the regulations in 10 CFR Part 20 during facility operation
- The staff concludes the information in Hermes PSAR Chapter 11 is sufficient and meets the applicable guidance and regulatory requirements identified for the issuance of a construction permit in accordance with 10 CFR 50.35 and further information can be reasonably left for the OL application