



- GENERAL NOTES:
- FOR SYMBOL LIST SEE DWG'S 3032 & 3070.
  - ALL CONTROLS, RELAYS, METERS & ASSOCIATED DEVICES SHOWN ON 4160V SWGR BUSES MAIN BREAKERS & FEEDER BREAKERS SHALL BE LOCATED IN 4160V SWGR UNLESS OTHERWISE NOTED BY SYMBOL I.C. FOR LEGEND OF REMOTE EQUIPMENT LOCATIONS D.C. SEE DWG 3032.
  - ALL 4160V SWITCHGEAR BREAKERS ARE RATED 1200A CONTINUOUS UNLESS OTHERWISE INDICATED.
  - ALL MOTOR CONTROL CENTERS BRANCH FEEDERS (OTHER THAN MOTOR FEEDERS) SHALL HAVE FUSES SIZED SAME AS SWITCH SIZE UNLESS OTHERWISE INDICATED.
  - H121 (3022) INDICATES CABLE NUMBER. SEE SCHEDULES DWG 3050.
  - H121 (3022) INDICATES DWG # OF ASSOCIATED CONTROL ELEMENTARY DIAGRAM.
  - AN INTERLOCK EXISTS ON THE DOOR OF THE CABINET THAT IS HOUSING THIS PT. OPENING OF THIS DOOR WILL ISOLATE THE PT FROM THE BUS.
  - THESE ARE CABLES ON BOTH SIDES OF A DRYWELL ELECTRICAL PENETRATION ASSEMBLY.
  - SHORTED AND GROUNDED IN CABINET.

VERSIONS/REVISIONS BY NPPD			
NO.	DESCRIPTION	ORDER DFT	DATE
AD/250	DR-2021-0227 (TCC INSTALLATION)	5399796	DR/3/17/21
AD/250	DR-2021-0227 (REMOVING TCC)	5399796	DR/3/17/21
AD/250	DR-2017-0425	6039763	DR/10/16/22

  

SIGNIFICANT NUMBER		GROUP	
1	2	3	4

  

DRAWN		DATE	
7-11-94			
CHECKED		DATE	
APPROVED		DATE	
FILMED		DATE	

**AS BUILT**  
454003876

STATUS: Release  
STATUS DATE: 10/16/2022  
DS APPROVED: REJENSE  
VER: AJ REV: 37 STATE: F

**COOPER NUCLEAR STATION**  
**MAIN ONE LINE**  
**DIAGRAM**

**BURNS & ROE**

**3001**