



- NOTES:**
- UNLESS OTHERWISE INDICATED ALL PRESSURE AND/OR FLOW INSTRUMENT ROOT VALVES SHALL BE 3/4" V253X. ROOT VALVES FOR STAINLESS STEEL SYSTEMS SHALL BE 3/4" V226X LINE UP TO AND INCLUDING ROOT VALVE SHALL BE FURNISHED AND INSTALLED UNDER CONTRACT E-73-58
 - ALL TEMPERATURE TEST AND PROTECTING WELL PENETRATIONS SHALL BE 1" NPT UNLESS OTHERWISE NOTED.
 - ALL SAMPLING POINTS, CONNECTIONS, PROBES AND ROOT VALVES SHALL BE FURNISHED AND INSTALLED UNDER CONTRACT E-73-58. PROBES SHALL BE FURNISHED AND INSTALLED IN ACCORDANCE WITH CONTRACT PARA. 3.4.2 AND DRAWINGS SP-07211, FIG. NO. AS NOTED. CONTINUATION OF SAMPLE PIPING BY E-70-3.
 - LINE DESIGNATION SUFFIX (X) I.E. 1" MW-15X INDICATES LINE IS HEAT TRACED (ELECTRICALLY).
 - ALL STRAINER BLOWDOWN VALVES SHALL BE THE SAME SIZE AS THE STRAINER BLOWDOWN PORT AND SHALL BE TYPE 2535 FOR CARBON STEEL TRAPS AND TYPE 2265 FOR STAINLESS STEEL TRAPS.

AS BUILT
454003659

STATUS: Release
STATUS DATE: 09/07/2018
DS APPROVED: JAFORBE
VER: AB REV: 14 SIZE: F

FOR PREVIOUS REVISIONS, SEE SUPERSEDED CARDS				SIGNIFICANT NUMBER							
NO.	DESCRIPTION	DFTI	DATE	ENG	GROUP	1	2	3	4	5	6
AB/1410R-2018-0001			DJB/09/07/18	JL/DJR							

COOPER NUCLEAR STATION FLOW DIAGRAM AUGMENTED LIQUID RADWASTE SYSTEM				DRAWN: RGA DATE: 2/13/04 CHECKED: [] DATE: [] APPROVED: [] DATE: [] FILMED: []	BURNS & ROE 2079 SH 1
---	--	--	--	---	--------------------------