



- NOTES:
- UNLESS OTHERWISE INDICATED, ALL PRESSURE INSTRUMENT ROOT LINES SHALL BE 3/4"; ROOT VALVES SHALL BE 3/4" V253X. LINE UP TO AND INCLUDING ROOT VALVE SHALL BE FURNISHED AND INSTALLED UNDER CONTRACT E69-4.
 - FLOOR AND EQUIPMENT DRAIN FITTINGS AND PORTIONS OF EMBEDDED PIPING FURNISHED AND INSTALLED BY OTHERS AS SHOWN ON DWGS 2182, 2183, 2184, 2185, 2186 & 2187.
 - ALL VALVE NUMBERS IN PARENTHESIS () ARE NUMBERS TO BE USED IN OPERATING PROCEDURES. THESE NUMBERS ARE ASSIGNED BY NPPD AND WILL NOT BE SHOWN ON PIPING DRAWINGS.
 - CB IS PRIMARY CONTAINMENT BOUNDARY.
 - FOR DETAIL DRAWINGS SEE 2038 SH 2, UNLESS OTHERWISE NOTED.
 - WHERE LINES INTERCONNECT AND ARE CONTINUED ON OTHER DRAWINGS, ZONE NUMBERS ARE APPROXIMATE ONLY.

NOTE: ALL ITEMS MARKED THUS [A] ARE "AS BUILT" ITEMS AND ARE NOT SHOWN ON PIPING DRAWINGS.

AS BUILT
454003631
STATUS: Release
STATUS DATE: 10/09/2019
DS APPROVED: LJJENSE
VER: AG REV: 56 SIZE: F

REVISIONS TO THIS DRAWING
REQUIRES A REVISION TO THE
CORRESPONDING ISOKEY.

NO.	DESCRIPTION	ORDER/DFT	DATE	ENG
1	AS BUILT		10/09/2019	LJJENSE
2	REVISED		10/09/2019	LJJENSE

SIGNIFICANT NUMBER		DATE		DRAWN	DATE	CHECKED	DATE	APPROVED	DATE
GROUP	NO.	HY	18/02						
COOPER NUCLEAR STATION				BURNS & ROE	2038 SH 1	FILED	DATE	APPROVED	DATE
FLOW DIAGRAM									
REACTOR BUILDING FLOOR & ROOF DRAIN SYSTEMS									