

High Energy Arcing Fault Information Notice

Charles Moulton
Fire Protection Engineer
PRA Licensing Branch B
Division of Risk Assessment
Office of Nuclear Reactor Regulation

NRC Information Notice 2023-01



[Risk Insights from High Energy Arcing Fault Operating Experience and Analyses](#)

- Discusses qualitative and quantitative risk insights
- HEAF operating experience review
- Describes new HEAF PRA method

Insights

Prevention

- Simpler and more certain than mitigation
- Mitigation strategies are still important

Maintenance

- Good practices are key to preventing HEAF events
- Preventative maintenance/post-maintenance testing

PRA models

- Results can identify risk significant equipment
- Helps focus resources for prevention

Questions?

