

From: Mahesh Chawla
Sent: Friday, May 26, 2023 1:03 PM
To: Garcia, Richard M.
Cc: Jennifer Dixon-Herrity; Vic Cusumano; Michael Waters; Gilberto Blas Rodriguez; Andrea Russell
Subject: LIC-109 Acceptance Review of LAR for Columbia Generating Station - License Amendment Request to Clean-Up Operating License and Appendix A, Technical Specifications - EPID L-2023-LLA-0062

Dear Mr. Garcia,

By letter dated May 1, 2023 (Agencywide Documents Access and Management System Accession No. ML23121A294), Energy northwest (the licensee) submitted a license amendment request (LAR) for Columbia Generating Station (Columbia). Energy Northwest requests an amendment to revise the Columbia Generating Station Operating License (OL) NPF-21 and Appendix A, Technical Specifications (TS). As part of this request, Energy Northwest is proposing several clean-up changes to the OL and TS, including editorial changes and the removal of obsolete TS information, spelling error corrections, and removal of obsolete OL conditions. None of the proposed changes result in changes to technical or operating requirements.

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this LAR. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant. Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an application for an amendment to a license (including the TS) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed LAR in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 120 hours to complete. The NRC staff expects to complete this review in approximately 12 months, which is May 26, 2024. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for

the changes, along with the new estimates, will be communicated during the interactions with the assigned project manager.

These estimates are based on the NRC staff's initial review of the application, and they could change, due to several factors including requests for additional information (RAI), unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities. Additional delay may occur if the submittal is provided to the NRC in advance or in parallel with industry program initiatives or pilot applications.

If you have any questions, please contact me @

301-415-8371. Thanking you,

Sincerely,

Mahesh Chawla, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Hearing Identifier: NRR_DRMA
Email Number: 2107

Mail Envelope Properties (SA1PR09MB841502F0B9BD6128CBB0E649F1479)

Subject: LIC-109 Acceptance Review of LAR for Columbia Generating Station - License Amendment Request to Clean-Up Operating License and Appendix A, Technical Specifications - EPID L-2023-LLA-0062

Sent Date: 5/26/2023 1:03:26 PM

Received Date: 5/26/2023 1:03:00 PM

From: Mahesh Chawla

Created By: Mahesh.Chawla@nrc.gov

Recipients:

"Jennifer Dixon-Herrity" <Jennifer.Dixon-Herrity@nrc.gov>

Tracking Status: None

"Vic Cusumano" <Victor.Cusumano@nrc.gov>

Tracking Status: None

"Michael Waters" <Michael.Waters@nrc.gov>

Tracking Status: None

"Gilberto Blas Rodriguez" <Gilberto.BlasRodriguez@nrc.gov>

Tracking Status: None

"Andrea Russell" <Andrea.Russell@nrc.gov>

Tracking Status: None

"Garcia, Richard M." <rmgarcia@energy-northwest.com>

Tracking Status: None

Post Office: SA1PR09MB8415.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	3806	5/26/2023 1:03:00 PM

Options

Priority: Normal

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date: