

Job Performance Measure

REACTIVATION OF AN SRO LICENSEJPM Number: A-N-1-SRevision Number: 03Date: 12/22

Developed By: Derek Siuda / _____
Instructor: Print / Sign Date

Approved By: Jonathan Chapman / _____
Facility Representative: Print / Sign Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: OP-AA-105-102	Revision: 17
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date

Revision Record (Summary)

Revision #	Summary
00	New JPM for ILT 09-1 Cert Exam
01	Modified for ILT 15-1 (2016-301) NRC Exam
02	Updated for the ILT 19-1 (2020-301) NRC Exam
03	Updated for the ILT 22-1 (2023-301) NRC Exam

SETUP INSTRUCTIONS:

1. This is a tabletop JPM. It is not required to be performed in a simulator setting.
2. No Simulator setup needed.

DOCUMENT PREPARATION

1. A copy of OP-AA-105-102, NRC ACTIVE LICENSE MAINTENANCE.
2. A marked up copy of OP-AA-105-102, NRC ACTIVE LICENSE MAINTENANCE, Attachment 2, REACTIVATION OF LICENSE LOG.

INITIAL CONDITIONS

1. You are the Shift Manager.
2. An SRO is in the process of license reactivation.
3. OP-AA-105-102, Attachment 2, REACTIVATION OF LICENSE LOG, is filled out up to the point of Shift Manager review for the licensee.

INITIATING CUE

4. The Shift Operation Superintendent directs you to “perform the Shift Manager review of OP-AA-105-102, Attachment 2 for the licensee and return it to me”.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator’s Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the “Comment Number” column on the following pages. Then annotate that comment in the “Comments” section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site’s appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____

JPM Sequence #: _____ of 5

Task Standard:

The Examinee will verify the Reactivation of License Log IAW OP-AA-105-102, NRC ACTIVE LICENSE MAINTENANCE, and will determine there are multiple errors and the operator cannot return to active status.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Note	Provide the examinee with the filled in copy of OP-AA-105-102, Attachment 2, REACTIVATION OF LICENSE LOG, and the clean copy of OP-AA-105-102, NRC ACTIVE LICENSE MAINTENANCE				
1.	Review OP-AA-105-102, Attachment 2.	Reviews OP-AA-105-102, Attachment 2.	<input type="checkbox"/>	<input type="checkbox"/>	—
2.	Check that Hours on Shift are in the same calendar quarter.	Notes 12.0 hours listed on 3/31/23 are performed during the 1 st calendar quarter and cannot be counted towards license re-activation.	<input type="checkbox"/>	<input type="checkbox"/>	—
3.	Check that Hours on Shift are applicable for license reactivation.	Determines 12.0 hours as WEC listed on 4/2/23 cannot be credited towards license re-activation.	<input type="checkbox"/>	<input type="checkbox"/>	—
*4.	Check that licensee has the required 40 hours.	Determines that licensee does NOT have adequate hours to meet the 40 hour requirement.	<input type="checkbox"/>	<input type="checkbox"/>	—
*5.	Verifies Plant Tour completed per step 4.b.	Determines that Plant Tour date and signature are not completed.	<input type="checkbox"/>	<input type="checkbox"/>	—
*6.	Report the results of the review to the Shift Operations Superintendent (SOS).	Returns without signing OP-AA-105-102, Attachment 2 to the SOS. Informs the SOS that the licensee's license CANNOT be reactivated due to insufficient hours on shift and plant tour incomplete.	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	Acknowledge report				

JPM Stop Time: _____

Constellation Confidential/Proprietary

OP-AA-105-102

Revision 17

Page 8 of 8

KEY

ATTACHMENT 2 Reactivation Of License Log Page 2 of 2

5. Hours on Shift

- The SRO / RO License Holder has completed a minimum of 40 hours of shift functions in the presence and under the sole direct supervision of an active RO or SRO, as appropriate, in the position to which the individual will be assigned. Log hours in the Shift Position log.
- The SRO license holder being activated for fuel handling only has completed a minimum of one (1) 8 hour shift in the presence and under the sole direct supervision of an active SRO in the position to which the individual will be assigned.

Shift Position Log

Date	Shift Position	Shift	Number of Hours	Entered in Appropriate Log	Active License Signature
3/31/23	US	D	12	(Yes) No	<i>Must Supervise</i>
4/2/23	US	D	12	(Yes) No	<i>Must Supervise</i>
4/3/23	US	D	12	(Yes) No	<i>Must Supervise</i>
4/4/23	US	D	12	(Yes) No	<i>Must Supervise</i>
4/5/23	US	D	12	(Yes) No	<i>Must Supervise</i>
Required Action: Perform a complete plant tour under the sole direct supervision of an active license holder as required in Step 4 b. The tour shall be performed during the performance of the required hours on shift listed above. Obtain signature verifying completion.					

Reviewed by: _____
Shift Manager Date

Final Review and Approval:

Shift Operations Superintendent Date Operations Training Manager Date

Date to credit completion of reactivation (last shift stood) _____

SRRS 3.D.106

KEY

FORWARD ORIGINAL TO LICENSE HOLDER'S LICENSE FILE

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** ☒ SRO**JPM Title:** Reactivation of an SRO License**JPM Number:** A-N-1-S**Revision Number:** 03**Task Number and Title:** 299L024, Maintain an Active License**Task Standard:** The Examinee will verify the Reactivation of License Log IAW OP-AA-105-102, NRC ACTIVE LICENSE MAINTENANCE, and will determine there are multiple errors and the operator cannot return to active status.**K/A Number and Importance:** Generic 2.1.4 -- / 3.8**Suggested Testing Environment:** Classroom**Alternate Path:** ☐ Yes ☒ No **SRO Only:** ☒ Yes ☐ No **Time Critical:** ☐ Yes ☒ No**Reference(s):**

Procedure:	OP-AA-105-102	Revision:	17
Procedure:	_____	Revision:	_____
Procedure:	_____	Revision:	_____

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☒ Other**Testing Method:** ☐ Simulate ☒ Perform**Estimated Time to Complete:** 12 minutes**Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Shift Manager.
2. An SRO is in the process of license reactivation.
3. OP-AA-105-102, Attachment 2, REACTIVATION OF LICENSE LOG, is filled out up to the point of Shift Manager review for the licensee.

INITIATING CUE

1. The Shift Operation Superintendent directs you to “perform the Shift Manager review of OP-AA-105-102, Attachment 2 for the licensee and return it to me”.

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: _____	OP-AA-201-007	Revision: _____	01
Procedure: _____	TRM 3.7.n	Revision: _____	103
Procedure: _____	151 U2TB-53	Revision: _____	05
Procedure: _____		Revision: _____	
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

/	
SME / Instructor (Print/Sign)	Date
/	
SME / Instructor (Print/Sign)	Date
/	
SME / Instructor (Print/Sign)	Date

Revision Record (Summary)

Revision #	Summary
01	Bank JPM
02	Revised for ILT 18-1 (2016-301) NRC Exam
03	Modified for the ILT 22-1 (2023-301) NRC Exam

SETUP INSTRUCTIONS:

1. This is a tabletop JPM. It is not required to be performed in a simulator setting.
2. No Simulator setup needed.

DOCUMENT PREPARATION

1. A copy of OP-AA-201-007 with the initiator section of Attachment 1 filled out.
2. A copy of the Fire Pre-Plan 151 U2TB-53.
3. A copy of Fire Zone F-8-1 Sheet 1.
4. Ensure a copy of the TRM is available as a resource.

INITIAL CONDITIONS

1. You are the WEC Supervisor on midnights and are acting as the Fire Marshall Designee.
2. As part of a scheduled activity, the Electrical Maintenance Department must route an extension cord through the north door for U2 125 VDC Battery Room on elevation 549' and the work will begin promptly at 1600.
3. The activity is being performed under WO 123456-01 and is scheduled for 6 hours.
4. The cognizant Electrical Maintenance Supervisor is C. Block.
5. Area fire detectors are operable.
6. Neil notification is not required.
7. No additional compensatory measures required.

INITIATING CUE

1. Complete Attachments 1 and 2 of the Fire Protection Impairment Permit IAW OP-AA-201-007.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____

JPM Sequence #: _____ of 5

Task Standard:

The Examinee will complete paperwork for a TRM required Firewatch utilizing OP-AA-201-007, FIRE PROTECTION SYSTEM IMPAIRMENT CONTROL.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Note	Give the examinee the copy of OP-AA-201-007 with the initiator section of Attachment 1 filled out.				
Note	Fills out Attachment 1 of OP-AA-201-007 as follows:				
Cue	When the examinee states the need for the Fire Marshall No., inform them "The next available number in the Fire Protection Impairment Barrier Permit Log is 23-31." (May not be performed until later in the JPM)				
1.	Fire Impairment NO:	Examinee uses number provided and enters "23-31"	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	Direct the examinee to complete the fire watch authorization if not completed.				
	Section II				
2.	Determine Fire Zone.	Determines and enters Fire Zone as 7.0A.1 and/or 7.0A.2	<input type="checkbox"/>	<input type="checkbox"/>	—
3.	Barrier Functional.	Determines and marks Barrier as Non-Functional.	<input type="checkbox"/>	<input type="checkbox"/>	—
*4.	Technical Requirement Manual?	Determines TRM is applicable and identifies applicable sections as: 3.7.n (May include A.2.2.1 and A.2.2.2, correct if include, but not critical) If examinee chooses "Continuous" Firewatch, then the applicable TRM will be 3.7.n A.2.1 (this would satisfy the Critical Step as it is more conservative).	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	If asked: Another SRO is looking at the LCO requirements.				
*5.	Fire Watch Required?	Determines and marks that a Hourly Firewatch is required (may choose Continuous and that will satisfy the Critical Step as it is more conservative).	<input type="checkbox"/>	<input type="checkbox"/>	—
6.	Fire watch performed by:	Designates the Department responsible for Firewatch (must assign a department to be responsible).	<input type="checkbox"/>	<input type="checkbox"/>	—

STEP	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
7.	Additional Compensatory Measures Required?	Marks NO (per Initial Conditions).	<input type="checkbox"/>	<input type="checkbox"/>	—
8.	Required Components for TRM Action?	Marks NO (per Initial Conditions, Area Fire Detectors are operable).	<input type="checkbox"/>	<input type="checkbox"/>	—
9.	NEIL Notification Required?	Marks NO (per Initial Conditions).	<input type="checkbox"/>	<input type="checkbox"/>	—
10.	Fire Marshall Instructions:	Enters NONE or NA.	<input type="checkbox"/>	<input type="checkbox"/>	—
*11.	Restoration/Testing Requirements:	Enters “Door closed and latched” or instructions that convey a similar concept.	<input type="checkbox"/>	<input type="checkbox"/>	—
*12.	Fire Marshall (Designee) Authorization:	Signs name and enters today’s date.	<input type="checkbox"/>	<input type="checkbox"/>	—
Section III					
Note	This section may be left blank, as it is filled out when the Fire Watch is Established.				
13.	Detection Zones As Indicated In Section II Operable:	Marks NA or No	<input type="checkbox"/>	<input type="checkbox"/>	—
14.	Person Notified of Fire Watch:	Examinee writes WEC or names specific people.	<input type="checkbox"/>	<input type="checkbox"/>	—
15.	Shift Management Authorization:	Examinee signs their name as Shift Management Authorization and enter today’s date and current time.	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	Fills out Attachment 2 of OP-AA-201-007 as follows:				
Section I					
*16.	Reason for watch:	Examinee enters “Extension cord running through the U2 125 VDC Battery Room Door” or description conveying that concept.	<input type="checkbox"/>	<input type="checkbox"/>	—
*17.	TRM Section:	Examinee enters “3.7.n.”	<input type="checkbox"/>	<input type="checkbox"/>	—
18.	Impairment/PBI No.:	Examinee enters “23-31”	<input type="checkbox"/>	<input type="checkbox"/>	—
19.	WR/WR No.:	Examinee enters “123456-01”	<input type="checkbox"/>	<input type="checkbox"/>	—
*20.	Type of Fire Watch:	Examinee circles “Hourly” (may choose Continuous and that will satisfy the critical step as it is more conservative).	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
21.	Location:	Examinee marks: Unit "2" Bldg "TB" (conveys Turbine Bldg) Elev "549" Row - May be left blank Col - May be left blank	<input type="checkbox"/>	<input type="checkbox"/>	—
*22.	Description of area to be inspected:	Examinee indicates "U2 125 VDC Battery Room" or something that is on either side of the inoperable barrier.	<input type="checkbox"/>	<input type="checkbox"/>	—
*23.	Required Start Time/Date:	Examinee indicates "1700" and enters today's date. (May enter any time before 1700, but no later than 1700)	<input type="checkbox"/>	<input type="checkbox"/>	—
Section II					
24.	Responsible Department:	Examinee indicates "EMD" (or dept candidate assigned)	<input type="checkbox"/>	<input type="checkbox"/>	—
25.	Responsible Supervisor:	Examinee indicates "C. Block".	<input type="checkbox"/>	<input type="checkbox"/>	—
26.	Notification:	Examinee indicates time and date the responsible person is notified (may leave blank until person notified).	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	Section III should be left blank				
Section IV					
27.	Location to be inspected:	Examinee indicates "U2 125 VDC Battery Room" or something that conveys the U2 125 VDC Battery Room.	<input type="checkbox"/>	<input type="checkbox"/>	—
28.	Impairment / PBI No:	Examinee enters "23-31"	<input type="checkbox"/>	<input type="checkbox"/>	—
29.	Informs Evaluator task is complete	Informs Evaluator task is complete	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	Acknowledge report				

JPM Stop Time: _____

KEY

OP-AA-201-007

Revision 1

Page 18 of 22

ATTACHMENT 1
Manual Fire System Impairment (FSI) Permit

Page 1 of 1

FSI Log Number: 23-31

I. INITIATOR/Requestor:		Station: <u>12</u>	Unit: <u>02</u>
Name: <u>C. Block</u>	Phone: <u>x4444</u>	Dept/Co: <u>EMD</u>	
Sch. Start Date: <u>Today's date</u>	Bldg: <u>U2 TB</u>	EPN #: <u>125 VDC</u>	
Sch. End Date: <u>Tomorrow's date</u>	Elev: <u>549</u>	Door #: <u>82</u>	
WR/WO/CO#: <u>123456-01</u>	Row/Col: <u></u>	Det. Zone #: <u>42</u>	
		Pent #: <u>N/A</u>	
Impairment Description: <u>Extension cord running through the north door for U2 125 VDC Battery room.</u>		Structural fireproofing: <input type="checkbox"/>	
		Wall Penetration: <input type="checkbox"/>	
II. FIRE MARSHAL REVIEW:			
Fire Zone(s): <u>7.0A.1</u> <u>7.0A.2</u>			
Barriers: <input type="checkbox"/> Functional <input checked="" type="checkbox"/> Non-Functional			
Technical Requirement Manual? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		TRM Section: <u>3.7.n A.2.2.1 & A.2.2.2</u>	
Fire Watch Required? Continuous <input type="checkbox"/> <u>Hourly</u> <input checked="" type="checkbox"/> None / Other: <u></u>			
Fire Watch Performed By (if required): <u>EMD (examinee may choose different dept)</u>			
Additional Comp Measures Required? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		Description: <u></u>	
Required Components for TRM Action? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		List EIN's/EPN's <u></u>	
NEIL or FM Global Notification Required? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		List which <u></u>	
Fire Marshal Instructions: <u>None</u>			
Restoration/Testing Requirements: <u>Cord no longer running through the door and door closed (or similar)</u>			
Fire Marshal (Designee) Authorization: <u>Examinee Signature</u>		Date: <u>Today's date</u>	
III. AUTHORIZATION: <u>(Examinee may leave this section blank, as it is filled out when the Fire Watch is Established)</u>			
Required Components As Indicated In Section II Operable: YES <input type="checkbox"/> NO <input type="checkbox"/> NA <input checked="" type="checkbox"/> <u>No or NA are acceptable</u>			
Person Notified of Fire Watch: <u>WEC (or name)</u>			
Shift Management Authorization: <u>Examinee Signature</u>		Date: <u>Today's date</u>	
		Time: <u>Current time</u>	
IV. IMPAIRMENT RESTORATION:			
Field Work/Restoration/Testing Requirements As Indicated In Section II Met:			
Cognizant Individual <u></u>		Date: <u></u>	
Shift Management Authorization To Close Impairment, Terminate Fire Watch and/or Comp Measures (If Applicable):			
Name: <u></u>		Date: <u></u> Time: <u></u>	
Fire Watch/comp measurer provider notified Initials/Date <u></u>			

Place Original in Work Package if applicable.
FORWARD Completed impairment to the site Fire Marshal.

All Critical Items are **RED**

Non Critical Items are **GREEN**

KEY

KEY

OP-AA-201-007

Revision 1

Page 19 of 22

ATTACHMENT 2

Fire Watch Inspection Log

Page 1 of 2

Section I: Initiation

Reason for watch: Extension cord running through the U2 125 VDC Battery Room North Door (or similar)

TRM Section: 3.7.n Impairment / PBI No.: 23-31 WR / ~~WO~~ No: 123456-01

Type of fire watch (circle one): Hourly Continuous Other: _____

Location: Unit 2 Bldg TB Elev 549 Row * Col *

Description of area to be inspected:

U2 125 VDC Battery Room (or similar)

Required Start Time / Date: 1700++ / Today's Date

Section II: Assignment

Responsible Department: EMD (or dept candidate assigned)

Responsible Supervisor: C. Block

Notification: Current Time * / Today's date *
Time / Date

* May be left blank

++ Time may be before 1700, but must be set by 1700

Section III: Termination

Reason: _____

On Order of: _____

(Print name of Ops Shift Mgt individual who approved termination)

Date: _____ Time: _____

Completed log sheets shall be forwarded to the Fire Marshal.

All Critical Items are **RED**

Non Critical Items are **GREEN**

KEY

KEY

OP-AA-201-007

Revision 1

Page 20 of 22

ATTACHMENT 2

Fire Watch Inspection Log

Page 2 of 2

Section IV: Performance

Location to be inspected: **U2 125 VDC Battery Room**

Impairment / PBI No.: 23-31

[illegible]

HOURLY FIREWATCH INSTRUCTIONS

1. Record time using military time (e.g., 00:00 to 23:59)
2. **PERFORM** roving patrols as specified on the Fire Watch Inspection Log.
3. **REPORT** any conditions or hazards that could cause a fire or affect the severity of a fire, such as leaks, spills, accumulations of combustibles, equipment storage, or faulty equipment to Shift Management.
4. **Immediately REPORT** any fire conditions to the Control Room.
5. For hourly fire watches a "target time" should be established and the specified location should be inspected hourly, as close to the "target time" as practical with the interval between consecutive inspections of the specified location not exceeding 75 minutes.
6. Use a timer device for hourly fire watches.
7. Ensure a face-to-face turnover is performed with the relief fire watch.

CONTINUOUS FIREWATCH INSTRUCTIONS

1. **USE** this form to **DOCUMENT** the start, turnover, and termination of fire watches.
2. Record time using military time (e.g., 00:00 to 23:59)
3. The individual shall have communication equipment available for use.
4. **REPORT** any conditions or hazards that could cause a fire or affect the severity of a fire, such as leaks, spills, accumulations of combustibles, equipment storage, or faulty equipment to Shift Management.
5. **Immediately REPORT** any fire conditions to the Control Room.
6. **If** the Impairment Permit requires the fire watch to perform backup fire suppression, **then** the individual shall be **TRAINED** in its use.

Completed log sheets shall be forwarded to the Fire Marshal.

All Critical Items are RED

Non Critical Items are GREEN

KEY

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** ☒ SRO**JPM Title:** Initiate a Firewatch**JPM Number:** A-N-2-S**Revision Number:** 03**Task Number and Title:** 299L019, Initiate / Terminate a Firewatch**Task Standard:** The Examinee will complete paperwork for a TRM required Firewatch utilizing OP-AA-201-007, FIRE PROTECTION SYSTEM IMPAIRMENT CONTROL.**K/A Number and Importance:** Generic 2.1.20 -- / 4.6**Suggested Testing Environment:** Classroom**Alternate Path:** ☐ Yes ☒ No **SRO Only:** ☒ Yes ☐ No **Time Critical:** ☐ Yes ☒ No**Reference(s):**

Procedure:	<u>OP-AA-201-007</u>	Revision:	<u>01</u>
Procedure:	<u>TRM 3.7.n</u>	Revision:	<u>103</u>
Procedure:	<u>151 U2TB-53</u>	Revision:	<u>05</u>

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☒ Other**Testing Method:** ☐ Simulate ☒ Perform**Estimated Time to Complete:** 20 minutes **Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

INITIAL CONDITIONS

1. You are the WEC Supervisor on midnights and are acting as the Fire Marshall Designee.
2. As part of a scheduled activity, the Electrical Maintenance Department must route an extension cord through the north door for U2 125 VDC Battery Room on elevation 549' and the work will begin promptly at 1600.
3. The activity is being performed under WO 123456-01 and is scheduled for 6 hours.
4. The cognizant Electrical Maintenance Supervisor is C. Block.
5. Area fire detectors are operable.
6. Neil notification is not required.
7. No additional compensatory measures required.

INITIATING CUE

1. Complete Attachments 1 and 2 of the Fire Protection Impairment Permit IAW OP-AA-201-007.

**DRESDEN GENERATING STATION
PRE-FIRE PLAN**

**151 U2TB-53
Rev 5**

FIRE AREA/ZONE: FZ 7.0A.1-3/8.2.7

DESCRIPTION: UNIT 2 BATTERY ROOM ELEV. 549'

SUGGESTED ACCESS/EGRESS: Primary Access: DS key needed for entry. From door in Battery Room, north wall of Unit 2 TB, 549.
Secondary Access: Same as above.

HAZARDS IN AREA:

- Combustibles: The fire severity classification is Medium. This area contains acrylic plastic, cable insulation, and polyethylene.
- Physical Hazards: Entrapment possible - one means of ingress/egress. Battery acid.
- Explosives: None.
- Electrical: Station batteries, DC panels, cable trays.
- Mechanical: None.
- Chemical: Combustibles when involved in a fire condition may give off toxic products of combustion. Battery acid.
- Radiological: None.
- Construction: Reinforced concrete; Fire Doors.

PLANT SYSTEMS REQUIRING MANAGEMENT:

Safety Related:

125 VDC battery room
250 VDC battery room
DC Panel room

Non-Safety Related:

N/A

Vital Heat Sensitive Components That Need To Be Kept Cool:

N/A

FIRE EQUIPMENT:

- Hose Reels/Standpipe:
 - 1 hose reel located in room (refer to drawing)
 - 1 hose reel located outside south door (refer to drawing)
- Portable Extinguishers:
 - 2 CO₂ extinguishers (refer to drawing)
- Sprinkler System: None
- CO₂ or Halon Systems: None
- Extra Equipment: Fire dampers in battery rooms

FIRE AREA/ZONE: FZ 7.0A.1-3/8.2.7

DESCRIPTION: UNIT 2 BATTERY ROOM ELEV. 549'

SUGGESTED FIRE ATTACK:

Establish command post outside of NE entrance of 549". Initial attack should be made with portable extinguishers, backed up with one 1½" attack line.

The ultimate decision for the fire attack is at the Fire Brigade Leader/Incident Commander's discretion.

VENTILATION EQUIPMENT:

Under normal operation, ventilation air is supplied from the East Turbine Building ventilation system and exhausted into the exhaust registers. TBV is controlled exclusively from the Main control room.

SMOKE MANAGEMENT:

East Turbine Bldg. Vent System is a once through and does not contain any fire dampers and, therefore, the smoke will continue to follow the designed flow path and eventually will be exhausted to the outside. Smoke in any fire zone will get diluted with the large amount of air involved for ventilation and shall not hamper operations post-fire. In the event of exhaust fans failure, manual fans from the fire brigade carts can be setup to remove smoke.

COMMUNICATIONS:

- Portable Radios are ok for use.
- Phone available in area (refer to drawing).

RADIOACTIVE RELEASE CONSIDERATIONS:

Radiation release to any unrestricted area due to the direct effects of fire suppression activities (but not involving fuel damage) shall be as low as reasonably achievable and shall not exceed 10CFR Part 20 limits.

SPECIAL PRECAUTIONS:


Caution: Entrapment possible. This area contains combustible materials at the gap between the tops of various walls and the ceiling that may cause hidden fire spread.


REFERENCES:

Reference legend, 100 PREFIRE PLAN MASTER LEGEND

DRESDEN GENERATING STATION PRE-FIRE PLAN

151 U2TB-53
Rev 5





- (A) 2/3-9482-141
- (B) 2/3-9482-142
- (C) 2 - 9472-017
- (D) 2 - 9472-014
- (E) 2 - 9472-015
- (F) 2 - 9472-016
- (G) 2/3-9472-009
- (J) 2/3-9472-010
- (K) 2/3-9472-007
- (L) 2/3-9472-008
- (M) 2/3-9482-139
- (N) 2/3-9482-140



REV	DATE	DESCRIPTION	PREP	REVL	APPR
0	EDSF	DCP 0000371456	EDSF	EDSF	EDSF
1					
2					
3					

Exelon Dresden Station, Unit 2 & 3		SCALE: NONE DATE: --- DRAWN BY: --- ORG. BY: E133	F-8-1 SHEET NUMBER: 1 SIZE: F
--	--	--	--

DETECTION AND SUPPRESSION
CONTROL ROOM AND MISCELLANEOUS
TURBINE BUILDING FLOORS

Job Performance Measure**REVIEW ACPS**JPM Number: A-N-3-SRevision Number: 02Date: 12/22

Developed By: Derek Siuda / _____
Instructor: Print / Sign Date

Approved By: Jonathan Chapman / _____
Facility Representative: Print / Sign Date

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: <u>LS-AA-119</u>	Revision: <u>15</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date

Revision Record (Summary)

Revision #	Summary
00	New JPM for ILT 09-1 Cert Exam
01	Modified for ILT 15-1 (2016-301) NRC Exam
02	Updated for the ILT 19-1 (2020-301) NRC Exam
03	Updated for the ILT 22-1 (2023-301) NRC Exam

SETUP INSTRUCTIONS:

1. This is a tabletop JPM. It is not required to be performed in a simulator setting.
2. No Simulator setup needed.

DOCUMENT PREPARATION

1. Provide a clean copy of OP-AA-108-101, CONTROL OF EQUIPMENT AND SYSTEM STATUS.
2. Provide a blank Equipment Status Tag (EST)
3. Provide a marked up copy of OP-AA-108-101, CONTROL OF EQUIPMENT AND SYSTEM STATUS, Attachment 3, ABNORMAL COMPONENT POSITION SHEET (ACPS) NUMBERING LOG.

INITIAL CONDITIONS

1. You are the WEC SRO.
2. A leak has developed on the 2A Service Water Pump (2-3901-A).
3. The 2A Service Water Pump motor has been thoroughly wetted.
4. IR 1234567 was written to document the leakage and motor wetting.
5. The 2A Service Water Pump is currently in Pull-to-Lock on Panel 923-1.
6. The Equipment Status Tag (EST) database is currently unavailable.

INITIATING CUE

1. Complete OP-AA-108-101 Attachments 1 and 2 and an Equipment Status Tag (EST) as required to support EST and Abnormal Component Position Sheet (ACPS) for 2A Service Water Pump Control Switch.
2. When complete, inform the Unit 2 Unit Supervisor.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____

JPM Sequence #: _____ of 5

Task Standard:

The Examinee will properly fill out OP-AA-108-101 Attachments 1 and 2 and an Equipment Status Tag IAW OP-AA-108-101, CONTROL OF EQUIPMENT AND SYSTEM STATUS.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
Note	Provide the examinee with the supplied copy of OP-AA-108-101, marked up copy of OP-AA-108-101 ATTACHMENT 3, and a blank EST.				
1.	Examinee reviews OP-AA-108-101 locates attachments 1 and 2.	Locates Attachments 1 and 2.	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	The ACPS, Equipment Status Tag, and Equipment Status Tag Log are free form documents. Wording used for “tag location”, “purpose”, “actions required for removal” “name” and “normal position” may be different from the key.				
Note	Steps 2, 3 and 4 may be performed concurrently.				
*2.	Examinee performs step 4.2.1 and completes attachment 1.	See attached key.	<input type="checkbox"/>	<input type="checkbox"/>	—
*3.	Examinee performs step 4.2.2 and completes attachment 2.	See attached key. (RED is required, GREEN is not required)	<input type="checkbox"/>	<input type="checkbox"/>	—
*4.	Examinee fills out EST with information from attachment 1.	See attached key.	<input type="checkbox"/>	<input type="checkbox"/>	—
5.	Informs Unit Supervisor task is complete.	Examinee notifies the Unit Supervisor.	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	Acknowledge report of task completion				

JPM Stop Time: _____



KEY

OP-AA-108-101

Revision 18

Page 1 of 2

ATTACHMENT 1

EQUIPMENT STATUS TAG (EST) LOG

Page 1 of 1

Unit 2

[illegible]

*If ACPS associated with EST, then only the EST #, ACPS #, Tag Location and Restoration columns must be completed as other information is available on the ACPS.

KEY

KEY

OP-AA-108-101

Revision 13

Page 2 of 2

ATTACHMENT 2
Abnormal Component Position Sheet (ACPS)

Page 1 of 1

ACPS #: **23-124** (Refer to step 4.2.1.2)

Station: **Dresden**

Unit: **2**

System: **3900**

NOTE: The criteria below defines an operating boundary/threshold that ensures use of the ACPS does not or cannot adversely impact a system, structure or component as described in the UFSAR, or the method of performing or controlling a UFSAR-described design function. Use of the ACPS in accordance with the guidelines established below, i.e. answering NO to all of the questions, ensures that the activity is not within the scope of 10 CFR 50.59

Purpose for Abnormal Positioning: 2A Service Water Pump Motor Wetted								
Action Required for Removal (IR #, WR #, WO #, CO #, etc.): IR 1234567								
Will the change in component position alter a function required by regulation?							Y	<input checked="" type="radio"/> N
Will the change in component position alter a function required by license condition?							Y	<input checked="" type="radio"/> N
Will the change in component position alter a function required by NRC orders or technical specifications?							Y	<input checked="" type="radio"/> N
Will the change in component position affect the design basis function of the system?							Y	<input checked="" type="radio"/> N
Will the change in component position affect component(s) credited in the accident analysis?							Y	<input checked="" type="radio"/> N
Will the change in component position materially alter the plant response to an accident?							Y	<input checked="" type="radio"/> N
If the answer to any of the questions above is YES (Y), Then a 10CFR50.59 review is required. If the answer to all of the questions above is NO (N), Then the component may be positioned per the ACPS with no 10CFR50.59 review required.								
SRO Approval (Signature/Date/Time):					Candidate Signature		Date	Time
SRO Peer Check for Safety Related Equipment (Signature/Date/Time):					N/A		N/A	N/A
SRO Approval for Restoration (Signature/Date/Time):								
ABNORMAL POSITIONING						RESTORATION or Transfer to Other Approved Process		
EPN	EST Number*	Normal Position	Abnormal (Desired) Position	Performer Init / Date	Verifier Init / Date	Position	Performer Init / Date	Verifier Init / Date
2-3901-A	Tag #	Normal-after-close <u>OR</u> Normal-after-trip	PTL					
EST Log Updated:		Placement:			N/A	Removal:		N/A

*All EST(s) must have ACPS Number written or printed on them.
This form to be maintained in ACPS Binder until restoration is completed.

KEY

KEY

ACPS 23-124

EQUIPMENT STATUS TAG

TAG # 150965

EQUIPMENT#/NAME 2-3901-A
2A SW Pump

DEF/CONDITION Motor Wetted C/S in PTL

AR# 1234567

EQUIPMENT STATUS TAG

TAG # 150965

UNIT# 2 SYS# 3900

EQUIPMENT 2-3901-A

TAG LOCATION Panel 923-1

HUNG BY DATE

AUTHORIZED BY

1456759-4

FRONT

TAG # 150965

REASON Motor Wetted

HUNG BY DATE

TAG # 150965

REASON Motor Wetted

CONDITION C/S in PTL

AR#

BACK

****Circled information is required****

****All other information is optional.****

KEY

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** ☒ SRO**JPM Title:** Review ACPS**JPM Number:** A-N-3-S**Revision Number:** 02**Task Number and Title:** 299L014 Complete an equipment status tag for a given component and properly log per OP-AA-108-101**Task Standard:** The Examinee will properly fill out OP-AA-108-101 Attachments 1 and 2 and an Equipment Status Tag IAW OP-AA-108-101, CONTROL OF EQUIPMENT AND SYSTEM STATUS.**K/A Number and Importance:** Generic 2.2.14 -- / 4.3**Suggested Testing Environment:** Classroom**Alternate Path:** ☐ Yes ☒ No **SRO Only:** ☒ Yes ☐ No **Time Critical:** ☐ Yes ☒ No**Reference(s):**

Procedure:	OP-AA-108-101	Revision:	15
Procedure:	_____	Revision:	_____
Procedure:	_____	Revision:	_____

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☒ Other**Testing Method:** ☐ Simulate ☒ Perform**Estimated Time to Complete:** 15 minutes**Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

INITIAL CONDITIONS

1. You are the WEC SRO.
2. A leak has developed on the 2A Service Water Pump (2-3901-A).
3. The 2A Service Water Pump motor has been thoroughly wetted.
4. IR 1234567 was written to document the leakage and motor wetting.
5. The 2A Service Water Pump is currently in Pull-to-Lock on Panel 923-1.
6. The Equipment Status Tag (EST) database is currently unavailable.

INITIATING CUE

1. Complete OP-AA-108-101 Attachments 1 and 2 and an Equipment Status Tag (EST) as required to support EST and Abnormal Component Position Sheet (ACPS) for 2A Service Water Pump Control Switch.
2. When complete, inform the Unit 2 Unit Supervisor.



Constellation Confidential/Proprietary

OP-AA-108-101

Revision 18

Page 18 of 22

ATTACHMENT 3
Abnormal Component Position Sheet (ACPS) Numbering Log
Page 1 of 1

[illegible]

This log may be utilized, per Station direction, for consistency in ACPS numbering convention.

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure: <u>RP-AA-203</u>	Revision: <u>06</u>
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
Procedure: _____	Revision: _____
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date
_____ / _____ SME / Instructor (Print/Sign)	_____ Date

Revision Record (Summary)

Revision #	Summary
02	Bank JPM
03	Modified for 2009 NRC Exam
04	Revised for ILT 20-1 (2021-301) NRC Exam and new revision (01) of TQ-AA-150-J020.
05	Updated for the ILT 22-1 (2023-301) NRC Exam

SETUP INSTRUCTIONS:

1. This is a tabletop JPM. It is not required to be performed in a simulator setting.
2. No Simulator setup needed.

DOCUMENT PREPARATION

1. Markup a copy of an RWP and survey map for the 2/3 Radwaste Basement.

INITIAL CONDITIONS

1. You are the WEC Supervisor and will be briefing EOs to perform a Clearance Order First Hang in the 2/3 Radwaste Mezzanine under RWP DR-0-23-00333.
2. Five EOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than DR-0-23-00333.
3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five EOs to assist you in your planning:

Name	DDE dose received on RWP DR-0-23-00333 <u>Today</u>	Annual TEDE dose <u>To Date</u>
Sarah	5 mrem	1320 mrem
Tim	60 mrem	1800 mrem
Marcus	0 mrem	1610 mrem
Anya	5 mrem	1950 mrem
Luis	35 mrem	1250 mrem

4. The total expected stay time for each EO will be 45 minutes. Based on past job history, it will breakdown as follows:
 - 30 minutes total in the area near the following **two** pumps:
 - 2/3-2016A, 2/3A Floor Drain Sample Pump
 - 2/3-2016B, 2/3B Floor Drain Sample Pump
 - 15 minutes total in the area near the following **one** instrument Rack:
 - 2223-13, Instrument Rack
5. Exceeding administrative dose limits will NOT be authorized.

INITIATING CUE

1. CALCULATE the expected dose for the work in the RADWASTE MEZZANINE. DETERMINE which EO(s) CAN and which EO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the “Comment Number” column on the following pages. Then annotate that comment in the “Comments” section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site’s appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: _____

JPM Sequence #: _____ of 5

Task Standard:

The Examinee will determine whether personnel assigned to perform radiation work will exceed RWP and/or annual (administrative and/or regulatory) dose limits by calculating expected dose for the work task using the guidance in RP-AA-203.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Note	Provide the Examinee with the attached copy of the RWP and survey map of the 2/3 Radwaste Mezzanine and a copy of RP-AA-203. The following steps may be performed in any order.				
1.	Reviews Survey Maps to determine area dose rates.	Reviews the survey maps and determines area dose rates to be 40 mr/hr for the first group of 2 pumps and 140 mr/hr for the remaining instrument rack.	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	The following calculations should be made: 2 pump clearance projected dose = 0.50 hr x 40 mr/hr = 20 mrem 1 instrument rack clearance projected dose = 0.25 hr x 140 mr/hr = 35 mrem Total projected dose for the job = 20 mrem + 35 mrem = 55 mrem				
*2.	Calculates that the projected dose that will be received for the task is 55 mrem.	Determines the EO's will receive 20 mrem on the first 2 pumps and 35 on the instrument rack.	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	IF the candidate inquires whether any of the EOs have received permission to exceed any dose limits, respond: "None of the Equipment Operators have received permission to exceed any limits".				
Note	The following steps may be performed in any order.				
*3.	Determines that Sarah CAN perform the job because no limits will be exceeded.	Sarah's total RWP dose and Annual dose will remain below the limits.	<input type="checkbox"/>	<input type="checkbox"/>	—
*4.	Determines that Tim CAN NOT perform the job because they would exceed the 80 mrem dose alarm on RWP DR-0-21-00333.	Tim's total dose on RWP DR-0-21-00333 would be 115 mrem .	<input type="checkbox"/>	<input type="checkbox"/>	—
*5.	Determines that Marcus CAN perform the job because no limits will be exceeded.	Marcus's total RWP dose and Annual dose will remain below the limits.	<input type="checkbox"/>	<input type="checkbox"/>	—
*6.	Determines that Anya CAN NOT perform the job because they would exceed the 2000 mrem Exelon Annual limit.	Anya's total Annual dose would be 2010 mrem .	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*7.	Determines that Luis CAN NOT perform the job because they would exceed the 80 mrem dose alarm on RWP DR-0-21-00333.	Luis's total dose on RWP DR-0-21-00333 would be 90 mrem .	<input type="checkbox"/>	<input type="checkbox"/>	—
8.	Informs Evaluator task is complete	Informs Evaluator task is complete	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	Acknowledge report				

JPM Stop Time:

KEY

EVALUATOR: The candidate must determine that dose for the task will be 55 mrem and determine that only two EOs can receive the dose, necessary to complete the task. They are Sarah and Marcus. See the table below for projected job dose, 24 hour total dose on RWP DR-0-21-00333, and total Annual TEDE dose for each Operator.

Calculation:

2 pumps clearance (2/3A & B FDST Pumps) projected dose = $0.50 \text{ hr} \times 40 \text{ mr/hr} = \underline{20\text{mrem}}$

1 instrument rack clearance (2223-13) projected dose = $0.25\text{hr} \times 140 \text{ mr/hr} = \underline{35\text{mrem}}$

$20\text{mrem} + 35 \text{ mrem} = \underline{55 \text{ mrem}}$ projected job dose for clearance order hanging

Name	DDE dose received on RWP DR-0-21-00333 today	Annual TEDE dose as of Midnight To Date	Projected dose on RWP DR-0-21-00333 for the 24 hour period	Projected Annual TEDE (including all dose from last 24 hours)
Sarah	5 mrem	1320 mrem	$5 + 55 = \underline{60 \text{ mrem}}$	$1320 + 60 = \underline{1380 \text{ mrem}}$
Tim	60 mrem	1800 mrem	$60 + 55 = \underline{115 \text{ mrem}}$	$1800 + 115 = \underline{1915 \text{ mrem}}$
Marcus	0 mrem	1610 mrem	$0 + 55 = \underline{55 \text{ mrem}}$	$1610 + 55 = \underline{1665 \text{ mrem}}$
Anya	5 mrem	1950 mrem	$5 + 55 = \underline{60 \text{ mrem}}$	$1950 + 60 = \underline{2010 \text{ mrem}}$
Luis	35 mrem	1250 mrem	$35 + 55 = \underline{90 \text{ mrem}}$	$1250 + 90 = \underline{1340 \text{ mrem}}$

The **red bolded** values in the table exceed the applicable Company, RWP, or 10CFR limit.

KEY

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** ☒ SRO**JPM Title:** Select Personnel for Radiation Work**JPM Number:** A-N-4-S**Revision Number:** 05**Task Number and Title:** 29900LK119, Discuss the items to be considered prior to work authorization**Task Standard:** The Examinee will determine whether personnel assigned to perform radiation work will exceed RWP and/or annual (administrative and/or regulatory) dose limits by calculating expected dose for the work task using the guidance in RP-AA-203.**K/A Number and Importance:** Generic 2.3.12 -- / 3.7**Suggested Testing Environment:** Classroom**Alternate Path:** ☐ Yes ☒ No **SRO Only:** ☒ Yes ☐ No **Time Critical:** ☐ Yes ☒ No**Reference(s):**Procedure: RP-AA-203 Revision: 06

Procedure: _____ Revision: _____

Procedure: _____ Revision: _____

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☒ Other**Testing Method:** ☐ Simulate ☒ Perform**Estimated Time to Complete:** 10 minutes**Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

INITIAL CONDITIONS

1. You are the WEC Supervisor and will be briefing EOs to perform a Clearance Order First Hang in the 2/3 Radwaste Mezzanine under RWP DR-0-23-00333.
2. Five EOs are available this shift.
 - None of the five have received dose at any location other than Dresden Station.
 - None of the five have received dose since midnight on any RWPs other than DR-0-23-00333.
3. The Radiation Protection Department has provided the attached Survey map, and the following dose history for the five EOs to assist you in your planning:

Name	DDE dose received on RWP DR-0-23-00333 <u>Today</u>	Annual TEDE dose <u>To Date</u>
Sarah	5 mrem	1320 mrem
Tim	60 mrem	1800 mrem
Marcus	0 mrem	1610 mrem
Anya	5 mrem	1950 mrem
Luis	35 mrem	1250 mrem

4. The total expected stay time for each EO will be 45 minutes. Based on past job history, it will breakdown as follows:
 - 30 minutes total in the area near the following **two** pumps:
 - 2/3-2016A, 2/3A Floor Drain Sample Pump
 - 2/3-2016B, 2/3B Floor Drain Sample Pump
 - 15 minutes total in the area near the following **one** instrument Rack:
 - 2223-13, Instrument Rack
5. Exceeding administrative dose limits will NOT be authorized.

INITIATING CUE

1. CALCULATE the expected dose for the work in the RADWASTE MEZZANINE. DETERMINE which EO(s) CAN and which EO(s) CAN NOT be assigned to perform the task. EXPLAIN the basis for your determination.

RADIATION WORK PERMIT
Dresden Nuclear Power Station

2/3 Radwaste Mezzanine	RWP DR-0-23-00333
	Revision: 01

This RWP Permits HRA Access. A specific HRA brief by RP is required for entry

Comments: PP# 10015555		
Access List Required: N	<u>Begin Date</u> Yesterday	<u>Close on Date</u>

LOCATIONS			
Buildings	Elevations	Rooms	
Radwaste	507'	Mezzanine	
Back Out Radiological Conditions			
Description		Value	Unit
N/A			
RWP Tasks			
Task	Description		Status
1	Radwaste Mezzanine Walkdown		Active
RWP Requirements			
Requirement Groups		Requirement Descriptions	
N/A			
Additional Instructions			
RP Brief is required prior to accessing areas greater than 7 ft.			
RP Brief required prior to entry.			
Approvals			
Approver Title		Name	Date
RWP Approver		Jordan, Michael	Yesterday
Attachments			
N/A			

RADIATION WORK PERMIT Dresden Nuclear Power Station

2/3 Radwaste Mezzanine	RWP DR-0-23-00333	1
	Revision: 01	Task

This Task Permits HRA Access. A specific HRA brief by RP is required for entry.

Access List Required: N		Task Status: Active	
Alarm Settings			
	Dose (mrem)	Back Out (80%) Dose (mrem)	Dose Rate (mrem/hr)
Gamma	80	64	300

Back Out Radiological Conditions		
Description	Value	Unit
Gamma Dose Rate General Areas	300	mrem/hr
Beta/Gamma Loose Surface Contamination General Area	100K	dpm/100cm ²
RWP Requirements		
Requirement Groups	Requirement Description	
1. Risk Level	Low Risk	
	Medium Risk	
2. Alpha Level	Alpha Level 1, 2	
3. RP Coverage	Intermittent, Required for System Breach	
4. Air Sampling	N/A	
5. Dosimetry	Electronic Dosimeter and DLR required	
6. Contamination Control	N/A	
7. Protective Clothing	See Protective Clothing Matrix (RP-AA-410)	
8. Respiratory Protection	N/A	
9. Exposure Control	Use LOW DOSE Areas (Identified on survey maps)	
Additional Instructions		
RP Brief is required prior to accessing areas greater than 7 ft.		
When exiting satellite RCAs personnel shall perform a hand-and-shoe frisk and proceed to the nearest whole body monitor.		
Stop work if radiological conditions exceed Back Out Rad conditions or RWP Requirements unless approved by Alara Plan or other approved document.		
Attachments		
N/A		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation.
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

1. Task description and number, JPM description and number are identified. _____
2. Knowledge and Abilities (K/A) references are included. _____
3. Performance location specified. (in-plant, control room, simulator, or other) _____
4. Initial setup conditions are identified. _____
5. Initiating cue (and terminating cue if required) are properly identified. _____
6. Task standards identified and verified by instructor or SME review. _____
7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*). _____
8. IAW NUREG 1021 Appendix C, clearly identify the task standard (i.e., the predetermined qualitative or quantitative outcome) against which task performance will be measured. _____
9. Verify the procedure(s) referenced by this JPM reflects the current revision:

Procedure:	EP-AA-113	Revision:	16
Procedure:	EP-AA-113-F-02	Revision:	B
Procedure:	EP-AA-113-F-03	Revision:	G
Procedure:		Revision:	
10. Verify cues both verbal and visual are free of conflict. _____
11. Verify performance time is accurate. _____
12. If the JPM cannot be performed as written with proper responses, then revise the JPM. _____
13. When JPM is initially validated, sign and date JPM cover page. For subsequent validations, sign and date below: _____

/	
SME / Instructor (Print/Sign)	Date
/	
SME / Instructor (Print/Sign)	Date
/	
SME / Instructor (Print/Sign)	Date

Revision Record (Summary)

Revision #	Summary
01	Bank JPM
02	Revised for ILT 12-1 (2013-301) NRC Exam
03	Revised for ILT 16-1 (2017-301) NRC Exam
04	Updated for the ILT 22-1 (2023-301) NRC Exam

SETUP INSTRUCTIONS:

1. This is a tabletop JPM. It is not required to be performed in a simulator setting.
2. No Simulator setup needed.

DOCUMENT PREPARATION

1. A clean copy of EP-AA-113, PERSONNEL PROTECTIVE ACTIONS.
2. Two clean copies of EP-AA-113-F-02, AUTHORIZATION FOR EMERGENCY EXPOSURE
3. A clean copy of EP-AA-113-F-03, THYROID BLOCKING AGENT AUTHORIZATION

INITIAL CONDITIONS

1. You are the Shift Emergency Director
2. A General Emergency has been declared
3. There is an offsite release in progress
4. A Loss of the Fuel Clad Barrier has occurred, together with a failure of the RCS
5. Containment is currently being challenged
6. The TSC has NOT been activated, but the appropriate EAL has been declared
7. An Emergency life-saving operation **MUST** be performed
8. The operation will take between 15 and 20 minutes in a 200 R/hr field (CDE) with unknown fission product gas concentration in the room
9. The operation requires two people to enter the field
10. Clay Morrow, Employee ID #123456 and Jax Teller Employee ID #891001 have volunteered.
11. Clay's current annual exposure is 210 mRem.
12. Jax's current annual exposure is 141 mRem.
13. Clay and Jax have NEVER received an emergency exposure before
14. RP Manager, Tig Tager, has reviewed EP-AA-113 Attachment 1 with Clay and Jax.

INITIATING CUE

1. Execute sections 4.3 and 4.4 of EP-AA-113

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: _____

JPM Sequence #: _____ of 5

Task Standard:

The Examinee will determine if emergency exposure limits will be exceeded, authorize the volunteers to receive emergency exposure, and then give authorization to take KI IAW EP-AA-113, PERSONNEL PROTECTIVE ACTIONS.

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Note	Provide the examinee with the supplied copies of EP-AA-113, EP-AA-113-F-02, and EP-AA-113-F-03.				
1.	DETERMINE if emergency exposure limits in excess of 5 Rem TEDE (EPA-400 lower limits) are required for Exelon emergency workers.	Determines emergency exposure limits in excess of 5 Rem TEDE are required per initiating cue.	<input type="checkbox"/>	<input type="checkbox"/>	—
*2.	For exposures at or above 5 Rem TEDE (EPA-400 lower limits), COMPLETE an Authorization for Emergency Exposure (EP-AA-113-F-02).	Fills out EP-AA-113-F-02 for both Morrow and Teller See Attached Keys	<input type="checkbox"/>	<input type="checkbox"/>	—
3.	OBTAIN emergency worker's acknowledgment that they have volunteered and understand the associated risks. Acknowledgement should be in writing on Authorization for Emergency Exposure Form (EP-AA-113-F-02).	Morrow and Teller sign form	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	Evaluators sign EP-AA-113-F-02 in the Emergency Worker Signature block				
Note	If asked for Radiation Protection Manager to sign and date EP-AA-113-F-02, enter name as "TIG TRAGER" and today's date in the appropriate blanks.				
*4.	OBTAIN and DOCUMENT Station Emergency Director approval, by signature, for the use of the emergency dose limits above 5 Rem TEDE (EPA-400 lower limits) on the Authorization for Emergency Exposure form.	Signs EP-AA-113-F-02 as the Shift Emergency Director to authorize emergency dose limits.	<input type="checkbox"/>	<input type="checkbox"/>	—
Cue	If asked, Clay and Jax do NOT have any adverse reactions to KI.				
5.	Examinee recognizes per the initiating cue that authorization to take KI must also be completed prior to the emergency workers entering the space.	Recognizes that authorization to take KI must also be completed.	<input type="checkbox"/>	<input type="checkbox"/>	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*6.	Examinee determines there is or has been a Loss of Fuel Clad Barrier (based on initiating cues). Determines from step 4.4.1.B, condition 1, that workers will be entering an unknown radiological atmosphere that is suspected to have a high iodine concentration. Determines KI must be issued.	Determines KI must be issued.	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	If required, ask the examinee the reason for issuing KI				
*7.	Examinee documents the decision to issue KI using THYROID BLOCKING AGENT AUTHORIZATION Form (EP-AA-113-F-03).	Enters Employee Name and ID Numbers on EP-AA-113-F-03: Clay Morrow 123456 Jax Teller 891001 See Attached Key	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	If asked for Radiation Protection Manager to sign and date EP-AA-113-F-03, enter name as “TIG TRAGER” and today’s date in the appropriate blanks.				
8.	Examinee notifies Occupational Health (Medical) Services Department promptly that KI is to be issued to Exelon Nuclear personnel or contractors.	Examinee states that he/she would notify OHS.	<input type="checkbox"/>	<input type="checkbox"/>	—
Note	JPM is complete when applicant notifies OHS of KI use.				

JPM Stop Time:

Exelon
Nuclear

KEY

EP-AA-113-F-02

Revision B

Page 1 of 1

AUTHORIZATION FOR EMERGENCY EXPOSURE

Name: Clay Morrow Date / Time: Today's Date Current Time

Employee ID Number: 123456 Current Annual Exposure: 210 mRem

Reason For Request:

EMERGENCY LIFE SAVING ACTIONS (OR SIMILAR)

REQUESTING AUTHORIZATION TO EXCEED:

- ☐ 5 Rem TEDE (Authorized to receive greater than 5 Rem TEDE but less than 10 Rem TEDE)
- ☐ 10 Rem TEDE (Authorized to receive greater than 10 Rem TEDE but less than 25 Rem TEDE)
- ☒ 25 Rem TEDE (Authorized to receive greater than 25 Rem TEDE)

Evaluator signs Clay Morrow
Today's Date / Current Time

* Emergency Worker Signature

Date / Time

* Emergency Worker Exposure Limits and Associated Risks (EP-AA-113 Attachment 1) have been reviewed and the potential health affects are understood.

Evaluator signs Tig Trager
Today's Date / Current Time

Rad. Protection Management (Review)

Date / Time
Candidate's Signature
Today's Date / Current Time

Station Emergency Director (Authorization)

Date / Time

The Shift Manager (Shift Emergency Director) may approve prior to transferring Command and Control to the Station Emergency Director.

Critical items are in RED

KEY

Document Retention SRRS ID - 5B.100

Exelon Nuclear	KEY	EP-AA-113-F-02 Revision B Page 1 of 1
<u>AUTHORIZATION FOR EMERGENCY EXPOSURE</u>		
Name: <u>Jax Teller</u>	Date / Time: <u>Today's Date</u> <u>Current Time</u>	
Employee ID Number: <u>891001</u>	Current Annual Exposure: <u>141</u> mRem	
Reason For Request:		
EMERGENCY LIFE SAVING ACTIONS (OR SIMILAR)		
<u>REQUESTING AUTHORIZATION TO EXCEED:</u>		
<input type="checkbox"/> 5 Rem TEDE	(Authorized to receive greater than 5 Rem TEDE but less than 10 Rem TEDE)	
<input type="checkbox"/> 10 Rem TEDE	(Authorized to receive greater than 10 Rem TEDE but less than 25 Rem TEDE)	
<input checked="" type="checkbox"/> 25 Rem TEDE	(Authorized to receive greater than 25 Rem TEDE)	
Evaluator signs Clay Morrow	Today's Date / Current Time	
* Emergency Worker Signature	Date / Time	
* Emergency Worker Exposure Limits and Associated Risks (EP-AA-113 Attachment 1) have been reviewed and the potential health affects are understood.		
Evaluator signs Tig Trager	Today's Date / Current Time	
Rad. Protection Management (Review)	Date / Time	
Candidate's Signature	Today's Date / Current Time	
# Station Emergency Director (Authorization)	Date / Time	
# The Shift Manager (Shift Emergency Director) may approve prior to transferring Command and Control to the Station Emergency Director.		
<div style="border: 1px solid black; padding: 5px; display: inline-block;">Critical items are in RED</div> <div style="color: red; font-size: 2em; margin-left: 20px;">KEY</div>		
Document Retention SRRS ID – 5B.100		



Exelon Generation

KEY
EP-AA-113-F-03

Revision G

Page 1 of 2

THYROID BLOCKING AGENT AUTHORIZATION

OR ELECTRONIC FACSIMILE

Potassium Iodide (KI) Brief Verification / Authorization

NAME: <u>Clay Morrow</u>	Employee ID Number: <u>123456</u>
NAME: <u>Jax Teller</u>	Employee ID Number: <u>891001</u>
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____
NAME: _____	Employee ID Number: _____

The above-named personnel are hereby authorized to take Potassium Iodide (KI) for the purpose of protection against the inhalation/ingestion of radioactive I-131. The applicable dosage (see back of this form for recommended dosage) shall be taken for 10 consecutive days or until directed that the risk **no** longer exists.

Evaluator signs Tig Trager

Today's Date / Current Time

* Radiation Protection Manager (Reviewed)

Date / Time

* Acknowledges review of evaluation for need to use KI and that emergency worker(s) have been briefed on the potential health risks associated with KI. (see back of this form for briefing details)

Candidate's Signature

Today's Date / Current Time

Emergency Director responsible for authorization
of emergency exposure controls (Authorization)

Date / Time

KI Issuance Verification

** Radiation Protection Manager (Confirmation of KI issuance)

KI Issuance Date / Time

** Confirm that individuals listed on this authorization form have been issued a supply of KI and instructed to take appropriate dosage.

Critical items are in **RED**
KEY

Document Retention SRRS ID – 5B 100

JPM SUMMARY**Operator's Name:** _____ **Emp. ID#:** _____**Job Title:** ☒ SRO**JPM Title:** Authorize Use of KI**JPM Number:** A-N-5-S**Revision Number:** 04**Task Number and Title:** 295L160, Perform the duties of the Shift Emergency Director**Task Standard:** The Examinee will determine if emergency exposure limits will be exceeded, authorize the volunteers to receive emergency exposure, and then give authorization to take KI IAW EP-AA-113, PERSONNEL PROTECTIVE ACTIONS.**K/A Number and Importance:** Generic 2.4.40 -- / 4.5**Suggested Testing Environment:** Classroom**Alternate Path:** ☐ Yes ☒ No **SRO Only:** ☒ Yes ☐ No **Time Critical:** ☐ Yes ☒ No**Reference(s):**

Procedure:	EP-AA-113	Revision:	16
Procedure:	EP-AA-113-F-02	Revision:	B
Procedure:	EP-AA-113-F-03	Revision:	G

Actual Testing Environment: ☐ Simulator ☐ Control Room ☐ In-Plant ☒ Other**Testing Method:** ☐ Simulate ☒ Perform**Estimated Time to Complete:** 10 minutes**Actual Time Used:** _____ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be: ☐ Satisfactory ☐ Unsatisfactory**NOTE:** Enter finalized grading, comments, and notes relevant to this evaluation in the associated TQ-AA-150-F03A/B. (See AR [4282419](#)).**Evaluator's Name (Print):** _____**Evaluator's Signature:** _____ **Date:** _____

INITIAL CONDITIONS

1. You are the Shift Emergency Director
2. A General Emergency has been declared
3. There is an offsite release in progress
4. A Loss of the Fuel Clad Barrier has occurred, together with a failure of the RCS
5. Containment is currently being challenged
6. The TSC has NOT been activated, but the appropriate EAL has been declared
7. An Emergency life-saving operation MUST be performed
8. The operation will take between 15 and 20 minutes in a 200 R/hr field (CDE) with unknown fission product gas concentration in the room
9. The operation requires two people to enter the field
10. Clay Morrow, Employee ID #123456 and Jax Teller Employee ID #891001 have volunteered.
11. Clay's current annual exposure is 210 mRem.
12. Jax's current annual exposure is 141 mRem.
13. Clay and Jax have NEVER received an emergency exposure before
14. RP Manager, Tig Tager, has reviewed EP-AA-113 Attachment 1 with Clay and Jax.

INITIATING CUE

1. Execute sections 4.3 and 4.4 of EP-AA-113