

June 14, 2023

Docket No.: 52-026

ND-23-0453  
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 4  
ITAAC Closure Notification on Completion of ITAAC E.3.9.05.01.03 [Index Number 851]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 4 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item E.3.9.05.01.03 [Index Number 851]. This ITAAC confirms that selected Post-Accident Monitoring System parameters are retrievable in the Technical Support Center (TSC). The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli Roberts at 706-848-6991.

Respectfully submitted,



Jamie M. Coleman  
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 4  
Completion of ITAAC E.3.9.05.01.03 [Index Number 851]

JMC/CIP/sfr

U.S. Nuclear Regulatory Commission

ND-23-0453

Page 2 of 2

cc: Regional Administrator, Region II  
Director, Office of Nuclear Reactor Regulation (NRR)  
Director, Vogtle Project Office NRR  
Senior Resident Inspector – Vogtle 3 & 4

**Southern Nuclear Operating Company  
ND-23-0453  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 4  
Completion of ITAAC E.3.9.05.01.03 [Index Number 851]**

## **ITAAC Statement**

### **Program Commitment**

5.1 The licensee has established a technical support center (TSC) and an onsite operations support center (OSC). [H.1]

### **Inspections/Tests/Analyses**

5.1 An inspection of the as-built TSC and OSC will be performed, including a test of the capabilities.

### **Acceptance Criteria**

5.1.3 The plant parameters listed in UFSAR Table 7.5-1, *Post-Accident Monitoring System*, can be retrieved and displayed in the TSC.

## **ITAAC Determination Basis**

Multiple ITAAC are performed to ensure that the licensee has established a technical support center (TSC) and an onsite operations support center (OSC). This ITAAC performs an inspection of the as-built TSC to confirm that the plant parameters listed in the VEGP 3&4 Updated Final Safety Analysis Report (UFSAR) Section 7.5, Table 7.5-1, *Post-Accident Monitoring System* (Reference 1), can be retrieved and displayed in the TSC.

The inspection was performed as described in ITAAC Technical Report SV4-ERO-ITR-800851 (Reference 2) and verified that each of the plant parameters identified in Reference 1 can be retrieved and displayed in the TSC. The inspection results are documented in Reference 2 and verify that the plant parameters listed in UFSAR Table 7.5-1, *Post-Accident Monitoring System*, can be retrieved and displayed in the TSC.

Reference 2 is available for NRC inspection as part of the ITAAC E.3.9.05.01.03 Completion Package (Reference 3).

## **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there were no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC E.3.9.05.01.03 (Reference 3) and is available for NRC review.

## **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC E.3.9.05.01.03 was performed for VEGP Unit 4 and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. VEGP 3&4 Updated Final Safety Analysis Report, Section 7.5, Table 7.5-1, Post-Accident Monitoring System, Revision 12
2. SV4-ERO-ITR-800851, Rev. 0, "Unit 4 ITAAC 851 Displays: ITAAC E.3.9.05.01.03"
3. E.3.9.05.01.03-U4-CP-Rev0, ITAAC Completion Package