

OFFICE OF NUCLEAR REACTOR REGULATION

LIC-504

Management Decision



Approve

Deny

Approve with Comment

On August 23, 2023, the staff briefed the management lead on the technical issue, analyses, and recommendation on the risk-informed assessment of French stress corrosion cracking operational experience relative to US fleet. The staff presented two options:

- Option 1: Revise inspection requirements for susceptible piping locations consistent with the French OE.
- Option 2: Take no direct action but continue to monitor industry actions.

Due the safety significance demonstrated through the analyses in this LIC-503, the staff recommended Option 2. The management lead agreed with the recommendation and instructed the staff to implement Option 2, and plan on a public meeting with the industry to discuss these results. He also requested the staff brief the Office director on these results.

Name:

Brian Smith:
BThomson for

Job Title:

Director, DNRL

Date:

08/31/23

Signature: **/RA/**