



1. ALL TUBING STEEL
2. ALL PIPE SCH 40 - ASTM A53
3. ALL CONNECTORS - S.S.
4. ALL PIPE FITTINGS - ASTM A-105 GR.2

SIS PUMP.	1-1	1-2
DRAIN LINE NUMBER	(S2 693 2)	(S2 1614 2)

DRAWING STATUS	57	DATE
☒ FOR PLANT EQUIPMENT ☐ FOR CONSTRUCTION ☐ FOR CONSTRUCTION		
APPROVED FOR CONSTRUCTION		

<u>SIZE</u> <u>NPT</u>	<u>NO REQ'D.</u> <u>FOR ONE</u>	<u>DESCRIPTION</u>
1 1/2"	AS REQ'D.	PIPE - C.T.S.
1"	AS REQ'D.	TUBING .049 WALL THICKNESS
3/4"	AS REQ'D.	TUBING .049 WALL THICKNESS
2"	1	TEE - 2000#
1 1/2"	2	CROSS-2000#
1 1/2"	1	ELBOW - 2000#
1 1/2"x1"	2	HEX BUSHING
1 1/2"x1 1/2"	4	HEX BUSHING
2"x1 1/2"	2	HEX BUSHING
1"	4	16-16 FBZ-SS-OR EQUAL (
1/2"	8	12-8 FBZ-SS-OR EQUAL (

SIS. PUMP 1-1
SEAL & DRIP POCKET DRAIN SYSTEM
SEE TABLE FOR PUMP 1-2

WESTINGHOUSE EL. CORP. - APD.

<u>PUMP NO.</u>	<u>SPIN NO.</u>
② 45493/99	PSE SIAPSI - 1/2
45491/92	AEP SIAPSI - 1/2
45490/94	AMP SIAPSI - 1/2
45495/96	PNJ SIAPSI - 1/2
45497/98	PGE SIAPSI - 1/2
45489/500	PEG SIAPSI - 1/2

SAFETY INJECTION
CUST. OR NO. 54-E-705-03B SUPP.
DATE: 6-25-69

NO.	CHANGE DATE	DATE	PACIFIC PUMPS INC.	
1	WORKER TITLES REVISED	3/20/70	LOS ANGELES, CALIF	
2	PUMP SPIN NOS UP-DATED	4-6-70	SEAL & DRIP SOCKET DRAIN PIPING	
3			BILL NO. 1 DATES 4-22-70 DATES 4-22-70 CHECKED JDA APPROVED NINER TITCH PART 001	CSD 4 5489-1

DC-663216-28 UNIT-1 

P G & E CO.		102009	REV.
SHEET 6	PAGE 0		19