

**From:** Samson Lee  
**Sent:** Tuesday, December 26, 2023 8:13 AM  
**To:** Josh Turner  
**Cc:** Nathan Lee  
**Subject:** Acceptance Review: Wolf Creek request to revise the Ventilation Filter Testing Program in Technical Specifications (EPID: L-2023-LLA-0164)

By letter dated November 16, 2023 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML23320A277), Wolf Creek Nuclear Operating Corporation (the licensee) submitted a license amendment request (LAR) to revise the Technical Specifications (TSs) for the Wolf Creek Generating Station (Wolf Creek). The LAR would revise TS 5.5.11.b for the Ventilation Filter Testing Program by changing the testing requirements for the inplace test of the charcoal adsorber penetration and system bypass from less than 0.05% to less than 1%, as informed by Generic Letter 83-13 and Regulatory Guide 1.52, Revision 2. The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed the licensee's application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed change in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, the licensee will be advised by separate correspondence.

Based on the information provided in the licensee's submittal, the NRC staff has estimated that this licensing request will take approximately 375 hours to complete. The NRC staff expects to complete this review by December 26, 2024. If there are emergent complexities or challenges in the NRC staff's review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates, will be communicated during the routine interactions with the assigned project manager. These estimates are based on the NRC staff's initial review of the application and these estimates could change, due to several factors including complexity and uniqueness of the review, requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees. Additional delay may occur if the submittal is provided to the NRC in advance or in parallel with industry program initiatives or pilot applications.

If you have any questions, please contact me.

Samson Lee  
Wolf Creek Project Manager  
Plant Licensing Branch 4  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

301-415-3168

Docket No. 50-482

**Hearing Identifier:** NRR\_DRMA  
**Email Number:** 2352

**Mail Envelope Properties** (SA1PR09MB8653446750D3AE1A1618AFE59A98A)

**Subject:** Acceptance Review Wolf Creek request to revise the Ventilation Filter Testing Program in Technical Specifications (EPID L-2023-LLA-0164)  
**Sent Date:** 12/26/2023 8:12:32 AM  
**Received Date:** 12/26/2023 8:12:00 AM  
**From:** Samson Lee

**Created By:** Samson.Lee@nrc.gov

**Recipients:**  
"Nathan Lee" <Nathan.Lee@evergy.com>  
Tracking Status: None  
"Josh Turner" <Josh.Turner@evergy.com>  
Tracking Status: None

**Post Office:** SA1PR09MB8653.namprd09.prod.outlook.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	3213	12/26/2023 8:12:00 AM

**Options**  
**Priority:** Normal  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**