



L-2024-002  
10 CFR 55a(z)(2)  
January 08, 2024

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington D C 20555-0001

RE: St. Lucie Nuclear Plant, Unit 2  
Docket No. 50-389  
Renewed Facility Operating License NPF-16

Withdrawal of Proposed Alternative to American Society of Mechanical Engineers (ASME)  
Operation and Maintenance (OM) Code for the Auxiliary Feedwater (AFW) 2C Pump

Reference:

1. Florida Power & Light letter L-2023-099, Pump Relief Request 10 (PR-10), One-Time Request for an Alternative to the American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code for the Auxiliary Feedwater (AFW) 2C Pump. July 26, 2023 (ADAMS Accession No. ML23208A057)
2. Response to Request for Additional Information Regarding Pump Relief Request 10 (PR-10), One-Time Request for an Alternative to the American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code for the Auxiliary Feedwater (AFW) 2C Pump, October 26, 2023 (ADAMS Accession No. ML23300A003)

In Reference 1, Florida Power & Light Company (FPL) requested for St Lucie Nuclear Plant (St. Lucie) Unit 2, an alternative to American Society of Mechanical Engineers (ASME) Operation and Maintenance (OM) Code 2004/2006a, Subsection ISTB-6300, Systematic Error. The proposed alternative would provide on a one-time basis, relief from the ASME OM ISTB-6300 requirement to conduct a retest of the Auxiliary Feedwater (AFW) 2C Pump until plant conditions were appropriate to support a comprehensive pump test in accordance with ASME OM ISTB-3400. The requested relief followed the discovery of a test instrument employed during the prior AFW 2C pump comprehensive test that was subsequently determined to be outside the allowable calibration tolerance.

In Reference 2, FPL provided additional information deemed necessary to complete the NRC's review.

By this letter, FPL hereby withdraws Pump Relief Request 10 (PR-10) for St Lucie Unit 2. The withdrawal follows the satisfactory completion of an AFW 2C Pump comprehensive test on December 18, 2023.

Should you have any questions regarding this submission, please contact Mr. Kenneth Mack, Fleet Licensing Manager, at 561-904-3635.

This letter contains no new or modified regulatory commitments.

Sincerely,

*Dianne Strand*

---

Dianne Strand  
General Manager, Regulatory Affairs  
Florida Power & Light Company

cc: USNRC Regional Administrator, Region II  
USNRC Project Manager, St. Lucie Nuclear Plant, Units 1 and 2  
USNRC Senior Resident Inspector, St. Lucie Nuclear Plant, Units 1 and 2  
Mr. Clark Eldredge, Florida Department of Health

Florida Power & Light Company

---

6501 S. Ocean Drive, Jensen Beach, FL 34957