



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

March 9, 2024

Jamie M. Coleman
Regulatory Affairs Director
Southern Nuclear Operating Co., Inc.
3535 Colonnade Parkway
Birmingham, AL 35243

SUBJECT: EDWIN I. HATCH NUCLEAR PLANT, UNIT 1 – CORRECTION OF
AMENDMENT NO. 266 REGARDING LICENSE AMENDMENT REQUEST
REGARDING RELOCATION OF SPECIFIC SURVEILLANCE FREQUENCIES
TO A LICENSEE-CONTROLLED PROGRAM (TSTF-425, REVISION 3)

Dear Jamie Coleman:

On January 3, 2012, the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 266 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML11108A129) to Renewed Facility Operating License (RFOLs) DPR-57 for the Edwin I. Hatch Nuclear Plant (Hatch), Unit 1.

The amendment revised the Hatch, Unit 1, technical specifications (TSs) by relocating specific surveillance frequencies to a licensee-controlled program using a risk-informed justification, Technical Specification Task Force Traveler (TSTF)-425, Revision 3, "Relocate Surveillance Frequencies to Licensee Control -RITSTF [Risk-Informed TSTF] Initiative 5b" (ML090850642).

An administrative error on the part of the NRC staff was made on the issuance of TS page TS 3.7-17. The NOTE for Surveillance Requirement (SR) 3.7.6.1 was inadvertently left off the revised TS page.

By letter dated October 29, 2010 (ML103140510), Southern Nuclear Operating Company (SNC, the licensee) submitted its license amendment request (LAR) for TSTF-425, Revision 3. SR 3.6.6.1 on TS page TS 3.7-17 has the following NOTE:

-----NOTE-----
Not required to be performed until 31 days after
any main steam line not isolated and SJAE in
operation.

Consistent with NRC staff guidance dated January 16, 1997 (ML103260096) and based on the NRC's policy established by SECY-96-238, these errors can be corrected by a letter to the licensee from the NRC staff. These changes do not affect the NRC decision approving amendment No. 266 and do not affect the No Significant Hazards Consideration as published in the *Federal Register*.

J. Coleman

- 2 -

Enclosed please find corrected Hatch, Unit 1, TS page TS-3.6-17.

If you have any questions, please contact me at 301-415-3100 or John.Lamb@nrc.gov.

Sincerely,

/RA/

John G. Lamb, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No.: 50-321

Enclosure:
As stated

cc: Listserv

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.6.1</p> <p>-----NOTE----- Not required to be performed until 31 days after any main steam line not isolated and SJAE in operation. -----</p> <p>Verify the gross gamma activity rate of the noble gases is ≤ 240 mCi/second.</p>	<p>In accordance with the Surveillance Frequency Control Program</p> <p><u>AND</u></p> <p>Once within 4 hours after a $\geq 50\%$ increase in the nominal steady state fission gas release after factoring out increases due to changes in THERMAL POWER level</p>

SUBJECT: EDWIN I. HATCH NUCLEAR PLANT, UNIT 1 – CORRECTION OF AMENDMENT NO. 266 REGARDING LICENSE AMENDMENT REQUEST REGARDING RELOCATION OF SPECIFIC SURVEILLANCE FREQUENCIES TO A LICENSEE-CONTROLLED PROGRAM (TSTF-425, REVISION 3) DATED MARCH 9, 2024

DISTRIBUTION:

PUBLIC

PM Reading File

RidsAcrs_MailCTR Resource

RidsNrrDorlLpl2-1 Resource

RidsNrrLAKGoldstein Resource

RidsNrrPMHatch Resource

RidsRgn2MailCenter Resource

ADAMS Accession No. ML24069A001

OFFICE	NRR/DORL/LPL2-1/PM	NRR/DORL/LPL2-1/LA	NRR/DORL/LPL2-1/BC	NRR/DORL/LPL2-1/PM
NAME	JLamb	KGoldstein	MMarkley	JLamb
DATE	03/09/2024	03/09/2024	03/09/2024	03/09/2024

OFFICIAL RECORD COPY