

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Fuels, Materials, and Structures Subcommittee
Open Session

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, April 2, 2024

Work Order No.: NRC-2779

Pages 1-105

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

FUELS, MATERIALS, AND STRUCTURES SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

TUESDAY

APRIL 2, 2024

+ + + + +

The Subcommittee met via hybrid Video
Teleconference, at 1:00 p.m. EDT, Ron Ballinger,
Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chair

VICKI M. BIER, Member

CHARLES H. BROWN, JR., Member*

VESNA B. DIMITRIJEVIC, Member*

GREGORY H. HALNON, Member

WALTER L. KIRCHNER, Chair

JOSE A. MARCH-LEUBA, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ROBERT P. MARTIN, Member
2 DAVID A. PETTI, Member
3 THOMAS E. ROBERTS, Member

4

5 ACRS CONSULTANT:

6 DENNIS BLEY*

7

8 DESIGNATED FEDERAL OFFICIAL:

9 ZENA ABDULLAHI

10 LAWRENCE BURKHART

11

12 ALSO PRESENT:

13 PAUL CLIFFORD, Public Participant*

14 ZACHARY HARPER, WEC

15 KEVIN HELLER, NRR

16 JEFFREY KOBELAK, WEC*

17 SCOTT KREPEL, NRR

18 JAMES LAIRD, WEC

19 JOHN LEHNING, NRR

20 YUN LONG, WEC

21 SCOTT MOORE, ACRS*

22 BENJAMIN PARKS, NRR*

23 HAROLD SCOTT, Public Participant*

24 BRANDON WISE, NRR

25 *Participating remotely

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CONTENTS

Call to Order and ACRS Chairman

Introductory Remarks 4

NRC Leadership Staff Opening Remarks 7

WEC Leadership Staff Opening Remarks 8

NRC Staff 32

Public Comment 53

Nonconcurrency discussion 59

P-R-O-C-E-E-D-I-N-G-S

1:00 p.m.

CHAIR BALLINGER: Good afternoon. This meeting will now come to order.

This is a meeting of the Fuels, Materials, and Structures Subcommittee of the Advisory Committee on Reactor Safeguards.

Today's meeting is a hybrid meeting -- in-person and virtual attendance.

I'm Ron Ballinger, Chairman of the Subcommittee meeting.

ACRS members are Walt Kirchner, Jose March-Leuba, Matt Sunseri, Tom Roberts, Dave Petti, Greg Halnon, Robert Martin, Vicki Bier, and maybe some others will show.

We have online -- and I'm going to mess this up -- I know we have Vesna Dimitrijevic, and I don't know if there are any others. Correct me if I'm wrong, please.

(No response.)

Nobody is correcting. So, I'm assuming I'm okay.

MS. ABDULLAHI: Brown, I think I see him. Yes, I do.

CHAIR BALLINGER: Oh, is Charlie on?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 MS. ABDULLAHI: I think so.

2 CHAIR BALLINGER: Okay, I'll just assume
3 he is.

4 MS. ABDULLAHI: Yes, he's been accepted.

5 CHAIR BALLINGER: He's been accepted, but
6 not on.

7 And I was looking for Dennis. Is he on?

8 MS. ABDULLAHI: He should be.

9 MR. BLEY: He is.

10 CHAIR BALLINGER: Dennis is on. Okay.

11 MS. ABDULLAHI: Yes.

12 CHAIR BALLINGER: That should pretty much
13 cover it.

14 During today's meeting, the Subcommittee
15 will hear from NRC and Westinghouse staff on the
16 review of the Westinghouse Licensing Topical Report
17 WCAP-18446, Revision 0, "Incremental Extension of
18 Burnup Limit for Westinghouse and Combustion
19 Engineering Fuel Designs."

20 Today's meeting is an open and closed
21 session. The first part will be open, and then, we'll
22 have a closed session, if need be, with the latter
23 session intended to protect Westinghouse proprietary
24 information.

25 And we also will have a presentation by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the NRC staff related to a non-concurrence associated
2 with this review.

3 ACRS was established by the Atomic Energy
4 Act and is governed by the Federal Advisory Committee
5 Act. The ACRS is independent of the NRC staff.

6 When applicable, ACRS issues publicly
7 available Letter Reports that provide the Commission
8 independent technical reviews of NRC staff's Safety
9 Evaluations of licensees' amendments to their
10 operating licenses.

11 ACRS members will ask questions and at
12 times make statements. However, these statements are
13 individual member opinions and should not be construed
14 as ACRS findings or opinions. ACRS opinions are
15 documented only in our Letter Reports.

16 The ACRS section of the U.S. NRC public
17 website provides our Charter, Bylaws, agendas, Letter
18 Reports, and transcripts of all open session
19 Subcommittee and full Committee meetings, which
20 include the slides presented.

21 A transcript of this meeting is being
22 kept, and the open session transcript will be made
23 publicly available.

24 The meeting notice and the agenda for this
25 meeting are posted.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We have not received written statements or
2 requests to make an oral statement from the public or
3 prior to this meeting, although there is a statement
4 from the member of the public that will be read into
5 the record as part of this meeting.

6 Today's meeting is hybrid with virtual
7 participation over Microsoft Teams and in-house for
8 ACRS staff, members, NRC staff, and the public. There
9 is also a telephone bridge line and a Microsoft Teams
10 link allowing participation of the public to join all
11 open sessions.

12 Finally, when addressing the Subcommittee,
13 the participants should, first, identify themselves
14 and speak with sufficient clarity and volume, so that
15 they may be heard and the transcribing folks will
16 understand you.

17 When not speaking, we request that
18 participants mute their computer microphone, or phone
19 by pressing *6.

20 I'll now proceed with the meeting and
21 start by calling on -- let's see, who do I need to
22 call on? Scott Krepel.

23 MR. KREPEL: Hello. I'm Scott Krepel.
24 I'm speaking through a sign language interpreter.

25 I am the Branch Chief for the Nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Methods and Fuel Analysis Branch.

2 And obviously, today's material is an
3 issue of great concern for many of you. This is the
4 first time that we have had a discussion about
5 specific licensing activities that relate to decisions
6 going beyond our current license burnup.

7 There is a certain non-concurrence that we
8 will be discussing, as you mentioned, during this
9 presentation, and we invite your perspectives, your
10 feedback, et cetera, as we go through.

11 That's really all I have to say in terms
12 of opening. Thank you so much for engaging with us on
13 this Topical Report.

14 CHAIR BALLINGER: Thank you.

15 Zach, do you want to say something?

16 MR. HARPER: Yes. First, I'd like to
17 thank the ACRS Subcommittee for your time today, and
18 I appreciate the review of the Topical Report.

19 Jeff Kobelak will be the presenter. He's
20 not able to be with us physically today, but he will
21 be the presenter, and I'll be moving through the
22 slides.

23 Just appreciate your time and we look
24 forward to a good open and engaging discussion.

25 So, with that, can I turn it over to Jeff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to introduce yourself?

2 MR. KOBELAK: Okay. Thanks, Zach.

3 I guess, first, can you just confirm, are
4 you able to hear me clearly?

5 MR. HARPER: Yes.

6 MR. KOBELAK: Perfect.

7 All right. Yes, thank you very much for
8 giving us an opportunity to present today on this
9 Topical Report. It's something that we think is very
10 important to Westinghouse's plans, as I'll talk about
11 in a few moments here, and it's something that we
12 worked on for many years before submitting it, and the
13 staff has put many years of their time on as well.
14 So, we do think it's a very important topic that we're
15 covering today.

16 I work for Westinghouse Electric Company
17 in the Safety Analysis Group. I've been doing
18 analyses and method development for about 21 years
19 now. So, I'll be the primary presenter for the open
20 session, and then, in the closed session, we're going
21 to have a mix of several different people from
22 Westinghouse presenting.

23 So, I don't know, should I begin with the
24 presentation or are there any other opening remarks?

25 CHAIR BALLINGER: I think we're all set.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Why don't you start your presentation?

2 MR. KOBELAK: Okay. Perfect. Thank you
3 very much.

4 Okay. So, I wanted to start off this
5 presentation just by kind of speaking to how
6 incremental burnup relates to Westinghouse's plans for
7 developing advanced materials and methods, fuel
8 products, et cetera.

9 So, Westinghouse I think is unique in that
10 we decided to pursue burnup extension as a two-step
11 process. The first step is what we're talking about
12 today. It's the incremental burnup extension. And
13 for the incremental burnup extension, we are allowing
14 rods only in peripheral assemblies to go above the
15 current license burnup limit.

16 So, if you look at the graphic in the
17 upper left there, that's showing a quarter core for a
18 4-loop Westinghouse PWR. And all of those locations
19 that are marked in green would be assemblies for which
20 rods could go above the current license burnup limit.

21 And then, step two, which is a future and
22 entirely separate licensing action, would be to
23 increase the burnup limit for the entire core above 70
24 gigawatt-days per MTU, coincident with an enrichment
25 increase that's really needed to operate those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 assemblies to high burnup more economically.

2 Next slide, please, Zach.

3 So, this is a roadmap, I'll call it a
4 roadmap of the Westinghouse EnCore fuel, which is our
5 name for accident-tolerant fuel, as well as the High
6 Energy Fuel Program, which is what we refer to as
7 higher enrichment and higher burnup.

8 And this shows the progression with time.
9 So, if you look at the left side of this figure, the
10 ADOPT fuel pellets and AXIOM cladding, those are
11 materials that have already been reviewed and approved
12 by the NRC. I believe that both of those were
13 presented to the ACRS as those Topical Reports were
14 under review.

15 Where we're at now, Topicals that are
16 currently under review. So, incremental burnup is
17 what we're discussing today, and then, the Higher
18 Enrichment Topical Report was submitted last year, and
19 I believe there's an audit upcoming for that Topical
20 Report later this month. But that's in the early
21 stages of review right now.

22 The EPRI alternate licensing strategy, I
23 think that EPRI has presented on this once and is
24 going to be presenting again in June. So, this is an
25 approach to addressing FFRD for higher burnup fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rods.

2 And Westinghouse has made a submittal
3 already to the NRC that is intended to support EPRI
4 ALS. And I believe what I'll call the full umbrella
5 submittal from EPRI is expected to go in later on here
6 in April. So, that will imminently be under review.

7 And then, looking out to the future, we
8 have what I'll call near-term and long-term concepts.
9 So, near term, we're working on chromium-coated
10 cladding, which I think we expect to submit later this
11 year. And the full-core high burnup extension, which
12 is probably still a couple of years out before that's
13 fully submitted, and then, we've also been looking
14 long term at several advanced fuel materials, so
15 uranium nitride pellets and silicon carbide cladding,
16 but I think those are pretty well out into the future
17 right now.

18 Okay. I wanted to touch on some of the
19 benefits here in the open session. This is really the
20 motivation for why we decided to do the two-step
21 process.

22 So, the primary benefit, I think at least
23 for the utilities, are these first two main bullets
24 that are shown here. We can get slightly better fuel
25 utilization. So, that saves utilities a little bit of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 money each operating cycle, and the higher region
2 burnup allows some additional assemblies that would
3 have just been discharged to be used for an additional
4 cycle of operation.

5 And so, by reducing the number of feed
6 assemblies, that provides some benefit to utilities.
7 It also has a corresponding benefit relative to the
8 back-end cost. So, every assembly that operates,
9 obviously, has to be dealt with after operation is
10 done, and if plants are loading fewer assemblies, then
11 there's less waste being produced. So, there's less
12 that needs to be put into the spent fuel pool, and
13 then, into dry casks, and eventually, to wherever
14 permanent storage will occur.

15 And I think we also viewed this as a
16 benefit to Westinghouse, in that we do have a fair
17 amount of high burnup data, but, of course, we're
18 always looking for more. And this is a means of being
19 able to operate a number of assemblies and rods to
20 higher burnup, which allows us to continue building
21 upon and developing a more robust database for higher
22 burnup fuel.

23 And then, we're at a stage right now where
24 we have a number of customers who are, essentially,
25 waiting on this Topical Report. So, we do have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 commercial contracts for ADOPT fuel AXIOM cladding and
2 incremental burnup, once it's approved.

3 Okay. Here, I wanted to talk a little bit
4 about the applicability. So, this, essentially,
5 outlines where this Topical Report can be applied. It
6 will be valid for fuel rod burnups above 62-gigawatt-
7 days per MTU. It's not an unlimited we can go to
8 whatever burnup we want. We'll get into a little more
9 detail there in the closed session.

10 It's limited to the current fuel rod
11 enrichment. So, this does not allow for greater than
12 5 weight percent enrichment. As I mentioned before,
13 it's limited only to fuel rods and core peripheral
14 assemblies. So, basically, limiting it to lower-
15 power, non-limiting assemblies.

16 It is applicable to all the currently
17 manufactured Westinghouse and CE fuel designs, and
18 I'll talk more about that in the closed session, as to
19 how that came about.

20 In terms of cladding materials, it's
21 applicable to our ZIRLO cladding, Optimized ZIRLO
22 cladding, and AXIOM cladding, although I will say I
23 think that there are very few plants that remain on
24 ZIRLO cladding and we might be in a situation where
25 the remaining customers are transitioning to Optimized

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ZIRLO. So, practically speaking, we expect that the
2 majority of application would be to those latter two
3 materials.

4 And then, in the future, we would intend
5 to apply this with chromium-coated cladding. That is
6 outside of the scope of the current submittal.

7 And finally, in terms of fuel pellets, we
8 would intend this to be applicable to both standard
9 UO2 and ADOPT fuel pellets.

10 And the graphic here really just shows
11 this is what I would term an umbrella Topical Report.
12 So, rather than being a specific focus, like a fuel
13 rod performance method or a LOCA analysis method, this
14 is a Topical Report that covers the impact of this
15 incremental burnup increase across all the different
16 technical disciplines.

17 So, I wanted to take a couple of slides
18 here to provide an overall of the content of the
19 Topical Report. We did write this Topical Report with
20 the objective of ensuring efficient implementation.
21 And what I mean by that is we wanted to be very clear
22 on which previously approved Topical Reports have
23 limitations that are being exceeded; what are the
24 limitations that are associated with implementing this
25 Topical Report, and also, what are the licensee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 actions that are required whenever they go to
2 implement this Topical Report?

3 And in that last piece, we don't cover 100
4 percent of every evaluation that needs to be done, but
5 it is a nice roadmap of all the significant new
6 analyses, re-analyses, and evaluations that are
7 required for implementation.

8 So, this is something that we do really to
9 try to ensure that, when the Topical Report is
10 approved and a utility wants to implement, we ensure
11 that we're doing it aligned with staff expectations of
12 what would need to be done.

13 So, the remainder of the Topical Report,
14 there's a lot of sections between one and seven. That
15 is, basically, where we go through all the different
16 technical disciplines to address the effect of the
17 burnup extension. And the focus in each of those
18 areas was impacts on codes, methods, and acceptance
19 criteria.

20 So, the idea is that the Topical Report
21 will cover how the analyses and evaluations need to be
22 done, and then, the execution of them would occur as
23 part of a plant-specific implementation.

24 So, just in terms of a high-level overview
25 -- and we will get into a little bit more detail in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 some of these areas in the closed session -- this is
2 kind of in order that they appear in the Topical
3 Report.

4 So, Section 2 is mechanical design. This
5 is where we talked about the design basis for the fuel
6 assembly, all the different structural components and
7 materials, and what the impact was associated with
8 taking those assemblies up to a higher burnup level.

9 We, then, move from the assembly more to
10 look at the fuel rods themselves. So, Section 3 is
11 the core and fuel rod performance. That's where we
12 cover fuel rod design and justify the application of
13 PAD5 to this incremental burnup regime. So, PAD5 is
14 our latest Westinghouse fuel rod performance code.

15 We talk about nuclear design. And the
16 nuclear design section I think is important because
17 that's really one of the primary factors that was
18 driving incremental burnup.

19 However, in terms of the codes and
20 methods, we had previously submitted PARAGON2 for
21 review and approval, and also, our
22 Alpha/PHOENIX/PARAGON codes were reviewed and approved
23 through the burnup range of interest. So, there was
24 not a large focus on the codes and methods in terms of
25 nuclear design because we had already received

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 approvals for those codes and methods separately.

2 And then, in the -- sorry, was there a
3 question?

4 Okay. And then, in the thermal-hydraulic
5 design, the focus was really on our DMB methods and
6 the calculation of the DMB ratio and demonstrating
7 that those remain applicable to these incremental
8 burnup fuel rods, as well as addressing rod bow. So,
9 with higher burnup, there can be more penalizing
10 effect of rod bow. And our approach was to
11 demonstrate that these incremental burnup fuel rods
12 are non-limiting since they reside on the core
13 periphery and operate at low power.

14 MEMBER HALNON: This is Greg Halnon.

15 Is there any downside to putting them on
16 the periphery? I mean, you have other failure
17 mechanisms of fuel rods, such as debris capture and
18 vibrations, and other things happening. Is there any
19 downside to putting these things on the periphery?

20 MR. KOBELAK: So, we don't think so. The
21 actual residence time of the fuel assemblies is not
22 going to be any higher than what we currently have.
23 So, right now, in core designs that we frequently
24 utilize, a number of assemblies will operate a third
25 cycle out on the core periphery. And this method will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 not increase the burnup limit enough to be able to
2 allow a fourth cycle. So, it just allows more
3 assemblies to operate a third cycle. So, a lot of
4 those failure mechanisms I think are more associated
5 with residence time, and that is not going to change.

6 MEMBER HALNON: Okay. Thank you.

7 MR. KOBELAK: You're welcome.

8 Okay. Next slide, please, Zach.

9 Okay. So, then, starting with Section 4,
10 5, and 6, this is where we get more into the safety
11 and radiological analysis sections.

12 So, Section 4 covers LOCA analysis, and it
13 was focused on the updates required to our codes and
14 methods. They analyze higher burnup fuel rods. And
15 we'll touch on some of the biggest changes in more
16 detail in the closed session.

17 And then, of course, the other big factor
18 here was addressing the potential for fuel dispersal
19 from the fuel rods and the incremental burnup regime.
20 So, that was one of the primary objectives that we
21 were trying to tackle with this Topical Report
22 specific to this incremental burnup fuel rods.

23 Section 5 covers the transient and
24 containment analyses. And the biggest action there
25 was really just to assess and update the decay heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 modeling to ensure that our decay heat models remain
2 appropriately conservative for those analyses.

3 And also, with the issuance of Reg Guide
4 1.236, there was some new phenomena and acceptance
5 criteria that were identified in reactivity insertion
6 accidents. So, we had to account for those findings
7 within our method for incremental burnup.

8 And then, finally, in the radiological
9 consequence analysis section, which is Section 6 of
10 the Topical Report, that discusses how we account for
11 these higher burnup fuel rods when we're doing dose
12 analyses.

13 Okay. So, I did want to touch on fuel
14 fragmentation, relocation, and dispersal because this
15 is, obviously, one of the biggest new phenomena that
16 has been identified and needs to be addressed as we
17 move into high burnup.

18 And I guess I should maybe say at least
19 the dispersal piece is something new. The
20 fragmentation and relocation is something that we do
21 account for to some extent within existing methods.
22 So, the dispersal is the most significant piece that
23 was new to us.

24 So, there is a good body of research that
25 has been ongoing over the last decade. It certainly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will not stop. As I said, this is just our first kind
2 of incremental step into high burnup. The larger step
3 is that step two that we've actively working on. So,
4 that research and development is certainly going to
5 continue and there will be more updates past this
6 Topical Report.

7 But there were some safety assessments
8 that were completed specific to LOCA and non-LOCA
9 accidents and transients back in the 2015=2016
10 timeframe. And a lot of those assessments hinged on
11 the current burnup limit, as well as a number of other
12 factors, precluding any significant amount of
13 dispersal.

14 And so, that is something that is still in
15 place today and is being relied upon here. We are
16 more focused on the fuel rods that are in this
17 incremental burnup regime, and we will talk about that
18 more throughout the closed presentation.

19 There was a RIL issued by the NRC,
20 Research Information Letter 2021-13, that provided a
21 conservative interpretation of the much of the FFRD
22 data that was available at the time, or at least as
23 much as was available in the public domain.

24 And through the RAI process and within the
25 Topical Report, we do speak to a number of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 findings within that RIL. And the idea, as you'll see
2 at the end of the later presentations, is that we
3 fully address the potential for dispersal across all
4 accidents and transients as part of the incremental
5 burnup Topical Report.

6 Okay. And then, I wanted to kind of wrap
7 up here just with a picture of how we got to where we
8 are today. So, this was a Topical Report that
9 Westinghouse submitted for review back in December of
10 2020, and it was accepted by the NRC in March 2021.

11 There was also, I guess -- not shown on
12 this slide -- a supplemental voluntary submittal that
13 Westinghouse made shortly after that which provides
14 some additional information to the staff.

15 The staff provided their first round of
16 RAIs near the end of 2021, and it took us about six
17 months to provide those responses. So, we responded
18 in three different sets of responses, kind of the ones
19 that we could answer the fastest to the ones that took
20 the most time to answer.

21 There were some remaining questions that
22 the staff had after we submitted those responses. So,
23 there was a second round of RAIs issued in September
24 of 2022. And again, it took approximately six months
25 to provide those responses back to the staff. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 were provided in February of 2023.

2 We received the Draft SER in March of
3 2024, and that has led us to the ACRS Subcommittee
4 meeting today, and then, tentatively, a Final SER in
5 June of 2024.

6 So, that covers everything that I wanted
7 to touch on here in the open session. And if there's
8 any other questions, I'd be glad to take them.

9 CHAIR BALLINGER: Questions from the
10 members or our consultant?

11 Hearing none, thank you for your
12 presentation.

13 Is the NRC ready to go? This is the
14 staff. John, you're going to give both presentations?

15 Who's up?

16 MR. HELLER: I believe I am up to start
17 this.

18 CHAIR BALLINGER: Oh, the slides are
19 coming up.

20 MR. HELLER: Oh, sorry.

21 CHAIR BALLINGER: Can we make the screen
22 bigger? Whatever people do to that. Of course, I'm
23 fine with it. Oh, here we go. Oh, that's better.
24 All right.

25 Thank you.

1 MR. HELLER: So, my name is Kevin Heller.
2 I am with the Nuclear Methods and Fuel Analysis
3 Branch, one of the lead reviewers on this. My
4 associates here with me, this is John Lehning and this
5 is Brandon Wise.

6 Thank you for the opportunity to come
7 before you and present about our review of the
8 incremental burnup extension provided by Westinghouse.

9 Next slide, please.

10 Okay. So, this is just a brief
11 presentation outline kind of just showing the
12 breakdown, just more so for future reference.

13 Next slide, please.

14 Okay. So, going into this, I want to
15 provide some background regarding the nature of this
16 methodology and just to serve as a starting point for
17 our discussion.

18 So, as Westinghouse already alluded to,
19 the WCAP-18446 methodology, it contains a
20 comprehensive evaluation of the capabilities of
21 Westinghouse's analysis methods in order to address
22 fuel in the incremental burnup range.

23 So, from the staff's perspective, this is,
24 effectively, an umbrella Topical Report that serves
25 two purposes. First, justify extending the approved

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 limits of applicability for a host of Westinghouse's
2 existing codes and methods, and then, also, to define
3 a methodology by which those codes and methods can be
4 applied to analyze core designs within the incremental
5 burnup range. And a key point to this methodology,
6 again, as Westinghouse alluded to, it intends to
7 demonstrate no dispersal for fuel in the incremental
8 burnup range.

9 Next slide, please.

10 Okay. So, review timeline. I'll just go
11 over some of the high points here.

12 So, the initial submittal was in December
13 of 2020. The acceptance review was completed in March
14 of 2021. So, while the staff's initial acceptance
15 review there was sufficient information presented
16 within that submittal to begin a detailed review, the
17 acceptance review identified a set of topics for
18 supplementary information was necessary to support a
19 timely review.

20 And so, the staff did engage with
21 Westinghouse in an audit, an audit for understanding,
22 and that, ultimately, resulted in the voluntary
23 supplement of May 2021.

24 Staff ended up issuing one primary round
25 of RAIs and a second followup set later in the review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that was focused on clarification and expansion of the
2 information provided within the first round responses.
3 And as Westinghouse also indicated, their RAI
4 responses were provided within several stages.

5 And then, in May of 2023, Westinghouse
6 provided a voluntary supplement to the Topical Report,
7 providing justification to expand its scope to include
8 AXIOM cladding.

9 Also, after the completion of the initial
10 Draft SE, non-concurring staff generated a non-
11 concurrence and filed it in December of 2023. So,
12 there is a non-concurrence associated with this
13 review, but that's a topic that will be covered in a
14 separate presentation later.

15 Next slide, please.

16 This is a list of the key regulatory
17 requirements and guidance that the staff used during
18 the course of the review. I don't plan to spend too
19 much time here. We've seen a lot of this before. But
20 I'll just briefly point a few out.

21 So, for fuel and core performance, GDC-10,
22 for the specified acceptable fuel design limits;
23 NUREG-800; the Standard Review Plan, Chapter 4.2,
24 regarding precluding fuel system damage and
25 maintaining core coolability.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide.

2 For the loss-of-coolant accidents, 10 CFR
3 50.46, Appendix K, and the guidance in Chapter 15.6.5
4 of the SRP; Chapter 15.0.2 of the SRP as well, and Reg
5 Guide 1.203 for the transient accident analysis
6 methods.

7 Next slide, please.

8 Similarly, for the non-loss-of-coolant
9 accidents and transients, again, the Standard Review
10 Plan, Chapter 15, and Regulatory Guide 1.203.

11 And then, for the control rod ejection
12 reactivity insertion accident, Regulatory Guide 1.236.

13 For containment, GDC-50; for radiological
14 dose, Regulatory Guide 1.183.

15 And with that, I think I'll turn it over
16 to Brandon.

17 MR. WISE: So, I'll be discussing the fuel
18 assembly mechanical design section, which primarily
19 included three proposals -- those being a set of
20 design criteria to evaluate fuel assemblies up to the
21 higher burnup limit; a method of evaluating against
22 those criteria, and then, the results in a
23 demonstration of the evaluation for a specific design.

24 The NRC staff determined that the proposed
25 set of design criteria and methods of evaluation were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 acceptable and don't present any substantial increase
2 in risk of decremation or damage to the fuel assembly
3 structure.

4 The specific design evaluation was for the
5 17x17 OFA design. With approval of that, it received
6 generic approval for an incremental burnup extension
7 without any additional review. Other designs can
8 receive the same approval on a generic or plant-
9 specific basis, per LNC1.

10 Next slide, please.

11 And I think I'll hand it back to Kevin.

12 MR. HELLER: All right. Thanks, Brandon.

13 So, this, again, being an umbrella Topical
14 Report, there's a whole lot of discussion and
15 justification provided for the host of Westinghouse
16 codes and methods.

17 And so, for the core and fuel rod
18 performance sections, the Topical Report presents it
19 across these three areas: fuel rod performance,
20 nuclear design, and core thermal-hydraulic design.

21 So, the NRC staff ended up assessing each
22 of these areas in turn during the course of the
23 review, but here in the open session I'm really only
24 going to touch on the first of these, the fuel rod
25 performance, briefly. I'll go into that one in more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 detail in the closed.

2 Next slide, please.

3 So again, just briefly touching on the
4 fuel rod performance, the phenomenological models for
5 the fuel rod performance are contained within the PAD5
6 fuel performance code, and per Limitation and
7 Condition 7 within the SE, incremental burnup
8 analyses. We will be using this code.

9 Westinghouse provided justification for
10 the applicability of models that are associated with
11 each of the fuel rod design bases for use in
12 incremental burnups. We've got the list of design
13 bases here. So, the staff ended up going down through
14 and assessing all the models associated with those,
15 and ultimately, ended up finding them acceptable.

16 Now, the staff concluded that some of the
17 models associated with the fuel rod design bases are
18 applicable to the incremental burnup range only within
19 the scope of the WCAP-18446 methodology. And that's
20 what resulted in Limitation and Condition 4 and, in
21 part, Limitation and Condition 10. The details of
22 those particular models, again, I'll talk about in the
23 closed session.

24 So, for the nuclear design, Westinghouse
25 proposed to continue using their existing nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 design codes, which consist of PARAGON or PHOENIX-P.
2 Those are their lattice transport calculation codes.
3 ANC for their two- and three-dimensional nodal
4 calculations. And Westinghouse indicated that these
5 codes are applicable to the increased burnup
6 conditions within the existing enrichment limit.

7 So, when the NRC staff went through and
8 started assessing these codes, there were two larger
9 areas that they focused on, because there was a
10 consideration that these are likely to be stressed by
11 application of these methods within the incremental
12 burnup range. And that would be the production and
13 depletion of major uranium and plutonium isotopes.
14 That would be the first area. Westinghouse ended up
15 supplying additional validation data via RAI
16 responses, demonstrating those codes' continued
17 applicability in the incremental burnup range.

18 And the second area that the staff looked
19 at was modeling increased critical boron
20 concentration. And Westinghouse indicated via their
21 RAI responses that there would be no significant
22 changes to this; that their codes have sufficient
23 capabilities to analyze within the expected ranges in
24 the incremental burnup. And after taking into
25 consideration Westinghouse responses, the staff,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ultimately, concluded that the codes were performing
2 well there as well.

3 And then, lastly, the staff did, also,
4 take a look at, an overall assessment of the neutronic
5 codes, facilitated by code-by-code comparisons. You
6 know, sort of a spot-check; let's make sure everything
7 is working.

8 So, with that, the NRC staff found/finds
9 that Westinghouse nuclear design codes, as I mentioned
10 before, are applicable to core nuclear designs within
11 the scope of the incremental burnup methodology.

12 So, for the thermal-hydraulic design,
13 Westinghouse proposed no modification were necessary
14 to the existing methods for analyzing departure from
15 nucleate boiling. And I've got a list there of, in
16 particular, the codes and methods. So, their DNBR
17 correlations, their subchannel codes, their revised
18 thermal design procedure.

19 The NRC staff ended up assessing
20 Westinghouse's justification in each of these areas
21 and concluded that the codes and methods are
22 applicable up to the requested rod average burnup, the
23 incremental burnup.

24 Furthermore, Westinghouse also indicated
25 they would perform plant-specific analyses to confirm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that both departure from nucleate boiling and its
2 propagation are prevented.

3 MR. LEHNING: Okay. Thank you, Kevin.

4 And the next slide will be on the loss-of-
5 coolant accident, or LOCA.

6 And this is John Lehning from the staff
7 that's speaking now.

8 We just have an introductory slide in this
9 open session. We'll have about a dozen or so slides
10 in the closed presentation and go through in a bit
11 more detail. There also will be some discussion of a
12 non-concurrence and its disposition on this topic to
13 come.

14 So, just in brief, the objective of the
15 WCAP-18446 methodology was to demonstrate no cladding
16 rupture for fuel rods in the incremental burnup range.
17 And obviously, if that cladding doesn't rupture,
18 whether the fuel fragments or relocates, at least we
19 know it's not exiting the cladding where it started
20 out.

21 The model that Westinghouse uses to do
22 these calculations is based on the full-spectrum LOCA
23 methodology that was approved by the staff. I think
24 about eight, or ten or so, years ago, the reviews were
25 underway for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The codes that are used, the code that is
2 used for that methodology, WCOBRA/TRAC-TF2. And in
3 assessing the applicability of the evaluation model
4 for this application, Westinghouse did evaluate
5 against several PIRTs to look at whether some modeling
6 changes were needed to go to a higher burnup, and
7 that's described in our Safety Evaluation. In Table
8 1, we step through those models.

9 There were a couple of updates that
10 Westinghouse implemented as a result of its
11 evaluations, including fuel rod cladding and rupture
12 modeling in decay heat. And we can go through some
13 more of those details in the closed session. And so,
14 we'll just leave it at the introductory level for now
15 and sort of explain a little bit more of the basis for
16 acceptability in the closed session.

17 So, I'll turn it back over to Kevin.

18 MR. HELLER: All right. Thanks, John.

19 So, when it comes to non-loss-of-coolant
20 accidents, transients and accidents, these analysis
21 methods, Westinghouse separated these into two
22 categories of events: those events that are dependent
23 solely upon core average effects and those events that
24 are dependent upon local effects in the fuel rods.

25 So, for events dependent upon the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 average effects, Westinghouse indicated that these
2 events are analyzed to address core-wide or systemwide
3 criteria, and that the existing codes and methods can
4 readily accommodate any potential impacts the
5 incremental burnup may have. Therefore, the
6 evaluation models remain applicable.

7 So, the NRC staff went and assessed the
8 potential impacts of the incremental burnup against
9 relevant parameters for these analyses and concluded
10 that, I guess I'll call it the assertion that
11 Westinghouse made, that that is reasonable; that these
12 codes remain applicable.

13 For the second category events, those that
14 are dependent on the local fuel rod behavior, these
15 methodologies are for events that predict, for
16 example, fuel enthalpy, departure from nucleate
17 boiling ratio, fuel temperature, et cetera.

18 And so, the NRC -- or excuse me, I'm
19 getting ahead of myself.

20 Westinghouse did not propose any changes
21 to the acceptance criteria for these events or any
22 changes to the parameters.

23 So, the NRC staff also went through and
24 looked at those particular codes in light of the
25 justifications provided and concluded that, for these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 events, the particular codes have been either
2 individually approved already on a generic basis up to
3 the incremental burnup range or they were approved
4 within the scope of the incremental burnup Topical
5 Report. So, for example, PAD5.

6 And I think that's all I have on that
7 slide. So, next slide, please. We are already there.
8 All right.

9 So, for the reactivity insertion
10 accidents, Westinghouse discussed its conformance with
11 the fuel cladding failure thresholds in Regulatory
12 Guide 1.236. With regard to that, in particular, the
13 peak radial average fuel enthalpy, the departure from
14 nucleate boiling, heli clad and mechanical interaction,
15 fuel pellet, incipient melting.

16 Westinghouse proposes to apply its
17 multidimensional kinetics methodology to this event.
18 And so, the NRC staff assessed the discussions
19 provided for conformance with cladding failure
20 thresholds, and also, examined the code applicability.
21 Ultimately, the staff determined that Westinghouse's
22 evaluation of the control rod ejection analyses is
23 acceptable, in part, because of the discussions
24 provided, and then, also, because the codes used to
25 analyze control rod ejection have been shown to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 maintain adequate predictive capability within the
2 incremental burnup range.

3 Next slide.

4 So, Westinghouse also provided some
5 discussion justifying the continued use of their
6 containment integrity analysis methods, and they
7 provided these for both LOCA and main steam line break
8 scenarios.

9 Because Westinghouse's justifications and
10 the staff's conclusions are largely the same for both
11 of these, I'm going to be speaking to them side-by-
12 side.

13 So, when it comes to short-term mass and
14 energy releases, again, both LOCA and steam line
15 break, these, typically, involve a duration of 1 to 10
16 seconds. The results are generally dictated by mass
17 flux at the piping break, and they're really dominated
18 by, more or less, those instantaneous system
19 conditions, not fuel conditions.

20 So, the NRC conclusion was that changes in
21 core design to allow for changes in cycle length to
22 reach this -- so, is there a question?

23 So, the NRC conclusion was that, for
24 changes in core design to achieve these incremental
25 burnups, any changes that would result would not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 impact these analyses. A mass and energy release
2 would be consistent across core designs.

3 For the long-term releases, the NRC staff
4 concluded that the computer codes and methods approved
5 for these analyses would also remain applicable
6 because of the conservative treatment of decay heat
7 modeling, and any impacts from the burnup increase
8 could be readily accommodated by these codes.

9 One point to make, though, is the staff
10 did find that the manner in which the decay heat
11 models were implemented in certain instances in these
12 codes necessitated the introduction of limitations and
13 conditions. So, that's what 13 and 14 are about.

14 MEMBER MARTIN: I apologize. This is
15 Member Martin. I want to back up to the previous
16 slide just for a clarification, really, on the RAI.

17 The statement "no fuel dispersal permitted
18 in fuel rods in the incremental burnup range," that is
19 like a limitation/condition. And does that stem from
20 like the Westinghouse analysis of where it's located?
21 What would be some of the underlying details behind
22 that statement? I'm just looking for a clarification
23 on what is meant there.

24 MR. LEHNING: I can speak to that. This
25 is John Lehning.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And so, we believe from the staff side
2 that this was proposed by Westinghouse. And so, it
3 probably would be better if they want to speak to
4 this, especially in open session.

5 So, I don't know, Jeff, if you are on and
6 want to say something to why, what the motivation was
7 behind that?

8 MR. KOBELAK: Yes. I mean, in terms of
9 the motivation, we felt that one of the key tenets of
10 incremental burnup would be to demonstrate that there
11 was not the propensity for fuel dispersal from rods in
12 this incremental burnup regime from any accident or
13 transient from a requirements perspective. And so, a
14 lot of the work we did in the limitations in the
15 Topical are designed to do that.

16 As far as how we specifically achieved it,
17 if it's okay, I would probably prefer to defer to the
18 closed session.

19 MEMBER MARTIN: Okay. So, from the
20 staff's position, evidence is there that you're
21 satisfied with in their Topical to support that
22 statement, ultimately? Okay. And I'm getting a nod.

23 MR. HELLER: Yes. This is Kevin with the
24 staff. Yes.

25 MEMBER HALNON: On this slide -- this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Greg -- on this slide 17 that you had up there, yes,
2 you mentioned that they found that the codes were okay
3 because of the conservative modeling of the decay
4 heat. I don't want to put words in your mouth, but it
5 sounds like you're saying that they may be wrong, but
6 they're not so wrong that they're going to exceed the
7 conservative margins of the modeling of decay heat.
8 Is that not the right way of looking at this? Are you
9 saying that they're right enough or they're wrong, or
10 they're just a little wrong?

11 MR. HELLER: I'm going to try to choose my
12 words carefully because I don't want to trip over into
13 proprietary, potentially proprietary material.

14 MEMBER HALNON: Okay.

15 MR. HELLER: The decay heat models,
16 overall, are conservative in their application. We
17 recognize that. There are some nuances to -- I'm
18 trying to figure out how to articulate that.

19 MEMBER HALNON: Well, you just said that
20 the margin in the conservative modeling of decay heat,
21 those models are conservative to pick up the
22 uncertainties. Is that fair to say?

23 MR. HELLER: That would be reasonable.

24 MEMBER HALNON: Okay. So, it's not that
25 they're wrong or right? It's just that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 uncertainties were picked up by the conservatisms of
2 the decay heat models?

3 MR. LEHNING: I think that's probably fair
4 to say, and I didn't want to say that they're wrong
5 because I think that I would use intentionally
6 conservative or knowingly conservative. And so,
7 "wrong" would more to me, it wasn't intended to be
8 that way or there's some kind of mistake in that. But
9 I would say that they were intentionally conservative.

10 MEMBER HALNON: I'm just trying to -- you
11 said that the codes would be made applicable, which
12 tells me that they're either right or they're less
13 wrong.

14 MR. LEHNING: And if Westinghouse wants to
15 speak to that?

16 But the way I would say it is that the
17 amount of intentional conservatism that was originally
18 incorporated was enough to continue to cover the
19 small, maybe relatively effective incremental burnup,
20 is sort of the way I might state it.

21 MEMBER HALNON: They continue to work
22 together adequately?

23 MEMBER MARCH-LEUBA: This is Jose.

24 We are already into proprietary, which I
25 guess we'll discuss in an hour.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Would you say that the decay heat, that
2 this is a known in high burnup, and we can calculate
3 it? They calculated it. It's not that it's an
4 unknown. They just chose a conservative approach --

5 MEMBER HALNON: Okay.

6 MEMBER MARCH-LEUBA: -- which they rely
7 on.

8 MEMBER HALNON: Okay. I just wanted to
9 make sure that everything stacks up.

10 MR. LEHNING: Yes, we will have that
11 discussion.

12 MEMBER HALNON: Thank you.

13 MR. LEHNING: Okay. And so, with no other
14 questions, let me move on to give a few slides in the
15 open session about radiological consequence analysis.

16 So again, this is John Lehning from the
17 staff speaking.

18 Westinghouse addressed consequences of
19 three different types of accidents, including LOCA,
20 non-LOCA accidents, of which we've exemplified four of
21 these, and a fuel-handling accident as well. We'll
22 give you some general descriptions now and come back
23 with more details in the closed session.

24 So, for the loss-of-coolant accident, the
25 radiological consequence analyses are typically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 performed by licensees, per Regulatory Guide 1.183 or
2 1.195, depending on whether the alternative or
3 traditional source term would be used.

4 And Westinghouse concluded that the
5 guidance and codes and methods -- or the codes and
6 methods that it uses to conform to that guidance
7 remain applicable for the fuel and incremental burnup
8 range. And we'll explain that a little bit more in
9 the closed session, why they concluded that.

10 For non-LOCA, it's a similar story, that
11 there was a conclusion that the methods remain
12 applicable.

13 And Kevin just spoke to a little bit about
14 what types of evaluations they've done for thermal-
15 hydraulics, and so forth, for the fuel, as well as the
16 technical specification activity limits for certain
17 types of events where a coolant leakage and the
18 activity of that coolant might be one of the factors
19 that plays into the radiological dose. That doesn't
20 change as a result of this, just this Topical Report.

21 For the fuel-handling accident, the impact
22 of fuel dispersal for non-LOCA accidents is not
23 generically addressed in existing regulatory guidance.
24 And so, there is a little bit more of a need here to
25 consider some customized, I guess, or unique methods,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as opposed to the generic methods that don't fully
2 cover maybe the situation as well.

3 So, at a high level, some of the factors
4 that Westinghouse considered in evaluating this event
5 would be the behavior of key short- and long-lived
6 radionuclides, the power history for the fuel in the
7 incremental burnup range, and assumptions about that.
8 And as well, they had to contend with the expected
9 extent of fragmentation and dispersal. So, all of
10 those things are proprietary details which we'll cover
11 later.

12 But, in the end, licensees would
13 explicitly address this fuel-handling accident
14 consequences in their license amendment requests to
15 implement this Topical Report method, and the staff
16 would review those analyses at that time.

17 So, unless there are questions about that,
18 I'll turn it back over to Brandon.

19 MR. WISE: This is Brandon with the NRC
20 staff.

21 The ADOPT Fuel Pellet Topical Report was
22 approved in 2022 for existing burnup limits. That's
23 within 62-gigawatt-days per MTU. This was included in
24 the original submittal, in the scope of the original
25 submittal of the incremental burnup extension.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Therefore, the entirety of the review considered the
2 inclusion of ADOPT fuel pellets.

3 The staff reviewed the unique
4 characteristics of the ADOPT fuel pellets and found
5 that they perform acceptably similar to standard UO2
6 pellets, such that there is no adverse effect on the
7 predictive capability in modeling ADOPT pellets.

8 So, the staff found that the inclusion of
9 ADOPT pellets within the incremental burnup extension
10 Topical Report was acceptable, and that the
11 conclusions in the Topical Report and SE, throughout
12 the SE, also were applicable to ADOPT pellets.

13 Next slide, please.

14 The AXIOM cladding Topical Report was
15 approved in 2023, and in May of the same year,
16 Westinghouse submitted a supplement, to include AXIOM
17 cladding in the scope of the incremental burnup
18 extension.

19 The staff determined that the existing
20 cladding performance models for AXIOM cladding
21 contained adequate data up to the requested burnup
22 limit, such that the staff could come to a safety
23 determination. Furthermore, AXIOM-clad rods are
24 subject to the same incremental burnup -- or to the
25 same incremental burnup extension burnup limit and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 same placement restrictions, and the no-burst
2 criterion, as other cladding designs. They're not
3 given any special treatment.

4 And the NRC staff also determined that the
5 incremental burnup extension methodology is applicable
6 to AXIOM cladding and that the AXIOM cladding specific
7 models are acceptable at the high burnup limit.

8 And I think this is John or Kevin.

9 MR. LEHNING: Okay. I'll speak to this
10 slide. John Lehning.

11 So, as far as just a couple of the
12 limitations and conditions here that were related to
13 materials applicability that are able to be spoken
14 about in the open session here, Limitation and
15 Condition 2 in the staff's Safety Evaluation
16 identifies that the methodology only applies to fuel
17 products with uranium dioxide or ADOPT fuel pellets or
18 the -- I'm sorry -- and the fuel cladding type ZIRLO,
19 Optimized ZIRLO, or AXIOM, as we have discussed here.

20 And for Limitation and Condition 3, the
21 methodology applies to unpoisoned fuel, fuel with
22 integral fuel burnup absorbers, or fuel with gadolinia
23 only. But this does not preclude the use of discrete
24 fuel burnup absorbers. And I think both of these
25 were, basically, proposed by Westinghouse, basically,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 these limitations, because this is the subset of
2 materials that they intend to apply the method to.

3 MEMBER PETTI: So, the term "unpoisoned
4 fuel" is there's no poison in the fuel itself?

5 MR. LEHNING: Correct.

6 MEMBER PETTI: Because, as you read it, it
7 sounds like it excludes the next two.

8 MR. LEHNING: Okay. So, it's meant to be
9 all-inclusive of all three of those.

10 MEMBER PETTI: Right.

11 MR. LEHNING: I'm so sorry if I related
12 that --

13 MEMBER PETTI: Okay. No, no, I got you.

14 CHAIR BALLINGER: Well, what would be a
15 poisoned fuel?

16 MR. LEHNING: The poisoned fuel, like with
17 gadolinia.

18 CHAIR BALLINGER: But this says fuel, that
19 you can use gadolinia.

20 MR. LEHNING: Right, it does say that.
21 I'm sorry.

22 CHAIR BALLINGER: I'm wondering. It's
23 just the English is --

24 MEMBER MARCH-LEUBA: The presentation is
25 a little confusing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Can you give me an example of anything
2 that is not covered? What type of fuel --

3 MR. LEHNING: I think this might have to
4 do more with future, for example, ATF kinds of
5 concepts or other things. So, I'm not sure it
6 necessarily excludes a lot of the existing fuels that
7 are out there for Westinghouse. I don't think they
8 would want to do that. And so, I think they covered
9 existing fuels, but there may be some advanced designs
10 that they might not have to add and they didn't want
11 to get a lot of questions about the supply. Maybe
12 when they're ready, at that point they might apply or
13 expand it to cover those types of things, if they need
14 to. Okay?

15 MR. KOBELAK: Hey, John, this is Jeff. I
16 apologize. If you don't mind me jumping in for one
17 second?

18 MR. LEHNING: Please.

19 MR. KOBELAK: I think you characterized it
20 accurately, and the only other maybe example would be
21 Urbia. That's a burnable absorber that we've used in
22 the past that would be excluded here because we just
23 didn't look at it as part of the incremental burnup
24 extension.

25 MR. LEHNING: I appreciate that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And on to slide 25, Kevin.

2 MR. HELLER: All right. So, this is Kevin
3 again with the staff. Thanks, John.

4 So, for limitations and conditions, the
5 NRC staff's Draft Safety Evaluation contains 14
6 limitations and conditions that licensees adopting the
7 methodology need to address. Incorporated within that
8 list are nine limitations and conditions that were
9 actually initially proposed by Westinghouse.

10 One or two of them modified -- well,
11 actually, several I see listed here, yes, were
12 modified by the NRC staff during the course of the
13 review. So, the essence of their origin would be
14 Westinghouse imposed in nature, but modified during
15 the course by the staff.

16 The eight limitations and conditions that
17 have been noted in the foregoing presentation, we've
18 alluded to those. Some aspects we haven't been able
19 to speak to because of the proprietary nature of them.
20 And so, we will touch on those aspects in the closed
21 portion, and then, also, the remaining six limitations
22 and conditions that we haven't really discussed will
23 also be discussed in the closed.

24 MEMBER MARCH-LEUBA: From the presentation
25 point of view, when I hear you say it has 14

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 limitations, I say, well, the methodology must be bad.
2 But, in reality, the first nine are just you are
3 agreeing with the methodology. I mean, we should
4 start considering agreeing with the methodology is not
5 a limitation, and it sounds much better to have only
6 six, not 14, but from the bounding perspective.

7 CHAIR BALLINGER: I look at these kinds of
8 limitations and conditions as, basically,
9 administrative rules, something.

10 MEMBER KIRCHNER: These are they are
11 limiting it to their product. I can agree with Jose's
12 comment, though, in general. Yes, it makes it sound
13 like there's a lot more issue at play than really is,
14 in fact, the case. You're just saying, okay,
15 Westinghouse is only proposing it for these different
16 cladding types, this fuel type, et cetera. And you're
17 agreeing with them, but, as Jose indicates, it sounds
18 --

19 MR. LEHNING: Yes, I mean, I think at some
20 points in the past vendors had been encouraged to
21 maybe try to identify certain things that could be
22 limitations and conditions to get out in front of what
23 the staff might impose. So, that might be what's
24 behind it.

25 I agree with the critique that's being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 made there. I would just point out, beyond that, that
2 on a few of those nine that they proposed, we did
3 modify a couple of those just a little bit. But, yes,
4 I think the general sense of the comments being made
5 there are exactly correct.

6 MR. HELLER: All right. So, conclusions
7 then.

8 So, the staff found that the incremental
9 burnup methodology presented in WCAP-18446 provides an
10 acceptable approach for comprehensively evaluating
11 fuel operation within the requested incremental
12 burnup, the extended burnup range.

13 It was addressing fuel assembly mechanical
14 design, core and fuel rod performance, non-LOCA and
15 LOCA safety analyses, and the radiological
16 consequences.

17 The staff's conclusions are predicated
18 upon the methodology being used within its approved
19 range of applicability and licensees acceptably
20 addressing limitations and conditions within Section
21 4 of the staff's Safety Evaluation.

22 And with that, I think we're done. If
23 there are any questions?

24 MEMBER MARTIN: I guess, for the sake of
25 the public record, a simple question -- maybe.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Obviously, Westinghouse has leveraged a lot of the
2 work they've done in the past in all these areas. You
3 know, the elephant in the room is FFRD -- emphasis on
4 the "D".

5 With the submittal, did Westinghouse
6 provide analyses unique to these sort of methodologies
7 that you would not have necessarily seen before to
8 specifically address dispersal, maybe even define
9 their own acceptance criteria, or what have you --
10 something that sets it apart from things you've seen
11 before and have approved before?

12 MR. LEHNING: I think just in the open
13 session what we might say is that they attempted to
14 address that dispersal issue by, I would say, the easy
15 way, and on the slide here we point to preventing
16 cladding rupture. And so, that's something that's
17 pretty well understood. As you alluded to, there are
18 maybe some differences, as we note on this slide,
19 where they attempted to account for the potential for
20 increased burnup to affect that. But that's more of
21 this evolutionary change to existing models and not
22 trying to, or having to, needing to address some of
23 the more novel aspects of what happens outside of the
24 --

25 MEMBER MARTIN: A lot of that to prevent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cladding rupture. That's been their focus --

2 MR. LEHNING: Correct.

3 MEMBER MARTIN: -- and their lead
4 argument.

5 MR. LEHNING: Correct.

6 CHAIR BALLINGER: Okay. Other questions
7 from the members?

8 Okay. Now, we had originally scheduled
9 that the non-concurrence discussion would occur now.
10 That was because we got the slides for this late,
11 actually, yesterday or the day before, evening, or
12 something like that. And they were non-proprietary.
13 So, we said, okay, let's just do the non-proprietary
14 part all first.

15 But my question to the staff and to
16 Westinghouse is, based on what we've heard so far,
17 should we hear the proprietary session first before
18 the non-concurrence presentation because we think that
19 knowledge from those presentations would be
20 appropriate for the discussion of the non-concurrence?
21 And I don't know the answer to that. So, I'm asking
22 the staff and Westinghouse whether or not the
23 schedule, as written, just do the non-concurrence
24 discussion. It should be done now? Or would it be
25 more profitable to wait until after the closed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 session?

2 MR. LEHNING: From the staff side, I think
3 it might be beneficial to get the benefit of the
4 closed presentations first, if the Subcommittee agrees
5 to that.

6 CHAIR BALLINGER: Well, since you're the
7 authors of the darn thing -- (laughter) -- at least
8 two of you are --

9 MEMBER MARCH-LEUBA: To the extent that we
10 will have set a time for the public to rejoin us --

11 CHAIR BALLINGER: Right. And we have to
12 decide a few things first. Okay.

13 If we've decided that it's best to have
14 the non-concurrence presentation after the closed
15 session, then, now we have to arrange this. And that
16 means that -- I don't know; Larry can correct me -- we
17 need now to have two public comments because the non-
18 concurrence presentation will be afterwards. Is that
19 correct?

20 MR. BURKHART: Oh, I think if anybody
21 wants to make a -- you can call for public comment
22 now.

23 CHAIR BALLINGER: We're going to do it now
24 then, but --

25 MR. BURKHART: But, yes, and then, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 should set a time, as Jose says, when we can come back
2 to the public session. And then, if the public wants
3 to make comments after that, we can do that, too.

4 CHAIR BALLINGER: And then, the next
5 question is, when do we want to do the read-in?

6 MR. BURKHART: The read-in of what?

7 CHAIR BALLINGER: Harold Scott's --

8 MR. BURKHART: We can do that, we can do
9 that at this one.

10 CHAIR BALLINGER: We can do that now?

11 MR. BURKHART: Yes.

12 CHAIR BALLINGER: Okay. There is a member
13 of the public that would like us -- that sent us a
14 copy, that would like that to be read into the record.
15 And Zena will do that reading now.

16 Are you ready, Zena?

17 MR. BURKHART: Zena, we can't hear you.
18 This is Larry Burkhart.

19 CHAIR BALLINGER: Well, life intervenes,
20 I guess.

21 MR. BURKHART: Well, I did notice that Mr.
22 Scott -- this is Larry Burkhart -- Mr. Scott I believe
23 is on, in case he would want to provide a comment.

24 MR. SCOTT: I could try to read part of
25 it. Can you hear me? Can you hear me?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. BURKHART: Yes, sir. Please go ahead.

2 MR. SCOTT: Okay. It will take me a
3 minute to get ready. Can anybody else speak or do
4 something else right now? And then, I'll be ready to
5 talk.

6 Can you hear me okay?

7 MR. BURKHART: We can hear you, yes.

8 CHAIR BALLINGER: Why don't we go out,
9 first, while he's getting ready or until we find Zena,
10 to other public comments?

11 Are there members of the public now that
12 would like to make a comment? If there are, please
13 state your name and make your comment.

14 Okay. We haven't heard any public
15 comments.

16 Zena, are you on the line?

17 Harold, are you ready?

18 MR. SCOTT: Sorry.

19 MS. ABDULLAHI: Okay. Can you hear me
20 now?

21 CHAIR BALLINGER: Oh, there's Zena. Okay.

22 MS. ABDULLAHI: Yes, I am here.

23 CHAIR BALLINGER: Okay. All right, Zena,
24 why don't you read in Harold's comment?

25 MS. ABDULLAHI: Okay. Give me a second to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 locate it.

2 Excuse me. I --

3 (Pause.)

4 MR. SCOTT: Well --

5 MS. ABDULLAHI: I'm getting to it. I'm
6 sorry.

7 MR. SCOTT: Can I go ahead while she's --
8 can you hear me okay?

9 CHAIR BALLINGER: We should only have one
10 person talking at once.

11 MS. ABDULLAHI: Well, Harold can go ahead
12 while I find it. I sent it to Larry and I'm trying to
13 find it now.

14 MR. BURKHART: Okay. So this is Larry
15 Burkhart. So Harold's on the line.

16 MS. ABDULLAHI: Okay. Got it.

17 MR. BURKHART: He's providing a comment.
18 Mr. Scott, please go ahead.

19 MR. SCOTT: Another alternative approach
20 in a nonconcurrency document, ML No. -- could have
21 been to recognize the Dr. Mara petition -- that's PRM-
22 50-124, as a basis for setting regulatory limits
23 within existing regulations.

24 Now this is in red caps. Choose number of
25 allowable rods bursting rather than amount of fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 dispersal. Recall that 2,200 peak clad temperature
2 and 70 percent equipment clad reactors are now known
3 to be wrong. Not exact I should say. That means
4 allowable burst rods does not need to be rigorous.
5 And best estimate plus uncertainty should not have a
6 place for un-allocated perception of conservatism.

7 CHAIR BALLINGER: That's a lot shorter
8 than the one that was supposed to be read in, but I
9 guess we're okay.

10 MR. SCOTT: Well, we were just going to
11 read that one sentence. The rest of it people can
12 read if they have the whole email. Or it might be
13 posted in the transcript.

14 MS. ABDULLAHI: It will be posted in the
15 transcript.

16 CHAIR BALLINGER: Is that satisfactory?
17 Harold, is that satisfactory?

18 MR. SCOTT: Yes, yes, yes, yes.

19 CHAIR BALLINGER: Okay.

20 MR. SCOTT: Yes.

21 CHAIR BALLINGER: All right. Sorry for
22 the confusion and the like. So we've had no -- we
23 have no -- nobody in the public wants to make a
24 comment. So now we need to recess for I would say 10
25 minutes while we rearrange things and ensure that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 room is suitability set up for the closed session. So
2 we're in recess and --

3 MEMBER MARCH-LEUBA: Should the public be
4 back into this line say at 4:00, let them know if
5 we're -- we're late?

6 CHAIR BALLINGER: Good question.

7 MEMBER MARCH-LEUBA: It's two hours from
8 now. If we're done, we join them. If not, we send
9 somebody to tell them to wait.

10 CHAIR BALLINGER: The nonconcurrence was
11 going to be -- we were going to allow a little bit
12 more time, so that would be --

13 (Simultaneous speaking.)

14 MEMBER MARCH-LEUBA: -- Westinghouse and
15 staff closed session, we have it scheduled for two
16 hours?

17 CHAIR BALLINGER: Yes, two hours.

18 MEMBER MARCH-LEUBA: So I would -- I will
19 move that we tell the public to come back to this open
20 line at 4:00.

21 CHAIR BALLINGER: Okay.

22 MEMBER MARCH-LEUBA: That's roughly two
23 hours. If we are late, somebody will let them know
24 that --

25 CHAIR BALLINGER: Yes. Can we do that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Larry?

2 Okay. So we're going to recess until
3 2:09. Call it 2:15 or thereabouts. And we'll ask
4 that -- huh?

5 PARTICIPANT: 4:15.

6 CHAIR BALLINGER: No, no. We're going --

7 PARTICIPANT: We'll recess until.

8 CHAIR BALLINGER: We're going into closed
9 session now. So we're going to recess from --

10 MEMBER BIER: Oh, I see what you're
11 saying. Yes, thank you.

12 CHAIR BALLINGER: So now it's from 2:10 to
13 2:20 on that clock while we set up for the closed
14 session. And we'll remind that the public --
15 hopefully we'll be back in session, open session at
16 4:00. For the open session.

17 (Whereupon, the above-entitled matter went
18 off the record at 2:10 p.m. and resumed at 5:00 p.m.)

19 CHAIR BALLINGER: Okay. Are we all ready
20 to go? Okay.

21 MR. LEHNING: So this is John Lehning and
22 Kevin Heller, so comment presenting as individual
23 staff at this point. And in the interest of time
24 we're going to go through the slides quickly and maybe
25 cut out some of the material.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And the other thing I would just say
2 before we start there is some related different topics
3 currently with other ongoing processes such as
4 rulemakings or petitions or the PIRT. We may not be
5 able to address all the questions, but ask us and stop
6 us as you have questions and we'll do our best to
7 answer them.

8 CHAIR BALLINGER: I think the important
9 thing is to focus on the punch line.

10 MR. LEHNING: Sure. So the punch line
11 here, the summary of nonconcurrence 2, technical staff
12 who did the review of this topical report were unable
13 to concur because of conclusions regarding fuel
14 dispersal. And that was just a narrow part of the
15 topical report of this wide variety of things that
16 were looked at.

17 And the original safety evaluation that
18 the staff had drafted included a limitation and
19 condition requiring licensees implementing the method
20 to assess the potential for fuel rod -- fuel dispersal
21 from rods with less than 62 gigawatt days per metric
22 ton uranium rod average burnup. And then justify that
23 that amount of dispersal would not result in non-
24 compliance with the 5046 acceptance criteria.

25 That limitation and condition was removed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 by the agency management and without that limitation
2 or some alternative to it that would be acceptable the
3 nonconcurring staff concluded that we wouldn't be able
4 to determine that plants implementing the method would
5 comply with the regulatory requirements. And based on
6 a connection I'll explain in the presentation that --
7 we couldn't conclude that public health and safety
8 would be adequately protected.

9 So I'll skip over, but just for the record
10 here's some information about us. And again we're
11 just speaking for ourselves.

12 We wanted to just give a little bit of
13 background here. This isn't the focus of the
14 nonconcurrency. It's on this just specific topical
15 report, but I think this background is a little bit
16 needing to be understood, at least at some level
17 because they have these big generic things that
18 somehow have impacted this very particular review.
19 And understanding why that is I think is important.

20 And so we start off with a really key
21 question: Is there a valid safety question associated
22 with fuel dispersal? And this is one where the safety
23 evaluation that was modified and the nonconcurring
24 staff disagreed because the safety evaluation that was
25 modified states that fuel dispersal is not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 significant safety issue within current burnup limits,
2 but from the nonconcurring staff's point of view
3 there's not a clear basis for that whereas when we
4 look at some pieces of evidence available to us -- and
5 I'll just skim over really quickly -- we see at least
6 a question about whether this could be an issue that
7 could impact compliance.

8 And the first piece of evidence here is a
9 TopFuel paper from 2014. And this looked at a couple
10 of different plant scenarios for burnups consistent
11 with the current burnup range and it found that it
12 could be -- and again this study was corrected from
13 the original paper, but it found that there could be
14 up to 200 kilograms of dispersed fuel at end of cycle
15 for this particular case that was looked at. And
16 again that's not treated in the safety analysis for
17 plants at this time. So at least there's a question
18 there about that.

19 When we look at the RIL that we've talked
20 about a few times that summarizes research about
21 fragmentation, relocation, and dispersal, we can see
22 that this pellet average burnup -- and we talked about
23 again that this is pellet average and not rod average.
24 And so it could be potentially 20, 25 percent of the
25 fuel cycle where we could see rods in the operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor core that are above this type of a threshold.
2 And again this not saying again there's a problem, but
3 at least it poses the question for these plants of
4 whether there is a dispersal issue there or not.

5 And the third item here is a paper from
6 last year that was done for a high burnup core. So
7 it's not necessarily characteristic of the operating
8 burnup range. Okay? But still it gives some data
9 point that if the models in the RIL 2021-13 were used
10 here -- and again the authors of the paper believe
11 that the lower value is probably more realistic. This
12 high one may be overconservative.

13 And I think there's an error on the slide
14 that we gave you here. We'll give you the corrected
15 slides here after the meeting, but that if we look at
16 again a 100 tons of uranium dioxide in the core, that
17 could be something between half and four tons of fuel.
18 Again, maybe gearing more toward the lower estimate
19 that's less conservative. And again that's high-
20 burnup, but one could ask is there a fraction of that
21 that might occur for the current burnup range?

22 And so that leads us to the key contention
23 here in the nonconcurrency: Is it possible to
24 conclude with a high level of probability that
25 coolable geometry requirement is satisfied and as well

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as some other requirements when there's no clear
2 safety analysis that's done for what may be hundreds
3 of kilograms or hundreds of pounds of fuel.

4 And so the nonconcurrency says that this
5 is a well-founded safety question. It's not an
6 assertion that there is a non-compliance or that
7 plants need to take corrective actions, but those are
8 things that should be figured out using existing
9 agency processes and that those questions should be
10 answered perhaps prior to making more fuel burnup
11 increases that could exacerbate the issue.

12 So again I've made comments about the
13 safety basis for plants. Where is that? That's in
14 the FSAR, Final Safety Analysis Reports. There's a
15 chapter there on LOCA. The staff reviews those
16 things, reviews the evaluation models as well to do
17 those calculations.

18 And so do those existing calculations
19 address fuel dispersal and its impacts? The answer to
20 that is no, as I've already explained. And the safety
21 evaluation that was modified -- it talks about the
22 need for even -- or assemblies within current burnup
23 limits to satisfy regulatory requirements, but it has
24 -- the last sentence maybe in the one where the
25 nonconcurrent staff would focus on here that licensees

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 may continue to use their currently approved
2 methodologies for this burnup range of the currently
3 licensed burnup range. However, as I've just pointed
4 out, those methods, they don't include fuel dispersal
5 in their evaluation models. The analyses don't
6 include them. So can we get any confidence out of
7 that by just relying on those methods that don't
8 include the phenomena is the question.

9 MEMBER PETTI: So just a question. You
10 really have a concern with fuel rods even below 62.
11 So you know, licensee comes in with old methods.
12 Right now there's nothing in any of the rules that say
13 they can't just continue to do their usual reload
14 license amendment, right? And this still exists.
15 That's the --

16 MR. LEHNING: Right. And the limitation
17 and condition we were talking about wouldn't have
18 solve that, but one of the alternatives we talked
19 about was a backfit evaluation for the fleet of
20 plants. And that would have gone to that question and
21 settled it, whether that's acceptable because it's not
22 cost-beneficial or what have you, but at least it
23 would settle the problem. But that's a correct
24 statement that you made.

25 And so in the end the safety evaluation as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 modified, it doesn't make a finding about compliance
2 of currently operating reactors with the regulations.
3 The nonconcurrence believes that kind of demonstration
4 is necessary and presses the point that we would need
5 to take some action to make that determination because
6 the existing safety analyses don't address that issue
7 of dispersal. And so again this is just a safety
8 question that should be resolved from the staff's
9 point of view of nonconcurrence.

10 MEMBER HALNON: John, on the coolable
11 geometry, I mean we don't know what one looks like,
12 but we know what one is the result of. We can keep it
13 cool. Didn't we learn a lot from TMI meltdown that
14 coolable geometries, one, will come in a lot of
15 different configurations; and two, that was coolable
16 given a lot of dispersion and relocation on a
17 fragmentation? We had both melting and chattering.
18 Doesn't it give you any pause to say, well, maybe it's
19 not as crucial as what we're saying here and that
20 we're probably okay in this space?

21 MR. LEHNING: If I could address that on
22 a few more slides, I think -- I'll show some pictures
23 when we get to the pictures. I think I'd like to
24 respond to that then. But I understand the question.

25 MEMBER HALNON: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. HELLER: So, John, if you could go
2 back one slide. I'm not sure that you covered -- or
3 at least reasserted. It's that last bullet point. I
4 think that's important. The nonconcurrency does not
5 give us (audio interference) that licensees are
6 definitively out of compliance with the applicable
7 regulations. Rather, it advocates that a well-founded
8 safety question concerning fuel dispersal should be
9 resolved.

10 MR. LEHNING: Correct. Yes.

11 CHAIR BALLINGER: Will this likely be
12 resolved by the rulemaking?

13 MR. LEHNING: Well, we'll kind of talk to
14 that a little bit, too. I think we didn't want to
15 rely on that, just a punch line real quick. It could
16 be, but we don't know for sure. And again it's the
17 timeline and what's going to be the content of that
18 rulemaking. It's not clear at this point.

19 CHAIR BALLINGER: And respect to the
20 coolable geometry part, I read all of the papers and
21 stuff, and if somebody says there's 200 tons of fuel
22 that's dispersed, that doesn't mean the core is not
23 cool. That just means you've got fuel particles and
24 stuff circulating around the system. And believe it
25 or not, a main cold pump is designed to pump core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 barrel bolts. So it will pump that stuff.

2 MR. LEHNING: There might --

3 CHAIR BALLINGER: That to me was a problem
4 with those papers. It was like crying wolf a little
5 bit.

6 MR. LEHNING: Well, I guess we'll get to
7 that, but I guess if there's 200 tons of fuel
8 dispersed, then there's probably not a core left. So
9 there may be a fragment --

10 MEMBER PETTI: You're (audio interference)
11 200 KGs, not 200 tons.

12 MR. LEHNING: Okay. So sorry about that.
13 So I'll go onto this line, if that's -- yes. I'll go
14 onto just these slides in the interest of time.

15 And so I think why has there been a
16 challenge with figuring out whether plants are in
17 compliance? It's because there are large
18 uncertainties in determining the physical phenomena.
19 So how much fuel disperses? Could it be tens of
20 pounds, hundreds? Could it even be in the thousands?
21 Possibly. So that uncertainty may span a few decades
22 of different values.

23 And then also there's a question here
24 about what the regulatory acceptance criteria would
25 be. And I've heard some comments that -- from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 members here that that sort of go to some of the
2 discussions that maybe staff might have here. And so
3 there's -- these two things together have made this a
4 little bit difficult. And I'll touch more on this in
5 a minute.

6 And so as far as what these uncertainties
7 are, the staff is taking action. The agency is taking
8 action to try to allay these uncertainties. We're
9 continuing, as we have been, sponsoring research on
10 fuel dispersal which may eventually give -- put us in
11 a place where we can make more precise estimates. And
12 we're also developing calculational methods, as in
13 some of the papers we just referenced, that would help
14 us do those calculations. But even lacks of data and
15 such make it hard to validate those models.

16 And so I think we're a far cry from
17 licensing basis methods that might satisfy this MDAP
18 that I've referenced here from Reg Guide 1.203 in
19 terms of validation at different scales and integral
20 scales and so forth. And that sort of is captured in
21 these uncertainties and these values from some of
22 these journal papers.

23 And so we come back now to this question
24 of how much fuel dispersal would be acceptable. And
25 I would argue that there's not a clear position on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that because when we look back to maybe when the
2 original rule was issued, we're going to argue that
3 maybe the threshold was a pretty low threshold. But
4 if the agency continued to have that perspective, I
5 don't think there would have been an objection to the
6 limitation and condition. I think that would have
7 been, oh, if it's nearly -- it's very little that's
8 dispersed --

9 (Audio interference.)

10 CHAIR BALLINGER: I have no idea what's
11 going on.

12 PARTICIPANT: Cybersecurity issues.

13 CHAIR BALLINGER: It's no one of you guys,
14 so keep going.

15 MR. LEHNING: Okay. And so the specific
16 intent of that regulation is important. And so when
17 we consider the historical basis, the thing the staff
18 keeps in mind is that we have the delegated authority
19 to do routine matters, but we can't reinterpret or
20 change regulations. That has to go through the
21 Commission and our public process. And so whatever
22 that regulation meant when it was issued, in the
23 staff's mind here -- again we're not lawyers, but this
24 is our best understanding of what we've been told,
25 that's the meaning of that regulation. So that sets

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the table for this discussion.

2 And we pulled this picture. It may have
3 been pulled from a member's LinkedIn blog here that
4 goes through a lot of great information there, so just
5 noting that.

6 But the Commission, they spoke about what
7 was the purpose of the peak cladding temperature of
8 2,200 and 17 percent local oxidation? So the purpose
9 of these criteria was to ensure that the cladding
10 would remain sufficiently attached to retain the UO2
11 fuel in an easily coolable array. And so when we
12 think about that, that's not a coolable pile
13 necessarily, but -- and the Commission then
14 acknowledged that conservative calculations would --
15 could lead to rupture of fuel rods, but as long as
16 there wasn't too much oxidation, even when the re-
17 flood occurred, there would not be this brittle
18 failure of the entire rod and there would still be an
19 ability to retain uranium dioxide fuel pellets.

20 And so what does that look like? So even
21 if we get these ruptures we end up with a state where
22 we don't have a lot of dispersal for what these two
23 criteria are trying to accomplish here for -- at the
24 hottest node or the hottest rod we're avoiding the
25 failure of this cladding such that we disperse a bunch

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of pellets. That's the intent at least of these two
2 criteria from the Commission.

3 Now if we want to look at what did the
4 Commission want to avoid, there are some words about
5 that, too. They wanted to avoid this large mass with
6 insufficient external area that wouldn't be able to
7 remove heat. And there's this interim state about
8 uranium dioxide fuel pellets falling together into a
9 heap that would be difficult to cool. So that's the
10 thing they didn't want to have happen.

11 And so if we drew a picture of that, what
12 that might look like, the failure of the ECCS. So
13 there's no water in here. The core is gone in this
14 picture. Again it's an idealization just as the
15 previous picture was. And we have this big pile of
16 pellets. It hasn't all fused together yet in this
17 diagram. But that's what the Commission stated that
18 they wanted to avoid by this regulation.

19 And so now let's consider what does the
20 picture look like with fuel dispersal per this
21 fragmentation mechanism? I mean we see a picture
22 that's not exactly either of those two. It's
23 somewhere I would say in between where we have maybe
24 some very fine particulate here and maybe some of this
25 could escape from the vessel at some point, but we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 still have a core that's intact here. So this isn't
2 quite what we see with the criteria for peak cladding
3 temperature and local oxidation, what that would
4 ensure, but neither is it the core is completely lost
5 and gone.

6 And so the staff's concern or the position
7 that the staff was put in here was to try to basically
8 say whether or not this middle case is acceptable,
9 whether that meets the rule. And it's difficult for
10 us to do that again based on our understanding of what
11 the rule as it was issued meant and what the
12 Commission was trying to accomplish. They wanted to
13 put quite a bit of margin between the regulatory
14 acceptance criteria and the point of failure.

15 And so again whether this middle picture
16 does that or not, it's probably not the role of two
17 working-level staff to figure that out. It probably
18 needs some higher authority to do that. And we didn't
19 want to concur here in part because we didn't feel
20 like we have the ability to say that this middle
21 picture meets this regulation that the Commission when
22 it -- when sort of this picture looks like this left
23 side of the graph. And so we left this sort of as
24 again a safety question that does this meet the
25 regulation or not? That needs to be solved in some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 more comprehensive way. We need to come up with
2 criteria. We don't have acceptance criteria for how
3 much or whatever this is. And so this makes it
4 difficult to make regulatory decisions at the staff
5 level.

6 MEMBER HALNON: So when we were going
7 through the GSI-191 stuff, I mean that took what, a
8 decade-and-a-half to work out, we still approved
9 uprates and we still approved containment
10 modifications and we still approved many license
11 amendments that had to deal with inside containment
12 knowing that as we went through this you would
13 minimize your fiber, you would minimize your paint
14 chips, you would minimize all the stuff that could
15 block -- cause blockage. But we still didn't have a
16 definitive are you in compliance because we didn't
17 have all the testing done with the fiber and the fuel
18 assemblies and whatnot.

19 How is this different that we -- are we
20 going to hold up all approvals of anything on fuel
21 because we don't necessarily think -- I mean, that's
22 a bad generalization. Are we going to hold this up
23 because we don't have enough test data to show
24 definitely that we have -- or we're taking actions to
25 be conservative and make sure that we're at least not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 making it worse?

2 MR. LEHNING: So for GSI-191, I worked on
3 that issue for quite a while, and the thing I would
4 say there is those plants started out with very small
5 sump strainers. It could have been on the tens of
6 square foot, into the hundreds maybe. And so before
7 2008 they had all pretty much replaced these with
8 thousand square foot strainers. And so they had a
9 great argument. Hey, we're a lot better off than we
10 were. We've made the plant a whole lot better, a
11 whole lot safer in this overall sense.

12 And just to give a counter example, so
13 when we think about leak before break, my
14 understanding is that there were times when approvals
15 for that were paused. For example, pressurized water
16 stress corrosion cracking. So there have been times
17 where we said we don't understand yet this issue and
18 we need to get to work hard and solve it and then
19 we'll continue on. And so again it's not for us here,
20 the staff, to say that --

21 MEMBER HALNON: Okay.

22 MR. LEHNING: -- say what needs to happen.

23 MEMBER HALNON: No, that's fair.

24 MR. LEHNING: I would advocate that it
25 probably wouldn't take that long to do at least some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 backfit evaluation or some evaluation of it at least
2 to current knowledge. It may not be the best and most
3 perfect thing, but at least something to say here's
4 our position on this.

5 MEMBER HALNON: Okay. No, that's fair.
6 I appreciate that.

7 CHAIR BALLINGER: Let's use another
8 analogy though. Let's say we discover this problem,
9 which we have. And Appendix K was a long time ago.
10 I didn't see the date on the picture, but it was a
11 long time ago. But since that time the technology and
12 the operational procedures, the inspection techniques,
13 all of that stuff has improved orders of magnitude.
14 So the likelihood of having an event occur where this
15 would be an issue has had to have decreased greatly
16 between now -- between then and now. In other words,
17 talk about ALS. So how is that a similar analogy?

18 MR. LEHNING: So should the Commission
19 decide to pursue a pathway where the regulation -- it
20 becomes instead of postulate breaks up to and
21 including this double-ended guillotine break -- so
22 maybe it would allow some option like that to be used.
23 And that would be the new yardstick that the staff
24 would use to judge against. But as of right now the
25 way the regulation reads -- and again there's some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 question about what might or might not need to be done
2 to make ALS work per the regulations, but whatever
3 that regulation would change to the staff would then
4 regulate, too.

5 But in terms of Appendix K to now, it's
6 true that a lot of conservatisms were in that method.
7 Some of them have been taken advantage of with more
8 best estimate methods. And certainly the estimations
9 of break frequency and so forth are a lot more refined
10 and some of those are on the table for this regulatory
11 basis. And they may lead to rule changes just like
12 what you're saying, but for the time being staff is
13 only able to I think regulate to the rules that are on
14 the books right now.

15 MR. BURKHART: Ron, may I suggest that
16 instead of drawing analogies to other issues, in light
17 of the time, that we hear out the two staff members
18 here hopefully in the next 10 minutes? And then we're
19 going to hear from their management on why it's okay
20 -- why they think it's okay to go ahead with this
21 action, which is documented in the safety evaluation.
22 We do have limited time and we need to hear from Scott
23 Krepel after them.

24 MEMBER HALNON: Yes, Scott's only got six
25 slides, so we're going to through those quickly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. LEHNING: Okay.

2 MEMBER HALNON: But back to the TMI. Go
3 back one picture. I mean, that middle picture is TMI.
4 You have a random relocation, some chattering, some --
5 however you want to put a word picture of array, or
6 that word that you -- that they used back in 1950-
7 something. That is TMI.

8 And my point was is that even with that we
9 showed that there's a -- it was a coolable geometry.
10 And not a nice -- it was ugly, no doubt, but it was
11 cool. And there was relocation throughout the RCS
12 including piles on top of the seismic gap. And that
13 was coolable and it went sub-critical and everything
14 else.

15 So it's not that it makes it okay or in
16 compliance, but does it -- it gives us at least a
17 level of certainty that that random relocation and
18 melting and core configuration was coolable.

19 MR. LEHNING: Yes, and I wouldn't argue
20 with that, but the counter that I will give back to
21 you is that I think that's a good argument for why do
22 we need PCT at 2,200 and local oxidation at 17
23 percent? We know that if we just completely -- I mean
24 melt two-thirds of the core, let's say, we're still
25 coolable. And if that's where we want to go with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 rulemakings or things like that, that could be done,
2 but --

3 MEMBER HALNON: I wasn't trying to say
4 that was an acceptable thing. I'm just trying to give
5 us a level of confidence that we're not making a
6 safety issue to the point where it's going to be a
7 public health and safety --

8 (Simultaneous speaking.)

9 MR. LEHNING: Yes, and I get that. And I
10 guess the thing that I think we're trying to say here
11 is that there ought be a consistency. So if on the
12 one hand we're going to say in this left-hand picture
13 we're going to regulate peak cladding temperature and
14 local oxidation to the point where even on the hottest
15 node, the hottest rod we're not going to release
16 pellets and we're going to keep the vessel looking
17 like this on the inside, why would we need to do that
18 if this middle picture is acceptable? And there may
19 be reasons why, but it's not obvious. And perhaps
20 this is something that people high in the agency ought
21 to make their opinions known on and go forward with
22 based on where we are at least at this point. That's
23 all we're advocating here --

24 MEMBER HALNON: Okay.

25 MR. LEHNING: -- not trying to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: No, I get it.

2 MR. LEHNING: -- argue your point --

3 MEMBER HALNON: No, I get it.

4 MR. LEHNING: -- because I think you have
5 a good point.

6 I'll try to just wrap up a little bit
7 quickly. I'll skip over a little bit. I mean this
8 point was on regulatory compliance, and regulatory
9 compliance is the basis for in general the public
10 health and safety being protected.

11 And this past history I'll skip over, but
12 this issue was brought up as a generic issue before.
13 It wasn't resolved there. And the staff did try to
14 look at getting a more general resolution of the
15 issue, but it didn't work out with the process the
16 agency was in at that time.

17 And this question goes to sort of the
18 resolution schedule and we know that increased
19 enrichment and high burnups, some of these efforts are
20 under way to finish or to start being implemented by
21 2027. And so again this is a question of whether we
22 should maybe in a similar sense trying to get our arms
23 around this operating reactor dispersal question on a
24 similar time scale. But we don't know that there are
25 activities defined to do that at this point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So I'll just go through -- I'll skip over
2 I think the alternative discussion in general, but let
3 me just go through a few more slides here. I'll try
4 to wrap up in about -- within 10 minutes. Is that
5 enough time? Or five minutes? What do you guys
6 think?

7 MEMBER MARCH-LEUBA: Five? Two for five
8 minutes.

9 MR. LEHNING: Five minutes? Okay. So
10 I'll wrap up on five minutes. And so again there are
11 policy issues here. We're not trying to set the
12 policy, but they influenced our decision. And the
13 point here is that the safety evaluation wouldn't as
14 it stands ensure compliance with regulatory
15 requirements.

16 And let me skip over this slide, but I
17 think that I'll just make a mention here. So why are
18 we concerned? I think even if there's not an increase
19 predicted in dispersal for these higher increased
20 burnup cores, well the last time we increased burnup
21 there were a couple of issues that we didn't recognize
22 at the time, and one of them obviously was this
23 dispersal issue itself. We didn't recognize that, nor
24 did we recognize this thermal conductivity degradation
25 issue, TCD. And so these issues take a long time to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 resolve. Based on when we're starting from an in-
2 compliance state, we have the time and space needed do
3 to that. But if we don't, then do we still have the
4 ability to really take our time, take the time needed
5 to address the issues?

6 And so this takes us to where I think I
7 just have -- I'll just go over three more slides then,
8 and these will be the sort of punch line that we'll
9 end with.

10 So how can the NRC address emergent safety
11 questions? And there are two ways that -- in general
12 that we might use. One would be voluntary forward-
13 looking licensing basis changes. And the other would
14 be mandatory backfits. And let me just explain what
15 those are.

16 So for the voluntary forward-looking
17 change, when an applicant agrees to -- that basically
18 occurs when an applicant has some application from the
19 staff. They want to get permission to do something.
20 And as a condition for basically being able to do that
21 they implement some measure that might be a safety
22 improvement. For example, this incorporation of PAD-5
23 could be one example.

24 And so this would only be effective for
25 licensees that voluntarily implement the topical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 report, but on the other hand it's a lot easier to do
2 this. There's a burden of proof on the applicant not
3 on the staff like in the backfit case like we'll
4 explain. And so this is often the way that is used to
5 accomplish these types of things in practice because
6 of the backfit approach being difficult to implement.

7 But there is -- obviously per 10 CFR
8 50.109 the NRC has statutory authority to require
9 corrective actions under certain conditions on us.
10 And this type of corrective action could be
11 implemented on all operating plants irrespective of
12 whether they implement this topical report, but the
13 burden of proof would be on the staff. And so in the
14 case of regulatory compliance there's also adequate
15 protection and other ways to go about it, but in the
16 case of compliance, which we're focused on here, not
17 only would there be a need to demonstrate that this
18 action is necessary for compliance, but there would
19 also be a cost-benefit justification.

20 And the staff, who nonconcurrent, believe
21 that such an evaluation would be appropriate because
22 of the importance of core coolability to reactor
23 safety and this would give us a valid rationale for
24 either an action we take or inaction, that we don't
25 need to do anything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And actually let me just do the conclusion
2 slide. I'll skip over all of the alternatives we
3 discussed with management. We had good discussions
4 with them, respectful discussions on a couple of other
5 alternatives. If you want to read those on your own,
6 please do that.

7 But here's the conclusion slide.

8 Two staff, Kevin and myself, have nonconcurred
9 on a modified draft safety evaluation that deals with
10 increased fuel burnups. And specifically on the topic
11 of fuel dispersal was the issue because the staff
12 concluded that we didn't have a basis to say that
13 plants implementing the method would be in compliance
14 with NRC regulations.

15 (Audio interference) agency decisions,
16 again not to criticize them, there are a lot of
17 considerations at stake and I think we made the best
18 decisions we can, as always as an agency, but this led
19 us down the pathway where these generic policy issues
20 have come into play in this very specific review to a
21 level where the staff find it difficult to make this
22 regulatory decision because of the high-level policy-
23 type questions that are involved.

24 And meanwhile, fuel dispersal -- again,
25 this came out of the 1990s, the burnup increases in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the 1990s. So it's been out there all that time. We
2 started to recognize it maybe 20 or so I think years
3 ago. It continues on, in the nonconcurring staff's
4 eyes, as an ongoing safety question, not currently --
5 obviously not in the safety analysis or any operating
6 reactor. If you look at their FSAR, you're not going
7 to find it treated anywhere. The path forward to
8 resolve it again is not clear as we compare -- like we
9 have a clear pathway for going to higher burnup, for
10 instance, but it's not clear how this is going to get
11 resolved. There are some possibilities, but it's not
12 clear how that would be.

13 And so that's the message I think I would
14 leave off on and open for any other questions, if we
15 have time.

16 MEMBER KIRCHNER: John, I have one. For
17 the immediate question, or what's on the table right
18 now, there -- you've outlined the much bigger picture,
19 but for the immediate question that's on the table is
20 this methodology. And that's why I was exploring the
21 direction I was going. One way that the staff in its
22 review could address this concern is some -- and I'm
23 not going to align 100 percent what the Westinghouse
24 proposal, but an approach where you introduce a new
25 figure of merit that's not part of the existing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 regulatory framework. That provides some level of
2 confidence that you avoid the high -- with a high
3 probability you try and avoid the potential for this
4 dispersal.

5 Now you could argue one way to do that is
6 just don't increase the burnup of the fuel, but you
7 could also run the system less hard, so to speak in
8 terms of thermal limits, which then -- because
9 somewhere along the line that contributes to the
10 mechanism that leads to the eventual dispersal.

11 In your opinion do you find that the --
12 obviously we have this nonconcurrence, but is that an
13 approach that they're using -- is that an approach in
14 the interim that could be used to address this bigger
15 open-ended problem of fuel dispersal?

16 MR. LEHNING: An approach like what you
17 suggested, or what -- I think that Westinghouse might
18 have a thought on that and if they want to speak up --
19 I had the feeling that maybe Westinghouse believed
20 that there might not be a ready way to do that and
21 that the penalties that might be incurred from that
22 economically might negate the benefit of the method is
23 sort of the impression I got from them.

24 MEMBER KIRCHNER: Okay.

25 CHAIR BALLINGER: We need to have time for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Scott.

2 MR. LEHNING: Thank you.

3 CHAIR BALLINGER: Thanks again.

4 So where does -- oh, he's going to go up
5 there.

6 MR. KREPEL: Testing. Does this
7 microphone work?

8 PARTICIPANT: Sounds like it does.

9 MR. BLEY: Yes, works great.

10 MR. KREPEL: Okay. Are you ready to share
11 the slides?

12 Hello. Thanks for having me here to
13 present what I call the management perspective, and
14 that's a combined effort from various people including
15 myself, Ben Parks, who did the evaluation for the
16 nonconcurrency. And he is a current senior level
17 advisor in DANU, and I believe he is on listening so
18 he can answer any questions. We also had Vic
19 Cusumano, who approved the nonconcurrency. But I
20 volunteered to provide the briefing on behalf of all
21 the management.

22 So first off, it's pretty simple. From
23 the technical issues raised by the nonconcurrency,
24 they're all valid issues and the nonconcurrency
25 resolution did not dispute any of them. There are a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 lot of documentations, discussion, and so forth, but
2 this is not the basis for how we disposed the
3 nonconcurrency.

4 Next slide, please. For the
5 nonconcurrency from the management perspective there
6 are two critical points. So first is safety
7 significance, which is related to the technical issues
8 themselves and how it impacts the accident
9 consequences. And then the second is the regulatory
10 process issues that link to the regulatory findings
11 within the topical report.

12 Next slide. This is kind of a key slide
13 for my presentation. It talks about the safety
14 concerns. And right now the agency has already put
15 out their position in SECY 2015 associated with
16 50.46(c) rule that says that we do not believe that
17 dispersal is a significant issue at this time. And I
18 understand at that time of 50.46(c) had been hung up
19 for three years while the NRC continued to investigate
20 and there was a lot of work that went into FFRD to get
21 into the conclusions of FFRD, and that was documented
22 within the SECY 2015.

23 After that the NRC continued to do further
24 research that led to the 2021 RIL, but we revisited
25 the conclusions of the SECY and there were no changes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that were made. We still believe that it was not a
2 significant safety concern and it expanded upon why
3 further within the nonconcurrency which had to do with
4 things happening at the end of the cycle. We had
5 conservative estimates and assumptions to figure out
6 how much fuel would disperse. And at the end of the
7 day, even after all of those assumptions, 200
8 kilograms -- that's about two-third cubic feet of fuel
9 material and you can make sand out of that to scatter
10 within a certain area which would be about the size of
11 this table. So it becomes hard for us to think and
12 come up with a very strong technical reason on why we
13 would believe there would be a problem with
14 coolability and so on.

15 We know that we do have some gaps in
16 information and although there are gaps it does not
17 prevent us from making a decision at this point. We
18 still continue to investigate further. We know we
19 have industry interested in going to higher burnups,
20 and so a lot of FFRD related to those issues are still
21 being addressed in some way. We have the PIRT to
22 identify those gaps and what gaps need to be looked
23 at. We have the increased enrichment rulemaking and
24 policy issues based on potential new regulatory
25 frameworks that will be a better fit for FFRD-related

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 things.

2 And I will pause to see if there's any
3 questions before I proceed.

4 Okay. The next slide. This is related to
5 the nexus of the topical report. You have seen
6 several slides during the closed session, and
7 obviously I will not discuss that, but it kind of sets
8 the framework for the Westinghouse methodology in
9 which the basis for acceptability (audio
10 interference). Westinghouse effectively established
11 a separate basis for acceptability of WCAP-184 (audio
12 interference) acceptable within its range (audio
13 interference) gigawatt days per metric ton.

14 Today we've discussed the applicability
15 within the range and the bottom line is that
16 management, NRC management does not view the
17 limitation and condition proposed to the -- by the
18 staff to be within the appropriate scope of this
19 topical report. It is basically out of scope for this
20 specific topical report. And so that is how the
21 regulatory process goes.

22 And last slide. This really just
23 summarizes everything I just said.

24 MEMBER HALNON: Scott, when you laid out
25 your sand and you -- I got it that it's coolable. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think it's also sub-critical?

2 PARTICIPANT: And pumpable.

3 MEMBER HALNON: Well, it's going to be
4 pumpable, but from a neutronics perspective are you
5 still satisfied that that is still not an issue as
6 well?

7 MR. KREPEL: That is my understanding from
8 the discussion that has gone on in the research that
9 has led to that conclusion, yes.

10 MEMBER HALNON: Okay. And then when you
11 say it's out of scope of this effort, it's out of
12 scope because -- I'm going to put words in your mouth
13 -- out of scope because it is not a safety issue or
14 because it's just not covered by this issue? In other
15 words, should it be in scope?

16 MR. KREPEL: So --

17 PARTICIPANT: I would add or should it be
18 in scope (audio interference)?

19 MEMBER HALNON: Yes, or should it be in
20 scope?

21 MR. KREPEL: Yes, you're right. So yes,
22 you are putting words in my mouth.

23 (Laughter.)

24 MR. KREPEL: But yes, we think that this
25 issue should be addressed eventually especially as we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 move to higher burnups, but for this specific topical
2 report, not really.

3 MEMBER HALNON: Okay.

4 MEMBER PETTI: So my sense is there's a --
5 was a fair amount of frustration on the part of the
6 staff. And I read nonconcurrency as, management, get
7 your act together, get this resolved. We got a PIRT.
8 We got a potential rulemaking. Let's get the ducks
9 aligned and get this going. Because the longer you
10 wait -- you don't want this to last as long as GSI-
11 191, for instance. You want a timely resolution. And
12 that may require some more experiments, because I'm
13 not convinced that all the experiments are as relevant
14 as some, which we put in our letter. But that was how
15 I sort of viewed it.

16 MR. KREPEL: Yes, understood. So I will
17 emphasize, as I did before, and I've mentioned this
18 already, you don't need to have all the data to make
19 a regulatory decision. So here some people might
20 disagree on how much data is sufficient. And that's
21 okay. And that's why we're going through this
22 n o n c o n c u r r e n c e p r o c e s s .

23 My staff and I still have a very good
24 relationship and we agree to disagree.

25 All right. That's it for me. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Thank you.

2 MR. KREPEL: Thanks again, everyone.

3 MEMBER MARCH-LEUBA: Comment from the
4 public again?

5 CHAIR BALLINGER: Yes, I'm just asking
6 about more questions from the members first. Any
7 questions from the members?

8 Okay. One last time, who is that?

9 PARTICIPANT: That's Harold Scott.

10 CHAIR BALLINGER: Harold, your forehead
11 looks really nice.

12 So are there members of the public that
13 would like to make a comment? If there are, please
14 state your name and then make your comment.

15 MEMBER HALNON: Just call on Paul, Paul
16 Clifford.

17 CHAIR BALLINGER: Who?

18 MR. CLIFFORD: Yes, hello.

19 CHAIR BALLINGER: Oh, Paul Clifford?

20 MR. CLIFFORD: Yes. Hello, can you hear
21 me?

22 CHAIR BALLINGER: Yes, we can hear you,
23 Paul.

24 MR. CLIFFORD: Okay. Thanks for hearing
25 my comment. You know, as a 20-year veteran of the NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I feel for the staff. There seems to be a reluctance
2 within NRC management to go into the 5109 backfit
3 process. And in the backfit process you can use risk,
4 safety significance, and even cost to evaluate whether
5 new research findings such as fuel fragmentation needs
6 to be backfit onto the industry. But that's not being
7 done.

8 So the staff is faced -- and the industry
9 is in a weird situation. If you're saying that
10 there's any dispersal at all, that's a compliance
11 nightmare. It's difficult to show compliance if
12 there's any dispersed fuel. And the research suggests
13 that there may be under 62. It's not risk
14 significance, but it's compliance significant. And
15 when the staff is evaluating the design-basis
16 evaluation by the industry, they're forced in
17 compliance space.

18 So I feel for the staff. I really do.
19 That's my only comment. Thank you for hearing it.

20 CHAIR BALLINGER: Thank you.

21 Other comments from the public?

22 Hearing none, I think we are --

23 PARTICIPANT: Harold Scott just raised his
24 hand.

25 CHAIR BALLINGER: Huh?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PARTICIPANT: Harold Scott just raised his
2 hand.

3 CHAIR BALLINGER: Oh, Harold?

4 MR. SCOTT: Can you hear?

5 CHAIR BALLINGER: Now, yes.

6 MR. SCOTT: Do I have a second to ask --
7 make an additional comment?

8 CHAIR BALLINGER: Make your comment.

9 MR. SCOTT: Okay. I'm going to read a
10 paragraph from a memo from Myron Wiesenack. I'll give
11 the ML number. By the way, Wiesenack is spelled W-I-
12 E-S-E-N-A-C-K. The ML ADAMS number is ML24024A061.
13 And here's what the paragraph I (audio interference)
14 says:

15 The benefits of such a rule change would
16 be significant. It would resolve the FFRD issue and
17 appropriately put it in a confirmatory role. It would
18 permit burnup extensions beyond the current de facto
19 limit of 62 and it would eliminate the cladding
20 temperature limit of 2,200 F in the balloon and burst
21 regions of the cladding, a temperature that is
22 difficult to estimate, unnecessarily limiting, and
23 could lead to misguided core designs and developmental
24 efforts.

25 So we're looking at the wrong figure of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 merit when we're looking at temperatures. We go to
2 look at the pressure that causes burst. How many rods
3 do you burst? If you limit those, then they -- you do
4 still come back to the -- how much fuel is in the
5 core. Thank you very much.

6 CHAIR BALLINGER: Thank you.

7 I'm not seeing where people are raising
8 their hands. I apologize.

9 PARTICIPANT: It's the new background on
10 Teams. It doesn't jump out of like it used to.

11 CHAIR BALLINGER: Yes, it doesn't jump
12 out.

13 MS. ABDULLAHI: Harold, are you going to
14 send me that one, or I should send the one that you
15 have now?

16 MR. SCOTT: I read from what you already
17 have.

18 MS. ABDULLAHI: Okay. Thank you.

19 MR. SCOTT: Number two.

20 MS. ABDULLAHI: Okay. Number 2, the one
21 -- okay. Then I will make sure that both statements
22 go into the transcript.

23 MR. SCOTT: Thank you.

24 MS. ABDULLAHI: You're welcome.

25 CHAIR BALLINGER: Okay. Thank you again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Thank you for the applicant as well as the staff. So
2 I think the time now is for the committee to have
3 discussion related to the path forward. And in
4 compliance with the request of the Chairman, I have
5 put together an outline for a potential paper because
6 we're -- if we decide to write a paper, it will be
7 presented in the May Full Committee.

8 MEMBER MARCH-LEUBA: You mean letter?

9 CHAIR BALLINGER: Excuse me. Letter.
10 Full Committee meeting.

11 So we can either put that up there and
12 scream at me or we can have a discussion right now
13 about what we should do and what should the path
14 forward be.

15 MR. MOORE: Chair, I don't think you have
16 time.

17 CHAIR BALLINGER: Well, we have --

18 MR. MOORE: Ten minutes.

19 CHAIR BALLINGER: -- 10 minutes. So
20 that's my time limit and I'm sticking to it.

21 PARTICIPANT: Well, I guess I would just
22 ask what would we write about that we haven't already
23 written on our other letter?

24 CHAIR BALLINGER: Well, we have to do
25 something about the WCAP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER KIRCHNER: Yes, I mean what don't
2 you just outline, Ron, what your thinking is at this
3 point? And that will --

4 CHAIR BALLINGER: Yes, can you put --

5 MEMBER KIRCHNER: -- give us --

6 CHAIR BALLINGER: -- that up here?

7 MEMBER KIRCHNER: -- focus.

8 CHAIR BALLINGER: Do we need the court --
9 the recorder and everything for this?

10 MR. MOORE: Yes, you don't need the court
11 reporter for the general discussion about what should
12 be in a letter, but then you can't go back to anything
13 else --

14 CHAIR BALLINGER: Oh, okay.

15 MR. MOORE: -- in the Subcommittee.

16 CHAIR BALLINGER: Okay. Again this is the
17 first time I've done this, and so it's -- I think
18 we --

19 MEMBER MARCH-LEUBA: Wait. Wait. If we
20 put the letter in and you haven't adjourned, we need
21 to put that in the transcript, right?

22 MR. MOORE: Well, what he's saying will be
23 in the transcript.

24 MEMBER MARCH-LEUBA: I suggest that we
25 adjourn and then we have committee discussions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 afterwards.

2 CHAIR BALLINGER: Is that something we can
3 do?

4 MR. BURKHART: We're not adjourning
5 because the meeting is still going on. So we can let
6 the court reporter go and end his duty. Then I think
7 you want to just discuss where you think the
8 Subcommittee should go on this with respect to Full
9 Committee, right?

10 CHAIR BALLINGER: Okay. I think let's
11 just keep going. I would just for now put up the
12 straw man for the conclusions and recommendations.
13 Just keep going.

14 Okay. There we go. I had conclusions and
15 recommendations related to the WCAP itself. And those
16 are the ones that I'm -- I just wrote them down. And
17 the bottom line is is that they made an adequate case
18 for this. Or, whoops. What happened?

19 MR. BURKHART: Okay. Yes, Ron, we need to
20 make sure -- I would suggest you talk about topics.
21 And I needed to take the letter of for a reason. So
22 I just wanted to -- there was some information on
23 there that shouldn't have been, so I suggest you just
24 talk about the topics.

25 CHAIR BALLINGER: Okay. All right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Sorry.

2 So I had the basic conclusion was that the
3 WCAP should be issued. And they've supplied enough
4 reasons for that to happen. But there was a set of
5 conclusions and recommendations based on the
6 nonconcurrence. And they were that: (A) it was a very
7 -- to my mind it was a very well-written document. It
8 stated a case which we know exists, but that there is
9 a resolution process in place going forward that will
10 ultimately resolve their concerns. So those are the
11 two main sets of results and conclusions.

12 MEMBER PETTI: Can we urge them to move
13 posthaste?

14 CHAIR BALLINGER: Yes. Well, we -- that's
15 true. Well, they are --

16 MEMBER PETTI: I mean the agency to move
17 forward to resolve this. Just give them all the
18 stakeholder --

19 CHAIR BALLINGER: I mean this is not a
20 GSI-191 thing.

21 MEMBER PETTI: Without saying that, yes.

22 CHAIR BALLINGER: But that's what I would
23 propose, but I don't know -- other members have a
24 different opinion? And we can send that document out
25 to the members.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PARTICIPANT: No, no, not yet.

2 PARTICIPANT: It needs to be reviewed
3 first.

4 MEMBER HALNON: Remind me why this was not
5 put in the GS -- in our safety issue process. Does
6 anyone remember?

7 MEMBER PETTI: It was. The slide said it
8 was supposed to be part of the 50.46(c).

9 MEMBER HALNON: And then a rulemaking.

10 MEMBER PETTI: Right. No, no, it screened
11 out of the GSI process.

12 MEMBER HALNON: That's what --
13 (Simultaneous speaking.)

14 MEMBER PETTI: -- a generic safety issue.

15 MEMBER HALNON: If you have some of the
16 staff calling for a 50.109, it sounds like it could be
17 very easily --

18 MEMBER PETTI: No. Yes, it was screened
19 out and the argument was because they were going to
20 handle in 50.46(c).

21 MEMBER HALNON: Oh, okay.

22 MEMBER PETTI: And they didn't handle it
23 in 50.46(c). And somehow nobody -- that didn't close.

24 MEMBER HALNON: And now it's hanging?

25 MEMBER PETTI: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER HALNON: Do we have an opinion
2 about that then, to find a process to put this in
3 rather than just --

4 CHAIR BALLINGER: But now we're talking
5 about something that's not the --

6 (Simultaneous speaking.)

7 MEMBER PETTI: I'll just give you my
8 comment. We made in a very recent letter on Part 53
9 a recommendation to get a draft Reg Guide and make it
10 a real Reg Guide. And we didn't get a -- pushing the
11 staff sometimes is like pushing on string, I think.
12 I mean, I didn't think that was like a huge ask. This
13 is a bigger ask, but there's a lot more in the line
14 here.

15 MEMBER HALNON: Well, I always in my
16 career figured that the best way to get something
17 resolved that is hanging is to make sure it's in the
18 appropriate process and let that process handle it
19 with the -- typically it was the corrective action
20 process for a licensee. You put in the corrective
21 action process and now you know that there's going to
22 be a series of steps. Right now it doesn't feel that
23 way for this.

24 MEMBER PETTI: Yes, well we didn't hear it
25 in the slides, but the paper had all those different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 options, right?

2 MEMBER HALNON: Yes. Right. And all
3 those would have been fleshed out during --

4 (Simultaneous speaking.)

5 MEMBER PETTI: Right.

6 CHAIR BALLINGER: But do we think that the
7 rulemaking process will take care of this?

8 MEMBER PETTI: This is a process question.
9 This is not us formally. We are not experts on this
10 stuff. My opinion is, as we reiterated in the RIL, we
11 think this is an important issue. It ought to be
12 resolved as expeditiously as possible by whatever
13 process the staff (audio interference).

14 (Simultaneous speaking.)

15 MEMBER HALNON: And now we're talking
16 about the FFRD.

17 CHAIR BALLINGER: Yes.

18 MEMBER PETTI: Yes. Well then --

19 MEMBER HALNON: Well, that is the essence
20 of the nonconcurrency. I mean nowhere do they say you
21 applied this incorrectly in the WCAP. This is all
22 about a coolable geometry and the resolution of the
23 FFRD, or at least understanding of that.

24 CHAIR BALLINGER: Okay. Are we in
25 agreement that a letter is appropriate?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER PETTI: I think the --

2 (Simultaneous speaking.)

3 MEMBER PETTI: Look, we have written
4 letters from other vendors. We have to write a letter
5 here.

6 CHAIR BALLINGER: Okay.

7 MEMBER PETTI: I think. I mean it would
8 show some sort of bias that isn't really real.

9 MEMBER HALNON: Well, I think it also gets
10 -- keeps the pressure on.

11 MEMBER PETTI: Yes.

12 MEMBER HALNON: And I think we can't sit
13 back and say, well, we're part of the folks that are
14 just waiting to see.

15 CHAIR BALLINGER: I mean, my personal
16 opinion as this committee, as a committee this is one
17 way to keep the pressure on. There's another way to
18 keep the pressure on with -- when we get the ALS
19 presentation. We have an opportunity as a committee
20 to keep the pressure on. And I think that's a good
21 thing.

22 Yes, I wish I could say that I'm looking
23 forward to the letter writing in May.

24 PARTICIPANT: You have one minute to
25 adjourn, Ron.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Yes. All right. If
2 there aren't any -- I've been properly excoriated. I
3 told you I was going to be excoriated.

4 MEMBER KIRCHNER: I think you'll do it,
5 but go ahead and say thank you to the staff.

6 CHAIR BALLINGER: Yes. Yes. Thank you
7 very much --

8 MEMBER KIRCHNER: -- specifically the
9 presenters today --

10 CHAIR BALLINGER: -- everybody and --

11 MEMBER KIRCHNER: -- for bringing this to
12 the fore.

13 CHAIR BALLINGER: -- I'm sure that May
14 letter writing will be interesting for the staff and
15 the applicants.

16 So thank you once again for presenting,
17 and we are I think adjourned.

18 (Whereupon, the above-entitled matter went
19 off the record at 5:59 p.m.)
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

Enclosure 2

Westinghouse Open Session Slide Package for the ACRS Subcommittee Meeting on WCAP-18446-P/NP

(Non-Proprietary)

March 2024

ADOPT™, AXIOM®, Optimized ZIRLO™, and ZIRLO® are trademarks of Westinghouse Electric Company LLC, its affiliates, and/or its subsidiaries through the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

**Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066**

**© 2024 Westinghouse Electric Company LLC
All Rights Reserved**

ADOPT, AXIOM, Optimized ZIRLO, and ZIRLO are trademarks or registered trademarks of Westinghouse Electric Company LLC, its subsidiaries and/or its affiliates in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

© 2024 Westinghouse Electric Company LLC
All Rights Reserved



ACRS Fuels, Materials, and Structures Subcommittee Meeting

Incremental Extension of Burnup Limit for Westinghouse and Combustion Engineering Fuel Designs, Westinghouse Topical Report WCAP-18446-P/NP


Open Session

Jeffrey Kobelak

Consulting Engineer, Westinghouse Electric Company


April 2024

Burnup Extension Program as 2-Step Process




Step 1: Increase burnup limit for rods in peripheral assemblies above 62 GWd/MTU

Step 2: Increase burnup limit for entire core to above 70 GWd/MTU with enrichment increase




Westinghouse EnCore® Fuel and High Energy Fuel Programs

Timeline of Various Products



AXIOM® Cladding



Higher Enrichment



Chromium-Coated Cladding



Uranium Nitride (UN) Pellets





Photo courtesy of Los Alamos National Lab

Product and Methods Evolution

ADOPT™ Pellets




Incremental Burnup



EPRI Alternate Licensing Strategy

Full Core High Burnup



SiGA™ Silicon Carbide (SiC) Composite Cladding



Photo courtesy of General Atomics




Incremental Burnup Extension Benefits

- Primary benefit is improved fuel utilization
 - Enabling higher region discharge burnup → improved fuel utilization
 - Target is to reduce number of required feed assemblies each reload
- Improved backend cost
 - Optimum utilization of spent fuel pool capacity with higher burnup fuel
 - Lower dry cask storage needs with fewer fuel assemblies
 - Less volume for permanent storage
- Westinghouse has contracted with customers to implement **ADOPT™** fuel, **AXIOM®** cladding, and the incremental burnup extension (once approved)

Incremental Burnup Extension Applicability

- Fuel Rod Average Burnup
 - > 62 GWd/MTU
- Fuel Rod Initial Enrichment
 - < 5 w/o enrichment
- Core Location
 - Peripheral Assemblies
- Fuel Assembly Designs
 - All



- Cladding Materials
 - **ZIRLO[®]**, **Optimized ZIRLO[™]**, and **AXIOM** cladding
 - Chromium-coated cladding (future)
- Fuel Pellets
 - Standard UO₂ and **ADOPT** fuel pellets

Incremental Burnup Extension Topical Report Overview

- WCAP-18446-P/NP was written to ensure efficient implementation of the incremental burnup extension
 - Limitations associated with prior topical reports which are superseded are identified in Section 1.4
 - Limitations of applicability clearly defined in Section 7.1
 - Licensee actions for implementation are discussed in Section 7.2
- Impacts of incremental burnup extension addressed functional area-by-functional area
 - Codes
 - Methods
 - Acceptance Criteria

Incremental Burnup Extension Topical Report Overview

- Mechanical Design
 - Fuel assembly design bases
 - Structural components
 - Materials

- Core and Fuel Rod Performance
 - Fuel Rod Design
 - Justify application of PAD5 to incremental burnup regime
 - Nuclear Design
 - Codes are already applicable to incremental burnup regime
 - Thermal-Hydraulic Design
 - DNB methods and determination of DNBR remain applicable to incremental burnup fuel rods
 - Incremental burnup rods are non-limiting for rod bow due to low power

Incremental Burnup Extension Topical Report Overview

- Loss-of-Coolant Accident Analysis
 - Update codes and methods to analyze higher burnup fuel rods
 - Address potential for fuel dispersal from fuel rods in the incremental burnup regime
- Transient and Containment Analysis
 - Assess / update decay heat modeling for analysis of higher burnup fuel rods
 - Address phenomena for high burnup fuel rods related to reactivity insertion accidents
- Radiological Consequence Analysis
 - Account for higher burnup fuel rods in dose analyses

Fuel Fragmentation, Relocation, and Dispersal (FFRD)

- Research regarding FFRD ongoing for the last decade
- Safety assessments were completed for FFRD relative to design basis non-LOCA and LOCA transients and accidents
 - SECY-15-0148: *The experimental results have continued to support the hypothesis that FFRD phenomena are primarily a high burnup fuel issue and that the current licensing limits in the U.S. are adequate to prevent dispersal of large quantities of fine fuel fragments.*
- RIL 2021-13 issued to provide conservative interpretation of subset of FFRD-related data at the time of publication
- **Incremental burnup extension considers potential for dispersal during various accidents and transients**

Incremental Burnup Topical Report Schedule

- Topical Report Submittal December 2020
- NRC Acceptance Review March 2021
- First Round of RAIs Issued December 2021
- Responses to Round 1 RAIs June 2022
- Second Round of RAIs Issued September 2022
- Responses to Round 2 RAIs February 2023
- Draft SER Issued March 2024
- ACRS Sub Committee April 2024
- Final SER to be Issued June 2024

Questions



Acronyms / Codes / Labels

Acronym	Definition
ACRS	Advisory Committee on Reactor Safeguards
ADOPT	Advanced Doped Pellet Technology
ALS	Alternate Licensing Strategy (for FFRD)
DNB	Departure from Nucleate Boiling
DNBR	Departure from Nucleate Boiling Ratio
EPRI	Electric Power Research Institute
FFRD	Fuel Fragmentation, Relocation, and Dispersal
LOCA	Loss-of-Coolant Accident
NRC	Nuclear Regulatory Commission
PAD	Performance Analysis and Design

Acronyms / Codes / Labels (continued)

Acronym	Definition
RAI	Request for Additional Information
RIL	Research Information Letter
SER	Safety Evaluation Report
SiC	Silicon Carbide
UN	Uranium Nitride

NRC Staff's Review of
Westinghouse Topical Report
WCAP-18446-P,
*Incremental Extension of Burnup Limit for
Westinghouse and Combustion Engineering Fuel
Designs*

Open Presentation to
Advisory Committee on Reactor Safeguards,
Fuels, Materials, and Structures
Subcommittee

April 2, 2024


K. Heller, U.S. NRC
J. Lehning, U.S. NRC
B. Wise, U.S. NRC

Presentation Outline

Topic	# of Slides
Introduction	3
Review History	1
Requirements and Guidance	4
Technical Evaluation (open portion)	15
• Fuel Assembly Mechanical Design	[1]
• Core and Fuel Rod Performance	[4]
• Loss-of-Coolant Accident Analysis Methods	[1]
• Non-Loss-of-Coolant Accident Analysis Methods	[3]
• Radiological Consequence Analysis	[4]
• Applicability to ADOPT™ Fuel Pellets and AXIOM® Cladding	[2]
Applicability, Limitations and Conditions	2
Conclusions	1
Presentation Total	26

Introduction

- Westinghouse proposed WCAP-18446-P/NP to allow an incremental burnup increase beyond currently licensed limits
 - Westinghouse considers proposed incremental burnup limit to be proprietary
- WCAP-18446-P/NP contains a comprehensive evaluation of the capability of Westinghouse's analysis methods to address fuel in incremental burnup range
- The WCAP-18446-P/NP methodology is intended to demonstrate no dispersal for fuel in incremental burnup range



Review Timeline


Westinghouse



NRC


Key Regulatory Requirements and Guidance

- Fuel and Core Performance
 - General Design Criterion 10
 - Specified acceptable fuel design limits to assure cladding integrity for normal operation and anticipated operational occurrences
 - NUREG-0800, Standard Review Plan, Chapter 4.2
 - The fuel system is not damaged due to normal operation and anticipated operational occurrences
 - Fuel system damage is never so severe as to prevent control rod insertion when required
 - The number of fuel rod failures is not underestimated for postulated accidents
 - Core coolability is maintained



Key Regulatory Requirements and Guidance

- Loss-of-Coolant Accident
 - 10 CFR 50.46
 - General Design Criterion 35
 - Appendix K to 10 CFR 50
 - NUREG-0800, Standard Review Plan
 - Chapter 15.6.5, Loss-of-Coolant Accident
 - Chapter 15.0.2, “Review of Transient and Accident Analysis Methods”
 - Regulatory Guide 1.157, “Best-Estimate Calculations of Emergency Core Cooling System Performance”
 - Regulatory Guide 1.203, “Transient and Accident Analysis Methods”



Key Regulatory Requirements and Guidance

- Non-Loss-of-Coolant Accidents and Transients
 - NUREG-0800, Standard Review Plan, Chapter 15
 - Regulatory Guide 1.203, “Transient and Accident Analysis Methods”
 - General Design Criterion 27
 - Combined reactivity control systems capability
 - General Design Criterion 28
 - Reactivity limits
 - Regulatory Guide 1.236, “Pressurized-Water Reactor Control Rod Ejection and Boiling-Water Reactor Control Rod Drop Accidents”

Key Regulatory Requirements and Guidance

- Containment
 - General Design Criterion 50, Containment design basis
- Technical Specifications
 - 10 CFR 50.36
- Radiological Dose
 - 10 CFR 100
 - 10 CFR 50.67
 - Regulatory Guide 1.195
 - Regulatory Guide 1.183

Fuel Assembly Mechanical Design

- Westinghouse proposed a methodology for extending the burnup limit for fuel assemblies
 - A set of design criteria
 - A method of evaluating against that criteria
 - The results of the evaluation for a specific design
- The 17x17 OFA design is generically approved for an incremental burnup extension. Other designs can be approved on a generic or plant-specific basis per L&C 1
- Westinghouse determined and the NRC staff found that the proposed assembly design criteria and evaluation methods were acceptable

Core and Fuel Rod Performance

- WCAP-18446-P/NP presents discussions across three separate phenomenological areas of Westinghouse codes and methods to justify extending the rod-average burnup limit:
 1. Fuel rod performance
 2. Nuclear design
 3. Core thermal-hydraulic design

Fuel Rod Performance

- Analyses will use the NRC-approved PAD5 code (L&C 7)
- Westinghouse evaluated the applicability of key models in the extended burnup range for each fuel rod design basis:
 - Fuel rod internal pressure
 - Fuel rod cladding stress
 - Fuel rod cladding strain
 - Pellet-cladding interaction
 - Fuel cladding oxidation and hydriding
 - Fuel temperature
 - Clad free standing
 - Fuel cladding fatigue
 - Fuel cladding flattening
 - Fuel rod axial growth
 - Fuel cladding wear
- NRC staff assessed these models and underlying phenomena and found them acceptable within WCAP-18446-P/NP (L&C 4, L&C 10)

Nuclear Design

- Westinghouse proposed to continue using existing nuclear design codes
 - PARAGON or PHOENIX-P for lattice transport calculations
 - ANC for two- and three-dimensional nodal calculations
- Westinghouse asserted these codes are applicable to increased burnup conditions within existing 5% enrichment limit
 - Applicability of WCAP-18446-P/NP is limited to 5% enrichment per Limitation and Condition 5
- NRC staff examined two areas most likely to be stressed at an extended burnup range:
 - Production and depletion of major uranium and plutonium isotopes
 - Modeling increased critical boron concentrations
 - Found these areas are acceptable within the scope of WCAP-18446-P/NP

Thermal-Hydraulic Design

- Westinghouse proposed that no modifications are necessary to existing methods for analyzing departure for nucleate boiling
 - DNB correlations
 - VIPRE/W code
 - Revised Thermal Design Procedure, Westinghouse Thermal Design Procedure, etc.
 - DNB propagation
 - Fuel rod bow
- The NRC staff found that the T/H codes and methods are applicable up to the requested rod-average burnup extension limit

Non-Loss-of-Coolant Accident Analysis Methods

- Transient (Anticipated Operational Occurrence) Analysis
 - Westinghouse divided these events into two categories:
 - Events dependent upon core-average effects
 - Events analyzed to assess local fuel rod behavior
 - Westinghouse stated that approved evaluation models remain applicable

Non-Loss-of-Coolant Accident Analysis Methods

- Reactivity Insertion Accidents
 - Westinghouse discussed its conformance with the fuel cladding failure thresholds in RG 1.236:
 - Peak radial average fuel enthalpy (calories per gram)
 - Departure from nucleate boiling
 - Pellet-cladding mechanical interaction
 - Fuel pellet incipient melting
 - Westinghouse proposed to apply its multi-dimensional kinetics methodology (WCAP-15806-P-A) or another approved evaluation model for this event
 - No fuel dispersal permitted for fuel rods in incremental burnup range

Non-Loss-of-Coolant Accident Analysis Methods

- Containment integrity analysis for LOCA and main steam line break (MSLB)
 - Short-term mass and energy release
 - Dominated by system conditions, not fuel conditions
 - E.g., break area, system temperature, pressure
 - Not impacted by incremental burnup extension
 - Long-term mass and energy release
 - Licensed methods for LOCA
 - WCAP-10325-P-A
 - WCAP-17721-P-A
 - CENPD-132P
 - Licensed methods for MSLB
 - LOFTRAN
 - RETRAN
 - SGNIII
 - Conservative modeling of decay heat and other parameters
 - As supported by Limitations and Conditions 13 and 14

Radiological Consequence Analysis

- Westinghouse addressed the radiological consequences of three types of accidents:
 - LOCA
 - Non-LOCA accidents
 - Steam generator tube rupture
 - Main steam line break
 - Reactor coolant pump locked rotor
 - Control rod ejection
 - Fuel handling accident
- General non-proprietary information provided in open presentation

Radiological Consequence Analysis: LOCA

- LOCA radiological consequence analysis typically performed per RG 1.183 or RG 1.195
- Westinghouse concluded that this guidance, and the codes and methods it uses to conform thereto, remain applicable for fuel in the incremental burnup range

Radiological Consequence Analysis: Non-LOCA Accidents

- Westinghouse stated that existing transient and radiological analysis methods for fuel within current burnup limits remain valid for fuel in incremental burnup range
- Existing technical specifications limit activity of primary and secondary systems

Radiological Consequence Analysis: Fuel Handling Accident

- Impact of fuel dispersal for non-LOCA accidents not generically addressed in existing regulatory guidance
- Westinghouse considered the impacts of key factors, including
 - Behavior of key short- and long-lived radionuclides
 - Expected power history for fuel in incremental burnup range
 - Expected extent of fragmentation and dispersal
- Licensees will explicitly address fuel-handling accident consequences as part of license amendment requests proposing an incremental burnup extension

Applicability to ADOPT Fuel Pellets

- ADOPT fuel pellet topical report (WCAP-18482-P-A) approved in 2022 for existing burnup limits (i.e., within 62 GWd/MTU)
- December 2020 submittal of WCAP-18446-P/NP included consideration of ADOPT fuel pellets as an appendix
- The NRC staff found that ADOPT pellets perform acceptably similarly to standard UO₂ pellets such that the analyses and conclusions throughout the TR and SE remain applicable for ADOPT pellets

Applicability to AXIOM Cladding

- AXIOM cladding topical report (WCAP-18546-P-A) approved in 2023 for existing burnup limits (i.e., within 62 GWd/MTU)
 - Added to WCAP-18446-P/NP review scope by May 2023 voluntary supplement
- Existing cladding performance models contain adequate data up to the requested burnup limit
- AXIOM-clad rods in the incremental burnup range are subject to the same placement restrictions and no-burst criterion as fuel rods with other cladding designs
- The NRC staff determined that WCAP-18446-P/NP methodology applies to AXIOM cladding and the AXIOM specific models are acceptable at the higher burnup limit.

Material Applicability Conditions

- Per Limitation and Condition 2, WCAP-18446-P/NP is only applicable to fuel products with
 - Uranium dioxide or ADOPT fuel pellets
 - ZIRLO[®], Optimized ZIRLO[™], or AXIOM cladding
- Per Limitation and Condition 3, WCAP-18446-P/NP is only applicable to
 - Unpoisoned fuel
 - Fuel with integral fuel burnable absorbers
 - Fuel with gadolinia

(this limitation does not preclude use of discrete burnable absorbers)

Limitations and Conditions

- The NRC staff's draft safety evaluation contains 14 limitations and conditions that licensees adopting the methodology must address
 - Incorporated therein are 9 limitations Westinghouse proposed in WCAP-18446-P/NP or RAI responses
 - NRC staff modified several of the limitations proposed by Westinghouse
- Eight limitations and conditions have been noted in the foregoing presentation
 - The remaining 6 will be discussed during the closed presentation

Conclusions

- The NRC staff found the WCAP-18446-P/NP incremental burnup methodology provides an acceptable approach for comprehensively evaluating fuel operation within the requested extended burnup limit, addressing
 - Fuel assembly mechanical design
 - Core and fuel rod performance
 - Non-LOCA & LOCA safety analyses
 - Radiological Consequences
- The staff's conclusions are predicated upon
 - The methodology being used within its approved range of applicability
 - Licensees acceptably addressing limitations and conditions in Section 4.0 of the staff's safety evaluation

Table of Abbreviations

ACRS	Advisory Committee on Reactor Safeguards
10 CFR	Title 10 of the <i>Code of Federal Regulations</i>
DNB	Departure for Nucleate Boiling
FC	Advisory Committee on Reactor Safeguards Full Committee
FULL SPECTRUM™ LOCA	WCAP-16996-P-A, Revision 1, 'Realistic LOCA Evaluation Methodology Applied to the Full Spectrum of Break Sizes (Full Spectrum LOCA Methodology)
GWd/MTU	Gigawatt-days per Metric Ton of Uranium
L&C	Limitations and Conditions
LOCA	Loss-of-Coolant Accident
NRC	U. S. Nuclear Regulatory Commission
OFA	Optimized Fuel Assembly
PAD5	Performance Analysis and Design Mode

Table of Abbreviations (Contd.)

RAIs	Requests for Additional Information
RG	Regulatory Guide
RG 1.183	Regulatory Guide 1.183, “Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors”
RG 1.195	Regulatory Guide 1.195, “Methods And Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light-Water Nuclear Power Reactors”
SC	Advisory Committee on Reactor Safeguards Subcommittee
SE	Safety Evaluation
TR	Topical Report
WCAP-18446-P/NP	WCAP-18446-P/WCAP-18446-NP, Revision 0, “Incremental Extension of Burnup Limit for Westinghouse and Combustion Engineering Fuel Designs”

Enclosure 4

**Westinghouse Closed Session Slide Package for the ACRS Subcommittee Meeting on
WCAP-18446-P/NP**

(Non-Proprietary)

March 2024

ADOPT™, AXIOM®, FSLOCA™, FULL SPECTRUM™, Optimized ZIRLO™, and ZIRLO® are trademarks of Westinghouse Electric Company LLC, its affiliates, and/or its subsidiaries through the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

**Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066**

**© 2024 Westinghouse Electric Company LLC
All Rights Reserved**

ADOPT, AXIOM, FSLOCA, FULL SPECTRUM, Optimized ZIRLO, and ZIRLO are trademarks or registered trademarks of Westinghouse Electric Company LLC, its subsidiaries and/or its affiliates in the United States of America and may be registered in other countries throughout the world. All rights reserved. Unauthorized use is strictly prohibited. Other names may be trademarks of their respective owners.

© 2024 Westinghouse Electric Company LLC
All Rights Reserved



ACRS Fuels, Materials, and Structures Subcommittee Meeting

Incremental Extension of Burnup Limit for Westinghouse and Combustion Engineering Fuel Designs, Westinghouse Topical Report WCAP-18446

Closed Session

Jeffrey Kobelak

Jim Laird

Yun Long

Westinghouse Electric Company

April 2024



Purpose of Meeting

- WCAP-18446-P/NP, “Incremental Extension of Burnup Limit for Westinghouse and Combustion Engineering Fuel Designs” was submitted for NRC review by letter dated December 14, 2020
- A draft Safety Evaluation Report (SER) on the topical report has been made available to Westinghouse and the ACRS
- This meeting will provide an overview of the incremental burnup extension to the ACRS Fuels, Materials, and Structures Subcommittee

Overview

- Introduction
- Key Findings from NRC Review
- Discussion of Specific Functional Areas
 - Nuclear Design
 - Fuel Rod Design
 - Mechanical Design
 - Thermal-Hydraulic Design, Non-LOCA and Containment Analysis
 - LOCA Analysis
- Plant-Specific Implementation



Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

Incremental Burnup Rationale and Benefits

- Utility Benefits
 - Improved fuel utilization
 - Improved backend cost
- Regulatory Benefits: Requires that various legacy issues are addressed and that utilities adopt latest regulatory guidance to implement
 - []^{a,c}
 - Incorporate PAD5 (explicitly accounts for thermal conductivity degradation (TCD)) into licensing basis
- Westinghouse Benefits
 - Provides a means to gather more high burnup data from rods in non-limiting locations

Constraints of Incremental Burnup Extension

- Limit on maximum rod average burnup of []^{a,c}
- Limited to rods in core peripheral assemblies
- Limited to rods which do not burst during a LOCA
- Limited to rods which []^{a,c}
- Expected limits on assembly and rod power vs burnup for incremental burnup rods and associated assemblies
 - Exact limits will be based on plant-specific implementation
 - Expect maximum rod relative power approximately []^{a,c}
 - Expect maximum assembly relative power approximately []^{a,c}

Constraints address fuel fragmentation, relocation, and dispersal (FFRD) for the fuel rods in the incremental burnup regime

Overview of Incremental Burnup Topical Report

- Section 1: Overview and Methodology Roadmap
- Section 2: Fuel Assembly Mechanical Design
- Section 3: Core and Fuel Rod Performance
 - **Section 3.1: Fuel Rod Performance**
 - **Section 3.2: Nuclear Design Methods and Application**
 - Section 3.3: Thermal-Hydraulic Design
- **Section 4: Loss-of-Coolant Accident Analysis Methods**
- Section 5: Non-LOCA Safety Analysis Methods
 - Section 5.1: Transient Analysis
 - Section 5.2: Containment Integrity Analysis
- Section 6: Radiological Consequence Analysis
- Section 7: Summary and Implementation

Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

Key Findings from NRC Review

- Nuclear Design
 - Technical Specification Limit on Hot Channel Enthalpy Rise (FdH) at High Burnup
- Fuel Rod Design
 - Applicability of PAD5 to Higher Burnup Fuel Rods
- Loss-of-Coolant Accident Analysis
 - Addressing Potential for Fuel Dispersal
 - Criterion for Cladding Rupture
 - Research Findings Underpinning Draft 10 CFR 50.46c Rulemaking
 - Transient Fission Gas Release

Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

Incremental Burnup Application Impact for Fuel Management

- Allows for fuel only in peripheral locations to exceed the current 62 GWD/MTU pin burnup limit
 - []^{a,c}
 - Allows higher burned assemblies following two cycles of operation interior to the core to be used on the periphery
- Allows for a []^{a,c} feed assembly reduction per cycle when compared to an optimized design at current burnup limits
 - Higher enrichment of remaining feed assemblies offset reduced number of feeds
 - []

]a,c

Application and Fuel Cost Benefit 3-Loop Core

a,c



Application and Fuel Cost Benefit 4-Loop Core

a,c



Impact of Incremental Burnup On Safety

- +/-8 Assemblies is within the current cycle-to-cycle variation
- Safety limit confirmation for each core reload to confirm assembly power assumed in LOCA analysis
- Peaking factors are slightly higher with lower number feeds but still retain acceptable margin to the TS limits

ND Codes and Methods for Incremental Burnup Extension

- Nuclear Design principal codes and methods are based on NRC approved ALPHA-(PHOENIX/PARAGON)-ANC or APA codes
- Rod burnup extension up to []^{a,c} does not require modification or updating of any previously NRC-approved topical reports assessing neutronics and nuclear design
- Methods implemented in the neutronic codes for fuel depletion remains unchanged and already contains the depletion capability to very high burnup for pellets exceeding 62 GWd/MTU in rods with an average burnup of 62 GWd/MTU

Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation


Fuel Rod Design - Introduction

- Westinghouse fuel performance code PAD5 licensed in 2017 (WCAP-17642-P-A) was licensed for rod average burnup of 62 GWd/MTU, but was intended for high burnup application to []^{a,c}
- Follow on topical extended PAD5 application to **ADOPT**[™] fuel and **AXIOM**[®] cladding
 - **ADOPT** fuel in WCAP-18482-P-A
 - **AXIOM** cladding in WCAP-18546-P-A
- Fuel performance models, database, and application methodology for design criteria were reassessed relative to extending the application to rod average burnups of []^{a,c} from 62 GWd/MTU
 - No changes are needed

Westinghouse PAD5 FRD methods are applicable to rod average burnup of []^{a,c}

Fuel Rod Design - PAD5 Database

- Halden Project experiments provide measured fuel temperatures for UO_2 and $\text{Gd}_2\text{O}_3\text{-UO}_2$ fuel to high burnup []^{a,c}
- Commercial irradiation programs provide measured fission gas release and rod growth data up to []^{a,c} rod average burnup
- Joint International test programs provide data on high burnup []^{a,c} fuel power ramp behavior



PAD5 has many high burnup and high duty data points

Fuel Rod Design – PAD5 High Burnup Models



Technical bases for rod average burnup up to []^{a,c} are provided in PAD5 topical



Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

Fuel Assembly Mechanical Design

- No change in current methods for evaluating Fuel Assembly (FA) performance under a given loading pattern for incremental burnup increase to a maximum of []^{a,c} rod average
- Methods are benchmarked to FA data with rods > []^{a,c}
- Codes providing inputs to FA analysis such as temperatures and fast neutron fluence are valid to > []^{a,c} rod average burnup
- []^{a,c}

]a,c

Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

T/H Design, Non-LOCA and Containment Analysis

a,c

Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

LOCA Analysis: Overview

- Primary LOCA-related concern with incremental burnup is FFRD
- Introduction of incremental burnup extension [


]a,c

- New and updated models implemented into the associated thermal-hydraulic system code (WCOBRA/TRAC-TF2) to analyze higher burnup fuel rods



Nuclear Physics Data

- Updated nuclear physics data to higher burnup
 - U-235 fission fraction shown as an example



Cladding Rupture Criterion: Evolution during Licensing

a,c



Cladding Rupture Criterion: Final Result

a,c

- Cladding rupture model based on NUREG-0630 framework
- Robust database
 - [


]a,c

[

]a,c



Research Underpinning Draft 10 CFR 50.46c Rulemaking




Current LOCA rule:
17% ECR and 2200°F PCT
throughout life of fuel

PCT
< 2200°F

PCT
≤ 2050°F

Oxygen enters cladding from
oxide-bond-fuel layer
OD ID



Transient Fission Gas Release

Prototypic LOCA Transient Fission Gas Release Testing

a,c



Transient Fission Gas Release Fuel Temperatures for Incremental Burnup Fuel Rod

a,c



Fuel pellets for incremental burnup rods []

a,c

Transient Fission Gas Release Fueled Rod Segment Heating Tests

a,c



Transient Fission Gas Release Conclusions

a,c



Introduction

Key Findings from NRC Review

Discussion of Specific Functional Areas

Nuclear Design

Fuel Rod Design

Mechanical Design

T/H Design, Non-LOCA and Containment Analysis

LOCA Analysis

Plant-Specific Implementation

Implementation

- Two parts to implementation
- 1: Generic topical report (today's topic)
 - Address burnup-related limitations and conditions on existing topical reports
 - Describe any required method updates or demonstrate that no updates are required for the various functional areas
 - Justify applicability of existing designs and methods for high burnup
- 2: Site-specific effort
 - Execute analyses, evaluations, and requirements of generic topical report
 - Plant-specific LAR submittal

Site-Specific Implementation

- []a,c
 - LOCA: Demonstrate no rupture in high burnup rods
- **FSLOCA** EM implementation (if not already completed)
 - Addresses TCD using fully NRC-approved methods
- “Not LOCA” PAD5 implementation (if not already completed)
 - Transient Analysis (Includes mechanistic DNB propagation evaluation method)
 - Fuel Rod Design

Site-Specific Implementation (continued)

- Assess impact on existing analyses
 - Confirm mechanical design criteria are met
 - Confirm fuel rod design criteria are met
 - Confirm reload limits continue to be met
 - Assess vessel fluence calculations
 - Assess spent fuel pool and dry cask heat removal analyses
- LAR submittal for NRC review

Questions



Acronyms / Codes / Labels

Acronym	Definition
3D	3-Dimensional
ACRS	Advisory Committee on Reactor Safeguards
ADOPT	Advanced Doped Fuel
BOC	Beginning of Cycle
Bu	Burnup
CFR	Code of Federal Regulations
DNB	Departure from Nucleate Boiling
DNBR	Departure from Nucleate Boiling Ratio
ECCS	Emergency Core Cooling System
EM	Evaluation Model

Acronyms / Codes / Labels

Acronym	Definition
EOC	End of Cycle
FA	Fuel Assembly
FGR	Fission Gas Release
FRD	Fuel Rod Design
FSLOCA	FULL SPECTRUM LOCA
IBLOCA	Intermediate Break LOCA
ID	Inner Diameter
LAR	License Amendment Request
LBLOCA	Large Break LOCA
LOCA	Loss-of-Coolant Accident

Acronyms / Codes / Labels

Acronym	Definition
NRC	Nuclear Regulatory Commission
OD	Outer Diameter
OFA	Optimized Fuel Assembly
PAD	Performance Analysis and Design
PCT	Peak Cladding Temperature
RG	Regulatory Guide
SBLOCA	Small Break LOCA
SER	Safety Evaluation Report
T/H	Thermal-Hydraulic
TCD	Thermal Conductivity Degradation

Acronyms / Codes / Labels

Acronym	Definition
TS	Technical Specification
tFGR	transient Fission Gas Release
WCAP	Westinghouse Commercial Atomic Power

Management Perspective

- The technical issues raised by the non-concurrenrs are valid issues, and the non-concurrence resolution did not dispute any of them.

Management Perspective

- The evaluation and disposition of this non-concurrence relied on two things:
 - How the technical issues are currently being handled by the NRC; and
 - How the technical issues relate to the topical report in question.

Current Actions on FFRD

- FFRD at burnups below 62 GWd/MTU are currently not considered to be an immediate safety issue.
 - Section B of the non-concurrence summarizes the reasons for this position.
- The agency continues to seek resolution of the key questions.
 - FFRD PIRT
 - IE rulemaking
 - Etc.

Nexus to WCAP-18446-P/NP

- Westinghouse effectively established a separate basis for acceptability of WCAP-18446-P/NP.
 - WCAP-18446-P/NP was shown to be acceptable within its range of applicability.
 - WCAP-18466-P/NP does not affect the current basis for acceptability of methodologies used to analyze rod average burnups up to 62 GWd/MTU.

Non-Concurrence Resolution

- The technical/safety issues raised by the non-concurrenrs are being handled within other appropriate activities by the agency.
- The specific issues regarding rod burnups below 62 GWd/MTU are not within the scope of WCAP-18446-P/NP, so the limitation proposed by the non-concurrenrs was deemed to not be appropriate as part of a regulatory decision on the acceptability of WCAP-18446-P/NP.

Abbreviations

FFRD	Fuel Fragmentation, Relocation, and Dispersal
GWd/MTU	Gigawatt-days per Metric Ton of Uranium
IE	Increased Enrichment
NRC	U. S. Nuclear Regulatory Commission
PIRT	Phenomena Identification and Ranking Table
WCAP-18446-P/NP	WCAP-18446-P/WCAP-18446-NP, Revision 0, “Incremental Extension of Burnup Limit for Westinghouse and Combustion Engineering Fuel Designs”

**NONCONCURRENCE ON
NRC SAFETY EVALUATION ON
WCAP-18446-P/NP**

**PRESENTATION TO
ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS
FUEL, MATERIALS, AND STRUCTURES
SUBCOMMITTEE**

**OPEN SESSION
APRIL 2, 2024**

**JOHN LEHNING, SR. NUCLEAR ENGINEER
KEVIN HELLER, NUCLEAR ENGINEER**

SUMMARY OF NONCONCURRENCE

- Two technical staff who reviewed WCAP-18446-P/NP are unable to concur upon the NRC's draft safety evaluation conclusions regarding fuel dispersal
- Original safety evaluation drafted by the staff included a limitation and condition requiring licensees implementing WCAP-18446-P/NP to
 - Assess the potential for fuel dispersal from rods with less than 62 GWd/MTU rod-average burnup
 - Justify that the estimated quantity of dispersed fuel does not result in non-compliance with the acceptance criteria in 10 CFR 50.46
- Agency management removed proposed limitation and condition
- Absent the proposed limitation and condition, the nonconcurring staff found insufficient basis to conclude that
 - Plants implementing the methodology would comply with existing regulatory requirements
 - Public health and safety would be adequately protected

PRESENTATION OUTLINE

- **NONCONCURRING STAFF**
- BACKGROUND
- DISCUSSION
- ALTERNATIVES TO
NONCONCURRENCE
- CONCLUSION

NONCONCURRING STAFF

J. Lehning

- 24 years of NRC service
- > 20 years in Division of Safety Systems
- M.S.E. & B.S.E., Nuclear Engineering & Radiological Sciences
- University of Michigan

K. Heller

- > 13 years of NRC service
- All in Division of Safety Systems
- M.S.E & Ph. D., Nuclear Engineering
- B.S., Electrical Engineering
- Pennsylvania State University

- This presentation describes the independent professional judgments of two long-serving employees in the Division of Safety Systems of NRR.
- Presentation is not intended to speak on behalf of the NRC staff

PRESENTATION OUTLINE



- NONCONCURRING STAFF
- **BACKGROUND**
- DISCUSSION
- ALTERNATIVES TO
NONCONCURRENCE
- CONCLUSION

IS THERE A VALID SAFETY QUESTION ASSOCIATED WITH FUEL DISPERSAL?

- The modified safety evaluation includes an assertion that the NRC has a current position that *"fuel dispersal is not a significant safety issue for burnups below 62 GWd/MTU"*
 - No experimental or analytical basis is cited that is capable of supporting such a definitive conclusion
- Meanwhile, recent experimental evidence and analytical calculations suggest that substantial quantities of fuel could be dispersed from the cores of operating reactors during a loss-of-coolant accident:
 - RIL 2021-13 summarizes recent experimental data and describes how fuel fragmentation and dispersal might be modeled
 - NRC staff analyses presented at TOPFUEL and NURETH
 - Additional proprietary information to be discussed in closed session


RAYNAUD & PORTER TOPFUEL PAPER (2014)

- Analysis using FRAPCON/FRAPTRAN and TRACE
- Dispersal of fuel assumed between 55 and 70 GWd/MTU local pellet burnup
 - Three different sensitivities on threshold
- Results at end-of-cycle very sensitive to burnup threshold for dispersal for Westinghouse 4-Loop reactor design
 - Core-average discharge burnup of 54.5 GWd/MTU
 - From ~~105 to 622~~ **35 - 207** kg of dispersed fuel predicted at EOC
- Other reactor designs considered showed no fuel dispersal
 - Combustion Engineering, General Electric BWR/4
 - Very low peak cladding temperatures (<975 K), apparently below rupture temperature for fuel rods susceptible to fragmentation



RESEARCH INFORMATION LETTER 2021-13

- Fuel fragmentation, relocation, and dispersal phenomena are correlated to burnup
 - Fuel dispersal is correlated with fuel fragment size and burst opening size
- Available data indicates that fuel dispersal is limited to fuel with
 - Pellet average burnup > 55 GWd/MTU
 - Cladding strain > 3%
- Modeling approaches in Appendix A can be used to predict the mass of dispersed fuel




	Difference between dispersal predicted by the model and all mobile fuel observed in the experiment	
SCIP test	Mass (g)	Prediction/Measured
OL1104-LOCA-2	125	250%
N05-LOCA	-19	76%
VUR1-LOCA-1	15	109%
WZR0067-LOCA	-16	83%
VUL2-LOCA1	-7	94%
VUL2-LOCA3	8	105%
VUL2-LOCA4	5	102%

BIELLEN, CORSON, STAUDENMEIER NURETH PAPER (2023)

- Analysis using SCALE/Polaris, PARCS/PATHS, TRACE, FAST
- EOL assembly burnups > 71 GWd/MTU
- Mass of fuel was estimated using various models derived from Appendix A of RIL 2021-13
- The paper calculated a percentage fuel dispersal between 0.6% and 3.5%...
- Considering that a large, Westinghouse 4-Loop reactor core, the total weight of UO_2 fuel may be ~100 tons...
 - the dispersed weight of fuel would be between ~0.5 and 4 tons

Parameter	Base Case	Chopped Cosine Power Shape	Top Peak Power Shape	Top Peak Power Shape (1 ECCS train)
Burst rods (%)				
IFBA	64	68	76	78
Non-IFBA	40	32	69	80
Total	58	58	74	78
Fuel dispersal (%)				
All fragment sizes	2.3	2.8	3.5	3.4
Fragments < 1 mm	1.1	1.9	2.1	2.1
Fragments < 1 mm above burst	0.6	1.3	1.1	1.1



Red/magenta = burst
Blue/cyan = non-burst

LHGR (kW/m)

KEY CONTENTION

- Absent further effort, it is not generally possible to conclude with the “*high level of probability*” required in 10 CFR 50.46(a)(1)(i) that compliance has been achieved with relevant regulatory requirements, including
 - coolable core geometry requirement in 10 CFR 50.46(b)(4)
 - long-term core cooling requirement in 10 CFR 50.46(b)(5)
 - equipment performance
- The nonconcurrency therefore advocates for the assessment and resolution of a well-founded safety question regarding fuel dispersal
 - The nonconcurrency is *not* asserting that
 - operating reactors are definitively out of compliance with regulatory requirements
 - corrective actions per 10 CFR 50.109 are necessarily justified
 - Rather, existing NRC processes should be exercised to address these safety questions
 - The NRC should further assure licensees’ regulatory compliance prior to approving additional increases in fuel burnup that could exacerbate the existing safety question

WHERE DO WE FIND THE TECHNICAL BASIS DEMONSTRATING THAT PLANT OPERATION IS SAFE?

- The safety of each operating plant is demonstrated by, among other things, the licensing-basis safety analysis that is typically included in Chapter 15 of the Final Safety Analysis Report
 - Analysis of the loss-of-coolant accident (LOCA) event is typically in Section 15.6.5
- Safety analyses are typically performed using evaluation models approved by the NRC staff for their intended application
 - E.g., Westinghouse's Full-Spectrum LOCA evaluation model

DO EXISTING LOCA ANALYSES OR EVALUATION MODELS ADDRESS FUEL DISPERSAL AND ITS IMPACTS?

- The agency's response to the nonconcurrency states that

The proposed analysis methodology and associated NRC staff evaluation only addresses fuel dispersal in the requested burnup range. Demonstration of compliance with 10 CFR 50.46 requires analysis of all the fuel assemblies in the core, regardless of burnup. Therefore, fuel assemblies with a burnup less than 62 GWd/MTU will continue to require analysis to demonstrate compliance with applicable rules and regulations. Licensees may utilize current approved methodologies to evaluate fuel assemblies for burnups up to 62 GWd/MTU.

- However, all existing LOCA evaluation models and analyses used for demonstrating compliance with the acceptance criteria in 10 CFR 50.46(b) completely neglect the modeling of fuel dispersal and its consequences
 - Can models that do not include the relevant phenomena be considered capable of providing confidence that regulatory compliance exists with respect to fuel dispersal?

NO DETERMINATION OF COMPLIANCE WITH REGULATIONS

- The modified draft safety evaluation does not find it necessary to address regulatory compliance for operating reactors:


... the NRC staff's approval of WCAP-18446-P/WCAP-18446-NP, Revision 0 does not imply any consideration about the acceptability of fuel dispersal for fuel cladding below 62 GWd/MTU peak rod average burnup...

- The nonconcurrency believes a compliance demonstration is necessary, and presses the point in a slightly different direction:
 - Absent additional effort, it is not generally possible to conclude that licensees affected by fuel dispersal are reasonably assured of maintaining a coolable core geometry and complying with other related regulatory requirements
- The nonconcurrency does not, however, go so far as to assert that licensees are definitively out of compliance with applicable regulations
 - Rather, the nonconcurrency advocates that well-founded safety question concerning fuel dispersal should be resolved prior to approval of further fuel burnup increases that could exacerbate existing safety question

WHICH FACTORS HAVE HINDERED A REGULATORY COMPLIANCE DETERMINATION WITH RESPECT TO FUEL DISPERSAL?

- Large uncertainties and significant unknowns exist with respect to physical phenomena governing fuel dispersal and its downstream impacts
- NRC does not have a well-defined, technically defensible agency position concerning what threshold quantity of fuel dispersal would constitute an uncoolable core geometry or result in other unacceptable safety outcomes

CORE COOLED WITH HIGH LEVEL OF PROBABILITY?



UNCERTAINTIES IN FUEL DISPERSAL AND DOWNSTREAM PHENOMENA

- The agency continues to sponsor research on fuel dispersal
 - This research may in the future yield sufficient insights to permit confident estimation of fuel fragmentation, relocation, and dispersal against defensible acceptance criteria
- Furthermore, the agency has used developmental analytical methods to provide the best available insights concerning with fuel dispersal and its impacts
- However, these developmental methods lack the pedigree of existing evaluation models used to satisfy requirements for peak cladding temperature and other 50.46(b) acceptance criteria
 - E.g., developmental approaches for modeling fuel dispersal and its impacts would not satisfy validation criteria or other guidance in RG 1.203, Evaluation Model Development and Assessment Process
 - Large uncertainties even on dispersed quantity (e.g., approximately a factor of 3 to 6 in published journal articles)... let alone downstream impacts


HOW MUCH FUEL DISPERSAL WOULD BE ACCEPTABLE?

- The nonconcurrency argues that the agency's actions regarding WCAP-18446-P/NP do not appear consistent with the existence of clear and documented acceptance criteria for fuel dispersal
 - The specific intent of the coolable core geometry requirement in 10 CFR 50.46(b)(4) with respect to dispersed fuel is not the central issue upon which this non-concurrency is founded
 - However, historical discussion is necessary to support a fulsome contextual understanding of existing regulatory requirements
- As we are considering the historical basis, we should keep in mind
 - While the Commission has delegated to the NRC staff authority to assess compliance with its regulations on routine matters, the NRC staff cannot change or reinterpret regulations
 - Revisions to regulations, including reinterpretation of existing requirements, must be done via rulemaking

COMMISSION'S OPINION ON 10 CFR 50.46 ACCEPTANCE CRITERIA

In its opinion on the matter of the rulemaking hearing on the acceptance criteria for emergency core cooling systems for light-water-cooled nuclear power reactors 10 CFR 50.46, the Commission stated relative to the acceptance criteria for peak cladding temperature and maximum local oxidation that

The purpose of these first two criteria is to ensure that the zircaloy cladding would remain sufficiently intact to retain the UO_2 fuel pellets in their separate fuel rods and therefore remain in an easily coolable array. Conservative calculations indicate that during the postulated LOCA, the cladding of many of the fuel rods would swell and burst locally with a longitudinal split. The split cladding would remain in one piece if it were not too heavily oxidized, and would still restrain the UO_2 pellets.




COMMISSION'S OPINION ON 10 CFR 50.46 CORE COOLABILITY




Concerning the requirement in (b)(4) for a coolable core geometry, the Commission further stated that

If there were no emergency core cooling after a LOCA, the core would probably eventually fuse together into a large mass with insufficient external surface area to allow the fission product heat generated within it to be transferred away. Intermediate steps in arriving at such a state might be the oxidation and melting of the zircaloy cladding, allowing the uranium dioxide fuel pellets to fall together into a heap that would be difficult to cool....

Considering all of the required features of the evaluation models, we are inclined to agree that, for any situation that we have been able to anticipate, this criterion should be superfluous. However, in view of the fundamental and historical importance of maintaining core coolability, we retain this criterion as a basic objective....



IS SIGNIFICANT DISPERSAL OF FUEL CONSISTENT WITH THE INTENT OF 10 CFR 50.46?



DOES REGULATORY COMPLIANCE MATTER?

- Absolutely – as stated in a 2004 Director’s Decision in response to a Union of Concerned Scientists petition concerning the Davis-Besse Nuclear Power Station:

Reasonable assurance of adequate protection of public health and safety is, as a general matter, defined by the Commission’s health and safety regulations themselves.


- An inability to demonstrate regulatory compliance is not logically equivalent to inadequate protection of public health and safety
- However, an inability to demonstrate compliance implies a safety question that should be addressed in a timely manner consistent with the regulator’s public safety mission

WHY ARE WE BEFORE YOU NOW? MISSED OPPORTUNITIES TO RESOLVE FUEL DISPERSAL SAFETY QUESTION

- Generic Issue Program (2011-2016)
 - Issue was submitted and passed acceptance review as generic issue
 - Issue screened out due to potential inclusion in 10 CFR 50.46c proposed rule
 - However, fuel dispersal was not included in 50.46c proposed rule
 - Subsequently, rather than continuing pursuit of fuel dispersal as a generic issue, the issue was closed out in 2016 with a 2-page memorandum
- SECY Paper for Increased Enrichment Rulemaking (2022)
 - Staff recommended a SECY paper to document explicitly the agency's interpretation of the core coolability requirement in 10 CFR 50.46
 - NRC staff anticipated the need to decide licensing requests such as WCAP-18446-P/NP prior to rulemaking completion
 - Agency-selected approach for the increased enrichment rulemaking did not include the recommended paper

WHAT IS THE TIMELINE FOR RESOLVING FUEL DISPERSAL AT OPERATING PLANTS?

Accident Tolerant Fuel (ATF), Increased Enrichment, and Higher Burnup Roadmap to Readiness



Refer to the New Fuels Infographic for information regarding fuel facilities, transportation, and spent fuel storage.



- An intricate timeline with defined dates exists for the licensing of advanced fuel designs (including high burnup)
 - Batch loading of near-term advanced fuel designs for pressurized-water reactors is planned for 2027
- Is an analogous process timeline in place for determining whether operating plants are in compliance with regulatory requirements for fuel dispersal?
 - No, despite the existence of agency processes specifically intended for addressing emergent safety questions

PRESENTATION OUTLINE

- NONCONCURRING STAFF
- BACKGROUND
- **DISCUSSION**
- ALTERNATIVES TO
NONCONCURRENCE
- CONCLUSION

OBJECTIVE OF NONCONCURRENCE

- The foregoing background discussion has discussed at least a few policy matters
 - Determining agency policy extends well beyond the responsibility of working-level technical staff
 - The nonconcurrency is not intended as advocacy for any particular policy
- Rather, technical staff is responsible for and does advocate for
 - Faithfully implementing the Commission's existing regulations
 - Ensuring a valid technical basis exists for agency decisions
- Nonconcurrency at its core simply reflects disagreement with a specific agency decision on the WCAP-18446-P/NP safety evaluation that, in the context of other related actions the agency is taking / not taking:
 - Does not ensure compliance with existing agency regulations
 - Does not provide a valid technical basis to demonstrate protection of public health and safety

BASIS FOR NOT FINDING WCAP-18446-P/NP TREATMENT OF FUEL DISPERSAL ACCEPTABLE

- Licensees cannot be assured of complying with 10 CFR 50.46(b)(4) and other regulatory requirements at the present time
 - Irrespective of whether the WCAP-18446-P/NP methodology would predict additional dispersal of fuel in incremental burnup range
 - Regulations are not concerned with whether excessive fuel dispersal is from fuel rods within current burnup limits or fuel rods in incremental burnup range
 - Plants implementing the methodology cannot be assured of complying with regulatory requirements
- Because existing margins to regulatory requirements may be degraded or negative for plants implementing WCAP-18446-P/NP, sufficient defense-in-depth margin may not be available to accommodate significant, irreducible uncertainties associated with fuel behavior at increased burnup.

SAFETY ISSUES ASSOCIATED WITH PAST BURNUP INCREASES: FUEL FRAGMENTATION / DISPERSAL

- In the 1990s, licensed burnup limits for many types of fuel were increased to approximately 62 GWd/MTU
- The potential for fuel fragmentation and dispersal was not known at the time and not explicitly addressed in the staff's approval of these fuel burnup increases
- Concerns with fragmentation, relocation, and dispersal of fuel are still being recognized and reckoned with now, decades later
- Fuel dispersal in particular is at present not analyzed or addressed within the licensing basis of any plant
 - The licensing basis safety analysis for a plant is the objective rationale presented to the outside world for the safety of the plant
 - Licensing basis analyses should address real phenomena that are significant to the calculation

SAFETY ISSUES ASSOCIATED WITH PAST BURNUP INCREASES: THERMAL CONDUCTIVITY DEGRADATION

- As fuel burnup increases, cracking creates gaps that impede heat transport within a fuel pellet, increasing stored heat
 - Consequently, loss-of-coolant accident results can become more limiting mid-cycle
- Issue was discussed in three information notices between 2009 and 2012
- Licensees have since implemented interim patches to their existing fuel thermal-mechanical analysis methods
- Fuel vendors have since received approval for updated fuel thermal-mechanical methods
 - However, 15 years later, not all licensees have yet adopted approved updated methods
 - WCAP-18446-P/NP safety evaluation, Limitation and Condition 7 is a testament to this fact (staff-imposed condition that implementing licensees must use PAD5 for all safety analyses)

ON THE NEED TO MAINTAIN DEFENSE IN DEPTH MARGIN


- The NRC strives for reasonable assurance of safety, not absolute assurance
 - While agency makes best possible decisions based on available evidence, its judgments are not infallible and new information or issues can emerge:
 - Fuel fragmentation, relocation, and dispersal
 - Thermal conductivity degradation
- Maintaining adequate defense-in-depth margin permits time for safety issue resolution:

Issue Resolution Stage	Fuel Dispersal	Thermal Conductivity Degradation
Issue initiation	1990s	1990s
Latency / issue recognition	2011	~2009
Assessment of significance	In progress (?)	~2009-2012
Interim measures	N/A	~2011-present
Approved solution	N/A	In progress


- If existing safety questions are left unresolved prior as fuel performance is pushed further, can we remain confident in the continued existence of adequate safety margins?

HOW CAN NRC ADDRESS EMERGENT SAFETY QUESTIONS?

Voluntary, forward-looking licensing basis changes



Mandatory backfit per 10 CFR 50.109



HOW CAN NRC ADDRESS EMERGENT SAFETY QUESTIONS? (1)

VOLUNTARY FORWARD-LOOKING CHANGE

- When an applicant agrees to implement a safety improvement, frequently as a condition for obtaining approval for a related, requested licensing action
- Only effective for licensees that voluntarily implement WCAP-18446-P/NP
- Burden of proof to demonstrate regulatory compliance is on licensees
- Use of voluntary, forward-looking change would be appropriate because a positive determination of compliance with relevant regulatory requirements is the basis for protection of public health and safety
 - Absent addressing fuel dispersal within current burnup limits, there is no basis for confidence that existing regulatory requirements are satisfied

HOW CAN NRC ADDRESS EMERGENT SAFETY QUESTIONS? (2)

MANDATORY BACKFIT PER 10 CFR 50.109

- When the NRC uses its statutory authority to require a licensee to implement corrective actions to its facility in accordance with 10 CFR 50.109
- Could be performed generically in a manner that encompasses all operating plants, irrespective of implementation of WCAP-18446-P/NP or other licensing actions
- Burden of proof is on staff to demonstrate:
 - Not only regulatory compliance
 - But also adequate cost-benefit justification
- Performance of a backfit evaluation for all operating plants would be appropriate because
 - Assuring a coolable core geometry is fundamental to reactor safety
 - A valid rationale for agency action / inaction supports principles of good regulation

PRESENTATION OUTLINE

- NONCONCURRING STAFF
- BACKGROUND
- DISCUSSION
- **ALTERNATIVES TO
NONCONCURRENCE**
- CONCLUSION

ALTERNATIVE 1:ISSUE SAFETY EVALUATION WITH A LIMITATION AND CONDITION

- Original draft safety evaluation had included a limitation and condition requiring licensees implementing WCAP-18446-P/NP to assess fuel dispersal and assure compliance with 10 CFR 50.46(b)(4):

“Licensees implementing WCAP-18446-P/WCAP-18446-NP, Revision 0, shall assess the potential for fuel dispersal from fuel rods with less than 62 GWd/MTU rod-average burnup and justify that the estimated quantity of dispersed fuel does not result in non-compliance with the acceptance criteria in 10 CFR 50.46.”

- Discussion clarifying how it could be addressed was also included:

“...the NRC staff has phrased Limitation and Condition 11 in a performance-based fashion that would allow licensees implementing WCAP-18446-P/WCAP-18446-NP to consider information and regulatory positions developed under the rulemaking process in the resolution of the limitation and condition.”

ALTERNATIVE 1:ISSUE SAFETY EVALUATION WITH A LIMITATION AND CONDITION (2)

- Limitation was not intended to mandate that licensees implementing WCAP-18446-P/NP must demonstrate zero fuel dispersal (or any other particular dispersal limit)
 - Proposed limitation was rather intended as a flexible, performance-based requirement to
 - Assess fuel dispersal - which has up through the present, not been evaluated with technically defensible methods within any operating plant's licensing basis
 - Justify that compliance exists with applicable regulatory requirements
 - NRC staff has considerable latitude to impose such limitations and conditions where necessary to reach a finding of regulatory compliance
- NRC management removal of the proposed limitation and condition prompted the nonconcurrence of the two technical staff reviewers

ALTERNATIVE 2: PERFORM A BACKFIT EVALUATION FOR ALL OPERATING REACTORS

- Issue the WCAP-18446-P/NP safety evaluation with a commitment that the NRC would initiate a timely backfit evaluation to assess for all affected licensees whether imposition of corrective actions to address impacts of fuel dispersal within existing burnup limits is justified.
- Would establish a clear, public commitment to perform a timely, comprehensive assessment of:
 - Whether licensees are in compliance with existing regulatory requirements
 - Any corrective actions necessary to assure adequate protection of public health and safety and regulatory compliance against 10 CFR 50.109
- Completion of such an evaluation would encompass all evaluations and any corrective actions necessary to address fuel dispersal for plants that could potentially adopt WCAP-18446-P/NP (i.e., the focus of this nonconcurrency)

ALTERNATIVE 2: PERFORM A BACKFIT EVALUATION FOR ALL OPERATING REACTORS (2)

- A public commitment in the safety evaluation for WCAP-18446-P/NP to complete a comprehensive backfit evaluation would provide:
 - Adequate assurance the safety evaluation could be issued at the present time, because
 - A reasonable expectation would exist that the backfit results would be available prior to the agency's passing judgment on requests to adopt WCAP-18446-P/NP
- Non-concurring staff would find a public commitment to performing a backfit analysis an acceptable alternative to nonconcurrency
- NRC management did not agree with this alternative

ALTERNATIVE 3: DELAY SAFETY EVALUATION UNTIL REGULATORY COMPLIANCE IS DETERMINED

- Delay issuance of the WCAP-18446-P/NP safety evaluation and regulatory determination concerning its acceptability until validated analytical capabilities can be established to
 - Quantify how much fuel may be dispersed under LOCA conditions
 - Assess downstream impacts
- As elaborated earlier, defining acceptance criteria and performing calculations for fuel dispersal and downstream impacts remains a significant challenge
- Ongoing research, some of which is connected to the increased enrichment rulemaking, may result in validation and modeling enhancements that could better resolve fuel dispersal and its impacts

ALTERNATIVE 3: DELAY SAFETY EVALUATION UNTIL REGULATORY COMPLIANCE IS DETERMINED (2)

- Non-concurring staff would find this approach acceptable
 - Allow time to develop an adequate technical basis for evaluating fuel dispersal
 - Technical basis would determine with reasonable assurance whether licensees implementing the methodology would be in compliance with 10 CFR 50.46(b)(4) and other requirements
- NRC management did not agree with this alternative

ALTERNATIVE 4: ISSUE SAFETY EVALUATION AND PROPOSE FUEL DISPERSAL AS A GENERIC ISSUE

- At present, the generic issue process appears incapable of determining in a timely manner how much fuel may be dispersed under LOCA conditions and the downstream impacts
 - Section IV of Management Directive 6.4 indicates the three-stage process for resolving generic issues may take between 6.75 and 14.5 years
 - Whereas, licensees may begin requesting implementation of fuel burnup increases as soon as WCAP-18446-P/NP is approved
- While potentially viable in 2011 (when fuel dispersal was first raised as a generic issue), referral to the generic issue program no longer appears capable of providing adequate basis for issuance of the safety evaluation
- Non-concurring staff do not find this approach acceptable

ALTERNATIVE 5:ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH

- The management-endorsed, modified safety evaluation essentially follows Alternative 5 as described in the nonconcurrency
- The nonconcurring technical staff support further testing and analysis to resolve the fuel dispersal issue
- However, the management-proposed approach to approve burnup increases before research and analysis is completed to demonstrate compliance with NRC regulations does not appear sufficient to protect public health and safety because
 - Future research plans, and any speculation concerning possible insights therefrom, should not influence present regulatory decisions
 - Regulatory conclusions should be based upon currently available knowledge of fuel dispersal and the methodology's compliance with current regulatory requirements

ALTERNATIVE 5:ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH (2)

- The modified safety evaluation asserts that the NRC has a current position that *"fuel dispersal is not a significant safety issue for burnups below 62 GWd/MTU"*
- It is not clear to the nonconcurring staff how NRC management reached a conclusion that fuel dispersal is not a significant safety issue
 - No validated, licensing-basis safety analysis including the impacts of fuel dispersal has been performed for any operating reactors
 - No comprehensive compliance determination or backfit analysis has been performed for the fleet of operating reactors
- For the nonconcurring technical staff, the limited available evidence remains insufficient to justify a definitive conclusion regarding the safety significance of fuel dispersal
 - Fuel dispersal remains an open safety question that should be addressed before concluding WCAP-18446-P/NP demonstrates compliance with regulatory requirements

ALTERNATIVE 5:ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH (3)


- The management-modified draft safety evaluation further notes that the NRC is sponsoring a PIRT on impacts of fuel dispersal
- The non-concurring staff note the agency's decision to perform such an exercise appears to acknowledge limited knowledge and significant open questions regarding fuel dispersal and its impacts
 - A PIRT is typically performed early in the process of analyzing a potential safety concern to identify and rank phenomena to focus upon in further experiments and analysis
- Is the acknowledged need for such basic research as a PIRT consonant with the definitive conclusion that *"fuel dispersal is not a significant safety issue for burnups below 62 GWd/MTU"*?

ALTERNATIVE 5:ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH (4)

- The modified safety evaluation notes that NRC will take appropriate regulatory action if future research challenges the NRC's position
- Non-concurring staff would agree appropriate regulatory action should be taken when a safety issue is identified after the NRC has made a regulatory decision, however:
 - The analytical effort involved with a backfit is far from trivial
 - The capability to justify imposing corrective actions per 10 CFR 50.109 is far from assured
 - The possible capability to impose corrective action via backfit is not an appropriate substitute for making an evidence-based, safety-focused, up-front decision

ALTERNATIVE 5: ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH (5)

- Considering the abstract nature of a PIRT, it appears unlikely, on its own, to be capable of confirming or refuting the safety significance of fuel dispersal for all operating reactors
- Definitive confirmation or refutation typically occurs via further downstream research or analysis for which the PIRT serves merely as a foundation
 - At present, such research and analyses sufficient to address fuel dispersal impacts at operating plants remain undefined and unscheduled
 - This indeterminacy is in contrast with the agency’s roadmap for implementing increased fuel burnup, which has a detailed plan for achieving implementation by 2027



ALTERNATIVE 5:ISSUE SAFETY EVALUATION WHILE CONTINUING FUEL DISPERSAL RESEARCH (6)

- The modified safety evaluation indicates an expectation that the conclusions of future research will not conflict with the staff's findings regarding WCAP-18446-P/NP
- However, no objective basis for this expectation is apparent
 - If the agency's knowledge in an area were already reasonably assured, additional research or analysis in that area would be unnecessary to reach a regulatory conclusion
 - Yet the agency has deemed additional research necessary, and this research is currently at an early stage
- Ultimately, the modified safety evaluation makes no conclusion regarding whether operating reactors are currently in compliance with applicable regulations
- An approach that relies upon the results of future research cannot assure that licensees implementing WCAP-18446-P/NP would be in compliance with regulatory requirements regarding fuel dispersal in the present
- The nonconcurring staff do not find this approach acceptable

ALTERNATIVE 6: ISSUE SAFETY EVALUATION; PRESUME FUEL DISPERSAL ADDRESSED BY RULEMAKING

- The NRC staff is currently developing a proposed rule for the Commission's consideration concerning increased enrichment and has been directed to address fuel fragmentation, relocation, and dispersal therein
- The nonconcurring staff would support consideration of any dispersed fuel, irrespective of burnup, in the increased enrichment rulemaking
 - Considering the stated position in the modified safety evaluation that fuel dispersal within existing burnup limits is not a significant safety issue, its fate remains unclear
- Ultimately, neither the Commission's decisions concerning the content and acceptability of the proposed rule, nor its timeline, are knowable in the present
- The nonconcurring staff could not concur with issuing a safety evaluation that does not assess compliance with existing NRC regulations, under the presumption that a future rulemaking effort would allow substantial fuel dispersal

PRESENTATION OUTLINE

- NONCONCURRING STAFF
- BACKGROUND
- DISCUSSION
- ALTERNATIVES TO
NONCONCURRENCE
- **CONCLUSION**

CONCLUSION

- Two individual staff have nonconcurred upon a management-modified draft safety evaluation associated with increased fuel burnups and fuel dispersal
 - The individual staff could not concur upon the safety evaluation's treatment of fuel dispersal
 - The safety evaluation is incapable of ensuring compliance with existing NRC regulations concerning core cooling and thereby assuring adequate protection of public health and safety
- Past agency decisions have not contributed to the effective resolution of the fuel dispersal safety question on a more generic basis
 - Decision not to fully assess fuel dispersal under Generic Issue program
 - Decision not to pursue a SECY paper to define intent of existing regulations
 - Decision not to pursue forward-looking regulatory action to address issue for licensees implementing WCAP-18446-P/NP
 - Decision not to undertake a generic backfit evaluation to address issue
- Fuel dispersal is an ongoing safety question that is not currently addressed in the safety analyses for operating reactors
 - The path forward for assessing and as necessary resolving the issue remains indeterminate
 - Even as well-defined plans further to increase fuel burnup continue to move forward

Meeting title
WCAP-18446-P Subcommittee
4/2/2024

Participants

13015209375
16307303055
17073184109
Anness, Michael, Westinghouse
Ashley Smith, NRC
Bachrach, Uriel, Westinghouse
Barber, Kevin J., Westinghouse
BAXTER Bob (FRA-FL), FRAMATOME
Benjamin Parks (He/Him/His), NRC
Bowman, Andrew, Westinghouse
Bradfute, Jeffrey L., Westinghouse
Brandon Wise, NRC
Christina Antonescu, ACRS
Christopher Brown, ACRS
CLIFFORD Paul (External), FRAMATOME
Dennis Bley (Guest), ACRS
Derek Widmayer, ACRS
Ekaterina Lenning, NRC
GERKEN Lisa (FRA-FL), FRAMATOME
Gerond George, NRC
Gregory Halnon, ACRS
harold scott
Harper, Zachary S., Westinghouse
Higby, William D., Westinghouse
HOLM Jerald (External), FRAMATOME
Jakub, Robert, Westinghouse
John Lehning, NRC
Joseph Messina, NRC
Josh Whitman, NRC
Joshua Kaizer, NRC
Kobelak, Jeffrey R., Westinghouse
Kris Cummings (NuScale)
Laird, James N., Westinghouse
Larry Burkhart, ACRS
Long, Yun, Westinghouse
Mackereth, Nathaniel J., Westinghouse
Mitchell, David B., Westinghouse
Rob Krsek (He/Him), ACRS
Robert Martin (He/Him), ACRS
Sam Wojack, Neal Gross (Court Reporter)
Sandra Walker, ACRS
Scott Krepel, NRC
Sivack, Michael R., Westinghouse

Sung, Yixing, Westinghouse
Tammy Skov, ACRS
Thomas Dashiell, ACRS
Vesna B Dimitrijevic (Guest), ACRS
WISSINGER Gordo (FRA-FL), FRAMATOME
Zena Abdullahi, ACRS