



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 29, 2024

Edward Casulli
Site Vice President
Susquehanna Nuclear, LLC
769 Salem Boulevard
NUCSB3
Berwick, PA 18603-0467

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – ISSUANCE
OF AMENDMENT NOS. 288 AND 272 RE: ADOPTION OF TSTF-563
(EPID L-2023-LLA-0153)

Dear Edward Casulli:

The U.S. Nuclear Regulatory Commission (NRC or the Commission) has issued the enclosed Amendment Nos. 288 and 272 to Renewed Facility Operating License Nos. NPF-14 and NPF-22, respectively, for the Susquehanna Steam Electric Station, Unit 1 and Unit 2. The amendments consist of changes to the technical specifications (TSs) in response to Susquehanna Nuclear, LLC's application dated November 2, 2023. The amendments revise TS 1.1, "Definitions," to adopt Technical Specifications Task Force (TSTF) Traveler TSTF-563, "Revise Instrument Testing Deficiencies to Incorporate the Surveillance Frequency Control Program," with plant-specific variations. The NRC's safety evaluation for the amendments is enclosed. The NRC will include a notice of issuance in its monthly *Federal Register* notice.

Sincerely,

/RA/

Audrey L. Klett, Senior Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosures:

1. Amendment No. 288 to License No. NPF-14
2. Amendment No. 272 to License No. NPF-22
3. Safety Evaluation

cc: Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SUSQUEHANNA NUCLEAR, LLC

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 288
Renewed License No. NPF-14

1. The U.S. Nuclear Regulatory Commission has found that:
 - A. The application for the amendment filed by Susquehanna Nuclear, LLC, dated November 2, 2023, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Renewed Facility Operating License and Technical Specifications, as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-14 is hereby amended to read, in part, as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 288, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. Susquehanna Nuclear, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Hipólito González, Chief
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed
Facility Operating License
and Technical Specifications

Date of Issuance: May 29, 2024

ATTACHMENT TO LICENSE AMENDMENT NO. 288

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

RENEWED FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following page of Renewed Facility Operating License No. NPF-14 with the attached revised page. The revised page is identified by amendment number and contains a marginal line indicating the area of change.

Remove
Page 3

Insert
Page 3

Replace the following page of the appendix A technical specifications with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove

Insert

1.1-1

1.1-1

1.1-2

1.1-2

1.1-3

1.1-3

1.1-3a

1.1-3a

1.1-4

1.1-4

1.1-5

1.1-5

1.1-6

1.1-6

1.1-7

1.1-7

- (3) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed neutron sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
 - (4) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
 - (5) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

Susquehanna Nuclear, LLC is authorized to operate the facility at reactor core power levels not in excess of 3952 megawatts thermal in accordance with the conditions specified herein. The preoperational tests, startup tests and other items identified in License Conditions 2.C.(36), 2.C.(37), 2.C.(38), and 2.C.(39) to this license shall be completed as specified.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 288, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. Susquehanna Nuclear, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

For Surveillance Requirements (SRs) that are new in Amendment 178 to Facility Operating License No. NPF-14, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 178. For SRs that existed prior to Amendment 178, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the Surveillance was last performed prior to implementation of Amendment 178.

1.0 USE AND APPLICATION

1.1 Definitions

----- NOTE -----

The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications and Bases.

<u>Term</u>	<u>Definition</u>
ACTIONS	ACTIONS shall be that part of a Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times.
AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)	The APLHGR shall be applicable to a specific planar height and is equal to the sum of the LHGRs for all the fuel rods in the specified bundle at the specified height divided by the number of fuel rods in the fuel bundle at the height.
CHANNEL CALIBRATION	A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass all devices in the channel required for channel OPERABILITY and the CHANNEL FUNCTIONAL TEST. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an in place qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CHANNEL CHECK	A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.

(continued)

1.1 Definitions (continued)

CHANNEL FUNCTIONAL TEST	A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY of all devices in the channel required for channel OPERABILITY. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CORE ALTERATION	<p>CORE ALTERATION shall be the movement of any fuel, sources, or reactivity control components, within the reactor vessel with the vessel head removed and fuel in the vessel. The following exceptions are not considered to be CORE ALTERATIONS:</p> <ul style="list-style-type: none"> a. Movement of source range monitors, local power range monitors, intermediate range monitors, traversing incore probes, or special movable detectors (including undervessel replacement); and b. Control rod movement, provided there are no fuel assemblies in the associated core cell. <p>Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.</p>
CORE OPERATING LIMITS REPORT (COLR)	The COLR is the unit specific document that provides cycle specific parameter limits for the current reload cycle. These cycle specific limits shall be determined for each reload cycle in accordance with Specification 5.6.5. Plant operation within these limits is addressed in individual Specifications.
DOSE EQUIVALENT I-131	DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries per gram) which alone would produce the same total effective dose equivalent (sum of committed effective dose equivalent {CEDE} from inhalation plus deep dose equivalent {DDE} or nominally equivalent to the effective dose equivalent {EDE} from external exposure {submersion}) as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The conversion factors that are used for this calculation of

(continued)

1.1 Definitions

DOSE EQUIVALENT I-131 (continued)

committed effective dose equivalent (CEDE) from inhalation shall be those listed in Table 2.1 of Federal Guidelines Report 11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion," EPA, 1988, as described in Regulatory Guide 1.183. The factors in the column headed "effective" yield doses corresponding to the CEDE. The conversion factors that are used for the calculation of EDE (or DDE) from external exposure (submersion) shall be those listed in Table III.1 of Federal Guidance Report 12, "External Exposure to Radionuclides in Air, Water, and Soil," EPA, 1993, as described in Regulatory Guide 1.183. The factors in the column headed "effective" yield doses corresponding to the EDE.

DRAIN TIME

The DRAIN TIME is the time it would take for the water inventory in and above the Reactor Pressure Vessel (RPV) to drain to the top of the active fuel (TAF) seated in the RPV assuming:

- a) The water inventory above the TAF is divided by the limiting drain rate;
- b) The limiting drain rate is the larger of the drain rate through a single penetration flow path with the highest flow rate, or the sum of the drain rates through multiple penetration flow paths susceptible to a common mode failure for all penetration flow paths below the TAF except:
 1. Penetration flow paths connected to an intact closed system, or isolated by manual or automatic valves that are closed and administratively controlled in the closed position, blank flanges, or other devices that prevent flow of reactor coolant through the penetration flow paths;
 2. Penetration flow paths capable of being isolated by valves that will close automatically without offsite power prior to the RPV water level being equal to the TAF when actuated by RPV water level isolation instrumentation; or

(continued)

1.1 Definitions

DRAIN TIME (continued)

3. Penetration flow paths with isolation devices that can be closed prior to the RPV water level being equal to the TAF by a dedicated operator trained in the task, who in continuous communication with the control room, is stationed at the controls, and is capable of closing the penetration flow path isolation device without offsite power.
- c) The penetration flow paths required to be evaluated per paragraph b) are assumed to open instantaneously and are not subsequently isolated, and no water is assumed to be subsequently added to the RPV water inventory;
- d) No additional draining events occur; and
- e) Realistic cross-sectional areas and drain rates are used.

A bounding DRAIN TIME may be used in lieu of a calculated value.

EMERGENCY CORE COOLING SYSTEM (ECCS) RESPONSE TIME

The ECCS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its ECCS initiation setpoint at the channel sensor until the ECCS equipment is capable of performing its safety function (i.e., the valves travel to their required positions, pump discharge pressures reach their required values, etc.). Times shall include diesel generator starting and sequence loading delays, where applicable. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

END OF CYCLE RECIRCULATION PUMP TRIP (EOC RPT) SYSTEM RESPONSE TIME

The EOC RPT SYSTEM RESPONSE TIME shall be that time interval from initial signal generation by the associated turbine stop valve limit switch or from when the turbine control valve hydraulic oil control oil pressure drops below the pressure switch setpoint to complete suppression of the electric arc between the fully open contacts of the recirculation pump circuit breaker. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

(continued)

1.1 Definitions (continued)

**ISOLATION SYSTEM
RESPONSE TIME**

The ISOLATION SYSTEM RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its isolation initiation setpoint at the channel sensor until the isolation valves travel to their required positions. Times shall include diesel generator starting and sequence loading delays, where applicable. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

LEAKAGE

LEAKAGE shall be:

a. Identified LEAKAGE

1. LEAKAGE into the drywell, such as that from pump seals or valve packing, that is captured and conducted to a collecting tank; or
2. LEAKAGE into the drywell atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be pressure boundary LEAKAGE;

b. Unidentified LEAKAGE

All LEAKAGE into the drywell that is not identified LEAKAGE;

c. Total LEAKAGE

Sum of the identified and unidentified LEAKAGE;

d. Pressure Boundary LEAKAGE

LEAKAGE through a nonisolable fault in a Reactor Coolant System (RCS) component body, pipe wall, or vessel wall.

**LINEAR HEAT GENERATION
RATE (LHGR)**

The LHGR shall be the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length.

(continued)

1.1 Definitions (continued)

LOGIC SYSTEM FUNCTIONAL TEST	A LOGIC SYSTEM FUNCTIONAL TEST shall be a test of all required logic components (i.e., all required relays and contacts, trip units, solid state logic elements, etc.) of a logic circuit, from as close to the sensor as practicable up to, but not including, the actuated device, to verify OPERABILITY. The LOGIC SYSTEM FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total system steps so that the entire logic system is tested.
MINIMUM CRITICAL POWER RATIO (MCPR)	The MCPR shall be the smallest critical power ratio (CPR) that exists in the core for each class of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.
MODE	A MODE shall correspond to any one inclusive combination of mode switch position, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
OPERABLE - OPERABILITY	A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PHYSICS TESTS	<p>PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation.</p> <p>These tests are:</p> <ol style="list-style-type: none">Described in Chapter 14, Initial Test Program of the FSAR;Authorized under the provisions of 10 CFR 50.59; or

(continued)

1.1 Definitions

PHYSICS TESTS (continued)	c. Otherwise approved by the Nuclear Regulatory Commission.
RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3952 MWt.
REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The RPS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RPS trip setpoint at the channel sensor until de-energization of the scram pilot valve solenoids. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.
SHUTDOWN MARGIN (SDM)	<p>SDM shall be the amount of reactivity by which the reactor is subcritical or would be subcritical throughout the operating cycle assuming that:</p> <ul style="list-style-type: none"> a. The reactor is xenon free; b. The moderator temperature is $\geq 68^{\circ}\text{F}$, corresponding to the most reactive state; and c. All control rods are fully inserted except for the single control rod of highest reactivity worth, which is assumed to be fully withdrawn. With control rods not capable of being fully inserted, the reactivity worth of these control rods must be accounted for in the determination of SDM.
STAGGERED TEST BASIS	A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during n Surveillance Frequency intervals, where n is the total number of systems, subsystems, channels, or other designated components in the associated function.
THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

(continued)

1.1 Definitions (continued)

TURBINE BYPASS SYSTEM
RESPONSE TIME

The TURBINE BYPASS SYSTEM RESPONSE TIME consists of the time from when the turbine bypass control unit generates a turbine bypass valve flow signal until the turbine bypass valves travel to their required positions. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SUSQUEHANNA NUCLEAR, LLC

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 272
Renewed License No. NPF-22

1. The U.S. Nuclear Regulatory Commission has found that:
 - A. The application for the amendment filed by Susquehanna Nuclear, LLC, dated November 2, 2023, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Renewed Facility Operating License and Technical Specifications, as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-22 is hereby amended to read, in part, as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 272, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. Susquehanna Nuclear, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Hipólito González, Chief
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed
Facility Operating License
and Technical Specifications

Date of Issuance: May 29, 2024

ATTACHMENT TO LICENSE AMENDMENT NO. 272

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

RENEWED FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following page of Renewed Facility Operating License No. NPF-22 with the attached revised page. The revised page is identified by amendment number and contains a marginal line indicating the area of change.

Remove

Page 3

Insert

Page 3

Replace the following page of the appendix A technical specifications with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove

1.1-1

1.1-2

1.1-3

1.1-3a

1.1-4

1.1-5

1.1-6

1.1-7

Insert

1.1-1

1.1-2

1.1-3

1.1-3a

1.1-4

1.1-5

1.1-6

1.1-7

- (3) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed neutron sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
 - (4) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
 - (5) Susquehanna Nuclear, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70 to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

Susquehanna Nuclear, LLC is authorized to operate the facility at reactor core power levels not in excess of 3952 megawatts thermal in accordance with the conditions specified herein. The preoperational tests, startup tests and other items identified in License Conditions 2.C.(20), 2.C.(21), 2.C.(22), and 2.C.(23) to this license shall be completed as specified.

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 272, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. Susquehanna Nuclear, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

For Surveillance Requirements (SRs) that are new in Amendment 151 to Facility Operating License No. NPF-22, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 151. For SRs that existed prior to Amendment 151, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the Surveillance was last performed prior to implementation of Amendment 151.

1.0 USE AND APPLICATION

1.1 Definitions

----- NOTE -----
 The defined terms of this section appear in capitalized type and are applicable throughout these Technical Specifications and Bases.

<u>Term</u>	<u>Definition</u>
ACTIONS	ACTIONS shall be that part of a Specification that prescribes Required Actions to be taken under designated Conditions within specified Completion Times.
AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)	The APLHGR shall be applicable to a specific planar height and is equal to the sum of the LHGRs for all the fuel rods in the specified bundle at the specified height divided by the number of fuel rods in the fuel bundle at the height.
CHANNEL CALIBRATION	A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass all devices in the channel required for channel OPERABILITY and the CHANNEL FUNCTIONAL TEST. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an in place qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CHANNEL CHECK	A CHANNEL CHECK shall be the qualitative assessment, by observation, of channel behavior during operation. This determination shall include, where possible, comparison of the channel indication and status to other indications or status derived from independent instrument channels measuring the same parameter.

(continued)

1.1 Definitions (continued)

CHANNEL FUNCTIONAL TEST	A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY of all devices in the channel required for channel OPERABILITY. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.
CORE ALTERATION	<p>CORE ALTERATION shall be the movement of any fuel, sources, or reactivity control components, within the reactor vessel with the vessel head removed and fuel in the vessel. The following exceptions are not considered to be CORE ALTERATIONS:</p> <ul style="list-style-type: none"> a. Movement of source range monitors, local power range monitors, intermediate range monitors, traversing incore probes, or special movable detectors (including undervessel replacement); and b. Control rod movement, provided there are no fuel assemblies in the associated core cell. <p>Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe position.</p>
CORE OPERATING LIMITS REPORT (COLR)	The COLR is the unit specific document that provides cycle specific parameter limits for the current reload cycle. These cycle specific limits shall be determined for each reload cycle in accordance with Specification 5.6.5. Plant operation within these limits is addressed in individual Specifications.
DOSE EQUIVALENT I-131	DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries per gram) which alone would produce the same total effective dose equivalent (sum of committed effective dose equivalent {CEDE} from inhalation plus deep dose equivalent {DDE} or nominally equivalent to the effective dose equivalent {EDE} from external exposure {submersion}) as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The conversion factors that are used for this calculation of

(continued)

1.1 Definitions

DOSE EQUIVALENT I-131 (continued)

committed effective dose equivalent (CEDE) from inhalation shall be those listed in Table 2.1 of Federal Guidelines Report 11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion," EPA, 1988, as described in Regulatory Guide 1.183. The factors in the column headed "effective" yield doses corresponding to the CEDE. The conversion factors that are used for the calculation of EDE (or DDE) from external exposure (submersion) shall be those listed in Table III.1 of Federal Guidance Report 12, "External Exposure to Radionuclides in Air, Water, and Soil," EPA, 1993, as described in Regulatory Guide 1.183. The factors in the column headed "effective" yield doses corresponding to the EDE.

DRAIN TIME

The DRAIN TIME is the time it would take for the water inventory in and above the Reactor Pressure Vessel (RPV) to drain to the top of the active fuel (TAF) seated in the RPV assuming:

- a) The water inventory above the TAF is divided by the limiting drain rate;
- b) The limiting drain rate is the larger of the drain rate through a single penetration flow path with the highest flow rate, or the sum of the drain rates through multiple penetration flow paths susceptible to a common mode failure for all penetration flow paths below the TAF except:
 1. Penetration flow paths connected to an intact closed system, or isolated by manual or automatic valves that are closed and administratively controlled in the closed position, blank flanges, or other devices that prevent flow of reactor coolant through the penetration flow paths;
 2. Penetration flow paths capable of being isolated by valves that will close automatically without offsite power prior to the RPV water level being equal to the TAF when actuated by RPV water level isolation instrumentation; or

(continued)

1.1 Definitions

DRAIN TIME (continued)

3. Penetration flow paths with isolation devices that can be closed prior to the RPV water level being equal to the TAF by a dedicated operator trained in the task, who in continuous communication with the control room, is stationed at the controls, and is capable of closing the penetration flow path isolation device without offsite power.
- c) The penetration flow paths required to be evaluated per paragraph b) are assumed to open instantaneously and are not subsequently isolated, and no water is assumed to be subsequently added to the RPV water inventory;
 - d) No additional draining events occur; and
 - e) Realistic cross-sectional areas and drain rates are used.

A bounding DRAIN TIME may be used in lieu of a calculated value.

EMERGENCY CORE COOLING SYSTEM (ECCS) RESPONSE TIME

The ECCS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its ECCS initiation setpoint at the channel sensor until the ECCS equipment is capable of performing its safety function (i.e., the valves travel to their required positions, pump discharge pressures reach their required values, etc.). Times shall include diesel generator starting and sequence loading delays, where applicable. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

END OF CYCLE RECIRCULATION PUMP TRIP (EOC RPT) SYSTEM RESPONSE TIME

The EOC RPT SYSTEM RESPONSE TIME shall be that time interval from initial signal generation by the associated turbine stop valve limit switch or from when the turbine control valve hydraulic oil control oil pressure drops below the pressure switch setpoint to complete suppression of the electric arc between the fully open contacts of the recirculation pump circuit breaker. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

(continued)

1.1 Definitions (continued)

**ISOLATION SYSTEM
RESPONSE TIME**

The ISOLATION SYSTEM RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its isolation initiation setpoint at the channel sensor until the isolation valves travel to their required positions. Times shall include diesel generator starting and sequence loading delays, where applicable. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

LEAKAGE

LEAKAGE shall be:

a. Identified LEAKAGE

1. LEAKAGE into the drywell, such as that from pump seals or valve packing, that is captured and conducted to a collecting tank; or
2. LEAKAGE into the drywell atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be pressure boundary LEAKAGE;

b. Unidentified LEAKAGE

All LEAKAGE into the drywell that is not identified LEAKAGE;

c. Total LEAKAGE

Sum of the identified and unidentified LEAKAGE;

d. Pressure Boundary LEAKAGE

LEAKAGE through a nonisolable fault in a Reactor Coolant System (RCS) component body, pipe wall, or vessel wall.

**LINEAR HEAT GENERATION
RATE (LHGR)**

The LHGR shall be the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length.

(continued)

1.1 Definitions (continued)

LOGIC SYSTEM FUNCTIONAL TEST	A LOGIC SYSTEM FUNCTIONAL TEST shall be a test of all required logic components (i.e., all required relays and contacts, trip units, solid state logic elements, etc.) of a logic circuit, from as close to the sensor as practicable up to, but not including, the actuated device, to verify OPERABILITY. The LOGIC SYSTEM FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total system steps so that the entire logic system is tested.
MINIMUM CRITICAL POWER RATIO (MCPR)	The MCPR shall be the smallest critical power ratio (CPR) that exists in the core for each class of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.
MODE	A MODE shall correspond to any one inclusive combination of mode switch position, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
OPERABLE - OPERABILITY	A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PHYSICS TESTS	<p>PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation.</p> <p>These tests are:</p> <ol style="list-style-type: none"> a. Described in Chapter 14, Initial Test Program of the FSAR; b. Authorized under the provisions of 10 CFR 50.59; or

(continued)

1.1 Definitions

PHYSICS TESTS (continued)	c. Otherwise approved by the Nuclear Regulatory Commission.
RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3952 MWt.
REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The RPS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RPS trip setpoint at the channel sensor until de-energization of the scram pilot valve solenoids. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.
SHUTDOWN MARGIN (SDM)	SDM shall be the amount of reactivity by which the reactor is subcritical or would be subcritical throughout the operating cycle assuming that: <ul style="list-style-type: none"> a. The reactor is xenon free; b. The moderator temperature is $\geq 68^{\circ}\text{F}$, corresponding to the most reactive state; and c. All control rods are fully inserted except for the single control rod of highest reactivity worth, which is assumed to be fully withdrawn. With control rods not capable of being fully inserted, the reactivity worth of these control rods must be accounted for in the determination of SDM.
STAGGERED TEST BASIS	A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during n Surveillance Frequency intervals, where n is the total number of systems, subsystems, channels, or other designated components in the associated function.
THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

(continued)

1.1 Definitions (continued)

TURBINE BYPASS SYSTEM
RESPONSE TIME

The TURBINE BYPASS SYSTEM RESPONSE TIME consists of the time from when the turbine bypass control unit generates a turbine bypass valve flow signal until the turbine bypass valves travel to their required positions. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION FOR

AMENDMENT NO. 288 TO RENEWED FACILITY OPERATING LICENSE NO. NPF-14

AMENDMENT NO. 272 TO RENEWED FACILITY OPERATING LICENSE NO. NPF-22

SUSQUEHANNA NUCLEAR, LLC

ALLEGHENY ELECTRIC COOPERATIVE, INC.

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1 AND UNIT 2

DOCKET NOS. 50-387 AND 50-388

1.0 INTRODUCTION

By application dated November 2, 2023 (Agencywide Documents Access and Management System Accession No. ML23306A198), Susquehanna Nuclear, LLC (the licensee) submitted a license amendment request (LAR) to revise the technical specifications (TSs) for Susquehanna Steam Electric Station (Susquehanna), Units 1 and 2.

The amendments would revise the current instrumentation testing definitions of channel calibration and channel functional test to permit determination of the appropriate frequency to perform the surveillance requirement (SR) based on the devices being tested in each step. The proposed changes are based on Technical Specifications Task Force (TSTF) Traveler TSTF-563, Revision 0, "Revise Instrument Testing Definitions to Incorporate the Surveillance Frequency Control Program," dated May 10, 2017 (ML17130A819). The U.S. Nuclear Regulatory Commission (NRC or the Commission) issued a final safety evaluation (SE) approving TSTF-563, Revision 0, on December 4, 2018 (ML18333A152).

A surveillance frequency control program (SFCP) was incorporated into the TSs by license amendment nos. 266 and 247 for Susquehanna, Units 1 and 2, respectively, dated May 20, 2016 (ML16005A234).

The licensee has proposed variations from the TS changes described in TSTF-563. The variations are described in section 2.2 of this SE and evaluated in section 3.2.

2.0 REGULATORY EVALUATION

2.1 Description of SFCP and Instrument Testing

The TSs require the surveillances for instrumentation channels be performed within the specified frequency using any series of sequential, overlapping, or total channel steps. License amendment nos. 266 and 247 revised the TSs to relocate all periodic surveillance frequencies to licensee control. Changes to the relocated surveillance frequencies are made in accordance with the TS program referred to as the SFCP. The SFCP allows a new surveillance frequency to be determined for the channel, but that frequency must consider all components in the channel and applies to the entire channel.

A typical instrument channel consists of many different components, such as sensors, rack modules, and indicators. These components have different short-term and long-term performance (drift) characteristics, resulting in the potential for different calibration frequency requirements. Under the current TSs, the most limiting component calibration frequency for the channel must be chosen when a revised frequency is considered under the SFCP. As a result, all components that makeup a channel must be calibrated at a frequency equal to the channel component with the shortest (i.e., most frequent) surveillance frequency.

Some channel components, such as pressure transmitters, are very stable with respect to drift and could support a substantially longer calibration frequency than the other components in the channel. Currently, the SRs in many plants are performed in steps (e.g., a pressure sensor or transmitter is calibrated during a refueling outage, and the rack signal conditioning modules are calibrated while operating at power). The proposed change extends this concept to permit the surveillance frequency of each step to be determined under the SFCP based on the component(s) surveilled in the step instead of all components in the channel. This will allow each component to be tested at the appropriate frequency based on the component's long-term performance characteristics.

Allowing an appropriate surveillance frequency for performing a channel calibration on each component or group of components could reduce radiation dose associated with in-place calibration of sensors, reduce wear on equipment, reduce unnecessary burden on plant staff, and reduce opportunities for calibration errors.

2.2 Proposed Changes to TS 1.1, "Definitions"

Currently, the channel calibration and channel functional test may be performed by any series of sequential, overlapping, or total channel steps. The proposed changes to the TSs would revise the definitions of channel calibration and channel functional test to indicate that the step must be performed within the most limiting frequency for the components included in that step by adding the phrase, "and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step," at the end of the last sentence of each definition.

The following paragraph denotes the changes to the channel calibration definition. Changes are shown in ***bold italics*** (additions are underlined, and deletions are in stricken text):

A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass ***all devices in the channel required for channel OPERABILITY*** ~~the entire channel, including the required sensor, alarm, display, and trip functions,~~ and ~~shall include~~ the CHANNEL FUNCTIONAL TEST. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an in place qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps ~~so that the entire channel is calibrated, and each step must be~~ ***performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.***

The following paragraph denotes the changes to the channel functional test definition. Changes are shown in ***bold italics*** (additions are underlined, and deletions are in stricken text):

A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify ***OPERABILITY of all devices in the channel required for channel OPERABILITY, including required alarm, interlock, display, and trip functions, and channel failure trips.*** The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps ~~so that the entire channel is tested, and each step must be performed~~ ***within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.***

The various instrumentation functions in the TSs require surveillances to verify the correct functioning of the instrument channel. The proposed change extends the definition of instrumentation channel components to permit the surveillance frequency of each step to be determined under the SFCP based on the component(s) surveilled in the step instead of all components in the channel. This will allow each component to be tested at the appropriate frequency based on the component's long-term performance characteristics.

The proposed changes in the definition for instrument testing would also allow the licensee to control the frequency of associated components being tested in each step. The SR for the overall instrumentation channel remains unchanged. The proposed change has no effect on the design, fabrication, use, or methods of testing the instrumentation channels, and will not affect the ability of the instrumentation to perform the functions assumed in the safety analysis.

These instrumentation testing definitions state that, "[t]he [test type] may be performed by means of any series of sequential, overlapping, or total channel steps." The surveillance frequency of these subsets would be established based on the characteristics of the components in the step rather than the most limiting component characteristics in the entire channel. Each of these steps would be evaluated in accordance with the SFCP.

The licensee proposed the following variations from the TS changes described in TSTF-563 or the applicable parts of the NRC staff's SE for TSTF-563.

- a. The Susquehanna TS definition of channel calibration states, in part:

The CHANNEL CALIBRATION shall encompass *the entire channel, including the required sensor, alarm, display, and trip functions, and shall include* [emphasis added] the CHANNEL FUNCTIONAL TEST. ... The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps *so that the entire channel is calibrated* [emphasis added].

The definition of channel calibration in NUREG-1433, Revision 4, "Standard Technical Specifications General Electric BWR/4 Plants," Volume 1, "Specifications" (ML12104A192), states, in part:

The CHANNEL CALIBRATION shall encompass *all devices in the channel required for channel OPERABILITY and* [emphasis added] the CHANNEL FUNCTIONAL TEST. ... The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps.

The licensee proposed to adopt the NUREG-1433, Revision 4 phrasing of the channel calibration definition and indicated that this proposal would not change the meaning or intent of the Susquehanna TS definition. The licensee indicated the proposed change would be consistent with TSTF-205-A, Revision 3, "Revision of Channel Calibration, Channel Functional Test, and Related Definitions" (ML040570179), which the NRC approved on January 13, 1999 (ML20199E634). The licensee indicated that the proposed change was necessary to adopt TSTF-563.

- b. The Susquehanna TS definition of channel functional test states:

A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY, *including required alarm, interlock, display, and trip functions, and channel failure trips* [emphasis added]. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps *so that the entire channel is tested* [emphasis added].

The definition of channel functional test in Revision 4 of NUREG-1433 states:

A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify OPERABILITY *of all devices in the channel required for channel OPERABILITY* [emphasis added]. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps.

The licensee proposed to adopt the NUREG-1433, Revision 4 phrasing of the channel functional test definition and indicated that this proposal would not change the meaning

or intent of the Susquehanna TS definition. The licensee indicated the proposed change would be consistent with TSTF-205-A, Revision 3. The licensee indicated that the proposed change was necessary to adopt TSTF-563.

- c. The licensee proposed editorial changes to TS 1.1 that include correcting list lettering, using "(continued)" across pages, correcting punctuation, and repositioning content that rolls across pages. The licensee proposed these changes to align the units' TS 1.1 sections and to fix latent formatting and content issues.

2.3 Applicable Regulatory Requirements and Guidance

Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.36(a)(1) requires each applicant for a license authorizing operation of a utilization facility to include in the application the proposed TSs.

The regulation at 10 CFR 50.36(b) requires:

Each license authorizing operation of a ... utilization facility ... will include technical specifications. The technical specifications will be derived from the analyses and evaluation included in the safety analysis report, and amendments thereto, submitted pursuant to [10 CFR 50.34, "Contents of applications; technical information"]. The Commission may include such additional technical specifications as the Commission finds appropriate.

The categories of items required to be in the TSs are provided in 10 CFR 50.36(c). One such category is SRs, which are defined in 10 CFR 50.36(c)(3) as "requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation will be met." Another such category is administrative controls, which are defined in 10 CFR 50.36(c)(5) as the provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure operation of the facility in a safe manner.

License amendment nos. 266 and 247 (ML16005A234) for Susquehanna, Units 1 and 2, respectively, replaced specific surveillance frequencies with references to a SFCP required by TS 5.5.15. That TS requires the licensee to establish, implement, and maintain an SFCP to ensure that TS SRs are performed at intervals listed in, and controlled by, the SFCP. TS 5.5.15 also requires that changes to the surveillance frequencies listed in the SFCP be made in accordance with NRC staff-approved topical report (TR) Nuclear Energy Institute (NEI) 04-10, Revision 1, "Risk-Informed Technical Specifications Initiative 5b, Risk-Informed Method for Control of Surveillance Frequencies, Industry Guidance Document," dated April 2007 (ML071360456).

TR NEI 04-10, Revision 1, describes an evaluation process and a multi-disciplinary plant decision-making panel that considers the detailed evaluation of proposed surveillance frequency revisions. The evaluations are based on operating experience, test history, manufacturers' recommendations, codes and standards, and other deterministic factors, in conjunction with risk insights. The evaluation considers all components being tested by the SR. Process elements are included for determining the cumulative risk impact of the changes, updating the licensee's probabilistic risk assessment (PRA) models, and for imposing corrective actions, if necessary, following implementation of a revised frequency.

The NRC staff's guidance for the review of TSs is in Chapter 16.0, "Technical Specifications," of NUREG-0800, Revision 3, "Standard Review Plan [SRP] for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water Reactor] Edition," dated March 2010 (ML100351425). As described therein, as part of the regulatory standardization effort, the NRC staff has prepared standard technical specifications (STS) for each of the LWR nuclear designs. Accordingly, the NRC staff's review includes consideration of whether the proposed changes are consistent with the applicable reference STS (i.e., the current STS), as modified by NRC-approved TSTF travelers. In addition, the guidance states that comparing the change to the previous STS can help clarify the TS' intent.

Regulatory Guide (RG) 1.174, Revision 2, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," dated May 2011 (ML100910006), describes an acceptable risk-informed approach for assessing the nature and impact of proposed permanent licensing basis changes by considering engineering issues and applying risk insights. This regulatory guide also provides risk acceptance guidelines for evaluating the results of such evaluations.

RG 1.177, Revision 1, "An Approach for Plant-Specific, Risk-Informed Decision-making: Technical Specifications," dated May 2011 (ML100910008), describes an acceptable risk-informed approach specifically for assessing proposed TS changes.

RG 1.200, Revision 2, "An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities," dated March 2009 (ML090410014), describes an acceptable approach for determining the technical adequacy of PRAs.

The NRC staff's guidance for evaluating the technical basis for proposed risk-informed changes is provided in SRP, Chapter 19, Section 19.2, "Review of Risk Information Used to Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance," dated June 2007 (ML071700658). The NRC staff's guidance for evaluating PRA technical adequacy is provided in SRP, Chapter 19, Section 19.1, Revision 3, "Determining the Technical Adequacy of Probabilistic Risk Assessment for Risk-Informed License Amendment Requests After Initial Fuel Load," dated September 2012 (ML12193A107). More specific guidance related to risk-informed TS changes is provided in SRP, Chapter 16, Section 16.1, Revision 1, "Risk-Informed Decision Making: Technical Specifications," dated March 2007 (ML070380228), which includes changes to surveillance test intervals (STIs) (i.e., surveillance frequencies) as part of risk-informed decision-making. Section 19.2 of the SRP references the same criteria as RG 1.177, Revision 1, and RG 1.174, Revision 2, and states that a risk-informed application should be evaluated to ensure that the proposed changes meet the following key principles:

- The proposed change meets the current regulations unless it explicitly relates to a requested exemption or rule change.
- The proposed change is consistent with the defense-in-depth philosophy.
- The proposed change maintains sufficient safety margins.
- When proposed changes result in an increase in risk associated with core damage frequency or large early release frequency, the increase(s) should be small and consistent with the intent of the Commission's Safety Goal Policy Statement.
- The impact of the proposed change should be monitored using performance measurement strategies.

NUREG-1433, Revision 5.0, "Standard Technical Specifications, General Electric Plants, BWR/4," Volume 1, "Specifications," and Volume 2, "Bases," dated September 2021 (ML21272A357 and ML21272A358, respectively), provide the STS for General Electric BWR/4-designed reactors.

3.0 TECHNICAL EVALUATION

3.1 Evaluation of SR Frequency-Related Changes to TS Definitions

Revising the frequency of a channel calibration and channel functional test instrument channel under the SFCP requires assurance that component performance characteristics, such as drift between each test, will not result in undetected instrument errors that exceed the assumptions of the safety analysis and supporting instrument loop uncertainty calculations. These requirements are consistent with the methodology described in NEI 04-10, which is required by the SFCP. The SFCP does not permit changes to the TS allowable values or nominal trip setpoints; but allows only the surveillance frequency to be changed when determined permissible by NEI 04-10. Therefore, prior to extending the test intervals for an instrument channel component or components associated with a given calibration step, the component performance characteristics must be evaluated to verify the allowable value or nominal trip setpoint will still be valid and to establish a firm technical basis supporting the extension. In addition, each change must be reviewed by the licensee to ensure the applicable uncertainty allowances are conservative (bounding) (e.g., sensor drift, rack drift, indicator drift). Documentation to support the changes shall be retained per the guidance in NEI 04-10.

Five key safety principles that must be evaluated before changing any surveillance frequency are identified in section 3.0 of NEI 04-10. Principle 3 requires confirmation of the maintenance of safety margins, which, in this case, includes performance of deterministic evaluations to verify preservation of instrumentation trip setpoint and indication safety margins.

The evaluation methodology specified in NEI 04-10 also requires consideration of common-cause failure effects and monitoring of the instrument channel component performance following the frequency change to ensure channel performance is consistent with the analysis to support an extended frequency.

The method of evaluating a proposed surveillance frequency change is not dependent on the number of components in the channel. Each step needs to be evaluated to determine the acceptable surveillance frequency for that step. The proposed change to permit changing the surveillance frequency of channel component(s) does not affect the test method or evaluation method. The requirement to perform a channel calibration or channel functional test on the entire channel is not changed.

For example, an evaluation in accordance with NEI 04-10 may determine that a field sensor (e.g., a transmitter) should be calibrated every 48 months, that the rack modules should be calibrated every 30 months, and the indicators should be calibrated every 24 months. Under the current TS requirements, all devices in the channel must be calibrated every 24 months. However, under the proposed change, sensors, rack modules, and indicators would be calibrated at the appropriate frequency for the tested devices. As required by the channel calibration definition, the test would still encompass all devices in the channel required for channel operability.

Per TS 5.5.15, the NEI 04-10 methodology must be used to evaluate surveillance frequency changes to determine if such SR extensions could be applied. Process elements are used to determine the cumulative risk impact of changes, update the PRA, and impose corrective actions, if needed, following implementation. Several steps are required by NEI 04-10, section 4.0, step 7, to be evaluated prior to determining the acceptability of changes. These steps include history of surveillance tests, industry and plant specific history, impact on defense-in-depth, vendor recommendations, required test frequencies for the applicable codes and standards, ensuring that plant licensing basis would not be invalidated and other factors. The NRC staff finds these measures acceptable in determining the SR extensions.

In addition, NEI 04-10, section 4.0, step 16 requires an independent decision-making panel (IDP) to review the cumulative impact of all STI changes over a period of time. This is also required by RGs 1.174 and 1.177. The IDP is composed of the site maintenance rule expert panel, surveillance test coordinator, and subject matter expert, who is a cognizant system manager or component engineer. Based on the above information, the NRC staff finds that the setpoint changes will be tracked in an acceptable manner.

Licensees with an SFCP may currently revise the surveillance frequency of instrumentation channels. The testing of these channels may be performed by means of any series, sequential, overlapping, or total channel steps. However, all required components in the instrumentation channel must be tested in order for the entire channel to be considered operable.

The NRC staff notes that industry practice is to perform instrument channel surveillances, such as channel calibrations and channel functional tests, using separate procedures based on the location of the components. Each of these procedures may be considered a "step." The results of all these procedures are used to satisfy the SRs using the existing allowance to perform it "by means of any series of sequential, overlapping, or total channel steps." The proposed changes would allow for determining an acceptable surveillance frequency for each step.

The NRC staff notes that the NEI 04-10 methodology includes the determination of whether the structure, system, and components (SSCs) affected by a proposed change to a surveillance frequency are modeled in the PRA. Where the SSC is directly or implicitly modeled, a quantitative evaluation of the risk impact may be carried out. The methodology adjusts the failure probability of the impacted SSCs based on the proposed change to the surveillance frequency. Where the SSC is not modeled in the PRA, bounding analyses are performed to characterize the impact of the proposed change to the surveillance frequency. Potential impacts on the risk analyses due to screening criteria and truncation levels are addressed by the requirements for PRA technical adequacy, consistent with the guidance contained in RG 1.200, and by sensitivity studies identified in NEI 04-10. The licensee is not proposing to change the methodology, or the acceptance criteria for extending STIs, and the licensee will need to evaluate changes in the frequency for performing each of the steps in the instrumentation surveillance test per the methodology in NEI 04-10.

Therefore, the NRC staff concludes that the proposed change determines an acceptable test frequency for individual steps within instrumentation channel surveillance tests is acceptable because any extended STIs will be developed within the established constraints of the SFCP and NEI 04-10.

The regulatory requirements in 10 CFR 50.36 are not specific regarding the frequency of performing surveillance tests. The proposed change only affects the frequency of performance

and does not affect the surveillance testing method or acceptance criteria. Therefore, the proposed change is consistent with the surveillance testing requirements of 10 CFR 50.36.

PRA Acceptability

The guidance in RG 1.200 states that the quality of a licensee's PRA should be commensurate with the safety significance of the proposed TS change and the role the PRA plays in justifying the change. That is, the greater the change in risk or the greater the uncertainty in that risk as a result of the requested TS change, or both, the more rigor that should go into ensuring the quality of the PRA.

The NRC staff has performed an assessment of the PRA models used to support the approved SFCP that uses NEI 04-10, using the guidance of RG 1.200 to assure that the PRA models are capable of determining the change in risk due to changes to surveillance frequencies of SSCs, using plant-specific data and models. Capability Category II of the NRC-endorsed PRA standard¹ is the target capability level for supporting requirements for the internal events PRA for this application. Any identified deficiencies to those requirements are assessed further to determine any impacts to proposed decreases to surveillance frequencies, including the use of sensitivity studies, where appropriate, in accordance with NEI 04-10.

The SFCP permits revising of the surveillance frequency for instrumentation channels. The NRC staff evaluated whether NEI 04-10 can be applied to subsets in an instrument channel when the SFCP currently specifies a surveillance interval that is applied to the entire channel. The NRC staff notes that the current channel surveillance may be performed by means of any series of sequential, overlapping, or total channel steps. In practice, this means that a channel is divided into subsets and each subset is tested separately. Therefore, the current instrument channel testing is already composed of a sequence of individual tests.

The instrument function may be modeled in the PRA differently depending on the site and the function (e.g., channel may be modeled individually, subsets may be modeled, or the channel function may be modeled as a single entity). There are different steps through the evaluation methodology in NEI 04-10 that could be used based on the different PRA modeling approaches. The appropriate modeling of these different approaches is included in the NRC staff's review of the PRA modeling during the review of the application to implement an SFCP that uses NEI 04-10.

The PRA in use at Susquehanna is the same as that was used to support the license amendment that authorized the SFCP and follows NEI 04-10. Currently, the TSs allow the licensee to change the surveillance frequency of an entire channel under the SFCP. The amendment will allow the licensee to change the surveillance frequency of each subset of the channel. The NRC staff finds that changes to the surveillance frequency caused by defining and using individual, testable component subsets can be appropriately evaluated with the current SFCP and the current PRAs. The NRC staff finds that the risk-informed methodology review and the PRA acceptability review that were performed during the review of the application for an amendment authorizing the SFCP that uses NEI 04-10 is adequate.

The NRC staff determined that the proposed changes to the TS meet the standards for TS in 10 CFR 50.36(b). The regulations at 10 CFR 50.36 require that TS include items in specified

¹ ASME RA-Sb-2005, "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," Addendum B to ASME RA-S-2002, ASME, New York, New York, December 30, 2005.

categories, including SRs. The proposed changes modify the definitions applicable to instrumentation channel components but do not alter the technical approach that was approved by the NRC in NEI 04-10, and the TS, as revised, continue to specify the appropriate SRs for tests and inspections to ensure the necessary quality of affected SSCs is maintained.

Additionally, the NRC staff finds the proposed TS changes to be technically clear and consistent with customary terminology and format in accordance with SRP Chapter 16.0. The NRC staff reviewed the proposed changes against the regulations and concludes that the changes continue to meet the requirements of 10 CFR 50.36(b), 10 CFR 50.36(c)(3), and 10 CFR 50.36(c)(5), for the reasons discussed above, and thus provide reasonable assurance that the revised TSs provide the requisite requirements and controls for the facility to operate safely. Therefore, the NRC staff concludes that the proposed TS changes are acceptable.

3.2 Variations from TSTF-563

Section 2.2 describes the licensee's proposed variations from TSTF-563.

The licensee proposed to revise the definitions of channel calibration and channel functional test to those documented in TSTF-205-A, Revision 3 to adopt TSTF-563. TSTF-205-A, Revision 3, revised the definitions for channel calibration, channel functional test, and related definitions in the improved STSs to remove potential ambiguity in what constitutes an acceptable test.

The current definitions for instrumentation channel calibration and channel functional test use phrases like "required sensor, alarm, interlock, display and trip functions" to describe those instrument channel devices required to be included for specified tests. In its LAR, the licensee stated that there is ambiguity in the application of the word "required" and whether the current phrasing is inclusive or representative. Therefore, the licensee proposed to replace this phrasing with that like "all devices in the channel required for channel OPERABILITY," consistent with TSTF-205-A, Revision 3. The NRC staff finds that the proposed changes clarify the use of the word "required" and makes clear that the components that are required to be tested or calibrated are only those that are necessary for the channel to perform its safety function.

The licensee proposed to delete "so that the entire channel is [calibrated or tested]" from the definitions of channel calibration and channel functional test. The NRC staff finds that deleting this phrasing from the definitions eliminates a conflict between this phrasing and the flexibility of testing permitting a "... successful test to be the verification of the change of state of a single contact of the relay..." as stated in the STS Bases.

The NRC staff reviewed the proposed variations to the channel calibration and channel functional test definitions and determined that they are consistent with TSTF-205-A, TSTF-563, and NUREG-1433 and do not result in any substantive change in operating requirements, and continue to meet the intent of TSTF-563. The NRC staff finds that the changes clarify that the components required to be tested or calibrated are those that are necessary for the channel to perform its safety function. Additionally, the NRC staff finds the proposed TS changes to be technically clear and consistent with customary terminology and format in accordance with SRP Chapter 16.0. The NRC staff reviewed the proposed changes against the regulations and concludes that the changes continue to meet the requirements of 10 CFR 50.36(b), 10 CFR 50.36(c)(3), and 10 CFR 50.36(c)(5), for the reasons discussed above, and thus provide reasonable assurance that the revised TSs provide the requisite requirements and

controls for the facility to operate safely. Therefore, the NRC staff concludes that the proposed TS changes are acceptable.

The licensee's proposed editorial changes to TS 1.1 are summarized in section 2.2. The NRC staff confirmed that the proposed editorial changes do not materially change technical specification requirements and, therefore, the changes are acceptable.

4.0 STATE (COMMONWEALTH) CONSULTATION

In accordance with the Commission's regulations in 10 CFR 50.91(b), the NRC staff notified the Commonwealth of Pennsylvania official on February 14, 2024, of the proposed issuance of the amendments. The Commonwealth official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of facility components located within the restricted area as defined in 10 CFR Part 20, "Standards for protection against radiation," and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding in the *Federal Register* on January 23, 2024 (89 FR 4342, ML24036A019) that the amendments involve no significant hazards consideration, and there has been no public comment on this finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded based on the considerations discussed above that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) there is reasonable assurance that such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

7.0 PRINCIPAL CONTRIBUTOR

Tarico Sweat, NRR

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2 – ISSUANCE OF AMENDMENT NOS. 288 AND 272 RE: ADOPTION OF TSTF-563 (EPID L-2023-LLA-0153) DATED MAY 29, 2024

DISTRIBUTION:

PUBLIC

- RidsNrrLAKZeleznock Resource
- RidsNrrPMSusquehanna Resource
- RidsRgn1MailCenter Resource
- RidsACRS_MailCTR Resource
- RidsNrrDorlLpl1 Resource
- RidsNrrDexEicb Resource
- RidsNrrDssStsb Resource
- TSweat, NRR
- HVu, NRR

ADAMS Accession No.: ML24127A226

NRR-058

OFFICE	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	NRR/DEX/EICB/BC
NAME	AKlett	KZeleznock	FSacko
DATE	05/10/2024	05/08/2024	05/07/2024
OFFICE	NRR/DSS/STSB/BC	OGC (NLO)	NRR/DORL/LPL1/BC
NAME	SMehta	MCarpentier	HGonzález
DATE	05/13/2024	05/23/2024	05/29/2024
OFFICE	NRR/DORL/LPL1/PM		
NAME	AKlett		
DATE	05/29/2024		

OFFICIAL RECORD COPY