

PG&E Letter DCL-24-056

10 CFR 21.21

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Power Plant, Units 1 and 2
10 CFR Part 21 Interim Report

In accordance with the requirements of 10 CFR 21.21(a)(2), Pacific Gas and Electric Company (PG&E) hereby submits this interim report for Diablo Canyon Power Plant (DCPP).

This issue did not adversely affect plant safety or operations.

On March 28, 2024, PG&E received a vendor analysis that confirmed an installed emergency diesel generator (EDG) fuel snubber valve assembly did not perform as expected. The snubber valve assembly was supplied as a commercial grade item and dedicated by PG&E. PG&E has determined that the observed issue constitutes a deviation, as defined by 10 CFR 21.3.

The non-installed fuel snubber valve assemblies have been removed from unrestricted spares and are undergoing further material analyses. This issue does not affect the operability of installed plant equipment.

This interim report is being submitted as a result of PG&E's determination that a 10 CFR Part 21 evaluation is needed and will not be completed within 60 days of discovery. The evaluation is expected to be completed no later than August 29, 2024.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this report. Corrective actions associated with this issue and the evaluation process are being tracked in the DCPP Corrective Action Program.

If you have any questions or require additional information, please contact James Morris, Manager, Regulatory Services, at 805-545-4609.

Sincerely,



Adam S. Peck
Site Vice President

May 28, 2024

Date

dqmg/51231137-5

cc: Diablo Distribution
Mahdi O. Hayes, NRC Senior Resident Inspector
Samson S. Lee, NRR Senior Project Manager
John D. Monninger, NRC Region IV Administrator