

the air-to-borated water interface inside the piping, and confirm that the installation of the stainless steel piping exceeds this elevation.

4. This subsequent renewed license is effective as of the date of issuance, and shall expire at midnight April 10, 2053.

K. Improved Technical Specifications Implementation License Conditions

1. Relocation of Certain Technical Specification Requirements

License Amendment 290 authorizes the relocation of certain Technical Specifications previously included in Appendix A to other licensee-controlled documents. Implementation of this amendment shall include relocation of the requirements to the specified documents, as described in Table R, Relocated Specifications and Removed Detail Changes, attached to the NRC staff's Safety Evaluation, which is enclosed in this amendment.

2. Schedule for New and Revised Surveillance Requirements (SRs)

The schedule for performing SRs that are new or revised in License Amendment 290 shall be as follows:

- a. For SRs that are new in this amendment, the first performance is due at the end of the first Surveillance interval, which begins on the date of implementation of this amendment.
- b. For SRs that existed prior to this amendment, whose intervals of performance are being reduced, the first reduced Surveillance interval begins upon completion of the first Surveillance performed after implementation of this amendment.
- c. For SRs that existed prior to this amendment, whose intervals of performance are being extended, the first extended Surveillance interval begins upon completion of the last Surveillance performed prior to implementation of this amendment.
- d. For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance subject to the modified acceptance criteria is due at the end of the first Surveillance interval that began on the date the Surveillance was last performed prior to the implementation of this amendment.