

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BEFORE THE PETITION REVIEW BOARD**

In the matter of
Pacific Gas and Electric Company
Diablo Canyon Nuclear Power Plant
Units 1 and 2

Docket Nos. 50-275, 50-323
Seismic Shutdown Petition
June 7, 2024

SUPPLEMENTAL DECLARATION OF PETER BIRD, Ph.D

Under penalty of perjury, I, Peter Bird, declare as follows:

I. INTRODUCTION

1. My name is Peter Bird. I am Professor of Geophysics and Geology, Emeritus at the University of California at Los Angeles (UCLA). On March 4, 2024, I submitted to the U.S. Nuclear Regulatory Commission (NRC) a declaration in support of a petition by San Luis Obispo Mothers for Peace, Friends of the Earth and Environmental Working Group (Petitioners) for shutdown of the Diablo Canyon nuclear power plant (DCPP) due to the unacceptable risk of a seismic core damage accident. In this Supplemental Declaration, the shutdown petition will be referred to as “Petition” and my supporting declaration will be referred to as “Bird March 4, 2024 Declaration.”
2. I reaffirm that the facts stated in my March 4, 2024 Declaration are true and correct to the best of my knowledge and that the opinions expressed therein are based on my best professional judgment.
3. On March 28, 2024, Petitioners received an email from Perry Buckberg of the NRC, stating that the NRC Staff had determined that immediate closure of DCPP was not necessary and that the concerns raised by the Petition had been referred to a Petition Review Board (PRB). On May 15, 2024, in another email from Perry Buckberg to the Petitioners, the PRB reported its “initial assessment” that the concerns presented in the Petition and the Bird March 4, 2024 Declaration did not satisfy NRC guidance for taking action on the Petition because the issues we raised had previously been the subject of a facility-specific or generic NRC staff review and that we had not provided significant new information that the staff did not consider in a prior review. This Supplemental Declaration will refer to the NRC’s response to our concerns as the “Initial Assessment.”
4. The purpose of this Supplemental Declaration is to respond to the assertions made by the PRB in the Initial Assessment, including each of the four technical grounds for refusing to consider the Petition.

II. DISCUSSION¹

5. At the outset, the PRB is incorrect in stating that the issues we raised in the Petition and the Bird March 4, 2024 Declaration have “previously been the subject” of a review by the NRC. We have reviewed the NRC’s technical evaluations of Pacific Gas & Electric Co.’s (PG&E’s) seismic studies and find no evidence that the NRC considered or even understood our concerns and the data on which they are based. The PRB’s Initial Assessment continues to demonstrate the same fundamental failure to grasp our concerns or to consider the basic geological concepts and data underlying them. Instead, the PRB accuses the Petitioners of disregarding established geologic data. In making this accusation, however, the PRB fails to recognize that all of PG&E’s seismic analyses are based on an artificially-limited geologic dataset, starting with PG&E’s deficient Fault Geometry Models (FGMs). Starting in 2015, these deficient FGMs led to a biased Seismic Source Characterization (SSC), which led to a biased Seismic Probabilistic Risk Assessment (SPRA). These studies grossly underestimated the frequency of seismic core damage and caused both PG&E and the NRC to falsely conclude that the seismic risk to DCPD is acceptable. The purpose of the Bird March 4, 2024 Declaration was to demonstrate the fallacy of PG&E’s assumptions and their significance with respect to accident risk at DCPD.
6. On page 1, the Initial Assessment provides a summary of four specific technical concerns raised in the Petition and the Bird March 24, 2024 Declaration. Our first concern is accurately described as follows:

Thrust faulting is neglected by Pacific Gas & Electric Company’s (PG&E’s) 2012 Seismic Source Characterization (SSC) model, because the model assumes that a majority of large earthquakes affecting Diablo Canyon are strike-slip and disregards the significant contribution of thrust faulting earthquake sources under the Diablo Canyon site and the adjacent Irish Hills. In addition, PG&E did not use a hanging-wall term for the modeling of potential ground motions from the Los Osos and San Luis Bay thrust faults.

7. In response, the PRB states:

The licensee’s seismic models (ML15071A045) developed in response to NRC’s 10 CFR 50.54(f) request include the potential for thrust faulting, as both the Los Osos and San Luis Bay thrust faults were evaluated in great detail and considered by PG&E to be primary fault sources in the models used for the hazard calculations. For both thrust faults, the ground motion model developed by PG&E includes a hanging wall term to incorporate the potential for higher ground motions. The NRC staff assessment (ML16341C057) of PG&E’s 2015 seismic

¹ Note to the reader: In the discussion below, quotations of the PRB’s summaries of my principal concerns are underlined. Quotations from the PRB’s assessment of my concerns are italicized.

hazard reevaluation includes confirmatory calculations of the hazard from both the Los Osos and San Luis Bay thrust faults and concludes that the licensee adequately characterizes the seismic hazard for Diablo Canyon, including the potential for thrust faulting near the site.

8. But the PRB's response perpetuates two fundamental errors by PG&E that yield a gross underestimate of the seismic hazard at DCP, *i.e.*, by almost two orders of magnitude. First, the PRB accepts assumptions by PG&E of thrust fault dips that range from the unlikely to the impossible. Our contention regarding the Los Osos thrust fault is that it should be modeled with a dip of $\sim 25^\circ$ like most other thrust faults in the lab or in the field, worldwide. But PG&E (2015; 2015L; 2024) assigned alternative dips of 30° or 50° or 80° , assigning a combined weight of 70% to the dips of 50° to 80° in their logic-tree. But dips of 50° or 80° are mechanically impossible; such faults would not slip under the present horizontal compressive stress regime. Due to the irrationally steep dips assumed by PG&E, PG&E also assumes that the FGM variant fault planes within the seismogenic (upper-crustal) portion of the Los Osos thrust fault does not pass below DCP. The combined distance from DCP and the excessive dip angle artificially and severely reduced the hanging-wall effect at DCP in PG&E's hazard models.
9. Second, we estimate that the total slip rate in all thrust-faulting under the Irish Hills is about 2.8 mm/year. As discussed in the Bird March 24, 2024 Declaration, this estimate was confirmed by three different analytical methods. We also consider that the topographic symmetry of the Irish Hills implies a slip-rate for the Los Osos thrust fault of about half of this, or ~ 1.4 mm/year. However, PG&E modeled this fault as having a slip-rate of 0.2 or 0.4 mm/year, which is too low by a factor of 7 to a factor of 3.5, respectively.
10. The net result of these two errors was that PG&E underestimated the hazard at DCP from the Los Osos thrust fault by factors of about 12 to 24, or more than one order of magnitude.
11. PG&E also incorrectly minimized the significance of the San Luis Bay fault. PG&E assigned unphysical dips of 45° – 75° , which would be implausible or impossible, respectively. Furthermore, PG&E assigned 90%-confidence slip-rates of 0.24–0.46 mm/year to this fault. As discussed in (Bird, 2023) a slip-rate of 0.76–1.04 mm/year is justified as follows:

According to the geologic map of Fig. 13-16 [of PG&E's SSC] and associated cross-section C-C' (Fig. 13-17), the apparent throw (vertical offset) of stratigraphic unit Tmo Obispo Formation is 1.6–2.2 km across the Shoreline fault trace. . . . None of this can be explained by strike-slip on the Shoreline fault, because its slip-rate is very low and because regional strikes of bedding are roughly parallel to it. Instead, the simplest explanation is thrust-faulting, either on the Shoreline fault (if it is not actually vertical), or on another northeast-dipping

fault plane, such as a NW extension of the San Luis Bay thrust fault, that shares the surface trace of the Shoreline fault. Assuming a typical thrust-fault dip of 25° , the amount of slip required to create this throw is $(1.6\sim 2.2 \text{ km}) / \sin(25^\circ) = 3.8\sim 5.2 \text{ km}$. Then, assuming this occurred since $\sim 5 \text{ Ma}$. . . the mean rate of slip on the inferred thrust fault has been $0.76\sim 1.04 \text{ mm/a}$.

Finally, in many of PG&E's FGM model variants, this fault terminates to the South of DCP, so that DCP is not within its hanging-wall. This assumption is inconsistent with the geology (specifically, the present form of the once-horizontal Obispo Formation beds) showing that thrusting continues northwestward along the coast in the Inferred Coastline thrust fault.

12. Most importantly, we contend that there is an unrecognized Inferred Coastline Thrust fault just offshore from DCP, with a similar slip-rate of $0.76\sim 1.04 \text{ mm/year}$. Again, assuming a standard dip of $\sim 25^\circ$, this fault would pass under DCP at shallow depths, implying maximal hanging-wall effect (*i.e.*, increasing the intensity of shaking by a large factor relative to sites on the footwall).
13. The simplest demonstration that PG&E grossly underestimated the seismic hazard from thrust-faulting is this: In their SSC, the Los Osos and San Luis Bay faults have major seismic hazards (specifically, Peak Ground Accelerations (PGAs) over 1 g and spectral accelerations over 2 g which would cause SCD), adding up to less than the hazard from the strike-slip Hosgri fault, and consequently less than half of the total hazard. Yet, the Bird March 4, 2024 Declaration estimates that the joint hazard from the Inferred Coastline and Los Osos thrusts (alone) is $\sim 47\times$ greater than the total hazard (specifically, SCDF) estimated by PG&E. Together, these facts show that PG&E underestimated the hazard from thrust-faulting by a factor of at least 100, or two orders of magnitude.
14. The PRB accurately describes our second concern as follows:

The magnitude 7.5 (moment magnitude) January 2024 earthquake centered in the Noto Peninsula (Japan), with an average slip of 2 meters on the fault, is analogous to future potential thrust mechanism earthquakes beneath Diablo Canyon. Based on the slip rate of the Irish Hills adjacent to Diablo Canyon and the slip of the Noto earthquake, large thrust fault earthquakes will occur, on average, every 715 years near the Diablo Canyon site.

15. In response, the PRB states:

The petition did not provide sufficient factual information to conclude that the 2024 Noto Peninsula earthquake can be used as an analogous thrust earthquake beneath Diablo Canyon with an associated slip of 2 meters for a magnitude 7.5 earthquake. However, PG&E, based on the estimated length (70 kilometers [km]) and width (13 km) of the Los Osos fault and using the magnitude-area relation of Hanks and Bakun (2014), estimated a maximum moment magnitude of 7.0 for the

Los Osos fault. Similarly, PG&E modeled a maximum moment magnitude of 6.3 for the San Luis Bay fault based on its estimated length (15 km) and width (11 km). In addition to considering earthquakes on these two faults individually, PG&E also modeled several larger earthquake ruptures occurring on these two faults linked together with adjacent faults such as the Shoreline and Hosgri faults. The NRC staff assessment of PG&E's 2015 seismic hazard reevaluation concludes that the maximum magnitudes for the Los Osos and San Luis Bay faults are appropriate due to their estimated lengths and widths and that PG&E's hazard reevaluation adequately considered the potential for larger linked earthquake ruptures occurring on multiple adjacent faults.

16. This response suggests that the proper way to consider the 2024.01.01 Noto Peninsula earthquake (as an analogous source of shaking in the Irish Hills) is to reduce the earthquake to a magnitude and a fault location, and then plug these numbers into one or more Ground Motion Prediction Equations (GMPEs). This method might be acceptable for a minor source of hazard, but the analog Noto Peninsula earthquake is now seen as the major threat to DCP. Therefore, in order to provide a reasonably accurate assessment of seismic risk to DCP, actual seismograms from the Noto Peninsula must be used in a completely new SSC for DCP.
17. In such a future new SSHAC Level-3 SSC for DCP, the Technical Integration (TI) team might decide that the plausible length of a thrust rupture (combining the Inferred Offshore and San Luis Bay thrust) near DCP is less than the length of the recent Noto Peninsula rupture. If so, they can handle this detail by truncating the Noto Peninsula seismograms at the point where seismic S waves from the “excess” (non-comparable) parts of the rupture surface began to arrive, and use these truncated Noto Peninsula seismograms to compute PGA and spectral-acceleration estimates appropriate for DCP and the Irish Hills. However, as a seismologist, I expect that such a correction will have only a small effect, because the most intense shaking at a hanging-wall site is determined by the amount of fault slip underneath it, and by how fast this slip occurs. The total length of the rupture mostly affects the duration of shaking, but not its peak intensity.
18. We also have reason to expect that great thrust-faulting earthquakes under the Irish Hills will be more intense than in the Noto Peninsula, not less. The slip under DCP would probably occur more rapidly, because the seismic stress-drop there would be higher than under the Noto Peninsula. Rate-and-state friction theory, as developed by Prof. James Dieterich of UC Riverside over many scholarly publications, implies that the stress-drop of an earthquake varies as the logarithm of the time since the previous earthquake on the same fault patch. Given that crustal shortening is about 5× slower under the Irish Hills (~2 mm/year vs. ~10 mm/year), the recurrence time for Irish Hills thrust earthquakes should be ~5× greater (~733 years vs. ~146 years), and the expected stress-drop will therefore be higher. Peak Ground Acceleration (PGA) at sites close to the fault is proportional to stress-drop.

19. The PRB **inaccurately** describes our third concern as follows: “Uplift rates for the Irish Hills should be several times higher than the rates used by PG&E in its SSC model in 2012.”
20. The neotectonic uplift rate of the Irish Hills has been determined by PG&E (or possibly by its contracted consultants) to be approximately 0.2 mm/year, based on topography and ages of uplifted marine terraces compared to a global sea-level history. This is basic geologic data, and we are willing to stipulate that this uplift rate is approximately correct.
21. The PRB confuses the two distinct concepts of uplift rate and crustal thickening. As discussed in (Bird, 2023):

The neotectonic uplift rate of the whole Irish Hills region is uniform at 0.2 mm/a. . . . Because the Franciscan Complex basement is weak, and because there is no large isostatic gravity anomaly over the Irish Hills [Simpson et al., 1986], this uplift process should be modeled with Airy isostasy. The implied rate of crustal thickening is then about 6 times larger, or about 1.2 mm/a. If this crustal thickening is occurring on a single thrust fault of dip 25°, then its rate of slip should be $(1.2 \text{ mm/a}) / \sin(25^\circ) = 2.8 \text{ mm/a}$. Or, if the crustal thickening is driven by two oppositely-vergent and overlapping thrust faults . . . then each should have a slip-rate of ~1.4 mm/a. Obviously, more complex models with more thrust faults can be devised, but the implication for total strain and seismicity due to thrust-faulting will remain unchanged.

Since the first measurements of gravity (two centuries ago) it has been recognized that highlands have about the same mass-per-unit-area as lowlands, because highlands have crustal “roots” that mirror the surface topography but with amplitude ~5× greater, and because crust is less dense than mantle. Thus, the creation of the Irish Hills required crustal thickening much greater than the visible topography. Under Airy isostasy, therefore, the rate of crustal thickening under the Irish Hills must be about 6× larger than the uplift rate, or about 1.2 mm/year. PG&E’s FGMs do not acknowledge or comply with this basic principle of geophysics, and so they are in conflict with gravity data.

22. The distinction between uplift rate and crustal thickening is important, because there is an elementary trigonometric relation between the rate of crustal thickening and the rate of thrust-faulting: (crustal thickening rate) = (thrust fault slip-rate) × sin (fault dip angle). This led us to the conclusion (and still does) that PG&E grossly underestimated the slip-rates and areas of active thrust faults under the Irish Hills.
23. Thus, our second concern should be summarized as: Thrust fault slip-rates in the Irish Hills should be much higher than the rates used by PG&E in its SSC model in 2015, because they should be based on crustal thickening rates rather than uplift rates.”
24. In response to our third concern, the PRB states:

The petition's postulated magnitude recurrence rate of 1.4×10^{-3} /yr for large thrust fault earthquakes near Diablo Canyon, is based on the slip (2 m) from a single earthquake in Japan (2024 Noto earthquake) and an uplift rate for the Irish Hills (2.88 millimeters per year [mm/yr]) that is several times higher rather than the rates inferred from geologic field observations in the region surrounding Diablo Canyon. Based on geologic studies in the region, PG&E assumed an uplift rate for the Irish Hills that ranges from about 0.15 to 0.35 mm/yr and apportioned this rate to several scenario thrust earthquakes in the region. The PRB concludes that a long-term slip rate of 2.88 mm/yr for the Irish Hills is inconsistent with the slip rates inferred from geologic studies in the region. The NRC staff assessment of PG&E's 2015 seismic hazard reevaluation concludes that PG&E adequately characterized the potential for thrust fault earthquakes in the vicinity of the Diablo Canyon site.

25. This objection is based on a mis-statement of our model, as detailed above in ¶¶ 19-23. Our figure of 2.8 mm/year for the Irish Hills describes the total of the slip-rates of all thrust faults of 25° dip under the Irish Hills (assuming that each of these thrust faults underlies all of the Irish Hills). It is not an estimate of uplift rate, for which we accept the results of PG&E studies (0.15 to 0.35 mm/year). Furthermore, if PG&E did, in fact, “partition” this uplift rate into slip-rates of their model thrust faults, they made a fatal error by ignoring the Airy-isostasy factor of $\sim 6\times$ for the ratio of crustal thickening rate to uplift rate.

26. The PRB accurately describes our fourth concern as follows: “Seismic core damage frequency (SCDF), estimated by PG&E in 2018 to be 3×10^{-5} , should be 1.4×10^{-3} per year (about once every 715 years) based on this higher recurrence rate for thrust earthquakes.”

27. In response to our fourth concern, the PRB states:

The calculation of SCDF involves consideration of the seismic hazard curve and equipment fragility. Seismic hazard curves are developed based on the characterization of all potential seismic sources in the region, including their estimated fault slip rates. The PRB finds that it is inappropriate to estimate a new SCDF using modeled slip rates that are several times higher than those inferred from geologic field observations in the region surrounding Diablo Canyon. The NRC's assessment (ML18254A040) of PG&E's 2018 seismic probabilistic risk assessment concludes that PG&E adequately characterized the risk to the Diablo Canyon site.

28. Obtaining a definitive value for SCDF from all sources requires lengthy calculations; however, with our model we obtained a useful lower limit on SCDF by considering only the thrust faults under the Irish Hills that can produce earthquakes comparable to the 2024 Noto Peninsula earthquake. We merely noted that the PGA of 1.0~2.3 g recorded on the Noto Peninsula would be associated with 5-Hz spectral accelerations

- of 2.0~4.6 g at hanging-wall sites, which would cause core damage at DCPD (according to the SPRA filed by PG&E in 2015). Therefore, the recurrence interval for SCD is almost the same as the recurrence interval for great thrust earthquakes. There is no question that these important calculations should be redone by competent and disinterested professionals to get the full value of SCDF – which I believe may be slightly higher than the already-high lower limit we have estimated.
29. We are particularly concerned by the PRB’s assertion that: “[I]t is inappropriate to estimate a new SCDF using modeled slip rates that are several times higher than those inferred from geologic field observations in the region surrounding Diablo Canyon.” In brief, we accept the validity of existing “geologic field observations.” But, we find 3 fatal errors in the assumptions that PG&E used to “infer” their deficient FGMs and the resulting biased SSC. Each point will be expanded on in the following paragraphs 30 through 34.
 30. The primary “geologic field observations” available to constrain the activity of thrust faults are the relative vertical offset rates (throw rates) across fault traces obtained from relative vertical offsets of quasi-horizontal features. In the case of the San Luis Bay thrust fault, these offset features are marine terraces carved in Late Quaternary time, and their ages can be obtained in multiple ways (*e.g.*, relative sea-level still-stands, amino acid racemization in fossil shells, cosmogenic nuclide dating of exposed rocks). In the case of the Los Osos thrust fault, these offset features are river terraces which were correlated with coastal marine terraces also deposited in Late Quaternary time (*e.g.*, by Lettis and Hall, 1994). We accept these data as valid constraints.
 31. The first false assumption made by PG&E in their analysis was that only offsets of Late Quaternary features are relevant to hazard. In fact, a detailed statistical analysis of geologic constraints on fault offset rates in the western United States by Bird (2007) found that the probability of “inapplicability” of a dated offset feature (defined in that paper, and graphed in its Figures 7 and 8) is equally low for all offset features up to 3 Ma (late Pliocene) in age, and almost as low for features of 5-6 Ma (Miocene/Pliocene boundary, or the time at which the Irish Hills began to form). Furthermore, that study concluded that a single offset feature is very rarely enough to make the fault offset rate “well-constrained;” instead, 4 offset features are needed to achieve a 50%-chance that the rate is “well-constrained,” and 7 offset features are needed to guarantee it. Thus, PG&E was negligent and unprofessional in failing to consider additional geologic constraints from older offset features, such as the once-planar Obispo Formation beds. Our own analysis (*e.g.*, Figure 1 of Bird’s March 24, 2024 Declaration to NRC, repeated as Figure 1 here) shows that including this feature will increase the throw-rate for the San Luis Bay-Inferred Coastline thrust system of faults. PG&E should have created one or more structure models showing how this formation (and overlying sedimentary rocks) came to be bent into the present Pismo syncline and other folds in the center of the Irish Hills. It is strikingly negligent that they never considered or attempted this.

32. The second false assumption made by PG&E is that the dip angles of thrust faults can be assigned whimsically based on very weak evidence or alleged analogies to other tectonic belts. In fact, the Mohr-Coulomb theory for frictional faulting (which is now a century old and included in every structural geology textbook) proves that these dip angles must be less than 45°, and that the specific angle depends on the coefficient of friction of the rocks. Since the vast majority crustal rocks have coefficients of friction around 0.85 (Byerlee, 1978), the appropriate and most common dip angle for thrust faults is 25°. The critical importance of correct dip is shown by 2 simple formulas: (i) (fault slip-rate) = (throw-rate) / sin(dip); (ii) Assuming a brittle-ductile transition depth of B, the (down-dip seismogenic length of a thrust fault) = B / sin(dip). Because “seismic potency rate” (per unit length of thrust fault trace) is the product of these two factors, it is extremely sensitive to dip. For example, a seismic potency rate that is correctly computed as 5.6 (using relative units) using a dip of 25° becomes a seismic potency of only 1.7 using an impossible dip of 50°, or only 1.03 using a ridiculous dip of 80°. Furthermore, characteristic earthquake frequency is proportional to seismic moment rate, and seismic moment rate is proportional to seismic potency rate. Thus, PG&E’s assertion of impossibly steep dips for the 2 known thrust faults caused them to underestimate the seismic hazard from these 2 faults by factors of 3.3 to 5.4, quite apart from the throw-rate issues mentioned in PP. 31 and the fault-extension-under-DCPP issue mentioned in PP. 8 above.
33. The third false assumption made by PG&E is that only these 2 mapped thrust faults (Los Osos and San Luis Bay) can produce earthquakes. But the crustal “basement” under the folded sedimentary rocks of the Irish Hills is Franciscan Complex, which contains numerous Jurassic-Cretaceous thrust faults available for reactivation. Slip on those thrust faults would not reach the surface (allowing for mapping) because this slip encounters and folds the layered sedimentary rocks of the Pismo syncline. Thus, there are an unknown number of “blind” thrust faults active, such as those that produce devastating earthquakes under the Zagros Mountains of Iran, or in Nepal. Therefore, Bird’s March 24, 2024 Declaration necessarily introduced two global measures of the total activity of all thrust faults under the Irish Hills: (i) the rate of crustal thickening inferred from the uplift rate of the Irish Hills and their (negative) isostatic gravity anomaly; and (ii) the rate of horizontal convergence along SSW-NNE axes measured by Global Positioning System (GPS) permanent stations. These essential kinds of geophysical evidence showed that the total rate of thrust fault slip under the Irish Hills is 2.2~2.8 mm/year, with the higher value preferred.
34. Because of these 3 false assumptions, the Fault Geometry Models (FGMs) produced by PG&E (2015, 2015L, 2024) are grossly inadequate and systematically deficient.
35. In addition, the FGMs in the SSC studies by PG&E (2015, 2015L, 2024) are contradicted by 3 critical facts:
- a) The sedimentary beds of the Miocene Obispo Formation (which were originally flat) have been offset vertically by 1.6~2.2 km at the southwest coastline of the Irish Hills, near DCP. This is documented in the geologic map of Figure 13-16 and the geologic section of Figure 13-17 of PG&E (2015), the latter of which Dr.

Bird modified to create Figure 1 (attached to this Supplementary Declaration). Neither the Shoreline nor the San Luis Bay faults in the FGMs from PG&E can explain this.


- b) About 7 permanent Global Positioning System (GPS) stations around the Irish Hills have been recording crustal velocities continuously for a decade or more, achieving horizontal precisions of ~ 0.2 mm/year. These data show crustal shortening at a rate of ~ 2 mm/year in the SW-NE direction across the Irish Hills. Specifically, this convergence rate is from the deformation model that Shen & Bird (2022) computed for use in the 2023 Update of the USGS National Seismic Hazard Model. PG&E (2015, 2015L, 2024) never computed a horizontal shortening rate for the Irish Hills from their FGMs. Instead, PG&E ignored this critical constraint.
 - c) Gravity data shows that there has been major crustal thickening under the Irish Hills since they began to form ~ 5 Ma. In fact, the local isostatic gravity anomaly near DCPD is about -37 mGal (Chapter 6 of PG&E, 2024 Updated SSC). This shows that local crustal thickening has been more than enough to balance the weight of the Irish Hills. However, the FGMs of PG&E predict very minor crustal thickening, and a large positive isostatic gravity anomaly from the unbalanced weight of the Irish Hills topography.
36. Thus, in all likelihood, the 2015 and 2024 FGMs would be ruled “not technically defensible” as proposed sets of seismic sources if a new SSHAC Level-3 SSC study were performed.
37. In contrast, we have corrected the FGM to be consistent with these 3 facts by: (1) setting the dips of the Los Osos and San Luis Bay thrusts to 25° and increasing their slip-rates to ~ 1.4 mm/year; and (2) adding the Inferred Coastline thrust to explain the fault throw, gravity, and topography in the area around DCPD. After these corrections, seismic hazard at DCPD is dominated by these 3 thrusts (and/or additional “blind” and unmapped thrust faults in the basement), and the strike-slip faults (*e.g.*, Hosgri and Shoreline) emphasized by PG&E make only minor contributions. Our new estimate of the lower limit on SCDF (considering the 2024.01.01 Noto Peninsula earthquake as a comparable thrust event) is high enough to justify our petition for immediate shut-down.
38. In conclusion, repetition of arguments and assertions found in PG&E filings (2015, 2015L, 2024) is not an adequate basis for failing to seriously consider our new estimates of very high seismic hazard at DCPD, which are based on the same geologic data, plus additional offsets of older features, and also incorporate gravity, GPS, and stress-regime data, as well as more defensible assumptions and logic. The PRB should engage our well-supported concerns and re-evaluate the Petitioners demand for the immediate shutdown of DCPD. Before continued operation of DCPD can be allowed, the NRC should require a new and independent SSC that evaluates currently available data without skewing it towards a desired outcome.

Under penalty of perjury, I declare that the foregoing statements of fact are true and correct to the best of my knowledge and that the statements of opinion expressed above are based on my best professional judgment.

Executed in Accord with 10 C.F.R. § 2.304(d) by
Peter Bird

Date: June 7, 2024

**Mark-up (in red) by P. Bird, 2023 of
Figure 13-17 of SSC for DCPD
(PG&E, 2015)**



REFERENCES CITED

Bird, P. [2007] Uncertainties in long-term geologic offset rates of faults: General principles illustrated with data from California and other western states, *Geosphere*, 3(6), 577-595; doi:10.1130/GES00127.1, + 9 digital file appendices.

Bird, P. [2024] Declaration of Peter Bird, Ph.D, submitted to the U.S. Nuclear Regulatory Commission in support of Request by San Luis Obispo Mothers for Peace, Friends of the Earth and Environmental Working Group for Hearing on Pacific Gas & Electric Company's License Renewal Application for the Diablo Canyon Nuclear Plant and Petition by San Luis Obispo Mothers for Peace, Friends of the Earth and Environmental Working Group for Shutdown of Diablo Canyon Nuclear Power Plant Due to Unacceptable Risk of Seismic Core Damage Accident, NRC ADAMS Accession No. ML24065A434, filed March 4, 2024.

Byerlee, J. [1932] Friction in rocks, *Pure and Applied Geophysics*, v. 116, p. 615-626.

Lettis, W. R., and N. T. Hall [1994] Los Osos fault zone, San Luis Obispo County California, in: I. B. Alterman, R. B. McMullen, L. S. Cluff, and D. B. Slemmons (ed.s), *Seismotectonics of the Central California Coast Ranges*, Geological Society of America Special Paper, v. 292, p. 73-102.

Pacific Gas and Electric Company [2014] Geologic Map of the Irish Hills and Adjacent Area, 1:32,000, DCPG Geologic Mapping Project, Ch9.GEO.DCPG.TR.14.01 R0, https://www.pge.com/includes/docs/pdfs/safety/systemworks/dcpp/report/Ch9.GEO.DCPG.TR.14.01_R0_Plates.pdf , NRC ADAMS Accession No. ML14260A068.

Pacific Gas and Electric Company (PG&E) [2015] Seismic Source Characterization for the Diablo Canyon Power Plant, San Luis Obispo County, California; report on the results of SSHAC level 3 study, Rev. A, March; 652 pages plus Appendices. Available online at <http://www.pge.com/dcpp-ltsp>; downloaded 2023.05.11.

Pacific Gas and Electric Company (PG&E) [2015L] Letter DCL-15-035 re: Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding the Seismic Aspects of Recommendation 2.1 of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident: Seismic Hazard and Screening Report (Mar. 11, 2015) (NRC Accession No. ML15071A045).

Pacific Gas and Electric Company (PG&E) [2018] Letter DCL-18-027 re: Seismic Probabilistic Risk Assessment for the Diablo Canyon Power Plant, Units 1 and 2 – Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding the Seismic Aspects of Recommendation 2.1: Seismic of the (sic) Near-Term Task force Review of Insights from the Fukushima Dai-Ichi Accident (Apr. 24, 2018) (NRC Accession No. ML18120A201).

Pacific Gas and Electric Company (PG&E) [2023] Appendix E: Applicant's Environmental Report, Operating License Renewal Stage, Diablo Canyon Power Plant Units 1 and 2, November 2023: NRC ADAMS Accession No. ML23311A154, dated 2023.11.07, 1,137-page PDF file, accessed 2024.02.

Pacific Gas and Electric Company (PG&E) [2024] Diablo Canyon Updated Seismic Assessment: Response to Senate Bill 846, 1 February 2024, 392 pages.

Shen, Z.-K., and P. Bird [2022] NeoKinema deformation model for the 2023 update to the U.S. National Seismic Hazard Model, *Seismol. Res. Lett.*, 93(6), 3037-3052, <https://doi.org/10.1785/0220220179>, 16 pages.

CURRICULUM VITAE of Peter Bird was included the Bird March 24, 2024 Declaration, and is not repeated here.