

JAFP-24-0026

June 12, 2024

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

James A. FitzPatrick Nuclear Power Plant  
Renewed Facility Operating License No. DPR-59  
NRC Docket No. 50-333

Subject: Supplement to License Amendment Request to Modify Technical Specification Surveillance Requirement (SR) 3.4.3.1 Safety Relief Valves (SRVs) Setpoint Lower Tolerance

Reference: Letter from D. Gudger (Constellation Energy Generation, LLC) to U.S. Nuclear Regulatory Commission, "License Amendment Request to Modify Technical Specification Surveillance Requirement (SR) 3.4.3.1 Safety Relief Valves (SRVs) Setpoint Lower Tolerance," JAFP-23-0038 (ML23209A003), dated July 28, 2023.

By letter dated July 28, 2023, Constellation Energy Generation, LLC (CEG) requested a change to the James A. FitzPatrick Technical Specifications (TS) in accordance with the provisions of Title 10 of the Code of Federal Regulations with the provisions of 10 CFR 50.90.

The NRC identified an editorial error in Attachment 4 of the Reference. The specific error was that the Clean Page for TS Page 3.4.3-2 was not consistent with the requested change discussed in Attachment 1 or the marked-up page in Attachment 2.

Attachment 1 in this letter replaces the Clean Page for TS Page 3.4.3-2 in Attachment 4 of the Reference, in its entirety. The new Clean Page is consistent with the requested change; therefore, it does not change the intent of the license amendment request.

License Amendment Request  
Safety Relief Valves Setpoint Lower Tolerance  
Docket No. 50-333  
June 12, 2024  
Page 2

Should you have any questions concerning this submittal, please contact Christian Williams at [Christian.Williams@Constellation.com](mailto:Christian.Williams@Constellation.com)

I declare under penalty of perjury that the foregoing is true and correct. Executed on the June 12, 2024.

Respectfully,

*David T. Gudger*

---

Dave T. Gudger  
Senior Manager - Licensing & Regulatory Affairs  
Constellation Energy Generation, LLC

Attachments:

1. Corrected Technical Specification Clean Page 3.4.3-2.

cc: USNRC Region I, Regional Administrator	w/attachment
USNRC Senior Resident Inspector, JAF	w/attachment
USNRC Project Manager, JAF	w/attachment
A. L. Peterson, NYSERDA	w/attachment

**ATTACHMENT 1**

License Amendment Request

James A. FitzPatrick Nuclear Power Plant

Docket No. 50-333

CORRECTED TECHNICAL SPECIFICATION CLEAN PAGE 3.4.3-2.

**SURVEILLANCE REQUIREMENTS**

SURVEILLANCE		FREQUENCY
SR 3.4.3.1	Verify the safety function lift setpoint of the required S/RVs is 1145 + 34.3 or - 57.2 psig. Following testing, lift settings shall be within ± 1%.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.4.3.2	Verify each required S/RV is capable of being opened.	In accordance with the INSERVICE TESTING PROGRAM