

DISTRIBUTION - VOLUME 13 – EMERGENCY PREPAREDNESS PROCEDURES

Page 3 of 3

Distribution Date: 06/27/24

Filed By: _____

Prepared by: _____

Procedure Number	Revision
13.1.1	050

Procedure Number	Revision

Procedure Number	Revision

TO: ENERGY NORTHWEST EXTERNAL CONTROLLED COPY PROCEDURE HOLDERS

The following documents have been revised and are to be inserted into your controlled copy manual and the superseded revisions removed and destroyed. No receipt acknowledgement is required for the listed document(s).

Should you have questions on this distribution please contact Alan Page, Records, and Information at (509)377-8595 or atpage@energy-northwest.com.

EXTERNAL DISTRIBUTION

Copy #	Location	Procedures
26	Region IV – US Nuclear Regulatory Commission	All
52	State of Washington, Military Department	All
55	Federal Emergency Management Agency (FEMA)	All
57	Benton County – Department of Emergency Management	All
87	Document Control Desk – NRC	All
142	Hanford EOC/SMT	All
164	Oregon State Department of Energy	All
223	Franklin County Emergency Management	All
224	Washington State Department of Health – Office of Radiation Protection	All

& PPM 13.1.1 and is printed in color, single sided, on 11" x 17" paper, folded, 3-hole punched, stapled on top and distributed by Document Control. All ERO Positional-Specific Binder procedures are stapled.

% Contact Security – All Security Procedures go to the SCC for signature

NOTE: Distribution of the PPM 13.1.1 wall flow charts are controlled by PPM 13.1.1A and distribution is performed by EP.

Updated 01/18/2024

AX45
NR R

GENERAL EMERGENCY			SITE AREA EMERGENCY			ALERT			UNUSUAL EVENT																			
C Cold SD/ Refuel System Malfunc.	1 RPV Level	Loss of RPV inventory affecting fuel clad integrity with containment challenged CG1.1 4 5 RPV level LT -161 in. for GE 30 min. (Note 1) AND Any of the following indications of containment challenge: CONTAINMENT CLOSURE not established (Note 5) Explosive mixture inside PC (H₂ GE 6% and O₂ GE 5%) UNPLANNED rise in PC pressure RB area radiation GT any Maximum Safe Operating level (EOP Table 24) CG1.2 4 5 RPV level cannot be monitored for GE 30 min. (Note 1) AND Core uncover is indicated by any of the following: UNPLANNED wetwell level rise GT 2 inches VALID indication of RB room flooding as identified by high level alarms (EOP Table 25) Observation of UNISOLABLE RCS leakage outside primary containment of sufficient magnitude to indicate core uncover AND Any of the following indications of containment challenge: CONTAINMENT CLOSURE not established (Note 5) Explosive mixture inside PC (H₂ GE 6% and O₂ GE 5%) UNPLANNED rise in PC pressure RB area radiation GT any Maximum Safe Operating level (EOP Table 24)	Loss of RPV inventory affecting core decay heat removal capability CS1.1 4 5 (1) CONTAINMENT CLOSURE not established AND RPV level LT -129 in. OR (2) CONTAINMENT CLOSURE established AND RPV level LT -161 in. CS1.2 4 5 RPV level cannot be monitored for GE 30 min. (Note 1) AND Core uncover is indicated by any of the following: UNPLANNED wetwell level rise GT 2 inches VALID indication of RB room flooding as identified by high level alarms (EOP Table 25) Observation of UNISOLABLE RCS leakage outside primary containment of sufficient magnitude to indicate core uncover	Significant loss of RPV inventory CA1.1 4 5 (1) Loss of RPV inventory as indicated by RPV level LT -50 in. OR (2) RPV level cannot be monitored for GE 15 min. (Note 1) AND UNPLANNED increase in any Table 1 sump or pool levels due to a loss of RPV inventory Table 1 Sumps/Pool Any valid Hi-Hi level alarm on R-1 through R-5 sumps EDR GE 25 GPM FDR GE 10 GPM Wetwell level rise Observation of UNISOLABLE RCS leakage	Unplanned loss of RPV inventory CU1.1 4 5 (1) UNPLANNED loss of reactor coolant results in RPV level less than a required lower limit for GE 15 min. (Note 1) OR (2) RPV level cannot be monitored AND UNPLANNED increase in any Table 1 sump or pool levels due to a loss of RPV inventory Table 2 AC Power Sources Offsite Startup Transformer TR-S Backup Transformer TR-B Backfeed 500 KV power through Main Transformers (if already aligned in modes 4, 5, def only) Onsite DG1 DG2 Main Generator via TR-N1/N2																							
	2 Loss of Emergency AC Power	None	None	Loss of all offsite and all onsite AC power to emergency buses for 15 minutes or longer CA2.1 4 5 DEF Loss of all offsite and all onsite AC power capability to emergency buses SM-7 and SM-8 for GE 15 min. (Note 1)	Loss of all but one AC power source to emergency buses for 15 minutes or longer CU2.1 4 5 DEF AC power capability, Table 2, to emergency buses SM-7 and SM-8 reduced to a single power source for GE 15 min. (Note 1) AND Any additional single power source failure will result in a loss of all AC power to SAFETY SYSTEMS																							
	3 RCS Temp.	None	Table 7 RCS Reheat Duration Thresholds * If an RCS heat removal system is in operation within this time frame and RCS temperature is being reduced the EAL is not applicable <table><tr><th>RCS Status</th><th>Containment Closure Status</th><th>Heat-up Duration</th></tr><tr><td>Intact</td><td>N/A</td><td>60 min. *</td></tr><tr><td>Not intact</td><td>established</td><td>20 min. *</td></tr><tr><td></td><td>not established</td><td>0 min.</td></tr></table>	RCS Status	Containment Closure Status	Heat-up Duration	Intact	N/A	60 min. *	Not intact	established	20 min. *		not established	0 min.	Inability to maintain plant in cold shutdown CA3.1 4 5 UNPLANNED increase in RCS temperature to GT 200°F for GT Table 7 duration (Note 1) OR UNPLANNED RPV pressure increase GT 10 psig	UNPLANNED increase in RCS temperature CU3.1 4 5 UNPLANNED increase in RCS temperature to GT 200°F CU3.2 4 5 Loss of all RCS temperature and RPV water level indication for GE 15 min. (Note 1)											
	RCS Status	Containment Closure Status	Heat-up Duration																									
	Intact	N/A	60 min. *																									
	Not intact	established	20 min. *																									
	not established	0 min.																										
4 Loss of Vital DC Power	None		None	Loss of vital DC power for 15 minutes or longer CU4.1 4 5 Indicated voltage LT 108 VDC on required 125 VDC buses DP-S1-1 and DP-S1-2 for GE 15 min. (Note 1)																								
5 Loss of Comm.	Table 4 Communication Methods <table><tr><th>System</th><th>Onsite</th><th>ORO</th><th>NRC</th></tr><tr><td>Plant Public Address (PA) System</td><td>X</td><td></td><td></td></tr><tr><td>Plant Telephone System</td><td>X</td><td>X</td><td></td></tr><tr><td>Plant Radio System Operations and Security Channels</td><td>X</td><td></td><td></td></tr><tr><td>Offsite calling capability from the Control Room via direct telephone</td><td></td><td>X</td><td>X</td></tr><tr><td>Long distance calling capability on the commercial phone system</td><td></td><td>X</td><td>X</td></tr></table>	System	Onsite	ORO	NRC	Plant Public Address (PA) System	X			Plant Telephone System	X	X		Plant Radio System Operations and Security Channels	X			Offsite calling capability from the Control Room via direct telephone		X	X	Long distance calling capability on the commercial phone system		X	X	None	None	Loss of all onsite or offsite communications capabilities CU5.1 4 5 DEF Loss of all Table 4 onsite communication methods OR Loss of all Table 4 ORO communication methods OR Loss of all Table 4 NRC communication methods
System	Onsite	ORO	NRC																									
Plant Public Address (PA) System	X																											
Plant Telephone System	X	X																										
Plant Radio System Operations and Security Channels	X																											
Offsite calling capability from the Control Room via direct telephone		X	X																									
Long distance calling capability on the commercial phone system		X	X																									
6 Hazardous Events Affecting Safety Systems		Table 8 Hazardous Events Seismic event Internal or external FLOODING event High winds Tornado strike FIRE EXPLOSION Volcanic ash fallout Other events with similar hazard characteristics as determined by the Shift Manager	Hazardous event affecting a SAFETY SYSTEM needed for the current operating mode CA6.1 4 5 The occurrence of any Table 8 hazardous event AND Event damage has caused indications of degraded performance on one train of a SAFETY SYSTEM needed for the current operating mode AND EITHER: Event damage has caused indications of degraded performance to a second train of a SAFETY SYSTEM needed for the current operating mode OR Event damage has resulted in VISIBLE DAMAGE to a second train of a SAFETY SYSTEM needed for the current operating mode (Notes 9, 10)	None																								

Modes:

4

Cold Shutdown

5

Refueling

DEF

Defueled



13.1.1 Rev. 50
CLASSIFYING THE EMERGENCY
6/27/2024
COLD CONDITIONS
(RCS ≤ 200°F)

